



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 03, 2026

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: EPMS Lead Testing

Order No.: 26050790

Dear John Harding:

Neilson Research Corporation received 68 sample(s) on 5/19/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at www.nrclabs.com. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26050790
Date: 6/3/2026

CLIENT: Eagle Point School District #9
Project: EPMS Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-01 Client Sample ID: 039BW
 Collection Date: 5/19/2026 5:12:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 039BW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-02 Client Sample ID: 001BF
 Collection Date: 5/19/2026 5:21:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 001BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-03 Client Sample ID: 002BF
 Collection Date: 5/19/2026 5:23:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 002BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-04 Client Sample ID: 003BF
 Collection Date: 5/19/2026 5:25:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 003BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-05 Client Sample ID: 004BF
 Collection Date: 5/19/2026 5:27:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 004BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.896		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-06 Client Sample ID: 005BF
 Collection Date: 5/19/2026 5:29:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 005BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-07 Client Sample ID: 006BF
 Collection Date: 5/19/2026 5:32:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 006BF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-08 Client Sample ID: 007KF
 Collection Date: 5/19/2026 5:36:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 007KF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-09 Client Sample ID: 077KF
 Collection Date: 5/19/2026 5:39:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 077KF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-10 Client Sample ID: 008KF
 Collection Date: 5/19/2026 5:41:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 008KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-11 Client Sample ID: 009KF
 Collection Date: 5/19/2026 5:43:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 009KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.608		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-12 Client Sample ID: 010KF
 Collection Date: 5/19/2026 5:46:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 010KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.90		0.515	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-13 Client Sample ID: 012CF
 Collection Date: 5/19/2026 5:48:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 012CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-14 Client Sample ID: 013CF
 Collection Date: 5/19/2026 5:50:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 013CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.671		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-15 Client Sample ID: 014CF
 Collection Date: 5/19/2026 5:52:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 014CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-16 Client Sample ID: 015CF
 Collection Date: 5/19/2026 5:54:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 015CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.47		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-17 Client Sample ID: 016CF
 Collection Date: 5/19/2026 5:56:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 016CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.08		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-18 Client Sample ID: 017BF
 Collection Date: 5/19/2026 5:59:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 017BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-19 Client Sample ID: 018BF
 Collection Date: 5/19/2026 6:02:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 018BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-20 Client Sample ID: 019BF
 Collection Date: 5/19/2026 6:03:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 019BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-21 Client Sample ID: 020BW
 Collection Date: 5/19/2026 6:06:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 020BW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-22 Client Sample ID: 021DW
 Collection Date: 5/19/2026 6:08:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 021DW

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-23 Client Sample ID: 022BF
 Collection Date: 5/19/2026 6:10:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 022BF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-24 Client Sample ID: 023BF
 Collection Date: 5/19/2026 6:14:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 023BF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-25 Client Sample ID: 024BF
 Collection Date: 5/19/2026 6:16:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 024BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.46		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-26 Client Sample ID: 060NS
 Collection Date: 5/19/2026 6:21:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 060NS

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.33		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-27 Client Sample ID: 079BF
 Collection Date: 5/19/2026 6:24:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 079BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.671		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-28 Client Sample ID: 038BF
 Collection Date: 5/19/2026 6:27:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 038BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-29 Client Sample ID: 056BF
 Collection Date: 5/19/2026 6:28:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 056BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.76		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-30 Client Sample ID: 040DW
 Collection Date: 5/19/2026 6:33:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 040DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-31 Client Sample ID: 026DW
 Collection Date: 5/19/2026 5:57:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 026DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.549		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-32 Client Sample ID: 027CF
 Collection Date: 5/19/2026 6:00:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 027CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.52		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-33 Client Sample ID: 028CF
 Collection Date: 5/19/2026 6:03:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 028CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.42		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-34 Client Sample ID: 029CF
 Collection Date: 5/19/2026 6:04:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 029CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.74	1	0.500	ppb	1	5/27/2026	15.0	A	

Lab ID: 26050790-35 Client Sample ID: 030CF
 Collection Date: 5/19/2026 6:06:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 030CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	5.53		0.500	ppb	1	5/27/2026	15.0	A	

Lab ID: 26050790-36 Client Sample ID: 031CF
 Collection Date: 5/19/2026 6:07:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 031CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.41		0.500	ppb	1	5/27/2026	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-37 Client Sample ID: 032CF
 Collection Date: 5/19/2026 6:07:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 032CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-38 Client Sample ID: 078CF
 Collection Date: 5/19/2026 6:11:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 078CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.29		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-39 Client Sample ID: 033CF
 Collection Date: 5/19/2026 6:13:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 033CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.832		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-40 Client Sample ID: 034DW
 Collection Date: 5/19/2026 6:14:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 034DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.732		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-41 Client Sample ID: 045DW
 Collection Date: 5/19/2026 5:15:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 045DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-42 Client Sample ID: 044WB
 Collection Date: 5/19/2026 5:16:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 044WB

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-43 Client Sample ID: 041BF
 Collection Date: 5/19/2026 5:17:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 041BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.68		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-44 Client Sample ID: 042BF
 Collection Date: 5/19/2026 5:17:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 042BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-45 Client Sample ID: 043BF
 Collection Date: 5/19/2026 5:18:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 043BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.928		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-46 Client Sample ID: 046BF
 Collection Date: 5/19/2026 5:23:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 046BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-47 Client Sample ID: 047BF
 Collection Date: 5/19/2026 5:24:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 047BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-48 Client Sample ID: 048BF
 Collection Date: 5/19/2026 5:25:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 048BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-49 Client Sample ID: 054CF
 Collection Date: 5/19/2026 5:29:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 054CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-50 Client Sample ID: 055DW
 Collection Date: 5/19/2026 5:30:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 055DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.534		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-51 Client Sample ID: 053CF
 Collection Date: 5/19/2026 5:32:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 053CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-52 Client Sample ID: 058BF
 Collection Date: 5/19/2026 5:38:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 058BF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-53 Client Sample ID: 049CF
 Collection Date: 5/19/2026 5:40:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 049CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-54 Client Sample ID: 050DW
 Collection Date: 5/19/2026 5:42:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 050DW

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.75		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-55 Client Sample ID: 051CF
 Collection Date: 5/19/2026 5:44:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 051CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-56 Client Sample ID: 052DW
 Collection Date: 5/19/2026 5:44:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 052DW

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.552		0.500	ppb	1	5/27/2026	15.0	A

Lab ID: 26050790-57 Client Sample ID: 035CF
 Collection Date: 5/19/2026 5:46:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 035CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/27/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-58 Client Sample ID: 036DW
 Collection Date: 5/19/2026 5:49:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 036DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.696		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-59 Client Sample ID: 057BF
 Collection Date: 5/19/2026 5:53:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 057BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-60 Client Sample ID: 025CF
 Collection Date: 5/19/2026 5:57:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 025CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/28/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-61 Client Sample ID: 037CF
 Collection Date: 5/19/2026 6:21:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 037CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.58		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-62 Client Sample ID: 064BF
 Collection Date: 5/19/2026 6:25:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 064BF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.756		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-63 Client Sample ID: 065BF
 Collection Date: 5/19/2026 6:26:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 065BF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.592		0.500	ppb	1	5/28/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-64 Client Sample ID: 062BF
 Collection Date: 5/19/2026 6:29:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 062BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-65 Client Sample ID: 063BF
 Collection Date: 5/19/2026 6:30:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 063BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-66 Client Sample ID: 061CF
 Collection Date: 5/19/2026 6:33:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 061CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/28/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26050790
 Date Reported: 6/3/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26050790
Received Date: 5/19/2026 9:29:00 AM
Reported Date: 6/3/2026 9:32:45 AM

Sample Information:

Lab ID: 26050790-67 Client Sample ID: 059KF
 Collection Date: 5/19/2026 6:34:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 059KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.23		0.500	ppb	1	5/28/2026	15.0	A

Lab ID: 26050790-68 Client Sample ID: 066DW
 Collection Date: 5/19/2026 6:34:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 066DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/28/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050790
 03-Jun-26

Client: Eagle Point School District #9
Project: EPMS Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36960	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980						
Client ID: PBW	Batch ID: 36960	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153668						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-36960	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980						
Client ID: LCSW	Batch ID: 36960	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153669						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0	102	85	115				

Sample ID: 26050790-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980						
Client ID: 039BW	Batch ID: 36960	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153671						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0.143	102	70	130				

Sample ID: 26050790-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980						
Client ID: 039BW	Batch ID: 36960	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153672						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	100	0.520	100	0.143	100	70	130	102	1.65	20	

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceeded
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050790

03-Jun-26

Client: Eagle Point School District #9
Project: EPMS Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36961	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980
Client ID: PBW	Batch ID: 36961	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153696
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.500			

Sample ID: LCS-36961	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980
Client ID: LCSW	Batch ID: 36961	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153697
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	102	0.505	100	0	102 85 115

Sample ID: 26050790-23AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980
Client ID: 022BF	Batch ID: 36961	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153699
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	99.5	0.505	100	0.279	99.2 70 130

Sample ID: 26050790-23AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980
Client ID: 022BF	Batch ID: 36961	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153700
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	99.3	0.505	100	0.279	99.0 70 130 99.5 0.248 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceeded
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050790

03-Jun-26

Client: Eagle Point School District #9
Project: EPMS Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36962	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980
Client ID: PBW	Batch ID: 36962	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153729
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.500			

Sample ID: LCS-36962	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980
Client ID: LCSW	Batch ID: 36962	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153730
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	102	0.505	100	0	102 85 115

Sample ID: 26050790-44AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980
Client ID: 042BF	Batch ID: 36962	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153732
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	100	0.505	100	0.481	99.6 70 130

Sample ID: 26050790-44AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/27/2026	RunNo: 69980
Client ID: 042BF	Batch ID: 36962	TestNo: E200.8	E200.8	Analysis Date: 5/27/2026	SeqNo: 1153733
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	99.8	0.505	100	0.481	99.3 70 130 100 0.226 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceeded
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26050790
 03-Jun-26

Client: Eagle Point School District #9
Project: EPMS Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36974	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2026	RunNo: 70023
Client ID: PBW	Batch ID: 36974	TestNo: E200.8	E200.8	Analysis Date: 5/28/2026	SeqNo: 1154721
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.500			

Sample ID: LCS-36974	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2026	RunNo: 70023
Client ID: LCSW	Batch ID: 36974	TestNo: E200.8	E200.8	Analysis Date: 5/28/2026	SeqNo: 1154722
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	101	0.500	100	0	101 85 115

Sample ID: 26050997-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2026	RunNo: 70023
Client ID: BatchQC	Batch ID: 36974	TestNo: E200.8	E200.8	Analysis Date: 5/28/2026	SeqNo: 1154734
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	97.5	0.500	100	0	97.5 70 130

Sample ID: 26050997-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2026	RunNo: 70023
Client ID: BatchQC	Batch ID: 36974	TestNo: E200.8	E200.8	Analysis Date: 5/28/2026	SeqNo: 1154735
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	98.2	0.500	100	0	98.2 70 130 97.5 0.656 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceeds
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Sample Log-In Check List

Client Name: EAGLEPTSCHOOL Work Order Number: 26050790 RcptNo: 1

Logged by:	Ahlia Brown	5/19/2026 9:29:00 AM	<i>Ahlia Brown</i>
Completed By:	Kyler Woolsey	5/21/2026 10:10:31 AM	<i>Kyler Woolsey</i>
Reviewed By:	Dorie Evans	6/3/2026 9:22:40 AM	<i>Dorie Evans</i>

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
 2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
 4. Shipping container/cooler in good condition? Yes No
 Custody seals intact on shipping container/cooler? Yes No Not Present NA
 No. Seal Date: Signed By:
 5. Was an attempt made to cool the samples? Yes No NA
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
 7. Sample(s) in proper container(s)? Yes No
 8. Sufficient sample volume for indicated test(s)? Yes No
 9. Are samples (except VOA and ONG) properly preserved? Yes No
 10. Was preservative added to bottles? Yes No NA
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
 12. Were any sample containers received broken? Yes No
 13. Does paperwork match bottle labels? Yes No
 (Note discrepancies on chain of custody)
 14. Are matrices correctly identified on Chain of Custody? Yes No
 15. Is it clear what analyses were requested? Yes No
 16. Were all holding times able to be met? Yes No
 (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: <u>SRS</u> Address: <u>P.O. Box 548</u> <u>Engle Joint 0297524</u> Email: Phone: Fax: Collected By (Print): <u>Don O'Connor</u> Collected By (Sign): <u>[Signature]</u> Email Report ___ Mail Report ___ Fax Report ___	Section B Required Project Information Project Name: <u>EPMS</u> Project Number: Report To: Copy To:	Section C Invoice Information Attention: <u>John Harding</u> Company Name: Address: P.O. #	Section D Rush Status (Subject to Scheduling) Standard: 10 Business Days Priority: 5 Business Days (List x 1.50) Express: 3 Business Days (List x 1.75) Rush: 2 Business Days (List x 2.00) Rush: 1 Business Day (List x 2.50) Rush: Same Day (List x 3.00) Authorized ___ Yes ___ No
--	---	---	---

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>26050790</u>					
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers															
039BW 10080			5/19	5:12																
001BF 10067				5:21																
002BF 10078				5:23																
003BF 10092				5:25																
004BF 5606				5:27																
005BF 5604				5:29																
006BF 5630				5:32																
007KF 10065				5:36																
007KF 5651				5:39																
008KF 10094				5:41																

Remarks / Field Data	NRC Sample # Use Only	(Lab Use Only)
	01	
	02	
	03	
	04	
	05	
	06	
	07	
	08	
	09	
	10	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F		Print	Date	Time
Relinquish/Receive By:	<u>[Signature]</u>	<u>Don O'Connor</u>	<u>5/19/26</u>	<u>9:29</u>
Received By:				
Relinquish/Receive By:				
Received By:				
Relinquish/Receive By:				
Received By Laboratory:	<u>MB</u>	<u>Antia Brown</u>	<u>5/19/26</u>	<u>9:29</u>

Section G Lab Use Only	
Temp: <u>amb</u>	IR Therm ID:
≤6°C: ___ Yes ___ No	
Received on Ice: ___ Yes ___ No	
Number of Bottles Received:	
pH Checked:	
COC Seals Intact: ___ Yes ___ No ___ NA	
Field Blank Included: ___ Yes ___ No	
Received Via ___ UPS ___ FedEx ___ Other <u>Hand</u>	
Payment: <input checked="" type="checkbox"/> Invoice ___ Cash ___ VISA, M/C ___ Check # ___ Amount ___	

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: <u>JCSA9</u> Address: _____ Email: _____ Phone: _____ Fax: _____ Collected By (Print): <u>Loni Oconnor</u> Collected By (Sign): <u>[Signature]</u> Email Report ___ Mail Report ___ Fax Report ___		Section B Required Project Information Project Name: <u>EPMS</u> Project Number: _____ Report To: _____ Copy To: _____		Section C Invoice Information Attention: <u>John Hardway</u> Company Name: _____ Address: _____ P.O. # _____		Section D Rush Status (Subject to Scheduling) <input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00) Authorized ___ Yes ___ No	
---	--	---	--	---	--	---	--

Section E Sample Information					Analysis Requested												NRC Workorder # (Lab Use Only)												
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers																			Remarks / Field Data	NRC Sample # Use Only	(Lab)			
009KF 5637			5/19	5:43																									
010KF 10090				5:46																									
012KF 10093				5:48																									
013CF 5650				5:50																									
014CF 5644				5:52																									
015CF 5638				5:54																									
016CF 5631				5:56																									
017BF 5610				5:59																									
018BF 10077				6:02																									
019BF 5607				6:03																									

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive Relinquished By: <u>[Signature]</u> Sign Received By: <u>Loni Oconnor</u> Print Date: <u>5/19/16</u> Time: <u>9:29</u> Relinquished By: _____ Received By: _____ Relinquished By: _____ Received By Laboratory: <u>AB</u> <u>ahlia</u> Date: <u>5/19/16</u> Time: <u>9:29</u>			
---	--	--	--

Section G Lab Use Only Temp: <u>amb</u> IR Therm ID: _____ ≤6°C: ___ Yes ___ No Received on Ice: ___ Yes ___ No Number of Bottles Received: _____ pH Checked: _____ COC Seals Intact: ___ Yes ___ No ___ NA Field Blank Included: ___ Yes ___ No Received Via ___ UPS ___ FedEx ___ Other ___ Hand Payment: ___ Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____	
---	--

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: <u>JCS09</u> Address: Email: Phone: _____ Fax: _____ Collected By (Print): <u>Loni O'Connor</u> Collected By (Sign): <u>[Signature]</u> Email Report <input type="checkbox"/> Mail Report <input type="checkbox"/> Fax Report <input type="checkbox"/>	Section B Required Project Information Project Name: <u>EPMS</u> Project Number: Report To: Copy To:	Section C Invoice Information Attention: <u>John Harding</u> Company Name: Address: P.O. #	Section D Rush Status (Subject to Scheduling) <input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00) Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
---	---	---	---

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only)						
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers													Remarks / Field Data	NRC Sample # Use Only	(Lab)	
020BW 5635			5/19	6:06																26050790	
021DW 5647				6:08																21	
022BF 5642				6:10																22	
023BF 10091				6:14																23	
024BF 10066				6:16																24	
060MS 5615				6:21																25	
079BF 10072				6:24																26	
038BF 5652				6:27																27	
056BF 5657				6:28																28	
040DW 5656				6:33															29		
																		30			

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive			
Relinquished By: <u>[Signature]</u>	Print: <u>Loni O'Connor</u>	Date: <u>5/19/21</u>	Time: <u>9:28</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: <u>[Signature]</u>	Print: <u>Alina Brown</u>	Date: <u>5/19/21</u>	Time: <u>9:29</u>

Section G Lab Use Only	
Temp: <u>amb</u>	IR Therm ID:
≤6°C: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Number of Bottles Received:	
pH Checked:	
COC Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	
Field Blank Included: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Received Via <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand	
Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # _____ Amount _____	



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: JCSPG
 Address: _____
 Email: _____
 Phone: _____ Fax: _____
 Collected By (Print): Loni O'Connor
 Collected By (Sign): [Signature]
 Email Report Mail Report Fax Report

Section B

Required Project Information

Project Name: EPMS
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: John Hardwig
 Company Name: _____
 Address: _____
 P.O. #: _____

Section D

Rush Status (Subject to Scheduling)

Standard: 10 Business Days
 Priority: 5 Business Days (List x 1.50)
 Express: 3 Business Days (List x 1.75)
 Rush: 2 Business Days (List x 2.00)
 Rush: 1 Business Day (List x 2.50)
 Rush: Same Day (List x 3.00)
 Authorized Yes No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks / Field Data	NRC Sample # (Lab Use Only)
026 DW			5/19	5:57	1		26050790		31
027 CF				6:00	1				32
028 CF				6:03	1				33
029 AF				6:04	1				34
030 CF				6:06	1				35
031 CF				6:07	1				36
032 CF				6:07	1				37
033 CF				6:11	1				38
034 DW				6:13	1				39
				6:14	1				40

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By: <u>[Signature]</u>	Print: <u>Loni O'Connor</u>	Date: <u>5/19/26</u>	Time: <u>9:29</u>
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By Laboratory: <u>AB</u>	<u>Abelia Brown</u>	<u>5/19/26</u>	<u>9:29</u>

Section G

Lab Use Only

Temp: AM IR Therm ID: _____
 ≤6°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: _____
 pH Checked: _____
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No
 Received Via UPS FedEx Other Hand
 Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: JCSDA

Address:

Email:

Phone: _____ Fax: _____

Collected By (Print): Loni O'Connor

Collected By (Sign): [Signature]

Email Report Mail Report Fax Report

Section B
Required Project Information

Project Name: EPMS

Project Number:

Report To:

Copy To:

Section C
Invoice Information

Attention: John Hardig

Company Name:

Address:

P.O. #

Section D
Rush Status (Subject to Scheduling)

Standard: 10 Business Days

Priority: 5 Business Days (List x 1.50)

Express: 3 Business Days (List x 1.75)

Rush: 2 Business Days (List x 2.00)

Rush: 1 Business Day (List x 2.50)

Rush: Same Day (List x 3.00)

Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks / Field Data	NRC Sample # Use Only	(Lab Use Only)
045 DW	10096		5/19	5:15	1		26050790			
044 WB	10062			5:16	1			41		
041 BF	10061			5:17	1			42		
042 BF	10082			5:17	1			43		
043 BF	10068			5:18	1			44		
046 BF	10064			5:23	1			45		
047 BF	10085			5:24	1			46		
048 BF	10087			5:25	1			47		
054 CF	10084			5:25	1			48		
055 DW	10011			5:30	1			49		
							50			

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By:	<u>[Signature]</u>	Sign	Print	Date	Time
Received By:			<u>Loni O'Connor</u>	<u>5/19/26</u>	<u>9:25</u>
Relinquished By:					
Received By:					
Relinquished By:					
Received By Laboratory:	<u>[Signature]</u>		<u>Allia Brown</u>	<u>5/19/26</u>	

Section G
Lab Use Only

Temp: AMB IR Therm ID:

≤6°C: Yes No

Received on Ice: Yes No

Number of Bottles Received:


pH Checked:

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>JCS D9</u>		Project Name: <u>EPMS</u>		Attention: <u>John Handberg</u>		<input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00)	
Address:		Project Number:		Company Name:		<input type="checkbox"/> Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Email:		Report To:		Address:			
Phone: Fax:		Copy To:		P.O. #			
Collected By (Print): <u>Lon O'Connor</u>							
Collected By (Sign): <u>[Signature]</u>							
Email Report <input type="checkbox"/> Mail Report <input type="checkbox"/> Fax Report <input type="checkbox"/>							

Analysis Requested									
1	2	3	4	5	6	7	8	9	10

Section E Sample Information					No. of Containers	NRC Workorder # (Lab Use Only) <u>26050790</u>	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks / Field Data	NRC Sample # (Lab Use Only)
053 CF			5/19	5:32	1		51
058 BF				5:38	1		52
049 CF				5:40	1		53
050 DW				5:42	1		54
051 CF				5:44	1		55
052 DW				5:44	1		56
035 CF				5:46	1		57
036 DW				5:49	1		58
057 BF				5:53	1		59
025 CF				5:57	1		60

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive			
Relinquished By: <u>[Signature]</u>	Print: <u>Lon O'Connor</u>	Date: <u>5/19/26</u>	Time: <u>9:29</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: <u>[Signature]</u>	<u>Anita Brown</u>	<u>5/19/26</u>	<u>9:29</u>

Section G Lab Use Only	
Temp: <u>amb</u>	IR Therm ID:
±6°C: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Number of Bottles Received:	
pH Checked:	
COC Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	
Field Blank Included: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Received Via <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand	
Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # <input type="checkbox"/> Amount	

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: <u>JCS09</u> Address: _____ Email: _____ Phone: _____ Fax: _____ Collected By (Print): <u>Loni Connor</u> Collected By (Sign): <u>[Signature]</u> Email Report <input type="checkbox"/> Mail Report <input type="checkbox"/> Fax Report <input type="checkbox"/>	Section B Required Project Information Project Name: <u>EPMS</u> Project Number: _____ Report To: _____ Copy To: _____	Section C Invoice Information Attention: <u>Sarah Harding</u> Company Name: _____ Address: _____ P.O. # _____	Section D Rush Status (Subject to Scheduling) <input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00) Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
---	---	--	---

Section E Sample Information						Analysis Requested												NRC Workorder # (Lab Use Only) <u>26050790</u>			
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers													Remarks / Field Data	NRC Sample # Use Only	(Lab)	
037 CF			5/19	6:21	1																
064 BF				6:25	1															61	
065 BF				6:26	1															62	
062 BF				6:29	1															63	
063 BF				6:30	1															64	
061 CF				6:33	1															65	
059 KF				6:34	1															66	
066 DW				6:34	1															67	
																				68	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive			
Relinquished By: <u>[Signature]</u>	Sign	Print	Date
Received By: _____		<u>Loni Connor</u>	<u>5/19/26</u>
Relinquished By: _____			Time
Received By: _____			<u>9:29</u>
Relinquished By: _____			
Received By: _____			
Relinquished By: _____			
Received By Laboratory: <u>ARB</u>		<u>adhia/Strawn</u>	<u>5/19/26</u>
			<u>9:29</u>

Section G Lab Use Only	
Temp: <u>AMU</u>	IR Therm ID: _____
≤6°C: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Number of Bottles Received: _____	
pH Checked: _____	
COC Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	
Field Blank Included: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Received Via <input type="checkbox"/> UPS <input type="checkbox"/> FedEX <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand	
Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # _____ Amount _____	