

Addendum

DATE:	June 3, 2026
ADDENDUM NO:	02
PROJECT:	Mt Solo Middle School - Boiler repair
T0:	2602.7

The following Addendum forms part of and modifies the Bidding and Contract Documents for this project. Contractor shall acknowledge receipt of this Addendum on the Bid Form.

ITEM	SHEET/SECTION NO.	DESCRIPTION
01	23 52 39.13 Section 2.04.D	Remove the reference to “Massimo” boiler panel. It has been determined that this panel is not compatible with the Riello burners. Provide a compatible panel.

END OF ADDENDUM