

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE:

4/21/2026

REPORT #:

26-02963

CLIENT/CLIENT ADDRESS

Northwest Service Co-Op
114 1st St W
Thief River Falls, MN 56701

SCHOOL/ADDRESS

Badger High School (ISD 676)
110 Carpenter Ave
Badger, MN 56714

SAMPLE INFORMATION

RECEIPT DATE/TIME:

3/31/2026 at 13:05

TEMP OF SAMPLE UPON RECEIPT:

16 °C

COLLECTED BY:

☐ TCWC

☒ CLIENT

☐ Other

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	ACTION LEVEL*	RESULT
26-02963	Lead	High School - Bottle Filler	3/26/2026	06:30	4/21/2026	12:35	SM3113B-93	5 µg/L	<2.00 µg/L
26-02964	Lead	High School - Drinking Fountain 1	3/26/2026	06:31	4/21/2026	12:41	SM3113B-93	5 µg/L	<2.00 µg/L
26-02965	Lead	High School - Drinking Fountain 2	3/26/2026	06:32	4/21/2026	12:47	SM3113B-93	5 µg/L	<2.00 µg/L
26-02966	Lead	Teacher's Lounge - Sink	3/26/2026	06:35	4/21/2026	13:05	SM3113B-93	5 µg/L	<2.00 µg/L
26-02967	Lead	Elementary - Bottle Filler	3/26/2026	06:40	4/21/2026	13:23	SM3113B-93	5 µg/L	<2.00 µg/L
26-02968	Lead	Elementary - Drinking Fountain	3/26/2026	06:41	4/21/2026	13:29	SM3113B-93	5 µg/L	<2.00 µg/L
26-02969	Lead	Kitchen - Sink	3/26/2026	06:50	4/21/2026	13:35	SM3113B-93	5 µg/L	<2.00 µg/L
26-02970	Lead	Dishwasher Area - Sink 1	3/26/2026	06:52	4/21/2026	13:41	SM3113B-93	5 µg/L	3.38 µg/L
26-02971	Lead	Dishwasher Area - Sink 2	3/26/2026	06:53	4/21/2026	13:47	SM3113B-93	5 µg/L	3.73 µg/L
26-02972	Lead	Dishwasher Area - Garbage Disposal Sink	3/26/2026	06:58	4/21/2026	13:53	SM3113B-93	5 µg/L	12.1 µg/L

*The action level is determined by MN Statute 121A.335.

NOTES

APPROVED BY:



Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.