

Lead Testing in School Drinking Water



Location:

Pre-K School
Elementary School
High/Middle School

Prepared for:

Bolivar-Richburg Central School District
100 School Street
Bolivar, New York 14715

LaBella Project No. 2232612.20

December 2025

Table of Contents

	Page No.
I. Background	1
II. Project Description	1
III. Sampling Procedures and Summary of Results	2
IV. Response and Recommendations	5
V. Reporting and Record Keeping	5

Appendix A – Laboratory Analytical Reports

Appendix B – Licenses and Certifications



I. BACKGROUND

Under Subpart 67-4 of the New York Codes, Rules and Regulations, Title X, “all school districts and boards of cooperative educational services are required to test potable water for lead contamination, and to develop and implement a lead remediation plan, where applicable.”

The Subpart 67-4 testing requirement was first promulgated under emergency legislation in 2016, and was subsequently signed into permanent law. Public Health Law PHL Section 1110 was amended on December 23, 2021 and these revisions to Subpart 67-4 went into effect on December 22, 2022. Notable revisions include 1) Action Level lowered from 15 ppb to 5 ppb, 2) Compliance monitoring will be every 3 years (previously every 5 years) and 3) Lead-free” buildings are no longer exempt from testing requirements. The comply with these new testing requirements sampling must be performed between January 1, 2023 and December 31, 2025.

Lead is a toxic metal that can be harmful to human health when ingested. Young children, especially those 6 years and younger, are at particular risk for lead exposure because they have frequent hand-to-mouth activity and absorb lead more easily than do adults. Children’s nervous systems are still undergoing development and thus are more susceptible to the effects of toxicants. Therefore, emphasis may be placed on assessment of lead exposure in schools and early childhood education facilities, where concentrations of a vulnerable population are regularly congregated.

Lead can be introduced into potable water by being present in the source water or, more commonly, by interaction of the water with fixtures and plumbing materials containing lead. Common sources of lead in potable water include solder, fluxes, pipes and pipe fittings, fixtures, and sediments. It is possible that different water outlets in a given building could have dissimilar concentrations of lead. It is also possible that, due to temporal fluctuations in water chemistry and physical conditions that may affect the integrity of the plumbing and the water being conveyed, the result obtained from a test at a given time may differ from the result obtained from a test at another time, even if the sampling procedures are identical.

II. PROJECT DESCRIPTION

LaBella Associates assisted the District with sample analysis and reporting in accordance with sections 1370-a and 1110, Subpart 67-4 of Title 10 (Health) of the Official Compilation of Codes, Rules and Regulations of the State of New York and United States Environmental Protection Agency (EPA) Guidelines. The Bolivar-Richburg Central School District self-performed all sample collection from the following buildings:

Pre-K School
100 School Street
Bolivar, New York 14715

Elementary School
PO Box 158
Main Street
Richburg, NY 14774

High/Middle School
100 School Street
Bolivar, New York 14715



III. SAMPLING PROCEDURES AND SUMMARY OF RESULTS

Water conditions were reported to be representative of normal consumption patterns with building occupancy controlled during stagnation and sampling periods. Bolivar-Richburg Central School District staff conducted sampling of target outlets on October 10, 2025 (Pre-K Building, Elementary Building and High/Middle School) and November 1, 2025 (Elementary Building).

Bolivar-Richburg Central School District shipped the samples directly LaBella for review and Labella proceeded to ship them to a New York State Department of Health (NYSDOH) Environmental Laboratory Approval Program (ELAP) accredited laboratory. Samples were analyzed utilizing EPA environmental analysis method 200.9 Rev 2.2 for lead in potable water. Results of the laboratory analysis were compiled and summarized.

Building	Total Number of Outlets	Total number of outlets at or below EPA action level (5 ppb)	Total number of outlets above EPA action level (5 ppb)
Pre-K School	4	4	0
Elementary School	23	22	1
High/Middle School	19	19	0
Total	46	45	1

Based on laboratory analyses of the samples collected, the following outlet was determined to exceed the NYS Action level of 5 parts per billion (ppb) or equivalent 5 micrograms per liter ($\mu\text{g/L}$). However, the following table does not include all of the outlets sampled during this inspection; for a full list of outlets sampled see Appendix A immediately following this report.

Sample Number	Sample Location	Outlet Type	Result ($\mu\text{g/L}$)
Elementary School			
EL-23	Gym	Sink	6.43

IV. Response and RECOMMENDATIONS

According to section Subpart 67-4.4 “Response” of the regulation, school districts shall prohibit the use of all outlets which exceed the 5 ppb action level. The outlet shall remain out of service until a lead remediation plan is implemented to reduce the level of lead and resampling indicates lead levels that are at or below the action level. While the outlet is out of service the district must supply an appropriate amount of potable water for drinking or cooking to building occupants.

LaBella would provide the following recommendations for outlets in exceedance of the action level:

1. Follow up testing – This may include an additional first draw sample, or second draw sample to further investigate and evaluate the condition of the plumbing system upstream of the affected outlets. Sample results may provide some insight on trends, issues with certain portions of the plumbing system or links to specific outlets types and models.
2. Remedial Measures – The school district may elect to commence remediation of affected outlets with or without additional testing. Temporary remediation could include isolating



outlets and providing alternate sources of potable drinking or cooking water. Permanent remediation could include replacing outlets, permanently isolating outlets, adding water filtration, or renovations to the plumbing system.

V. Reporting and Record Keeping

In accordance with Subpart 67-4 the district shall:

- Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- Notify all staff and all persons in parental relation to children or students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.
- The school shall make available, on the school's website, the results of all lead testing performed and lead remediation plans implemented pursuant to this Subpart, as soon as practicable, but no more than 6 weeks after the school received the laboratory reports.
- As soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the Department, local health department, and State Education Department, through the Department's designated statewide electronic reporting system.
- The school shall retain all records of test results, lead remediation plans, determinations that a building is lead-free, and waiver requests, for ten years following the creation of such documentation. Copies of such documentation shall be immediately provided to the Department, local health department, or State Education Department, upon request.

Appendix A

Laboratory Analytical Results



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 658997

Matrix Drinking Water
Received 11/19/25
Reported 11/24/25

Attn:

Project: Bolivar Richburg CSD
Location: Pre-K
Number: 2232612.20

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
658997-001	#1	Drinking Fntn Head Start					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658997-002	#2	Drinking Fntn RM 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658997-003	#3	Pre K Bathroom Fntn					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658997-004	#4	Kitchen Pre K					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR

658997-11/24/25 03:15 PM

Kelly Muncy

Reviewed By: Kelly Muncy
Manager

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State	Certificate Number		
New York	ELAP 68765		
Virginia	VELAP 12761		

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results apply to the sample as received.

[illegible]



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 658998

Matrix Drinking Water
Received 11/19/25
Reported 11/25/25

Attn:

Project: Bolivar Richburg CSD
Location: Elementary
Number: 2232612.20

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
658998-001	1	Fntn G 2nd FL Bath					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-002	2	Fntn Cross 2nd FL Buntley					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-003	3	Fntn Cross 103					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-004	4	Fntn Cross Maintenance					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-005	5	Café Kitchen					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-006	6	Fntn Cross 21					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-007	7	RM 21 DF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-008	8	RM 22 DF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-009	9	RM 23 DF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-010	10	RM 24 DF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results apply to the sample as received.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 658998

Matrix Drinking Water
Received 11/19/25
Reported 11/25/25

Attn:

Project: Bolivar Richburg CSD
Location: Elementary
Number: 2232612.20

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
658998-011	11	RM 25 DF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-012	12	RM 26 DF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-013	13	RM 27 DF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-014	14	RM 28 DF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-015	15	Cafeteria 15 EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-016	16	Ftn 55 Wing EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-017	17	RM 3 EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-018	18	RM 4 EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-019	19	RM 5 EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-020	20	RM 2 EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results apply to the sample as received.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 658998

Matrix Drinking Water
Received 11/19/25
Reported 11/25/25

Attn:

Project: Bolivar Richburg CSD
Location: Elementary
Number: 2232612.20

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
658998-021	21	RM 6 EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-022	22	RM 8 EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658998-023	23	Gym EL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.43	5.00	µg/L	11/24/25	RR

658998-11/25/25 11:47 AM

Kelly Muncy

Reviewed By: **Kelly Muncy**
Manager

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified

State	Certificate Number
New York	ELAP 68765
Virginia	VELAP 12761

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results apply to the sample as received.

658998

V:658\658998

ssmith 11/19/2025 9:39:07 AM
UPS 1Z2E2899846815502

Submitting Co.	Labella Associates	State of Collection	NY	Cert. Required	☐ YES ☐ NO
300 Pearl Street, Suite 130		Acct #		Phone	
Buffalo, NY 14202		Email	EMiller@LabellaPC.com		
Project Name	Bolivar Richburg CSD	PO #			
Project Location	ELEMENTARY	Special Instructions: See Attached for LaBella COC - 10 Day Turn Around Time Please analyze as EPA 200.9 Rev 2.2			
Project Number	2232612.20				
Collected By	By District				

Turn Around Time**	Matrix	Tests/Analytes (Select ALL that Apply) - Blank spaces are for additional analytes			
☐ 2 Hour * ☐ Same day * ☐ 1 business day ☐ 2 business days ☐ 3 business days ☐ 5 business days * not available for all tests ** past 3 PM the TAT will begin next business day Please schedule rush tests in advance	☐ Air ☐ Paint ☐ Soil ☐ Wipe ☐ Bulk ☐ Waste Water ☐ Ground Water ☒ Drinking Water ☐ TSP / PM10 ☐ _____	Asbestos in Bulk ☐ PLM ☐ PLM Qualitative ☐ 400 Point Count ☐ 1000 Point Count ☐ Gravimetric Prep Asbestos in Air ☐ PCM ☐ PCM-B Rules	Metals Total ☒ Lead ☐ RCRA 8 Metals ☐ Chromium VI ☐ Mercury ☐ _____ Gravimetric ☐ Total Dust NIOSH 0500 ☐ Resp. Dust NIOSH 0600	TCLP ☐ Lead ☐ RCRA 8 Metals ☐ Full TCLP (w/ organics 10 Day) Miscellaneous ☐ Silica FTIR (7602) ☐ _____	Microbiology ☐ BACT (MPN/PA) ☐ Mold Direct Exam ☐ Allergens Sub-Contract ☐ TEM Chatfield ☐ TEM AHERA ☐ TEM 7402 ☐ Silica XRD (7500)

Sample #	Date Sampled	Time Sampled	Sample Identification (Employee, Bldg, Material, Type ¹)	Wipe Area	Time ²		Flow Rate ³		Total Air ⁴
					Start	Stop	Start	Stop	
			See Attached for LaBella COC						
			ELEMENTARY						
			1-23						

For Aqueous and Solid samples ensure enough sample is sent for duplicate and spike analysis

¹Type: A=Area, B=Blank, P=Personal, E=Excursion ²Beginning/End of Sample Period ³Liters/Minute ⁴Volume in Liters [time in min x flow in L/min]Relinquished By: one mich Signature: [Signature] Date/Time 11/16/25 11:00

ALL SHADED FIELDS MUST BE FILLED TO AVOID DELAYS

Report Address: Name: <u>Bolivar Richards CSD</u>		Billing or Copy to Information (if applicable): Name: <u>Bolivar Richards CSD</u>		Standard 14 DAY ☒ RUSH: Pre-authorization Required Next Day* ☐ 3-Day* ☐ 7-Day* ☐		*Additional charges apply to all RUSH turnaround times	
Company: <u></u>		Company: <u></u>		Date Needed or Special Instructions:			
Street: <u>main st Richburg</u>		Street: <u>100 School ST</u>		Authorization or P.O. #			
City/State: <u></u> Zip: <u></u>		City/State/Zip: <u>Bolivar NY 14715</u>					
Phone: <u></u>		Phone: <u>585-928-2561</u>					
Fax: <u></u>		Fax: <u>585-928-1368</u>					
email: <u>Elemenberry</u>		email: <u>rhacmon@bolivarrichburg.org</u>					

Client Project ID/Client Site ID

009

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers #	size/type	Analyses	Preservative Check	LSL ID#
1 10 fountain girls 2nd floor	10/10/25	10 AM								
2 2nd floor cross from fountain	10/10/25	10:05 AM								
3 fountain cross	10/10/25	10:10 AM	Grab	PWS	HNO ₃	1	p250ml	Lead		
4 fountain cross	10/10/25	10:15 AM								
5 Cate kitchen	10/10/25	10:25 AM								
6 fountain cross	10/10/25	10:30 AM								
7 Room 21	10/10/25	10:31 AM								
8 Room 22	10/10/25	10:32								
9 Room 23	10/10/25	10:33								

LSL use only:

Custody Transfers

Sampled By:	Received By:	Date	Time
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By:		
Shipment Method:	Received Intact: Y N	Sample Temp:	

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
Business and receiving hours vary by location. Please call local lab or 800-215-1090 for more info.

Containers this C-O-C

Report Address:
 Name: Bolivar Richburg CSD
 Company: _____
 Street: _____
 City/State: Elementary Zip: _____
 Phone: _____
 Fax: _____
 email: _____

Billing or Copy to Information (if applicable):
 Name: Bolivar Richburg CSD
 Company: _____
 Street: 100 School ST
 City/State/Zip: Bolivar NY 14715
 Phone: 585-928-2561
 Fax: 585-928-1368
 email: rhacmon@bolivarrichburg.org

Standard ☒ **RUSH: Pre-Authorization Required**
 14 DAY ☒ Next Day* ☐ 3-Day* ☐
 [X] 2-Day* ☐ 7-Day* ☐

*Additional charges apply to all RUSH turnaround times

Date Needed or Special Instructions:

Authorization or P.O. #

ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.

Client Project ID/Client Site ID

Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#
						#	size/type			
#10 Room 24 DF	10/10/25	10:35	Grab	PWS	HNO ₃	1	p250ml	Lead		
#11 Room 25 DF	10/10/25	10:35								
#12 Room 26 DF	10/10/25	10:35								
#13 Room 27 DF	10/10/25	10:40 AM								
#14 Room 28 DF	10/10/25	10:40								
Car Peter's #15 EL	11/11/25	12:10 PM								
Fountain 55 wing EL	11/11/25	12:12 PM								
17 Room 3 EL	11/11/25	12:13 PM								
18 Room 4 EL	11/11/25	12:16 PM								
19 Room 5 EL	11/11/25	12:17 PM								

LSL use only:

Custody Transfers

Sampled By: _____
 Relinquished By: _____
 Relinquished By: _____
 Shipment Method: _____

Received By: _____
 Received for Lab By: _____
 Received Intact: Y N

Sample Temp: _____

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY ***

Business and receiving hours vary by location. Please call local lab or 800-275-4990 for more info.

Port Address:
Name: Bolivar Richards CSD
Company:
Address: 100 School St
City/State/Zip: Bolivar NY 14715
Phone: 585-928-2561
Fax: 585-928-1368
Email: rhacmon@bolivarrichards.org

Billing or Copy to Information (if applicable):
Name: Bolivar Richards CSD
Company:
Street: 100 School St
City/State/Zip: Bolivar NY 14715
Phone: 585-928-2561
Fax: 585-928-1368
Email: rhacmon@bolivarrichards.org

Client Project ID/Client Site ID
Sample Date
Sample Time
Type
Matrix
Preservative
Added
Containers
#
size/type
Analyses
Lead
Preservative
Check
LSI ID#

Standard
14 Day
Next Day*
2-Day*
3-Day*
7-Day*
Date Needed or Special Instructions:
Authorization or P.O. #
LAB ONLY
ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO

Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preservative	Added	Containers	#	size/type	Analyses	Preservative	Check	LSI ID#
20 Room 2 EL	11/15	12:18pm	Grab	PWS	HNO ₃		1		p250ml	Lead			
21 Room 6 EL	11/15	12:18pm											
22 Room 8 EL	11/15	12:22pm											
23 Room 9 EL	11/15	12:30pm											

Use only:
Sampled By:
Relinquished By:
Received By:
Received for Lab By:
Received Intact: Y N
Shipment Method:
Sample Temp:

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***
 Business and receiving hours vary by location. Please call local lab or 800-275-8090 for more info.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 658999

Matrix Drinking Water
Received 11/19/25
Reported 11/24/25

Attn:

Project: Bolivar Richburg CSD
Location: High School
Number: 2232612.20

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
658999-001	HS-1	3rd FL G Bath RM					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-002	HS-2	3rd FL B Bath RM					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-003	HS-3	By G Bath RM 2nd FL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-004	HS-4	By B Bath RM 2nd FL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-005	HS-5	Faculty RM					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-006	HS-6	By G Bath RM 1st FL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-007	HS-7	By B Bath RM 1st FL					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-008	HS-8	DNK FNTN CAF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-009	HS-9	DNK FNTN B Gym					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-010	HS-10	DNK FNTN G Gym					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results apply to the sample as received.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 658999

Matrix Drinking Water
Received 11/19/25
Reported 11/24/25

Attn:

Project: Bolivar Richburg CSD
Location: High School
Number: 2232612.20

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
658999-011	HS-11	Dnk Fntn Bath RM Bsmt					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-012	HS-12	Dnk Fntn Fitness Center					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-013	HS-13	Kitchen					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-014	HS-14	Bus Garage					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-015	HS-15A	Bolivar Cncssn					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/22/25	RR
658999-016	HS-15B	FTBall Cncssn Fntn					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658999-017	HS-16	Bball Drink Cncssn Fntn					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658999-018	HS-17	Bball Cncssn					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658999-019	HS-18	Richburg Cncssn Dnk Fntn					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR
658999-020	HS-19	Richburg Cncssn					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	11/24/25	RR

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results apply to the sample as received.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 658999

Matrix Drinking Water
Received 11/19/25
Reported 11/24/25

Attn:

Project: Bolivar Richburg CSD
Location: High School
Number: 2232612.20

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
658999-11/24/25 05:03 PM							

Kelly Muncy

Reviewed By: **Kelly Muncy**
Manager

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified

State	Certificate Number
New York	ELAP 68765
Virginia	VELAP 12761

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results apply to the sample as received.



2512 West Cary Street, Richmond, Virginia 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

www.slabinc.com • info@slabinc.com

658999

V:\658\658999

11/19/2025 9:39:07 AM

1Z2E2899846815502

Submitting Co	Labella Associates	State of Collection	NY	Cert Required	☐ YES ☐ NO
300 Pearl Street, Suite 130		Acct #		Phone	
Buffalo, NY 14202		Email	EMiller@LabellaPC.com		
Project Name	Bolivar Richburg CSD	PO #			
Project Location	HIGH SCHOOL	Special Instructions: See Attached for LaBella COC - 10 Day Turn Around Time Please analyze as EPA 200.9 Rev 2.2			
Project Number	2232612.20				
Collected By	By District				

Turn Around Time **	Matrix	Tests/Analytes (Select ALL that Apply) Blank spaces are for additional analytes			
☐ 2 Hour * ☐ Same day * ☐ 1 business day ☐ 2 business days ☐ 3 business days ☐ 5 business days * not available for all tests ** past 3 PM the TAT will begin next business day <i>Please schedule rush tests in advance</i>	☐ Air ☐ Paint ☐ Soil ☐ Wipe ☐ Bulk ☐ Waste Water ☐ Ground Water ☒ Drinking Water ☐ TSP / PM10 ☐ _____	Asbestos in Bulk ☐ PLM ☐ PLM Qualitative ☐ 400 Point Count ☐ 1000 Point Count ☐ Gravimetric Prep	Metals Total ☒ Lead ☐ RCRA 8 Metals ☐ Chromium VI ☐ Mercury ☐ _____	TCLP ☐ Lead ☐ RCRA 8 Metals ☐ Full TCLP <i>(w/ organics 10 Day)</i>	Microbiology ☐ BACT (MPN/PA) ☐ Mold Direct Exam ☐ Allergens
		Asbestos in Air ☐ PCM ☐ PCM-B Rules	Gravimetric ☐ Total Dust NIOSH 0500 ☐ Resp. Dust NIOSH 0600	Miscellaneous ☐ Silica FTIR (7602) ☐ _____	Sub-Contract ☐ TEM Chatfield ☐ TEM AHERA ☐ TEM 7402 ☐ Silica XRD (7500)

[illegible]

For Aqueous and Solid samples ensure enough sample is sent for duplicate and spike analysis

¹Type: A=Area, B=Blank, P=Personal, E=Excursion ²Beginning/End of Sample Period ³Liters/Minute ⁴Volume in Liters [time in min × flow in L/min]

ERA MUA

2

11/16/25 1st

! ALL SHADED FIELDS MUST BE FILLED TO AVOID DELAYS !

Report Address: Name: <u>Bolivar Richburg CSD</u> Company: _____ Street: <u>100 School St</u> City/State: _____ Zip: _____ Phone: _____ Fax: _____ email: _____		Billing or Copy to Information (if applicable): Name: <u>Bolivar Richburg CSD</u> Company: _____ Street: <u>100 School St</u> City/State: <u>Bolivar NY</u> Zip: <u>14715</u> Phone: <u>585-928-2561</u> Fax: <u>585-928-1368</u> email: <u>rharmone@bolivarrichburg.org</u>		Standard 14 DAY ☒		RUSH: Pre-Authorization Required Next Day* ☐ 2-Day* ☐ 3-Day* ☐ 7-Day* ☐		*Additional charges apply to all RUSH turnaround times			
Date Needed or Special Instructions: _____											
Authorization or P.O. # _____											
ALL SAMPLES MUST BE KEPT IN REFRIGERATOR & DELIVERED TO LAB ON ICE.											
Client's Sample Identifications	Sample Date	Sample Time	Type grab/comp	Matrix	Preservative Added	Containers		Analyses	Preservative Check	LSL ID#	
						#	size/type				
3rd floor girls bathroom	10/10/25	6:30 A	Grab	PWS	HNO ₃	1	p250ml	Lead			
3rd floor boys bath	10/10/25	6:30 A									
3rd Girls Bathroom 2nd Floor	10/10/25	6:35 A									
4th Boys Bathroom 2nd Floor	10/10/25	6:40 A									
5 Faculty Room	10/10/25	6:50 A									
6 By Girls Bathroom 1st Floor	10/10/25	7:00 A									
7 By Boys Bathroom 1st Floor	10/10/25	7:05 A									
8. Drinking Fountain By Caf	10/10/25	7:10 A									
9 Drinking Fountain By Caf	10/10/25	7:15 A									
LSL use only: _____										Custody Transfers	
Sampled By: _____										Received By: _____	
Relinquished By: _____										Received By: _____	
Relinquished By: _____										Received for Lab By: _____	
Shipment Method: _____										Received Intact: Y N	
Containers this C-O-C										Sample Temp: _____	

*** All areas of this Chain of Custody Record MUST be filled out in order to process samples in a timely manner IN PEN ONLY***

Business and receiving hours vary by location. Please call local lab or 800-215-7888 for more info.

100

Report Address:										Billing or Copy to Information (if applicable):				Standard				RUSH: Pre-authorization Required				*Additional charges apply to all RUSH turnaround times	
Name: Bolivar Richburg CSD										Name: Bolivar Richburg CSD				14 DAY				Next Day*				3-Day*	
Company:										Company:				[X]				2-Day*				7-Day*	
Street: 100 School St										Street: 100 School St													
City/State: Bolivar NY Zip: 14715										City/State/Zip: Bolivar NY 14715													
Phone:										Phone 585-928-2561													
Fax:										Fax: 585-928-1368													
email:										email: rcharmon@bolivarrichburg.org													
Client Project ID/Client Site ID																							
Client's Sample Identifications		Sample Date		Sample Time		Type grab/comp		Matrix		Preservative Added		#		Containers size/type		Analyses		Preservative Check		LSL ID#			
#14	Bus Garage	10/10/25	8:00				Grab	PWS		HNO ₃		1		p250ml		Lead							
#15A	Bolivar Concession	10/10/25	8:10																				
#15B	Fountain Concession	10/10/25	8:20																				
#16	Baseball Drinking Fountain	10/10/25	9:00																				
#17	Baseball Concession	10/10/25	9:00																				
#18	Baseball Drinking Fountain	10/10/25	9:30																				
#19	Baseball Concession	10/10/25	9:35																				
LSL use only:										Custody Transfers										Date		Time	
Sampled By:										Received By:													
Relinquished By:										Received By:													
Relinquished By:										Received for Lab By:													
Shipment Method:										Received Intact: Y N												Sample Temp:	
Containers this C-O-C																							

Appendix B

Licenses and Certifications

United States Environmental Protection Agency

This is to certify that



Eric M Miller

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories


This certification is valid from the date of issuance and expires April 25, 2025

LBP-R-116039-2

Certification #

April 11, 2022

Issued On



Ben Conetta, Chief

Chemicals and Multimedia Programs Branch

United States Environmental Protection Agency

This is to certify that

LaBella Associates, D.P.C.

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires September 26, 2024

LBP-2226-2

Certification #

August 24, 2021

Issued On



Michelle Price, Chief

Lead, Heavy Metals, and Inorganics Branch

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2025
Issued April 01, 2024

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Lead, Total

EPA 200.9 Rev. 2.2



Serial No.: 68765

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.



NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2025
Issued April 01, 2024

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:*

Miscellaneous

Asbestos in Friable Material	EPA 600/M4/82/020
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Lead in Dust Wipes	EPA 7000B
Lead in Paint	EPA 7000B

Sample Preparation Methods

EPA 3050B
ASTM E-1979-17
ME-003-20-002



Serial No.: 68768

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.