

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

May 22, 2026

Batch #: 052226-4

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1900 Morningside Dr Bldg. - City High
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SML413	SST	1813	15-May-2026	10:00 AM	18-May-2026	2:50 PM	5.1
SPR194	SST	1312	15-May-2026	10:00 AM	18-May-2026	2:50 PM	3.6
SPR322	SST	1801A	15-May-2026	10:00 AM	18-May-2026	2:50 PM	2.4
SNL320	SST	1311	15-May-2026	10:00 AM	18-May-2026	2:50 PM	3.2
SOV271	SST	1311	15-May-2026	10:00 AM	18-May-2026	2:50 PM	3.3

Average Radon Concentration in:

1311

3.2 pCi/L

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E1549

Reader Calibration Due: 10/24/2026

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

May 22, 2026

Batch #: 052226-5

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
3100 E. Washington St Bldg.- Lemme
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNU568	SST	134A	15-May-2026	10:40 AM	18-May-2026	2:40 PM	8.4
SPR173	SST	134A	15-May-2026	10:40 AM	18-May-2026	2:40 PM	8.8
Average Radon Concentration in:			134A		8.6 pCi/L		

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E0747

Reader Calibration Due: 4/14/2026

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

May 22, 2026

Batch #: 052226-6

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1507 8th St Bldg.- NWMS
Coralville IA 52241

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNL473	SST	264	15-May-2026	11:15 AM	18-May-2026	2:00 PM	1.1
SNU657	SST	166A	15-May-2026	11:15 AM	18-May-2026	2:00 PM	10.4
SNX187	SST	102A	15-May-2026	11:15 AM	18-May-2026	2:00 PM	1.7
SOW036	SST	102A	15-May-2026	11:15 AM	18-May-2026	2:00 PM	1.5
Average Radon Concentration in:			102A		1.6 pCi/L		

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E1549

Reader Calibration Due: 10/24/2026

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

May 22, 2026

Batch #: 052226-7

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1400 Grissel Pl Bldg.- Shimek
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNL524	SST	130	15-May-2026	10:55 AM	18-May-2026	2:25 PM	1.0
SNL563	SST	130	15-May-2026	10:55 AM	18-May-2026	2:25 PM	0.8

Average Radon Concentration in:

130

0.9 pCi/L

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E1549

Reader Calibration Due: 10/24/2026

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ **Date:** _____