

Lead in School Drinking Water Report

Edgar Brown Memorial Stadium



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-04-21

Date(s) analyzed: 2026-05-04, 2026-05-05

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	424175	2026-04-21	Visitor Concessions	Sink - Multi-compartment	Visitor Concession Kitchen	1 of 1	Sprayer	center	19
2	424160	2026-04-21	Hospitality Building	Sink	Hospitality Room	1 of 1	Tap	center	3
3	424173	2026-04-21	Visitor Concessions	Sink - Multi-compartment	Visitor Concessions Kitchen	1 of 1	Tap	left	3
4	424164	2026-04-21	Hospitality Building	Fountain	Hospitality Bathroom	2 of 6	Water Fountain	center	2
5	424166	2026-04-21	Hospitality Building	Fountain	Hospitality Bathroom	3 of 6	Water Fountain	center	2
6	424167	2026-04-21	Field House/Locker Rooms	Sink	Locker D Training Rm	1 of 1	Tap	center	2
7	424170	2026-04-21	Hospitality Building	Fountain	Hospitality Bathroom	5 of 6	Water Fountain	center	2
8	424172	2026-04-21	Hospitality Building	Fountain	Hospitality Bathroom	6 of 6	Water Fountain	center	2
9	424162	2026-04-21	Hospitality Building	Fountain	Hospitality Bathroom	1 of 6	Water Fountain	center	1
10	424168	2026-04-21	Hospitality Building	Fountain	Hospitality Bathroom	4 of 6	Water Fountain	center	1

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	424177	2026-04-21	Visitor Concessions	Sink - Multi-compartment	Visitor Concession Kitchen	1 of 1	Tap	right	1
12	424182	2026-04-21	Home Concessions	Fountain	Home Concession Restrooms	4 of 6	Water Fountain	center	1
13	424186	2026-04-21	Home Concessions	Fountain	Home Concession Restrooms	6 of 6	Water Fountain	center	1
14	424161	2026-04-21	Field House/Locker Rooms	Fountain - Multi-level	Locker C	1 of 1	Water Fountain	right	<1
15	424163	2026-04-21	Field House/Locker Rooms	Fountain - Multi-level	Locker D	1 of 1	Water Fountain	left	<1
16	424165	2026-04-21	Field House/Locker Rooms	Fountain - Multi-level	Locker D	1 of 1	Water Fountain	right	<1
17	424169	2026-04-21	Visitor Concessions	Fountain - Multi-level	Visitor Concessions	1 of 1	Water Fountain	left	<1
18	424171	2026-04-21	Visitor Concessions	Fountain - Multi-level	Visitor Concessions	1 of 1	Water Fountain	right	<1
19	424174	2026-04-21	Home Concessions	Ice Machine	Kitchen	1 of 1	Ice Machine	center	<1
20	424176	2026-04-21	Home Concessions	Fountain	Home Concession Restrooms	1 of 6	Water Fountain	center	<1
21	424178	2026-04-21	Home Concessions	Fountain	Home Concession Restrooms	2 of 6	Water Fountain	center	<1

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	424180	2026-04-21	Home Concessions	Fountain	Home Concession Restrooms	3 of 6	Water Fountain	center	<1
23	424184	2026-04-21	Home Concessions	Fountain	Home Concession Restrooms	5 of 6	Water Fountain	center	<1
24	424188	2026-04-21	Field House/Locker Rooms	Sink	Locker Room A Training Rm	1 of 1	Tap	center	<1
25	424190	2026-04-21	Field House/Locker Rooms	Fountain - Multi-level	Locker A	1 of 1	Water Fountain	left	<1
26	424192	2026-04-21	Field House/Locker Rooms	Fountain - Multi-level	Locker A	1 of 1	Water Fountain	right	<1
27	424194	2026-04-21	Field House/Locker Rooms	Fountain - Multi-level	Locker B	1 of 1	Water Fountain	left	<1
28	424196	2026-04-21	Field House/Locker Rooms	Fountain - Multi-level	Locker B	1 of 1	Water Fountain	right	<1
29	424198	2026-04-21	Field House/Locker Rooms	Fountain - Multi-level	Locker C	1 of 1	Water Fountain	left	<1