

Addendum#3 to DO Board Room RFP

Deadline for Submissions	Wednesday, June 17, 2026 by 4PM Please submit updated bids electronically to Melissa Lazorik at lazorikm1@svsd410.org .
Project Goals	We are looking to wall mount 3 PTZ cameras in the District Office Board Room for livestreaming board meetings. We are also looking to upgrade the A/V system, including a short throw projector or TV with wall speakers. This will all tie in to a mobile Producer station in the back of the room.
Timeline	• Project should be completed before July 31st, 2026 • Work can be scheduled anytime on weekdays and weekends
Addendum #1	Please also include ADA devices in your proposal. For example, something like: • Williams Sound FM 557 Pro Transmitter w/ Receivers • ANT 029 Antenna • Any other necessary ADA equipment
Addendum #2	• Please confirm there are three cameras in the AV system, with one camera requiring a wide-angle view from the back of the room. ◦ Three cameras, ideally all the same make and model, all PTZ. One will be used as a wide-angle but does not need to be a specific wide-angle model. • Please confirm whether the district will require integration with Extron GlobalViewer. ◦ We will handle this in-house. The system as a whole just needs to route back to our MDF. • Please confirm whether the district would like six boundary microphones and two handheld microphones with an 8-channel wireless microphone access point. ◦ We would like this included in the proposal. • Please confirm whether the district would like to utilize an in-room lectern with integrated AV rack in lieu of installing equipment in the existing at-capacity IDF (see attached specification).



	○ We do want all the equipment in the board room, not at the IDF, but would prefer a metal cabinet mounted to the wall over the provided lectern. ● Please confirm the two HDMI wall input locations: one at the front of the room and one at the control desk area in the back corner of the room. ○ Those are correct ● Please confirm cameras powered over CAT6 cabling are preferred. Please confirm the required CAT cabling type, brand, and product line. ○ CAT6 is correct. Our district standard is Leviton ● Please confirm the preferred production switcher the district would like AV integrators to procure and install. ○ Anything by BlackMagicDesign is preferred, but we're open to suggestions. ● Please confirm whether simultaneous live streaming, full-duplex video teleconferencing, and local audio reinforcement will be required. ○ This is required. ● Please confirm the 98-inch large-format display will utilize the existing nearby power outlet. AV integrator to provide Wiremold or similar on wall raceway solution for aesthetics. ○ It will use the outlet closest to the front of the room. ● Please confirm whether AV integrator should provide pricing for a short-throw projector and screen as an alternate option. ○ No short-throw is necessary; we've landed on a large TV for our display choice.
Addendum #3	● We are interested in receiving updated proposals that include the following cost savings: ○ Remove the Shure microphone equipment, we will provide our own ○ Remove the switch from the proposal, we will provide our own ○ Any other suggestions you may have to lower the overall cost to around 75K ● Please provide a product that will not require a large amount of wall conduit ● Additionally, if you haven't already, please provide a breakdown separating the materials cost and the labor costs. These will use different account codes, so we will need to know the exact cost for both.