



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

June 10, 2026

John Harding  
Eagle Point School District #9  
PO Box 548  
Eagle Point, OR 97524  
TEL: (541) 830-1240  
FAX (541) 830-6375

RE: EPHS Lead Testing

Order No.: 26051023

Dear John Harding:

Neilson Research Corporation received 46 sample(s) on 5/27/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at [www.nrclabs.com](http://www.nrclabs.com). If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Director of Project Management  
245 S Grape St  
Medford, OR 97501





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

## Case Narrative

WO#: 26051023  
Date: 6/10/2026

---

**CLIENT:** Eagle Point School District #9  
**Project:** EPHS Lead Testing

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-01      Client Sample ID: 063KF  
 Collection Date: 5/27/2026 5:11:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 063KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.23		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-02      Client Sample ID: 049OT  
 Collection Date: 5/27/2026 5:14:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 049OT

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.53		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-03      Client Sample ID: 050BF  
 Collection Date: 5/27/2026 5:22:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 050BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.24		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-04      Client Sample ID: 051BF  
 Collection Date: 5/27/2026 5:24:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 051BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.82		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-05      Client Sample ID: 048CF  
 Collection Date: 5/27/2026 5:30:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 048CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.516		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-06      Client Sample ID: 046BF  
 Collection Date: 5/27/2026 5:31:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 046BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.59		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-07      Client Sample ID: 047BF  
 Collection Date: 5/27/2026 5:31:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 047BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-08      Client Sample ID: 039BF  
 Collection Date: 5/27/2026 5:33:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 039BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.26		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-09      Client Sample ID: 040BF  
 Collection Date: 5/27/2026 5:34:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 040BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.72		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-10      Client Sample ID: 041DW  
 Collection Date: 5/27/2026 5:43:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 041DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-11      Client Sample ID: 042WB  
 Collection Date: 5/27/2026 5:44:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 042WB

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-12      Client Sample ID: 043DW  
 Collection Date: 5/27/2026 5:45:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 043DW

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-13      Client Sample ID: 044BF  
 Collection Date: 5/27/2026 5:46:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 044BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.87		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-14      Client Sample ID: 045BF  
 Collection Date: 5/27/2026 5:47:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 045BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.27		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-15      Client Sample ID: 065SF  
 Collection Date: 5/27/2026 5:51:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 065SF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.31		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-16      Client Sample ID: 064CF  
 Collection Date: 5/27/2026 6:07:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 064CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	12.4	1	0.500	ppb	1	6/8/2026	15.0	A	

**Lab ID:** 26051023-17      Client Sample ID: 081CF  
 Collection Date: 5/27/2026 6:13:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 081CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A	

**Lab ID:** 26051023-18      Client Sample ID: 083CF  
 Collection Date: 5/27/2026 6:18:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 083CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-19      Client Sample ID: 093CF  
 Collection Date: 5/27/2026 6:19:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 093CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-20      Client Sample ID: 084CF  
 Collection Date: 5/27/2026 6:26:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 084CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.80		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-21      Client Sample ID: 051BF  
 Collection Date: 5/27/2026 4:58:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 051BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-22      Client Sample ID: 055KF  
 Collection Date: 5/27/2026 4:59:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 055KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-23      Client Sample ID: 056KF  
 Collection Date: 5/27/2026 5:00:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 056KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-24      Client Sample ID: 054KF  
 Collection Date: 5/27/2026 5:02:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 054KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-25      Client Sample ID: 057KF  
 Collection Date: 5/27/2026 5:04:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 057KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.768		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-26      Client Sample ID: 058KF  
 Collection Date: 5/27/2026 5:06:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 058KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.13		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-27      Client Sample ID: 059KF  
 Collection Date: 5/27/2026 5:07:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 059KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.06		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-28      Client Sample ID: 060KF  
 Collection Date: 5/27/2026 5:08:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 060KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.89		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-29      Client Sample ID: 053KF  
 Collection Date: 5/27/2026 5:08:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 053KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-30      Client Sample ID: 052KF  
 Collection Date: 5/27/2026 5:10:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 052KF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.46		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-31      Client Sample ID: 085CF  
 Collection Date: 5/27/2026 6:30:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 085CF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.27		0.500	ppb	1	6/8/2026	15.0	A	

**Lab ID:** 26051023-32      Client Sample ID: 086CF  
 Collection Date: 5/27/2026 6:32:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 086CF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.648		0.500	ppb	1	6/8/2026	15.0	A	

**Lab ID:** 26051023-33      Client Sample ID: 087CF  
 Collection Date: 5/27/2026 6:34:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 087CF

Trace Metals by EPA 200.8 ICP-MS								Analyst:	PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.858		0.500	ppb	1	6/8/2026	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-34      Client Sample ID: 088CF  
 Collection Date: 5/27/2026 6:35:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 088CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.88		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-35      Client Sample ID: 089CF  
 Collection Date: 5/27/2026 6:37:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 089CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.524		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-36      Client Sample ID: 090CF  
 Collection Date: 5/27/2026 6:38:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 090CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-37      Client Sample ID: 091CF  
 Collection Date: 5/27/2026 6:39:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 091CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.719		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-38      Client Sample ID: 092CF  
 Collection Date: 5/27/2026 6:40:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 092CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-39      Client Sample ID: 062IM  
 Collection Date: 5/27/2026 6:45:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 062IM

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-40      Client Sample ID: 094IM  
 Collection Date: 5/27/2026 6:50:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 094IM

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-41      Client Sample ID: 099CF  
 Collection Date: 5/27/2026 6:57:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 099CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/5/2026	15.0	A

**Lab ID:** 26051023-42      Client Sample ID: 096CF  
 Collection Date: 5/27/2026 7:02:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 096CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/5/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-43      Client Sample ID: 098CF  
 Collection Date: 5/27/2026 7:05:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 098CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.17		0.500	ppb	1	6/5/2026	15.0	A

**Lab ID:** 26051023-44      Client Sample ID: 097CF  
 Collection Date: 5/27/2026 7:06:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 097CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.543		0.500	ppb	1	6/8/2026	15.0	A

**Lab ID:** 26051023-45      Client Sample ID: 147OT  
 Collection Date: 5/27/2026 7:24:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 147OT

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 26051023  
 Date Reported: 6/10/2026

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 26051023  
**Received Date:** 5/27/2026 9:09:00 AM  
**Reported Date:** 6/10/2026 9:32:11 AM

Sample Information:

**Lab ID:** 26051023-46      Client Sample ID: 148IM  
 Collection Date: 5/27/2026 7:26:00 AM      Collected By: Loni O'Connor  
 Matrix: Drinking Water      Sample Location: 148IM

Trace Metals by EPA 200.8 ICP-MS						Analyst: PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/8/2026	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 26051023

10-Jun-26

**Client:** Eagle Point School District #9

**Project:** EPHS Lead Testing

**TestCode:** LEAD\_SCHOOLS

Sample ID: <b>MB-37080</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70222</b>						
Client ID: <b>PBW</b>	Batch ID: <b>37080</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/5/2026</b>	SeqNo: <b>1158797</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.500

Sample ID: <b>LCS-37080</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70222</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>37080</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/5/2026</b>	SeqNo: <b>1158798</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.500 100 0 103 85 115

Sample ID: <b>26051207-01AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70222</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>37080</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/5/2026</b>	SeqNo: <b>1158800</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.500 100 0.166 100 70 130

Sample ID: <b>26051207-01AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70222</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>37080</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/5/2026</b>	SeqNo: <b>1158801</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 100 0.500 100 0.166 99.9 70 130 101 0.561 20

**Qualifiers:** CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed  
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 26051023

10-Jun-26

**Client:** Eagle Point School District #9

**Project:** EPHS Lead Testing

**TestCode:** LEAD\_SCHOOLS

Sample ID: <b>MB-37079</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70242</b>
Client ID: <b>PBW</b>	Batch ID: <b>37079</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2026</b>	SeqNo: <b>1159192</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: <b>LCS-37079</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70242</b>
Client ID: <b>LCSW</b>	Batch ID: <b>37079</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2026</b>	SeqNo: <b>1159193</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.500 100 0 103 85 115

Sample ID: <b>26051023-21AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70242</b>
Client ID: <b>051BF</b>	Batch ID: <b>37079</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2026</b>	SeqNo: <b>1159195</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.500 100 0.213 102 70 130

Sample ID: <b>26051023-21AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70242</b>
Client ID: <b>051BF</b>	Batch ID: <b>37079</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2026</b>	SeqNo: <b>1159196</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.500 100 0.213 102 70 130 102 0.235 20

**Qualifiers:** CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed  
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 26051023  
 10-Jun-26

**Client:** Eagle Point School District #9  
**Project:** EPHS Lead Testing

**TestCode:** LEAD\_SCHOOLS

Sample ID: <b>MB-37078</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70242</b>
Client ID: <b>PBW</b>	Batch ID: <b>37078</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2026</b>	SeqNo: <b>1159220</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.500			

Sample ID: <b>LCS-37078</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70242</b>
Client ID: <b>LCSW</b>	Batch ID: <b>37078</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2026</b>	SeqNo: <b>1159221</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	104	0.500	100	0	104 85 115

Sample ID: <b>26051023-01AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70242</b>
Client ID: <b>063KF</b>	Batch ID: <b>37078</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2026</b>	SeqNo: <b>1159223</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	104	0.500	100	1.23	103 70 130

Sample ID: <b>26051023-01AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_SCHO</b>	Units: <b>ppb</b>	Prep Date: <b>6/5/2026</b>	RunNo: <b>70242</b>
Client ID: <b>063KF</b>	Batch ID: <b>37078</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2026</b>	SeqNo: <b>1159224</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	104	0.500	100	1.23	103 70 130 104 0.189 20

**Qualifiers:** CI Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed  
 MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



# Sample Log-In Check List

Client Name: EAGLEPTSCHOOL

Work Order Number: 26051023

RcptNo: 1

Logged by: Ashley Spiegelberg	5/27/2026 9:09:00 AM	<i>Am</i>
Completed By: Kyler Woolsey	5/29/2026 10:50:17 AM	<i>Kyler Woolsey</i>
Reviewed By: Tamra Schmedemann	6/10/2026 8:50:23 AM	<i>Tamra Schmedemann</i>

**Chain of Custody**

1. Is Chain of Custody complete? Yes  No  Not Present   
 2. How was the sample delivered? Client

**Log In**

3. Coolers are present? Yes  No  NA   
 4. Shipping container/cooler in good condition? Yes  No   
 Custody seals intact on shipping container/cooler? Yes  No  Not Present  NA   
 No. Seal Date: Signed By:  
 5. Was an attempt made to cool the samples? Yes  No  NA   
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes  No  NA   
 7. Sample(s) in proper container(s)? Yes  No   
 8. Sufficient sample volume for indicated test(s)? Yes  No   
 9. Are samples (except VOA and ONG) properly preserved? Yes  No   
 10. Was preservative added to bottles? Yes  No  NA   
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes  No  No VOA Vials   
 12. Were any sample containers received broken? Yes  No   
 13. Does paperwork match bottle labels? Yes  No   
 (Note discrepancies on chain of custody)  
 14. Are matrices correctly identified on Chain of Custody? Yes  No   
 15. Is it clear what analyses were requested? Yes  No   
 16. Were all holding times able to be met? Yes  No   
 (If no, notify customer for authorization.)

**Special Handling (if applicable)**

17. Was client notified of all discrepancies with this order? Yes  No  NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

**Cooler Information**

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------