

Lead in Water Test Results Summary: Central Point Elementary

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Support Services Bathroom	20420100001BF25A	5/7/2025	ND	Non-Detect			
RM1 Sink	20420100002CF25A	5/7/2025	ND	Non-Detect			
RM1 Drinking Fountain	20420100003DW25A	5/7/2025	ND	Non-Detect			
Bathroom Between RM1 and RM3	20420100004BF25A	5/7/2025	ND	Non-Detect			
RM3 Sink	20420100005CF25A	5/7/2025	ND	Non-Detect			
RM3 Drinking Fountain	20420100006DW25A	5/7/2025	ND	Non-Detect			
East Wing Right Drinking Fountain	20420100007DW25A	5/7/2025	ND	Non-Detect			
East Wing Left Drinking Fountain	20420100008DW25A	5/7/2025	ND	Non-Detect			
East Wing Bottle Fill	20420100009WB25A	5/7/2025	ND	Non-Detect			
East Wing Girls Bathroom Left Sink	20420100010BF25A	5/7/2025	ND	Non-Detect			
East Wing Girls Bathroom Middle Sink	20420100011BF25A	5/7/2025	ND	Non-Detect			
East Wing Girls Bathroom Right Sink	20420100012BF25A	5/7/2025	ND	Non-Detect			
East Wing Boys Bathroom Right Sink	20420100013BF25A	5/7/2025	ND	Non-Detect			
East Wing Boys Bathroom Middle Sink	20420100014BF25A	5/7/2025	ND	Non-Detect			
East Wing Boys Bathroom Left Sink	20420100015BF25A	5/7/2025	0.579	Low			
RM5 Sink	20420100016CF25A	5/7/2025	0.518	Low			
RM5 Drinking Fountain	20420100017DW25A	5/7/2025	ND	Non-Detect			
Bathroom Sink Between RM5 and RM7	20420100018BF25A	5/7/2025	ND	Non-Detect			
RM7 Sink	20420100019CF25A	5/7/2025	ND	Non-Detect			
RM7 Drinking Fountain	20420100020DW25A	5/7/2025	ND	Non-Detect			
RM8 Drinking Fountain	20420100021DW25A	5/7/2025	ND	Non-Detect			
RM8 Sink	20420100022CF25A	5/7/2025	0.899	Low			
RM6 Drinking Fountain	20420100023DW25A	5/7/2025	ND	Non-Detect			
RM6 Sink	20420100024CF25A	5/7/2025	ND	Non-Detect			
RM27 Sink	20420100025CF25A	5/7/2025	ND	Non-Detect			
RM27 Bathroom Sink	20420100026BF25A	5/7/2025	ND	Non-Detect			
RM4 Drinking Fountain	20420100027DW25A	5/7/2025	ND	Non-Detect			
RM4 Sink	20420100028CF25A	5/7/2025	0.627	Low			
RM2 Drinking Fountain	20420100029DW25A	5/7/2025	ND	Non-Detect			
RM2 Sink	20420100030CF25A	5/7/2025	2.6	Low			
RM222 Sink	20420100031CF25A	5/7/2025	3.09	Low			
Library Storage Area Sink	20420100032CF25A	5/7/2025	1.08	Low			
RM10 Sink	20420100033CF25A	5/7/2025	2.87	Low			
RM10 Drinking Fountain	20420100034DW25A	5/7/2025	ND	Non-Detect			
RM12 Sink	20420100035CF25A	5/7/2025	1.02	Low			
RM12 Drinking Fountain	20420100036DW25A	5/7/2025	ND	Non-Detect			
RM14 Sink	20420100037CF25A	5/7/2025	1.56	Low			
RM14 Drinking Fountain	20420100038DW25A	5/7/2025	ND	Non-Detect			
RM28 Sink	20420100039CF25A	5/7/2025	6.06	Moderate			
RM28 Bathroom Sink	20420100040BF25A	5/7/2025	9.46	Moderate			
RM16 Sink	20420100041CF25A	5/7/2025	1.6	Low			
RM16 Drinking Fountain	20420100042DW25A	5/7/2025	ND	Non-Detect			
RM18 Sink	20420100043CF25A	5/7/2025	1.67	Low			
RM18 Drinking Fountain	20420100044DW25A	5/7/2025	0.792	Low			
RM19 Sink	20420100045CF25A	5/7/2025	0.989	Low			
RM19 Drinking Fountain	20420100046DW25A	5/7/2025	ND	Non-Detect			
RM17 Drinking Fountain	20420100047DW25A	5/7/2025	ND	Non-Detect			
RM17 Sink	20420100048CF25A	5/7/2025	1.04	Low			
West Wing Right Drinking Fountain	20420100049DW25A	5/7/2025	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
West Wing Left Drinking Fountain	20420100050DW25A	5/7/2025	ND	Non-Detect			
West Wing Bottle Fill	20420100051WB25A	5/7/2025	ND	Non-Detect			
West Wing Girls Bathroom Left Sink	20420100052BF25A	5/7/2025	6.75	Moderate			
West Wing Girls Bathroom Middle Sink	20420100053BF25A	5/7/2025	4.59	Low			
West Wing Girls Bathroom Right Sink	20420100054BF25A	5/7/2025	1.3	Low			
West Wing Boys Bathroom Right Sink	20420100055BF25A	5/7/2025	2.77	Low			
West Wing Boys Bathroom Middle Sink	20420100056BF25A	5/7/2025	ND	Non-Detect			
West Wing Boys Bathroom Left Sink	20420100057BF25A	5/7/2025	5.58	Moderate			
RM15 Drinking Fountain	20420100058DW25A	5/7/2025	2.61	Low			
RM15 Sink	20420100059CF25A	5/7/2025	ND	Non-Detect			
RM13 Drinking Fountain	20420100060DW25A	5/7/2025	ND	Non-Detect			
RM13 Sink	20420100061CF25A	5/7/2025	1.53	Low			
RM11 Drinking Fountain	20420100062DW25A	5/7/2025	4.96	Low			
RM11 Sink	20420100063CF25A	5/7/2025	ND	Non-Detect			
RM9 Drinking Fountain	20420100064DW25A	5/7/2025	0.751	Low			
RM9 Sink	20420100065CF25A	5/7/2025	6.02	Moderate			
Music Room Left Sink	20420100066CF25A	5/7/2025	3.71	Low			
Music Room Right Sink	20420100067CF25A	5/7/2025	2.33	Low			
Gym Drinking Fountain	20420100068DW25A	5/7/2025	ND	Non-Detect			
Playground Boys Bathroom Right Sink	20420100069BF25A	5/7/2025	0.861	Low			
Playground Boys Bathroom Left Sink	20420100070BF25A	5/7/2025	2.08	Low			
Playground Girls Bathroom Left Sink	20420100071BF25A	5/7/2025	3.72	Low			
Playground Girls Bathroom Right Sink	20420100072BF25A	5/7/2025	1.24	Low			
Hand Sink by Dish Room	20420100073KF25A	5/7/2025	10.4	High			
Dish Room Sprayer	20420100074KF25A	5/7/2025	ND	Non-Detect			
Pot Sink Sprayer	20420100075KF25A	5/7/2025	1.01	Low			
Pot Sink Left Faucet	20420100076KF25A	5/7/2025	1.23	Low			
Hand Sink by Kitchen Office	20420100078KF25B	5/7/2025	22.7	Action Req.	10/29/2025	1.64	Low
Kitchen Bathroom Sink	20420100079BF25A	5/7/2025	1.22	Low			
Pot Fill South Wall	20420100080KF25B	5/7/2025	23.5	Action Req.	1/14/2026	1.17	Low
Steamer Fill South Wall	20420100081KF25B	5/7/2025	123	Action Req.	10/29/2025	3.43	Low
Kettle Fill South Wall	20420100082KF25A	5/7/2025	0.578	Low			
Prep Sink Center Wall	20420100083KF25A	5/7/2025	1.22	Low			
Mixer Fill	20420100084KF26C	5/7/2025	100	Action Req.	1/14/2026	1.07	Low
Prep Sink West Wall	20420100085KF25A	5/7/2025	ND	Non-Detect			
Hand Sink Northwest Corner	20420100086KF25A	5/7/2025	12	High			
Hotwell Fill Serving Area	20420100087KF25A	5/7/2025	2.7	Low			
Staff Womens Bathroom Left Sink	20420100088BF25A	5/7/2025	ND	Non-Detect			
Staff Womens Bathroom Right Sink	20420100089BF25A	5/7/2025	ND	Non-Detect			
Staff Mens Bathroom Right Sink	20420100090BF25A	5/7/2025	0.892	Low			
Staff Mens Bathroom Left Sink	20420100091BF25A	5/7/2025	0.584	Low			
Staff Breakroom Sink	20420100092SF25A	5/7/2025	ND	Non-Detect			
Production RM Sink	20420100093SF25A	5/7/2025	0.862	Low			
Health RM Bathroom Sink	20420100094BF25A	5/7/2025	0.72	Low			
Health RM Nurse Sink	20420100095NS25A	5/7/2025	1.58	Low			
Calming RM Sink	20420100096SF25A	5/7/2025	0.974	Low			
Playground Left Drinking Fountain	20420100097DW25A	5/13/2025	ND	Non-Detect			
Playground Right Drinking Fountain	20420100098DW25A	5/13/2025	ND	Non-Detect			
Music RM Right Drinking Fountain	20420100099DW25A	5/13/2025	ND	Non-Detect			
<u>CPE PORTABLES</u>							
RM621 Sink	20420101001CF25A	5/7/2025	2.12	Low			
RM622 Sink	20420101002CF25A	5/7/2025	ND	Non-Detect			
RM623 Sink	20420102001CF25A	5/7/2025	1.45	Low			
RM623 Bathroom Sink	20420102002BF25A	5/7/2025	ND	Non-Detect			
RM624 Sink	20420102003CF25A	5/7/2025	0.869	Low			
RM624 Bathroom Sink	20420102004DF25A	5/7/2025	0.665	Low			
RM624 Drinking Fountain	20420102005DW25A	5/13/2025	ND	Non-Detect			
RM623 Drinking Fountain	20420102006DW25A	5/13/2025	ND	Non-Detect			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

CENTRAL POINT ELEM
AMENDED REPORT
SAMPLE COLLECTED
05/07/2025

May 19, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: CPE Lead Testing-AMENDED

Order No.: 25050304

Dear Dale Giovannetti:

Neilson Research Corporation received 101 sample(s) on 5/7/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050304
Date: 5/19/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: CPE Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-001 **Client Sample ID:** 20420100001BF25A
Collection Date: 5/7/2025 4:40:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100001BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-002 **Client Sample ID:** 20420100002CF25A
Collection Date: 5/7/2025 5:56:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100002CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-003 **Client Sample ID:** 20420100003DW25A
Collection Date: 5/7/2025 5:57:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100003DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-004 Client Sample ID: 20420100004BF25A
Collection Date: 5/7/2025 5:58:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100004BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-005 Client Sample ID: 20420100005CF25A
Collection Date: 5/7/2025 5:59:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100005CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-006 Client Sample ID: 20420100006DW25A
Collection Date: 5/7/2025 6:00:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100006DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-007 **Client Sample ID:** 20420100007DW25A
Collection Date: 5/7/2025 4:45:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100007DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-008 **Client Sample ID:** 20420100008DW25A
Collection Date: 5/7/2025 4:46:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100008DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-009 **Client Sample ID:** 20420100009WB25A
Collection Date: 5/7/2025 4:46:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100009WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-010 Client Sample ID: 20420100010BF25A
Collection Date: 5/7/2025 4:51:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100010BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-011 Client Sample ID: 20420100011BF25A
Collection Date: 5/7/2025 4:52:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100011BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-012 Client Sample ID: 20420100012BF25A
Collection Date: 5/7/2025 4:53:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100012BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-013 Client Sample ID: 20420100013BF25A
Collection Date: 5/7/2025 4:54:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100013BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-014 Client Sample ID: 20420100014BF25A
Collection Date: 5/7/2025 4:55:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100014BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-015 Client Sample ID: 20420100015BF25A
Collection Date: 5/7/2025 4:56:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100015BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.579		0.500	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-016 **Client Sample ID:** 20420100016CF25A
Collection Date: 5/7/2025 4:59:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100016CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.518		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-017 **Client Sample ID:** 20420100017DW25A
Collection Date: 5/7/2025 5:00:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100017DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-018 **Client Sample ID:** 20420100018BF25A
Collection Date: 5/7/2025 5:01:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100018BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-019 **Client Sample ID:** 20420100019CF25A
Collection Date: 5/7/2025 5:03:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100019CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-020 **Client Sample ID:** 20420100020DW25A
Collection Date: 5/7/2025 5:04:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100020DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-021 **Client Sample ID:** 20420100021DW25A
Collection Date: 5/7/2025 5:06:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100021DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-022 Client Sample ID: 20420100022CF25A
Collection Date: 5/7/2025 5:07:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100022CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.899		0.500	ppb	1	5/13/2025	15.0	A

Lab ID: 25050304-023 Client Sample ID: 20420100023DW25A
Collection Date: 5/7/2025 5:10:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100023DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-024 Client Sample ID: 20420100024CF25A
Collection Date: 5/7/2025 5:11:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100024CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-025 **Client Sample ID:** 20420100025CF25A
Collection Date: 5/7/2025 5:12:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100025CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-026 **Client Sample ID:** 20420100026BF25A
Collection Date: 5/7/2025 5:13:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100026BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-027 **Client Sample ID:** 20420100027DW25A
Collection Date: 5/7/2025 5:16:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100027DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-028 **Client Sample ID:** 20420100028CF25A
Collection Date: 5/7/2025 5:17:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100028CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.627		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-029 **Client Sample ID:** 20420100029DW25A
Collection Date: 5/7/2025 5:21:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100029DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-030 **Client Sample ID:** 20420100030CF25A
Collection Date: 5/7/2025 5:22:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100030CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.60		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-031 **Client Sample ID:** 20420100031CF25A
Collection Date: 5/7/2025 5:24:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100031CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.09		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-032 **Client Sample ID:** 20420100032CF25A
Collection Date: 5/7/2025 5:27:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100032CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.08		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-033 **Client Sample ID:** 20420100088BF25A
Collection Date: 5/7/2025 5:36:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100088BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-034 Client Sample ID: 20420100089BF25A
Collection Date: 5/7/2025 5:37:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100089BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-035 Client Sample ID: 20420100090BF25A
Collection Date: 5/7/2025 5:38:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100090BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.892		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-036 Client Sample ID: 20420100091BF25A
Collection Date: 5/7/2025 5:39:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100091BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.584		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-037 **Client Sample ID:** 20420100092SF25A
Collection Date: 5/7/2025 5:42:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100092SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-038 **Client Sample ID:** 20420100093SF25A
Collection Date: 5/7/2025 5:43:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100093SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.862		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-039 **Client Sample ID:** 20420100094BF25A
Collection Date: 5/7/2025 5:45:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100094BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.720		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-040 **Client Sample ID:** 20420100095NS25A
Collection Date: 5/7/2025 5:46:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420100095NS25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.58		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-041 **Client Sample ID:** 20420100033CF25A
Collection Date: 5/7/2025 5:12:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100033CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.87		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-042 **Client Sample ID:** 20420100034DW25A
Collection Date: 5/7/2025 5:13:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100034DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-043 **Client Sample ID:** 20420100035CF25A
Collection Date: 5/7/2025 5:15:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100035CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.02		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-044 **Client Sample ID:** 20420100036DW25A
Collection Date: 5/7/2025 5:16:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100036DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-045 **Client Sample ID:** 20420100037CF25A
Collection Date: 5/7/2025 5:17:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100037CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.56		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-046 **Client Sample ID:** 20420100038DW25A
Collection Date: 5/7/2025 5:17:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100038DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-047 **Client Sample ID:** 20420100039CF25A
Collection Date: 5/7/2025 5:19:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100039CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.06		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-048 **Client Sample ID:** 20420100040BF25A
Collection Date: 5/7/2025 5:20:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100040BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.46	1	0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-049 **Client Sample ID:** 20420100041CF25A
Collection Date: 5/7/2025 5:22:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100041CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.60		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-050 **Client Sample ID:** 20420100042DW25A
Collection Date: 5/7/2025 5:23:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100042DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-051 **Client Sample ID:** 20420100043CF25A
Collection Date: 5/7/2025 5:24:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100043CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.67		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-052 **Client Sample ID:** 20420100044DW25A
Collection Date: 5/7/2025 5:25:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100044DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.792		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-053 **Client Sample ID:** 20420100045CF25A
Collection Date: 5/7/2025 5:27:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100045CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.989		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-054 **Client Sample ID:** 20420100046DW25A
Collection Date: 5/7/2025 5:27:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100046DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-055 **Client Sample ID:** 20420100047DW25A
Collection Date: 5/7/2025 5:29:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100047DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-056 **Client Sample ID:** 20420100048CF25A
Collection Date: 5/7/2025 5:29:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100048CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.04		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-057 **Client Sample ID:** 20420100049DW25A
Collection Date: 5/7/2025 5:30:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100049DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-058 **Client Sample ID:** 20420100050DW25A
Collection Date: 5/7/2025 5:31:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100050DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-059 **Client Sample ID:** 20420100051WB25A
Collection Date: 5/7/2025 5:32:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100051WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-060 **Client Sample ID:** 20420100052BF25A
Collection Date: 5/7/2025 5:33:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100052BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.75		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-061 **Client Sample ID:** 20420100053BF25A
Collection Date: 5/7/2025 5:34:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100053BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.59		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-062 **Client Sample ID:** 20420100054BF25A
Collection Date: 5/7/2025 5:34:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100054BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.30		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-063 **Client Sample ID:** 20420100055BF25A
Collection Date: 5/7/2025 5:34:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100055BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.77		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-064 **Client Sample ID:** 20420100056BF25A
Collection Date: 5/7/2025 5:38:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100056BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-065 **Client Sample ID:** 20420100057BF25A
Collection Date: 5/7/2025 5:38:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100057BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.58		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-066 **Client Sample ID:** 20420100058DW25A
Collection Date: 5/7/2025 5:41:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100058DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.61		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-067 Client Sample ID: 20420100059CF25A
Collection Date: 5/7/2025 5:42:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100059CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-068 Client Sample ID: 20420100060DW25A
Collection Date: 5/7/2025 5:44:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100060DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-069 Client Sample ID: 20420100061CF25A
Collection Date: 5/7/2025 5:43:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100061CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.53		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-070 **Client Sample ID:** 20420100062DW25A
Collection Date: 5/7/2025 5:46:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100062DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.96		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-071 **Client Sample ID:** 20420100063CF25A
Collection Date: 5/7/2025 5:47:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100063CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-072 **Client Sample ID:** 20420100064DW25A
Collection Date: 5/7/2025 5:49:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100064DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.751		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-073 Client Sample ID: 20420100065CF25A
Collection Date: 5/7/2025 5:48:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100065CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.02		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-074 Client Sample ID: 20420100066CF25A
Collection Date: 5/7/2025 5:07:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100066CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.71		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-075 Client Sample ID: 20420100067CF25A
Collection Date: 5/7/2025 5:08:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100067CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.33		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-076 **Client Sample ID:** 20420100068DW25A
Collection Date: 5/7/2025 4:58:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100068DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-077 **Client Sample ID:** 20420100069BF25A
Collection Date: 5/7/2025 5:00:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100069BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.861		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-078 **Client Sample ID:** 20420100070BF25A
Collection Date: 5/7/2025 5:01:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100070BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.08		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-079 Client Sample ID: 20420100071BF25A
Collection Date: 5/7/2025 5:03:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100071BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.72		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-080 Client Sample ID: 20420100072BF25A
Collection Date: 5/7/2025 5:05:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100072BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.24		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-081 Client Sample ID: 20420100073KF25A
Collection Date: 5/7/2025 4:41:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100073KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.4	1	0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-082 Client Sample ID: 20420100074KF25A
Collection Date: 5/7/2025 4:42:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100074KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-083 Client Sample ID: 20420100075KF25A
Collection Date: 5/7/2025 4:44:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100075KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.01		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-084 Client Sample ID: 20420100076KF25A
Collection Date: 5/7/2025 4:44:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420100076KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.23		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-085 **Client Sample ID:** 20420100078KF25A
Collection Date: 5/7/2025 4:46:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100078KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	22.7	*1	0.515	ppb	1	5/15/2025	15.0	A	

Lab ID: 25050304-086 **Client Sample ID:** 20420100079BF25A
Collection Date: 5/7/2025 4:47:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100079BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.22		0.515	ppb	1	5/15/2025	15.0	A	

Lab ID: 25050304-087 **Client Sample ID:** 20420100080KF25A
Collection Date: 5/7/2025 4:48:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100080KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	23.5	*1	0.515	ppb	1	5/15/2025	15.0	A	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-088 **Client Sample ID:** 20420100081KF25A
Collection Date: 5/7/2025 4:49:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100081KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	123	*1	0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-089 **Client Sample ID:** 20420100082KF25A
Collection Date: 5/7/2025 4:52:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100082KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.578		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-090 **Client Sample ID:** 20420100083KF25A
Collection Date: 5/7/2025 4:52:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100083KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.22		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-091 **Client Sample ID:** 20420100084KF25A
Collection Date: 5/7/2025 4:53:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100084KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	100	*1	0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-092 **Client Sample ID:** 20420100085KF25A
Collection Date: 5/7/2025 4:54:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100085KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-093 **Client Sample ID:** 20420100086KF25A
Collection Date: 5/7/2025 4:55:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100086KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	12.0	1	0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-094 **Client Sample ID:** 20420100087KF25A
Collection Date: 5/7/2025 4:56:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420100087KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.70		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-095 **Client Sample ID:** 20420101001CF25A
Collection Date: 5/7/2025 5:54:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420101001CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.12		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-096 **Client Sample ID:** 20420101002CF25A
Collection Date: 5/7/2025 5:55:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420101002CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-097 **Client Sample ID:** 20420102001CF25A
Collection Date: 5/7/2025 5:58:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420102001CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.45		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-098 **Client Sample ID:** 20420102002BF25A
Collection Date: 5/7/2025 5:58:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420102002BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-099 **Client Sample ID:** 20420102003CF25A
Collection Date: 5/7/2025 6:00:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420102003CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.869		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050304
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050304
Received Date: 5/7/2025 10:24:00 AM
Reported Date: 5/19/2025 8:18:31 AM

Sample Information:

Lab ID: 25050304-100 Client Sample ID: 20420102004BF25A
Collection Date: 5/7/2025 6:01:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420102004BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.665		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050304-101 Client Sample ID: 20420100964SF25A
Collection Date: 5/7/2025 5:47:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420100964SF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.974		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050304
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: CPE Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31250	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59420						
Client ID: PBW	Batch ID: 31250	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970823						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID: LCS-31250		SampType: LCS		TestCode: LEAD_SCHO		Units: ppb		Prep Date: 5/13/2025			RunNo: 59420		
Client ID: LCSW		Batch ID: 31250		TestNo: E200.8		E200.8		Analysis Date: 5/13/2025			SeqNo: 970824		
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		104		0.500	100	0	104	85	115				

Sample ID: 25050504-01CMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59420						
Client ID: BatchQC	Batch ID: 31250	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970826						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.1	0.500	100	0.216	97.9	70	130				

Sample ID: 25050504-01CMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59420						
Client ID: BatchQC	Batch ID: 31250	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970827						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.7	0.500	100	0.216	97.5	70	130	98.1	0.390	20	

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050304
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: CPE Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31256	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424						
Client ID: PBW	Batch ID: 31256	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970967						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31256	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424						
Client ID: LCSW	Batch ID: 31256	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970968						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0	104	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050304-003AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424						
Client ID: 20420100003DW25A	Batch ID: 31256	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970970						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.500	100	0.114	100	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Sample ID: 25050304-003AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424						
Client ID: 20420100003DW25A	Batch ID: 31256	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970971						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.500	100	0.114	101	70	130	100	0.800	20	
------	-----	-------	-----	-------	-----	----	-----	-----	-------	----	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
RL	Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
MI	Recovery outside control limits due to Matrix Interference

DF	Dilution Factor
ND	Not Detected at the Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050304
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: CPE Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31275	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506						
Client ID: PBW	Batch ID: 31275	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972413						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31275	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506						
Client ID: LCSW	Batch ID: 31275	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972414						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.1	0.520	100	0	98.1	85	115				

Sample ID: 25050174-61AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506						
Client ID: BatchQC	Batch ID: 31275	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972416						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	92.7	0.520	100	0.543	92.1	70	130				

Sample ID: 25050174-61AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506						
Client ID: BatchQC	Batch ID: 31275	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972417						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.7	0.520	100	0.543	97.2	70	130	92.7	5.31	20	

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050304
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: CPE Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31294	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506
Client ID: PBW	Batch ID: 31294	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972441
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31294	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506
Client ID: LCSW	Batch ID: 31294	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972442
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 99.5 0.520 100 0 99.5 85 115

Sample ID: 25050304-029AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506
Client ID: 20420100029DW25A	Batch ID: 31294	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972444
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 99.4 0.520 100 0.253 99.2 70 130

Sample ID: 25050304-029AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506
Client ID: 20420100029DW25A	Batch ID: 31294	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972445
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 98.9 0.520 100 0.253 98.6 70 130 99.4 0.552 20

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050304
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: CPE Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31295	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506
Client ID: PBW	Batch ID: 31295	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972471
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: MB-31295	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506
Client ID: PBW	Batch ID: 31295	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972472
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31295	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506
Client ID: LCSW	Batch ID: 31295	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972473
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 99.9 0.520 100 0 99.9 85 115

Sample ID: 25050304-049AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506
Client ID: 20420100041CF25A	Batch ID: 31295	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972475
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.520 100 1.60 99.4 70 130

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050304
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: CPE Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25050304-049AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: 20420100041CF25A	Batch ID: 31295	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972476						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.520	100	1.60	99.1	70	130	101	0.259	20	

Sample ID: MB-31296	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: PBW	Batch ID: 31296	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972500						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31296	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: LCSW	Batch ID: 31296	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972501						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.9	0.520	100	0	97.9	85	115				

Sample ID: LCS-31296	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: LCSW	Batch ID: 31296	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972502						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	96.9	0.520	100	0	96.9	85	115				

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050304
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: CPE Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25050304-069AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: 20420100061CF25A	Batch ID: 31296	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972504						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.520	100	1.53	98.5	70	130				
------	-----	-------	-----	------	------	----	-----	--	--	--	--

Sample ID: 25050304-069AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: 20420100061CF25A	Batch ID: 31296	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972505						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.520	100	1.53	99.0	70	130	100	0.522	20	
------	-----	-------	-----	------	------	----	-----	-----	-------	----	--

Sample ID: MB-31297	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: PBW	Batch ID: 31297	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972529						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31297	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: LCSW	Batch ID: 31297	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972530						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.520	100	0	101	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
RL	Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
MI	Recovery outside control limits due to Matrix Interference

DF	Dilution Factor
ND	Not Detected at the Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050304
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: CPE Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25050304-089AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: 20420100082KF25A	Batch ID: 31297	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972532						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	99.1	0.520	100	0.578	98.5	70	130				

Sample ID: 25050304-089AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: 20420100082KF25A	Batch ID: 31297	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972533						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.9	0.520	100	0.578	97.3	70	130	99.1	1.22	20	

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Revision v1

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25050304

RcptNo: 1

Logged by: Dorie Evans 5/7/2025 10:24:00 AM

Completed By: Tamra Schmedemann 5/18/2025 7:28:37 AM

Reviewed By: Tamra Schmedemann 5/18/2025 7:28:41 AM

Dorie Evans
Tamra Schmedemann
Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH < 2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

Page 1 of 11

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>CPE</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: Fax:						☐ Other	
Collected By (Print): <u>MARK LILLICH</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	LEAD	Analysis Requested	NRC Workorder # (Lab Use Only) <u>25050304</u>	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100001 BF25A	112088	DW	5-7-25	4:40AM	1	X				01
20420100002 BF25A	130240	DW	5-7-25	5:52AM	1	X				02
20420100003 DW25A	112089	DW	5-7-25	5:57AM	1	X				03
20420100004 BF25A	130243	DW	5-7-25	5:58AM	1	X				04
20420100005 CF25A	112090	DW	5-7-25	5:59AM	1	X				05
20420100006 DW25A	130244	DW	5-7-25	6:00AM	1	X				06
20420100007 DW25A	130247	DW	5-7-25	4:45AM	1	X				07
20420100008 DW25A	112091	DW	5-7-25	4:46AM	1	X				08
20420100009 WB25A	130260	DW	5-7-25	4:46AM	1	X				09
20420100010 BF25A	130246	DW	5-7-25	4:51AM	1	X				10

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Seff Carr</u>	<u>5-7-25</u>	<u>10:24AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>Doriel Evans</u>	<u>5/7/25</u>	<u>10:24</u>

Section G Lab Use Only

Temp: <u>AMB</u>
4°C +/- 2°C: ☐ Yes ☒ NO
Received on Ice: ☐ Yes ☒ NO
Number of Bottles Received: <u>1</u>
pH Checked: <u>1</u>
COC Seals Intact: ☐ Yes ☒ NO <u>NA</u>
Field Blank Included: ☐ Yes ☒ NO <u>NA</u>
Received Via ☐ UPS ☐ FedEx ☒ Other <u>Hand</u>
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 2 of 11

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): MARK JULICH
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: CPE
Project Number: _____
Report To: _____
Copy To: _____
P.O. #: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. #: _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	LEAD	Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050304</u>	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100011 BF25A	130245	DW	5-7-25	4:52AM	1	X													11
20420100012 BF25A	112092	DW	5-7-25	4:53AM	1	X													12
20420100013 BF25A	112093	DW	5-7-25	4:54AM	1	X													13
20420100014 BF25A	130239	DW	5-7-25	4:55AM	1	X													14
20420100015 BF25A	130270	DW	5-7-25	4:56AM	1	X													15
20420100016 CF25A	130242	DW	5-7-25	4:59AM	1	X													16
20420100017 DW25A	130269	DW	5-7-25	5:00AM	1	X													17
20420100018 BF25A	130241	DW	5-7-25	5:01AM	1	X													18
20420100019 CF25A	130261	DW	5-7-25	5:03AM	1	X													19
20420100020 DW25A	130262	DW	5-7-25	5:04AM	1	X													20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
<u>[Signature]</u>	<u>[Signature]</u>	<u>Scff Carr</u>	<u>5-7-25</u>	<u>10:24am</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>DORIE EVANS</u>	<u>5/7/25</u>	<u>10:24</u>

Section G

Lab Use Only

Temp: AMB
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ☐ Yes ☐ No ☒ NA
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☐ Invoice ☒ Cash ☐ VISA/MC ☐ Check # _____ Amount: _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 3 of 11

Section A Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): MARK LILICH
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B Required Project Information

Project Name: CPE
Project Number: _____
Report To: _____
Copy To: _____

Section C Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	LEAD	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100021 DW25A	130268	DW	5-7-25	5:06AM	1	X		<u>25050304</u>		<u>21</u>
20420100022 CF25A	130293	DW	5-7-25	5:07AM	1	X				<u>22</u>
20420100023 DW25A	130294	DW	5-7-25	5:10AM	1	X				<u>23</u>
20420100024 CF25A	130265	DW	5-7-25	5:11AM	1	X				<u>24</u>
20420100025 CF25A	130258	DW	5-7-25	5:12AM	1	X				<u>25</u>
20420100026 BF25A	130257	DW	5-7-25	5:13AM	1	X				<u>26</u>
20420100027 DW25A	130291	DW	5-7-25	5:16AM	1	X				<u>27</u>
20420100028 CF25A	130295	DW	5-7-25	5:17AM	1	X				<u>28</u>
20420100029 DW25A	130272	DW	5-7-25	5:21AM	1	X				<u>29</u>
20420100030 CF25A	130266	DW	5-7-25	5:22AM	1	X				<u>30</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
<u>[Signature]</u>	<u>[Signature]</u>	<u>Jeff Carr</u>	<u>5-7-25</u>	<u>10:24am</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Dorie Evans</u>	<u>5/12/25</u>	<u>10:24</u>

Section G Lab Use Only

Temp: AMB
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: ☒
COC Seals Intact: ☐ Yes ☒ No NA
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☒ Other Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount: _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 4 of 11

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>CPE</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: Fax:			☐ Other
Collected By (Print): <u>MARK LILLICH</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No	Mail Report ☐ Yes ☐ No		
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	LEAD	Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050304</u>	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100031 CF25A	130267	DW	5-7-25	5:24AM	1	X													30
20420100032 CF25A	130259	DW	5-7-25	5:27AM	1	X													32
20420100038 BF25A	104631	DW	5-7-25	5:36AM	1	X													33
20420100089 BF25A	106878	DW	5-7-25	5:37AM	1	X													34
20420100090 BF25A	106893	DW	5-7-25	5:38AM	1	X													35
20420100091 BF25A	106877	DW	5-7-25	5:39AM	1	X													36
20420100092 SF25A	106865	DW	5-7-25	5:42AM	1	X													37
20420100093 SF25A	106855	DW	5-7-25	5:43AM	1	X													38
20420100094 BF25A	104628	DW	5-7-25	5:45AM	1	X													39
20420100095 NS25A	106854	DW	5-7-25	5:46AM	1	X													40

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-7-25</u>	<u>10:24am</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>DORIE EVANS</u>	<u>5/7/25</u>	<u>10:24</u>

Section G Lab Use Only

Temp: <u>AMB</u>	
4°C +/- 2°C: ☐ Yes ☒ No	
Received on Ice: ☐ Yes ☒ No	
Number of Bottles Received:	
pH Checked: ☒	
COC Seals Intact: ☐ Yes ☒ No	
Field Blank Included: ☐ Yes ☒ No	
Received Via: ☒ UPS ☐ FedEx ☐ Other	
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount	

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 5 of 11

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): Jeff Carr
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: CPE
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100033CF25A	130263	DW	5-7-25	5:12AM	1	X		25050304		41
20420100034DW25A	130289	DW	5-7-25	5:13A	1	X				42
20420100035CF25A	130271	DW	5-7-25	5:15AM	1	X				43
20420100036DW25A	130287	DW	5-7-25	5:16AM	1	X				44
20420100037CF25A	130280	DW	5-7-25	5:17AM	1	X				45
20420100038DW25A	130303	DW	5-7-25	5:17AM	1	X				46
20420100039CF25A	130311	DW	5-7-25	5:19AM	1	X				47
20420100040BF25A	130304	DW	5-7-25	5:20AM	1	X				48
20420100041CF25A	130312	DW	5-7-25	5:22AM	1	X				49
20420100042DW25A	130288	DW	5-7-25	5:23AM	1	X				50

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Received By:	<u>Jeff Carr</u>	<u>Jeff Carr</u>	<u>5-7-25</u>	<u>10:24AM</u>
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Dore Evans</u>	<u>5/7/25</u>	<u>10:24</u>

Section G

Lab Use Only

Temp: AMPB
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ☐ Yes ☒ No NA
Field Blank Included: ☐ Yes ☒ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 6 of 11

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): Jeff Carr
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: CPE
Project Number: _____
Report To: _____
Copy To: _____
P.O. #: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. #: _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100043CF25A	130285	DW	5-7-25	5:24AM	1	X												51
20420100044DW25A	130284	DW	5-7-25	5:25AM	1	X												52
20420100045CF25A	130286	DW	5-7-25	5:27AM	1	X												53
20420100046DW25A	130302	DW	5-7-25	5:27AM	1	X												54
20420100047DW25A	130310	DW	5-7-25	5:29AM	1	X												55
20420100048CF25A	130279	DW	5-7-25	5:29AM	1	X												56
20420100049DW25A	130278	DW	5-7-25	5:30AM	1	X												57
20420100050DW25A	130275	DW	5-7-25	5:31AM	1	X												58
20420100051WB25A	130276	DW	5-7-25	5:32AM	1	X												59
20420100052BF25A	130273	DW	5-7-25	5:33AM	1	X												60

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Received By:	<u>Jeff Carr</u>	<u>Jeff Carr</u>	<u>5-7-25</u>	<u>10:24am</u>
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>Dorie Evans</u>	<u>DORIE EVANS</u>	<u>5/7/25</u>	<u>10:24</u>

Section G

Lab Use Only

Temp: AMB
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: ☐ Yes ☒ No
GOC Seals Intact: ☐ Yes ☒ No
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # _____ Amount: _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 7 of 11

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: CPE
Project Number: _____
Report To: _____
Copy To: _____
P.O. # _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100053BF25A	130281	DW	5-7-25	5:34AM	1	X												61
20420100054BF25A	130274	DW	5-7-25	5:34AM	1	X												62
20420100055BF25A	130282	DW	5-7-25	5:34AM	1	X												63
20420100056BF25A	130283	DW	5-7-25	5:38AM	1	X												64
20420100057BF25A	106848	DW	5-7-25	5:38AM	1	X												65
20420100058DW25A	106895	DW	5-7-25	5:41AM	1	X												66
20420100059CF25A	106888	DW	5-7-25	5:42AM	1	X												67
20420100060OW25A	106839	DW	5-7-25	5:44AM	1	X												68
20420100061CF25A	104609	DW	5-7-25	5:43AM	1	X												69
20420100062DW25A	104616	DW	5-7-25	5:46AM	1	X												70

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-7-25</u>	<u>10:24AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>Dorie Evans</u>	<u>5/7/25</u>	<u>10:24</u>

Section G

Lab Use Only

Temp: AMB
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: —
COC Seals Intact: ☐ Yes ☒ No
Field Blank Included: ☐ Yes ☒ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Mail
Payment: ☒ Invoice ☐ Cash ☐ VISA/M/C ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 6 of 11

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): Jeff Carr
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: CPE
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100063CF25A	106887	DW	5-7-25	5:47AM	1	X		25050304		71
20420100064DW25A	104619	DW	5-7-25	5:49AM	1	X				72
20420100065CF25A	104575	DW	5-7-25	5:48AM	1	X				73
20420100066CF25A	104603	DW	5-7-25	5:07AM	1	X				74
20420100067CF25A	106835	DW	5-7-25	5:08AM	1	X				75
20420100068DW25A	106851	DW	5-7-25	5:58AM	1	X				76
20420100069BF25A	104611	DW	5-7-25	5:00AM	1	X				77
20420100070BF25A	106890	DW	5-7-25	5:01AM	1	X				78
20420100071BF25A	106844	DW	5-7-25	5:03AM	1	X				79
20420100072BF25A	106860	DW	5-7-25	5:05AM	1	X				80

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
<u>Jeff Carr</u>	<u>Jeff Carr</u>	<u>Jeff Carr</u>	<u>5-7-25</u>	<u>10:24AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Dorie Evans</u>	<u>5/7/25</u>	<u>10:24</u>

Section G

Lab Use Only

Temp: _____
4°C +/- 2°C: ☐ Yes ☐ No
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ☐ Yes ☐ No ☐ NA
Field Blank Included: ☐ Yes ☐ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☐ Hand
Payment: ☐ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 9 of 11

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: CPE
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050304</u>	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420100073KF25A	104625	DW	5-7-25	4:41AM	1	X												81
20420100074KF25A	104633	DW	5-7-25	4:42AM	1	X												82
20420100075KF25A	106857	DW	5-7-25	4:44AM	1	X												83
20420100076KF25A	104590	DW	5-7-25	4:44AM	1	X												84
20420100078KF25A	106856	DW	5-7-25	4:46AM	1	X												85
20420100079BF25A	104627	DW	5-7-25	4:47AM	1	X												86
20420100080KF25A	104629	DW	5-7-25	4:48AM	1	X												87
20420100081KF25A	104632	DW	5-7-25	4:49AM	1	X												88
20420100082KF25A	104614	DW	5-7-25	4:52AM	1	X												89
20420100083KF25A	104613	DW	5-7-25	4:52AM	1	X												90

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
<u>Jeff Carr</u>	<u>[Signature]</u>	<u>Jeff Carr</u>	<u>5-7-25</u>	<u>10:24am</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>DORIE EVANS</u>	<u>5/7/25</u>	<u>10:24</u>

Section G

Lab Use Only

Temp: AMB
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: -
COC Seals Intact: ☐ Yes ☒ No
Field Blank Included: ☐ Yes ☒ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 10 of 11

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email:
Phone: Fax:
Collected By (Print): Jeff Carr
Collected By (Sign): *Jeff Carr*
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name:	CPE
Project Number:	
Report To:	
Copy To:	

Section C
Invoice Information

Attention:
Company Name:
Address:
P.O. #

Section D
Rush Status (Subject to Scheduling)

☒	Standard 10-14 Days		
☐	5 Business Days (50% surcharge)		
☐	3 Business Days (75% surcharge)		
☐	24 - 48 hours (100% surcharge)		
☐	Other _____		
	Authorized _____	Yes _____	No _____

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of C	Level	Remarks/Field Data	NRC Sample # (Lab Use Only)
2042010084KF25A	104626	DW	5-7-25	4:53AM	1	X		91
20420100085KF25A	106872	DW	5-7-25	4:54AM	1	X		92
20420100086KF25A	106850	DW	5-7-25	4:55AM	1	X		93
20420100087KF25A	106839	DW	5-7-25	4:56AM	1	X		94
20420101001CF25A	104581	DW	5-7-25	5:54AM	1	X		95
20420101002CF25A	104598	DW	5-7-25	5:55AM	1	X		96
20420102001CF25A	106885	DW	5-7-25	5:58AM	1	X		97
20420102002BF25A	106867	DW	5-7-25	5:58AM	1	X		98
20420102003CF25A	104572	DW	5-7-25	6:00AM	1	X		99
20420102004BF25A	106886	DW	5-7-25	6:01AM	1	X		100

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wine OT - Other

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Sign

Print

Date _____

Time

Relinquished By:	Print	Date	Time
Received By:	Jeff Carr	5-7-25	10:24am
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	DORIE EVANS	5/7/25	10:24am

Section G
Lab Use Only

Temp: 14.5
4°C +/- 2°C: Yes ☐ No ☒
Received on Ice: Yes ☐ No ☒
Number of Bottles Received: 1
pH Checked: 1
COC Seals Intact: Yes ☐ No ☒ NA ☐
Field Blank Included: Yes ☐ No ☒

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash VISA, M/C Check # Amount

Chain of Custody Record

Page 11 of 11

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>CPE</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: Fax:						☐ Other _____	
Collected By (Print): <u>MARK LILLY</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
204201000965F25A	106845	DW	5-7-25	5:47AM	1	LEAD												101
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												
		DW			1	X												

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-7-25</u>	<u>10:24am</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>Dorie Evans</u>	<u>5/1/25</u>	<u>10:24</u>

Section G Lab Use Only

Temp: <u>AMB</u>
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: ☒
COC Seals Intact: ☐ Yes ☒ No <u>NA</u>
Field Blank Included: ☐ Yes ☒ No
Received Via ☐ UPS ☐ FedEx ☒ Other <u>Hand</u>
Payment: <u>Invoice</u> Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
 - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
 - B Analyte detected in the associated method blank.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
 - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
 - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
 - 1 Value exceeds one half of the Maximum Contaminant Level.