

Lead in Water Test Results Summary: Crater High School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
<u>STUDENT CENTER - 20420805</u>							
Boys Bathroom Left Sink	20420805001BF26A	2/27/2026	ND	Non-Detect			
Boys Bathroom Middle Sink	20420805002BF26A	2/27/2026	ND	Non-Detect			
Boys Bathroom Right Sink	20420805003BF26A	2/27/2026	ND	Non-Detect			
Girls Bathroom Right Sink	20420805004BF26A	2/27/2026	ND	Non-Detect			
Girls Bathroom Middle Sink	20420805005BF26A	2/27/2026	ND	Non-Detect			
Girls Bathroom Left Sink	20420805006BF26A	2/27/2026	ND	Non-Detect			
East Wall Drinking Fountain	20420805007DW26A	2/27/2026	1.27	Low			
Classroom 701 Sink	20420805008CF26A	2/27/2026	ND	Non-Detect			
Sink Outside Room 701 SE Door	20420805009CF26A	2/27/2026	0.545	Low			
Hand sink SW Corner of A la carte	20420805010KF26A	2/27/2026	ND	Non-Detect			
Hand sink NW Corner of A la carte (Out of Service)	20420805011KF						
Ice Machine A la carte	20420805012IM26A	2/27/2026	ND	Non-Detect			
Prep sink NE Corner of A la carte	20420805013KF26A	2/27/2026	ND	Non-Detect			
Bathroom Sink	20420805014BF26A	2/27/2026	ND	Non-Detect			
Prep sink East Wall	20420805015KF26A	2/27/2026	ND	Non-Detect			
Prep Sink Sprayer East Wall	20420805016KF26A	2/27/2026	ND	Non-Detect			
Kettle Fill	20420805017KF26A	2/27/2026	1.18	Low			
Prep Sink South Wall	20420805018KF26A	2/27/2026	ND	Non-Detect			
Dish Room Hand Sink	20420805019KF26A	2/27/2026	ND	Non-Detect			
Dish Room Right Pot Sink	20420805020KF26A	2/27/2026	ND	Non-Detect			
Dish Room Left Pot Sink	20420805021KF26A	2/27/2026	0.808	Low			
Dish Room Sprayer	20420805022KF26A	2/27/2026	ND	Non-Detect			
<u>PAC - 20420811</u>							
Girls Bathroom Right Sink	20420811001BF26A	2/27/2026	ND	Non-Detect			
Girls Bathroom 2nd to Right Sink	20420811002BF26A	2/27/2026	ND	Non-Detect			
Girls Bathroom 2nd to Left Sink	20420811003BF26A	2/27/2026	ND	Non-Detect			
Girls Bathroom Left Sink	20420811004BF26A	2/27/2026	ND	Non-Detect			
Boys Bathroom Left Sink	20420811005BF26A	2/27/2026	ND	Non-Detect			
Boys Bathroom 2nd to Left Sink	20420811006BF26A	2/27/2026	ND	Non-Detect			
Boys Bathroom 2nd to Right Sink	20420811007BF26A	2/27/2026	ND	Non-Detect			
Boys Bathroom Right Sink	20420811008BF26A	2/27/2026	ND	Non-Detect			
Green Room Drinking Fountain	20420811009DW26A	2/27/2026	ND	Non-Detect			
Green Room Sink	20420811010CF26A	2/27/2026	ND	Non-Detect			
Boys Dressing Room Left Sink	20420811011BF26A	2/27/2026	ND	Non-Detect			
Boys Dressing Room Right Sink	20420811012BF26A	2/27/2026	ND	Non-Detect			
Girls Dressing Room Left Sink	20420811013BF26A	2/27/2026	ND	Non-Detect			
Girls Dressing Room Right Sink	20420811014BF26A	2/27/2026	ND	Non-Detect			
<u>TECH CENTER - 20420804</u>							
Sink by Stairs	20420804001CF26A	2/27/2026	ND	Non-Detect			
Right Drinking Fountain by Stairs	20420804002DW26A	2/27/2026	ND	Non-Detect			
Bottle Fill by Stairs	20420804003WB26A	2/27/2026	ND	Non-Detect			
Classroom 603 NE Corner Room	20420804005CF26A	2/27/2026	ND	Non-Detect			
Classroom 603 Drink Fountain by South Exit	20420804006DW26A	out of order					
Rm 603 Bathroom Sink by South Exit	20420804007BF26A	2/27/2026	ND	Non-Detect			
Rm 604 Bathroom Sink by South Exit	20420804008BF26A	2/27/2026	ND	Non-Detect			

Rm 604 Right Sink	20420804009CF26A	2/27/2026	3.43	Low			
Rm 604 Middle Sink	20420804010CF26A	2/27/2026	7.51	Moderate			
Rm 604 Left Sink	20420804011CF26B	2/27/2026	25.4	Action Req.	3/31/2026	ND	Non-Detect
GYMNASIUM- 20420802							
Girls Lobby Bathroom Left Sink	20420802001BF26A	2/27/2026	ND	Non-Detect			
Girls Lobby Bathroom 2nd to Left Sink	20420802002BF26A	2/27/2026	ND	Non-Detect			
Girls Lobby Bathroom 2nd to Right Sink	20420802003BF26A	2/27/2026	ND	Non-Detect			
Girls Lobby Bathroom Right Sink	20420802004BF26A	2/27/2026	ND	Non-Detect			
Boys Lobby Bathroom Left Sink	20420802005BF26A	2/27/2026	ND	Non-Detect			
Boys Lobby Bathroom 2nd to Left Sink	20420802006BF26A	2/27/2026	ND	Non-Detect			
Boys Lobby Bathroom Middle Sink	20420802007BF26A	2/27/2026	ND	Non-Detect			
Boys Lobby Bathroom 2nd to Right Sink	20420802008BF26A	2/27/2026	ND	Non-Detect			
Boys Lobby Bathroom Right Sink	20420802009BF26A	2/27/2026	ND	Non-Detect			
Concession Stand Sink	20420802010KF26A	2/27/2026	0.965	Low			
Girls Locker Room Right Drinking Fountain	20420802011DW26A	2/27/2026	ND	Non-Detect			
Girls Locker Room Left Drinking Fountain	20420802012DW26A	2/27/2026	ND	Non-Detect			
Girls Locker Room Bottle Fill	20420802013WB26A	2/27/2026	ND	Non-Detect			
Girls Locker Room Bathroom Right Sink	20420802014BF26A	2/27/2026	ND	Non-Detect			
Girls Locker Room Bathroom Middle Sink	20420802015BF26A	2/27/2026	ND	Non-Detect			
Girls Locker Room Bathroom Left Sink	20420802016BF26A	2/27/2026	ND	Non-Detect			
Girls Locker Room Coach's bathroom Sink	20420802017BF26A	2/27/2026	ND	Non-Detect			
Boys Locker Room Left Drinking Fountain	20420802018DW26A	2/27/2026	ND	Non-Detect			
Boys Locker Room Right Drinking Fountain	20420802019DW26A	2/27/2026	ND	Non-Detect			
Boys Locker Room Bottle Fill	20420802020WB26A	2/27/2026	ND	Non-Detect			
Boys Locker Room Bathroom Right Sink	20420802021BF26A	2/27/2026	ND	Non-Detect			
Boys Locker Room Bathroom Left Sink	20420802022BF26A	2/27/2026	ND	Non-Detect			
Boys Locker Room Coach's Bathroom Sink	20420802023BF26A	2/27/2026	ND	Non-Detect			
Physical Therapy Room Sink	20420802024NS26A	2/27/2026	ND	Non-Detect			
Physical Therapy Room Bottle Fill	20420802025WB26A	2/27/2026	ND	Non-Detect			
Physical Therapy Ice Machine	20420802026IM26A	2/27/2026	0.563	Low			
Weight Room Drinking Fountain	20420802027DW26A	2/27/2026	ND	Non-Detect			
Weight Room Bottle Fill	20420802028WB26A	2/27/2026	ND	Non-Detect			
Gym South Wall Drinking Fountain (Out of Service)	20420802029DW						
North Staircase Landing Right Drinking Fountain	20420802030DW26A	2/27/2026	ND	Non-Detect			
North Staircase Landing Left Drinking Fountain	20420802031DW26A	2/27/2026	ND	Non-Detect			
North Staircase Landing Bottle Fill	20420802032WB26A	2/27/2026	ND	Non-Detect			
AG SHOP/HEADWATERS - 20420809							
Classroom 302 Left Sink	20420809001CF26A	3/4/2026	ND	Non-Detect			
Classroom 302 Right Sink	20420809002CF26A	3/4/2026	ND	Non-Detect			
Right Bathroom Sink	20420809003BF26A	3/4/2026	ND	Non-Detect			
Left Bathroom Sink	20420809004BF26A	3/4/2026	ND	Non-Detect			
Room 301 Right Sink	20420809005CF26A	3/4/2026	0.527	Low			
Room 301 2nd to Right Sink	20420809006CF26A	3/4/2026	ND	Non-Detect			
Room 301 Middle Sink	20420809007CF26A	3/4/2026	0.56	Low			
Room 301 2nd to Left Sink	20420809008CF26A	3/4/2026	ND	Non-Detect			
Room 301 Left Sink	20420809009CF26A	3/4/2026	ND	Non-Detect			
West Bathroom Sink	20420809010BF26A	3/4/2026	2.99	Low			
East Bathroom Sink	20420809011BF26A	3/4/2026	1.14	Low			
Staffroom Sink	20420809012SF26A	3/4/2026	ND	Non-Detect			
800 BUILDING - 20420816							
Room 801 Classroom Sink	20420816001CF26A	3/3/2026	0.557	Low			
Room 801 Bathroom Sink	20420816002BF26A	3/3/2026	ND	Non-Detect			
Room 802 Bathroom Sink	20420816003BF26A	3/3/2026	ND	Non-Detect			
Room 802 Classroom Sink	20420816004CF26A	3/3/2026	8.68	Moderate			
Room 802 Drinking Fountain	20420816005DW26A	3/3/2026	ND	Non-Detect			
Room 802 Kitchen Sink	20420816006KF26A	3/3/2026	ND	Non-Detect			
MUSIC ROOM - 20420803							
Main Floor Sink	20420803001CF26A	2/27/2026	0.895	Low			
Main Floor Drinking Fountain	20420803002DW26A	2/27/2026	ND	Non-Detect			
Bathroom Sink	20420803003BF26A	2/27/2026	ND	Non-Detect			
CRATER - SOFTBALL RESTROOMS - 20420812							
South Restroom	20420812001BF26A	3/31/2026	0.186	Low			

Drinking Fountain	20420812002DW26A	3/31/2026	0.188	Low			
North Restroom	20420812003BF26A	3/31/2026	0.157	Low			
<u>ANHORN CONCESSION/RESTROOMS - 20420823</u>							
Mens Restroom Left Sink	20420823001BF26A	3/31/2026	0.224	Low			
Mens Restroom Right Sink	20420823002BF26A	3/31/2026	0.165	Low			
Drinking Fountain Outside East Wall	20420823003DW26A	3/31/2026	0.942	Low			
Womens Restroom Left Sink	20420823004BF26A	3/31/2026	0.117	Low			
Womens Restroom Right Sink	20420823005BF26A	3/31/2026	0.125	Low			
<u>LAND LAB CLASSROOMS - 20420820</u>							
Classroom Sink North Wall	20420820001CF26A	3/3/2026	ND	Non-Detect			
<u>LAND LAB RESTROOMS</u>							
Left Drinking Fountain	20420831001DW26A	3/3/2026	0.639	Low			
Right Drinking Fountain	20420831002DW26A	3/3/2026	ND	Non-Detect			
Southwest Bathroom Sink	20420831003BF26A	3/3/2026	ND	Non-Detect			
Southeast Bathroom Sink	20420831004BF26A	3/3/2026	ND	Non-Detect			
East Bathroom Sink	20420831005BF26A	3/3/2026	2.15	Low			
Northeast Bathroom Sink	20420831006BF26A	3/3/2026	1.45	Low			
Northwest Bathroom Sink	20420831007BF26A	3/3/2026	2.23	Low			
West Bathroom Sink	20420831008BF26A	3/3/2026	ND	Non-Detect			
RV Water	20420831009OS26A	3/3/2026	1.19	Low			
<u>CRATER STADIUM - 20420801</u>							
Stadium Concession Left Sink	20420801001KF26A	3/31/2026	ND	Non-Detect			
Stadium Concession Right Sink	20420801002KF26A	3/31/2026	ND	Non-Detect			
Stadium Mens Bathroom Right Sink	20420801003BF26A	3/31/2026	ND	Non-Detect			
Stadium Mens Bathroom Left Sink	20420801004BF26A	3/31/2026	ND	Non-Detect			
Stadium Drinking Fountain by Bathroom	20420801005DW26A	3/31/2026	ND	Non-Detect			
Stadium Womens Bathroom Right Sink	20420801006BF26A	3/31/2026	ND	Non-Detect			
Stadium Womens Bathroom Left Sink	20420801007BF26A	3/31/2026	1.59	Low			
<u>CRATER SCIENCE BUILDING - 20420810</u>							
Boys Bathroom Left Sink	20420810001BF26A	3/4/2026	ND	Non-Detect			
Boys Bathroom Middle Sink	20420810002BF26A	3/4/2026	ND	Non-Detect			
Boys Bathroom Right Sink	20420810003BF26A	3/4/2026	0.524	Low			
Girls Bathroom Left Sink	20420810004BF26A	3/4/2026	ND	Non-Detect			
Girls Bathroom 2nd to Left Sink	20420810005BF26A	3/4/2026	ND	Non-Detect			
Girls Bathroom 2nd to Right Sink	20420810006BF26A	3/4/2026	ND	Non-Detect			
Girls Bathroom Right Sink	20420810007BF26A	3/4/2026	ND	Non-Detect			
Room 408 Sink	20420810008CF26A	3/4/2026	2.37	Low			
Room 407 Sink	20420810009CF26A	3/4/2026	4.65	Low			
Room Between 407 and 406 Sink	20420810010CF26A	3/4/2026	7.34	Moderate			
Room 406 Teacher Sink	20420810011CF26A	3/4/2026	12.2	High			
Room 406 NW Corner Sink	20420810012CF26A	3/4/2026	0.612	Low			
Room 406 SW Corner Sink	20420810013CF26A	3/4/2026	0.516	Low			
Room 406 Drinking Fountain	20420810014DW26A	3/4/2026	ND	Non-Detect			
Room 405 Teacher Sink	20420810015CF26A	3/4/2026	1.92	Low			
Room 405 NE Corner Sink	20420810016CF26A	3/4/2026	1.02	Low			
Room 405 SE Corner Sink	20420810017CF26A	3/4/2026	13.7	High			
Room 405 Drinking Fountain	20420810018DW26A	3/4/2026	ND	Non-Detect			
Room Between 405 and 404 Sink	20420810019CF26A	3/4/2026	3.63	Low			
Room 404 NW Corner Sink	20420810020CF26A	3/4/2026	0.868	Low			
Room 404 SW Corner Sink	20420810021CF26A	3/4/2026	ND	Non-Detect			
Room 404 Drinking Fountain	20420810022DW26A	3/4/2026	ND	Non-Detect			
Room 403 SW Sink	20420810023CF26A	3/4/2026	0.529	Low			
Room 403 NW Sink	20420810024CF26A	3/4/2026	1.27	Low			
Room 403 Drinking Fountain	20420810025DW26A	3/4/2026	1.93	Low			
Room Between 403 and 402 Sink	20420810026CF26B	3/4/2026	29.1	Action Req.	3/31/2026	3.2	Low
Room 402 Teacher Sink	20420810027CF26A	3/4/2026	10.3	High			
Room 402 SE Sink	20420810028CF26A	3/4/2026	6.05	Moderate			
Room 402 NE Sink	20420810029CF26A	3/4/2026	0.717	Low			
Room 402 Drinking Fountain	20420810030DW26A	3/4/2026	ND	Non-Detect			
Room 401 Teacher Sink	20420810031CF26A	3/4/2026	0.874	Low			
Room 401 Sink	20420810032CF26A	3/4/2026	0.628	Low			
Room 401 Drinking Fountain	20420810033DW26A	3/4/2026	ND	Non-Detect			

MAIN BUILDING - 20420800							
Hall A Drinking Fountain	20420800001DW26A	2/27/2026	ND	Non-Detect			
Hall A Bottle Fill	20420800002WB26A	2/27/2026	ND	Non-Detect			
Hall A Girls Bathroom Left Sink	20420800003BF26A	2/27/2026	ND	Non-Detect			
Hall A Girls Bathroom Right Sink	20420800004BF26A	2/27/2026	ND	Non-Detect			
Hall A Boys Bathroom Left Sink	20420800005BF26A	2/27/2026	ND	Non-Detect			
Hall A Boys Bathroom Right Sink	20420800006BF26A	2/27/2026	ND	Non-Detect			
Room 105 Sink	20420800007CF26A	2/27/2026	ND	Non-Detect			
Staff Room Mens Bathroom Sink	20420800008BF26A	2/27/2026	ND	Non-Detect			
Staffroom Sink	20420800009SF26A	2/27/2026	ND	Non-Detect			
Staffroom Womens Bathroom	20420800010BF26A	2/27/2026	ND	Non-Detect			
Room 004 Sink	20420800011SF26A	2/27/2026	4.38	Low			
Room 107 Sink	20420800012CF26A	2/27/2026	ND	Non-Detect			
Room 114 Sink	20420800013CF26A	2/27/2026	ND	Non-Detect			
Hall B Drinking Fountain	20420800014DW26A	2/27/2026	ND	Non-Detect			
Hall B Bottle Fill	20420800015WB26A	2/27/2026	ND	Non-Detect			
Room 116 Sink	20420800016CF26A	2/27/2026	1.72	Low			
Hall C Left Drinking Fountain	20420800017DW26A	2/27/2026	ND	Non-Detect			
Hall C Right Drinking Fountain	20420800018DW26A	2/27/2026	ND	Non-Detect			
Hall C Bottle Fill	20420800019WB26A	2/27/2026	ND	Non-Detect			
Hall C Girls Bathroom Left Sink	20420800020BF26A	2/27/2026	ND	Non-Detect			
Hall C Girls Bathroom Middle Sink	20420800021BF26A	2/27/2026	ND	Non-Detect			
Hall C Girls Bathroom Right Sink	20420800022BF26A	2/27/2026	ND	Non-Detect			
Hall C Boys Bathroom Right Sink	20420800023BF26A	2/27/2026	ND	Non-Detect			
Hall C Boys Bathroom Left Sink	20420800024BF26A	2/27/2026	ND	Non-Detect			
Hall D Drinking Fountain	20420800025DW26A	2/27/2026	ND	Non-Detect			
Hall D Bottle Fill	20420800026WB26A	2/27/2026	ND	Non-Detect			
Room 123 Sink	20420800027CF26A	2/27/2026	0.564	Low			
Library Back Office Sink	20420800028SF26A	2/27/2026	ND	Non-Detect			
South End Broadway Hall Bottle Fill	20420800029WB26A	2/27/2026	ND	Non-Detect			
South End Broadway Hall Right Drinking Fountain	20420800030DW26A	2/27/2026	ND	Non-Detect			
South End Broadway Hall Left Drinking Fountain	20420800031DW26A	2/27/2026	ND	Non-Detect			
Women Staff Bathroom Faucet by Room 026	20420800032BF26A	2/27/2026	ND	Non-Detect			
Mens Staff Bathroom Faucet by Room 026	20420800033BF26A	2/27/2026	0.605	Low			
Room 015 Sink	20420800034SF26A	2/27/2026	0.534	Low			
Room 029 Sink	20420800035SF26A	2/27/2026	ND	Non-Detect			
Broadway Hall Boys Bathroom Right Sink	20420800036BF26A	2/27/2026	ND	Non-Detect			
Broadway Hall Boys Bathroom Left Sink	20420800037BF26A	2/27/2026	ND	Non-Detect			
Broadway Hall Girls Bathroom Left Sink	20420800038BF26A	2/27/2026	ND	Non-Detect			
Broadway Hall Girls Bathroom Middle Sink	20420800039BF26A	2/27/2026	ND	Non-Detect			
Broadway Hall Girls Bathroom Right Sink	20420800040BF26A	2/27/2026	ND	Non-Detect			
Left Drinking Fountain by Room 126	20420800041DW26A	2/27/2026	ND	Non-Detect			
Right Drinking Fountain by Room 126	20420800042DW26A	2/27/2026	ND	Non-Detect			
Bottle Fill by Room 126	20420800043WB26A	2/27/2026	ND	Non-Detect			
Room 126 SW Corner Left Sink	20420800044CF26A	2/27/2026	ND	Non-Detect			
Room 126 SW Corner Right Sink	20420800045CF26A	2/27/2026	ND	Non-Detect			
Room 126 NW Corner Left Sink	20420800046CF26A	2/27/2026	0.774	Low			
Room 126 NW Corner Right Sink	20420800047CF26A	2/27/2026	3.03	Low			
Room 127 SW Corner Left Sink	20420800048CF26A	2/27/2026	6.52	Moderate			
Room 127 SW Corner Right Sink	20420800049CF26A	2/27/2026	ND	Non-Detect			
Room 127 NW Corner Sink	20420800050CF26A	2/27/2026	12.8	High			
Broadway Hall North End Left Drinking Fountain	20420800051DW26A	2/27/2026	ND	Non-Detect			
Broadway Hall North End Right Drinking Fountain	20420800052DW26A	2/27/2026	ND	Non-Detect			
Broadway Hall North End Bottle Fill	20420800053WB26A	2/27/2026	ND	Non-Detect			
Room 136 Sink	20420800054CF26A	2/27/2026	ND	Non-Detect			
Room 135 Sink	20420800055CF26A	2/27/2026	4.23	Low			
Room 133 East Wall Left Sink	20420800056CF26A	2/27/2026	ND	Non-Detect			
Room 133 East Wall Middle Sink	20420800057CF26A	4/1/2026	1.74	Low			
Room 133 East Wall Right Sink	20420800058CF26A	4/1/2026	2.05	Low			
Room 133 South Wall Left Sink	20420800059CF26A	4/1/2026	1.63	Low			
Room 133 South Wall Middle Sink	20420800060CF26A	4/1/2026	1.72	Low			
Room 133 South Wall Right Sink	20420800061CF26A	4/1/2026	1.59	Low			
Room 133 West Wall Left Sink	20420800062CF26A	4/1/2026	1.18	Low			
Room 133 West Wall Right Sink	20420800063CF26A	4/1/2026	22.4	Action Req.	3/31/2026	0.565	Low
La Clinica Bathroom Sink	20420800064BF26A	4/1/2026	9.29	Moderate			

La Clinica Room Next to Bathroom	20420800065SF26A	4/1/2026	6.28	Moderate			
South Exam Room Sink	20420800066NS26A	4/1/2026	ND	Non-Detect			
North Exam Room Sink	20420800067NS26A	4/1/2026	1.4	Low			
Room 131 Sink	20420800068CF26B	2/27/2026	26.3	Action Req.	3/31/2026	0.51	Low
Room 130 Sink	20420800069CF26A	2/27/2026	9.81	Moderate			
Room 129 Sink	20420800070CF26A	2/27/2026	2.15	Low			
2nd Floor Left Drinking Fountian	20420800071DW26A	2/27/2026	ND	Non-Detect			
2nd Floor Right Drinking Fountain	20420800072DW26A	2/27/2026	ND	Non-Detect			
2nd Floor Bottle Fill	20420800073WB26A	2/27/2026	ND	Non-Detect			
Girls Bathroom Left Sink	20420800074BF26A	4/1/2026	ND	Non-Detect			
Girls Bathroom Middle Sink	20420800075BF26A	4/1/2026	ND	Non-Detect			
Girls Bathroom Right Sink	20420800076BF26A	4/1/2026	ND	Non-Detect			
Boys Bathroom Left Sink	20420800077BF26A	4/1/2026	ND	Non-Detect			
Boys Bathroom Middle Sink	20420800078BF26A	4/1/2026	ND	Non-Detect			
Boys Bathroom Right Sink	20420800079BF26A	4/1/2026	ND	Non-Detect			
Fish Bowl Right Office	20420800080SF26A	4/1/2026	ND	Non-Detect			
Boys Bathroom South Wall Left Sink	20420800081BF26A	4/1/2026	8.36	Moderate			
Boys Bathroom South Wall Right Sink	20420800082BF26B	4/1/2026	19.4	Action Req.	4/14/2026	ND	Non-Detect
Girls Bathroom North Wall Left Sink	20420800083BF26A	4/1/2026	ND	Non-Detect			
Girls Bathroom North Wall Right Sink	20420800084BF26A	4/1/2026	7.15	Moderate			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 17, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater/Ag/Metal Shop Lead Testing

Order No.: 26030118

Dear Dale Giovannetti:

Neilson Research Corporation received 12 sample(s) on 3/4/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26030118
Date: 3/17/2026

CLIENT: Central Point School Dist #6

Project: Crater/Ag/Metal Shop Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26030118
Date Reported: 3/17/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26030118
Received Date: 3/4/2026 10:14:00 AM
Reported Date: 3/17/2026 1:19:22 PM

Sample Information:

Lab ID: 26030118-01 Client Sample ID: 20420809001CF26A
Collection Date: 3/4/2026 6:44:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809001CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/16/2026	15.0	A

Lab ID: 26030118-02 Client Sample ID: 20420809002CF26A
Collection Date: 3/4/2026 6:45:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809002CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/16/2026	15.0	A

Lab ID: 26030118-03 Client Sample ID: 20420809003BF26A
Collection Date: 3/4/2026 6:48:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809003BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/16/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26030118
Date Reported: 3/17/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26030118
Received Date: 3/4/2026 10:14:00 AM
Reported Date: 3/17/2026 1:19:22 PM

Sample Information:

Lab ID: 26030118-04 Client Sample ID: 20420809004BF26A
Collection Date: 3/4/2026 6:49:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809004BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/16/2026	15.0	A

Lab ID: 26030118-05 Client Sample ID: 20420809005CF26A
Collection Date: 3/4/2026 6:55:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809005CF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.527		0.515	ppb	1	3/16/2026	15.0	A

Lab ID: 26030118-06 Client Sample ID: 20420809006CF26A
Collection Date: 3/4/2026 6:56:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809006CF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/16/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26030118
Date Reported: 3/17/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26030118
Received Date: 3/4/2026 10:14:00 AM
Reported Date: 3/17/2026 1:19:22 PM

Sample Information:

Lab ID: 26030118-07 Client Sample ID: 20420809007CF26A
Collection Date: 3/4/2026 6:57:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809007CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.560		0.515	ppb	1	3/16/2026	15.0	A

Lab ID: 26030118-08 Client Sample ID: 20420809008CF26A
Collection Date: 3/4/2026 6:58:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809008CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/16/2026	15.0	A

Lab ID: 26030118-09 Client Sample ID: 20420809009CF26A
Collection Date: 3/4/2026 6:58:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809009CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/16/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26030118
Date Reported: 3/17/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26030118
Received Date: 3/4/2026 10:14:00 AM
Reported Date: 3/17/2026 1:19:22 PM

Sample Information:

Lab ID: 26030118-10 Client Sample ID: 20420809010BF26A
Collection Date: 3/4/2026 7:05:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809010BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.99		0.515	ppb	1	3/16/2026	15.0	A

Lab ID: 26030118-11 Client Sample ID: 20420809011BF26A
Collection Date: 3/4/2026 7:08:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809011BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.14		0.515	ppb	1	3/16/2026	15.0	A

Lab ID: 26030118-12 Client Sample ID: 20420809012SF26A
Collection Date: 3/4/2026 7:10:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420809012SF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/16/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26030118

17-Mar-26

Client: Central Point School Dist #6

Project: Crater/Ag/Metal Shop Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36060	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/13/2026	RunNo: 68212						
Client ID: PBW	Batch ID: 36060	TestNo: E200.8	E200.8	Analysis Date: 3/16/2026	SeqNo: 1118972						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-36060	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/13/2026	RunNo: 68212						
Client ID: LCSW	Batch ID: 36060	TestNo: E200.8	E200.8	Analysis Date: 3/16/2026	SeqNo: 1118973						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0	102	85	115				

Sample ID: 26030118-06AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/13/2026	RunNo: 68212						
Client ID: 20420809006CF26A	Batch ID: 36060	TestNo: E200.8	E200.8	Analysis Date: 3/16/2026	SeqNo: 1118975						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.520	100	0.282	100	70	130				

Sample ID: 26030118-06AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/13/2026	RunNo: 68212						
Client ID: 20420809006CF26A	Batch ID: 36060	TestNo: E200.8	E200.8	Analysis Date: 3/16/2026	SeqNo: 1118976						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	0.282	103	70	130	101	2.19	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded
RL Reporting Limit

Original

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26030118

RcptNo: 1

Logged by: Rachel Ueki 3/4/2026 10:14:00 AM

Completed By: Dorie Evans 3/6/2026 10:51:00 AM

Reviewed By: Dorie Evans 3/17/2026 1:14:35 PM

Rachel Ueki
Dorie Evans
Dorie Evans

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☒ NA ☐
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☒ NA ☐
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☒ NA ☐
Not required
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>CRATER/AG/METAL SHOP</u>	Attention:	☒ Standard: 10 Business Days _____ Priority: 5 Business Days (List x 1.50) _____ Express: 3 Business Days (List x 1.75) _____ Rush: 2 Business Days (List x 2.00) _____ Rush: 1 Business Day (List x 2.50) _____ Rush: Same Day (List x 3.00)
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	
<u>Central Point, OR 97502</u>	Report To:	Address:	
Email:	Copy To:	P.O. #	
Phone:			
Collected By (Print): <u>MARK LILLIE</u>	Analysis Requested		Authorized _____ Yes _____ No
Collected By (Sign): <u>Mark Lillie</u>			
Email Report ☒ Mail Report _____ Fax Report _____			

Section E Sample Information					No. of Containers	LEAD										NRC Workorder # (Lab Use Only) 26030118	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected												Remarks / Field Data	NRC Sample # Use Only)
20420809001CF26A	7814	DW	3-4-26	6:44A	1	X											01
20420809002CF26A	7795	DW	3-4-26	6:45A	1	X											02
20420809003BF26A	7821	DW	3-4-26	6:48A	1	X											03
20420809004BF26A	7817	DW	3-4-26	6:49A	1	X											04
20420809005CF26A	7951	DW	3-4-26	6:55A	1	X											05
20420809006CF26A	7791	DW	3-4-26	6:56A	1	X											06
20420809007CF26A	7978	DW	3-4-26	6:57A	1	X											07
20420809008CF26A	7799	DW	3-4-26	6:58A	1	X											08
20420809009CF26A	7797	DW	3-4-26	6:58A	1	X											09
20420809010BF26A	7798	DW	3-4-26	7:05A	1	X											10

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F	
Relinquish/Receive	Sign
Relinquished By: <u>Jeff Carr</u>	Print: <u>Jeff Carr</u>
Received By:	Date: <u>3-4-26</u> Time: <u>10:14AM</u>
Relinquished By:	
Received By:	
Relinquished By:	
Received By Laboratory: <u>Rachel Ueki</u>	Print: <u>Rachel Ueki</u> Date: <u>3/4/26</u> Time: <u>10:14</u>

Section G Lab Use Only	
Temp: <u>17.5</u>	IR Therm ID: <u>Q</u>
≤6°C: _____ Yes _____ <u>NO</u>	
Received on Ice: _____ Yes _____ <u>NO</u>	
Number of Bottles Received: <u>12</u>	
pH Checked: _____	
COC Seals Intact: _____ Yes _____ No _____ <u>NA</u>	
Field Blank Included: _____ Yes _____ No	
Received Via _____ UPS _____ FedEx _____ Other _____ <u>Hand</u>	

Payment: _____ <u>Invoice</u> _____ Cash _____ VISA, M/C _____ Check # _____ Amount _____

ARV



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email:
Phone:
Collected By (Print): MARX LILLY
Collected By (Sign): *Marx Lilly*
Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	CRATER/AG/METAL SHOP
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)

Authorized _____ Yes _____ No _____

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquished By:	<i>[Signature]</i>	<i>Self Carv</i>	<i>3-4-26</i>	<i>10:15AM</i>
Received By:				
Relinquished By:				
Received By:				<i>2:00</i>
Relinquished By:				<i>10:14</i>
Received By Laboratory:	<i>Rachel Ueki</i>	<i>Rachel Ueki</i>	<i>3/4/26</i>	<i>10:15</i>

Lab Use Only

Temp: 17.5 IR Therm ID: Q

≤6°C: ___ Yes ___ No

Received on Ice: ___ Yes ___ No

Number of Bottles Received: 12

pH Checked: —

COC Seals Intact: ___ Yes ___ No ___ NA

Field Blank Included: ___ Yes ___ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash VISA, M/C Check # Amount

Effective 10/5/2020



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 12, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater-800 Bldg Lead Testing

Order No.: 26021091

Dear Dale Giovannetti:

Neilson Research Corporation received 6 sample(s) on 2/27/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26021091
Date: 3/12/2026

CLIENT: Central Point School Dist #6
Project: Crater-800 Bldg Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021091
Date Reported: 3/12/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021091
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/12/2026 10:33:19 AM

Sample Information:

Lab ID: 26021091-01 **Client Sample ID:** 20420816001CF26A
Collection Date: 2/27/2026 8:29:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420816001CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.557		0.500	ppb	1	3/9/2026	15.0	A

Lab ID: 26021091-02 **Client Sample ID:** 20420816002BF26A
Collection Date: 2/27/2026 8:30:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420816002BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/9/2026	15.0	A

Lab ID: 26021091-03 **Client Sample ID:** 20420816003BF26A
Collection Date: 2/27/2026 8:31:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420816003BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/9/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021091
Date Reported: 3/12/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26021091
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/12/2026 10:33:19 AM

Sample Information:

Lab ID: 26021091-04 Client Sample ID: 20420816004CF26A
Collection Date: 2/27/2026 8:32:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420816004CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.68	1	0.500	ppb	1	3/9/2026	15.0	A

Lab ID: 26021091-05 Client Sample ID: 20420816005DW26A
Collection Date: 2/27/2026 8:33:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420816005DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/9/2026	15.0	A

Lab ID: 26021091-06 Client Sample ID: 20420816006KF26A
Collection Date: 2/27/2026 8:34:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420816006KF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/9/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021091

12-Mar-26

Client: Central Point School Dist #6

Project: Crater-800 Bldg Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35976	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/9/2026	RunNo: 68045						
Client ID: PBW	Batch ID: 35976	TestNo: E200.8	E200.8	Analysis Date: 3/9/2026	SeqNo: 1115727						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35976	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/9/2026	RunNo: 68045						
Client ID: LCSW	Batch ID: 35976	TestNo: E200.8	E200.8	Analysis Date: 3/9/2026	SeqNo: 1115728						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	105	0.500	100	0	105	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021075-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/9/2026	RunNo: 68045						
Client ID: BatchQC	Batch ID: 35976	TestNo: E200.8	E200.8	Analysis Date: 3/9/2026	SeqNo: 1115730						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	107	0.500	100	1.64	105	70	130				
------	-----	-------	-----	------	-----	----	-----	--	--	--	--

Sample ID: 26021075-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/9/2026	RunNo: 68045						
Client ID: BatchQC	Batch ID: 35976	TestNo: E200.8	E200.8	Analysis Date: 3/9/2026	SeqNo: 1115731						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	1.64	102	70	130	107	2.96	20	
------	-----	-------	-----	------	-----	----	-----	-----	------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26021091

RcptNo: 1

Logged by: Rachel Ueki 2/27/2026 10:56:00 AM

Completed By: Dorie Evans 3/2/2026 10:59:08 AM

Reviewed By: Tamra Schmedemann 3/11/2026 3:01:43 PM

Rachel Ueki

Dorie Evans

Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified:

Date:

By Whom:

Via:

☐ eMail

☐ Phone

☐ Fax

☐ In Person

Regarding:

Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Required Client Information

Company: Central Point School District #6

Address: 300 Ash Street

Central Point, OR 97502

Email:

Phone:

Collected By (Print): Jeff Carr

Collected By (Sign): 

Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	Crater- 900 bldg.
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)

Authorized	Yes	No
------------	-----	----

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:		Jeff Carr	2-27-26	10:56 AM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	Rachel Ueki	Rachel Ueki	2/27/26	10:56 AM

Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: ☐ Yes ☒ No

Received on Ice: ☐ Yes ☒ No

Number of Bottles Received: 6

pH Checked: _____

COC Seals Intact: ☐ Yes ☐ No ☒ NA

Field Blank Included: ☐ Yes ☐ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash VISA, M/C Check # Amount

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
 - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
 - B Analyte detected in the associated method blank.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
 - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
 - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
 - 1 Value exceeds one half of the Maximum Contaminant Level.



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

April 07, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater-Anhorn Field Lead Testing

Order No.: 26031263

Dear Dale Giovannetti:

Neilson Research Corporation received 6 sample(s) on 3/31/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26031263
Date: 4/7/2026

CLIENT: Central Point School Dist #6

Project: Crater-Anhorn Field Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26031263
Date Reported: 4/7/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26031263
Received Date: 3/31/2026 10:23:00 AM
Reported Date: 4/7/2026 9:25:07 AM

Sample Information:

Lab ID: 26031263-01 Client Sample ID: 20420823001BF26A
Collection Date: 3/31/2026 7:58:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420823001BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.224	J	0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031263-02 Client Sample ID: 20420823002BF26A
Collection Date: 3/31/2026 7:58:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420823002BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.165	J	0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031263-03 Client Sample ID: 20420823003DW26A
Collection Date: 3/31/2026 7:59:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420823003DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.942		0.500	ppb	1	4/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26031263
Date Reported: 4/7/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26031263
Received Date: 3/31/2026 10:23:00 AM
Reported Date: 4/7/2026 9:25:07 AM

Sample Information:

Lab ID: 26031263-04 Client Sample ID: 20420823004BF26A
Collection Date: 3/31/2026 8:00:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420823004BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.117	J	0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031263-05 Client Sample ID: 20420823005BF26A
Collection Date: 3/31/2026 8:01:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420823005BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.125	J	0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031263-06 Client Sample ID: 20420823006KF26A
Collection Date: 3/31/2026 7:56:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420823006KF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.58		0.500	ppb	1	4/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26031263
07-Apr-26

Client: Central Point School Dist #6
Project: Crater-Anhorn Field Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36252	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634						
Client ID: PBW	Batch ID: 36252	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127441						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-36252	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634						
Client ID: LCSW	Batch ID: 36252	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127443						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.500	100	0	103	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26031201-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634						
Client ID: BatchQC	Batch ID: 36252	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127445						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	98.2	0.500	100	0.603	97.6	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 26031201-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634						
Client ID: BatchQC	Batch ID: 36252	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127446						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	96.9	0.500	100	0.603	96.3	70	130	98.2	1.29	20	
------	------	-------	-----	-------	------	----	-----	------	------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	RL	Reporting Limit				

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26031263

RcptNo: 1

Logged by: Dorie Evans 3/31/2026 10:23:00 AM

Completed By: Danielle Garten 4/1/2026 11:07:48 AM

Reviewed By: Tamra Schmedemann 4/7/2026 9:13:40 AM

Dorie Evans
Danielle Garten
Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page of

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email: _____
Phone: _____
Collected By (Print): Jeff Carr
Collected By (Sign): Jeff Carr
Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	Crater - An Horn Field
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)
Authorized ☐ Yes ☐ No	

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:	<i>[Signature]</i>	<i>seff carr</i>	3-31-26	10:23AM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<i>[Signature]</i>	<i>Dorlie Evans</i>	3/31/26	10:23

Lab Use Only

Temp: AMB IR Therm ID: _____

≤6°C: ____ Yes ____ No

Received on Ice: ____ Yes ____ No

Number of Bottles Received: 6

pH Checked: -

COC Seals Intact: ____ Yes ____ No ____ NA

Field Blank Included: ____ Yes ____ No

UPS ____ FedEX ____ Other ____ Hand

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

Effective 10/5/2020



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 05, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater/Gym Lead Testing

Order No.: 26021108

Dear Dale Giovannetti:

Neilson Research Corporation received 31 sample(s) on 2/27/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26021108
Date: 3/5/2026

CLIENT: Central Point School Dist #6

Project: Crater/Gym Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-01 Client Sample ID: 20420802001BF26A
Collection Date: 2/27/2026 6:02:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802001BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-02 Client Sample ID: 20420802002BF26A
Collection Date: 2/27/2026 6:03:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802002BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-03 Client Sample ID: 20420802003BF26A
Collection Date: 2/27/2026 6:04:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802003BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-04 Client Sample ID: 20420802004BF26A
Collection Date: 2/27/2026 6:05:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802004BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-05 Client Sample ID: 20420802005BF26A
Collection Date: 2/27/2026 6:07:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802005BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-06 Client Sample ID: 20420802006BF26A
Collection Date: 2/27/2026 6:08:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802006BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-07 Client Sample ID: 20420802007BF26A
Collection Date: 2/27/2026 6:10:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802007BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-08 Client Sample ID: 20420802008BF26A
Collection Date: 2/27/2026 6:12:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802008BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-09 Client Sample ID: 20420802009BF26A
Collection Date: 2/27/2026 6:11:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802009BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-10 Client Sample ID: 20420802010KF26A
Collection Date: 2/27/2026 6:14:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802010KF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.965		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-11 Client Sample ID: 20420802011DW26A
Collection Date: 2/27/2026 6:19:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802011DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-12 Client Sample ID: 20420802012DW26A
Collection Date: 2/27/2026 6:20:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802012DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-13 **Client Sample ID:** 20420802013WB26A
Collection Date: 2/27/2026 6:21:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420802013WB26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-14 **Client Sample ID:** 20420802014BF26A
Collection Date: 2/27/2026 6:22:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420802014BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-15 **Client Sample ID:** 20420802015BF26A
Collection Date: 2/27/2026 6:23:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420802015BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-16 Client Sample ID: 20420802016BF26A
Collection Date: 2/27/2026 6:24:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802016BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-17 Client Sample ID: 20420802017BF26A
Collection Date: 2/27/2026 6:25:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802017BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-18 Client Sample ID: 20420802018DW26A
Collection Date: 2/27/2026 6:29:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802018DW26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-19 Client Sample ID: 20420802019DW26A
Collection Date: 2/27/2026 6:30:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802019DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-20 Client Sample ID: 20420802020WB26A
Collection Date: 2/27/2026 6:31:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802020WB26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-21 Client Sample ID: 20420802021BF26A
Collection Date: 2/27/2026 6:33:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802021BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-22 Client Sample ID: 20420802022BF26A
Collection Date: 2/27/2026 6:34:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802022BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-23 Client Sample ID: 20420802023BF26A
Collection Date: 2/27/2026 6:38:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802023BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-24 Client Sample ID: 20420802024NS26A
Collection Date: 2/27/2026 6:39:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802024NS26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-25 Client Sample ID: 20420802025WB26A
Collection Date: 2/27/2026 6:40:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802025WB26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-26 Client Sample ID: 20420802026IM26A
Collection Date: 2/27/2026 6:42:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802026IM26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.563		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-27 Client Sample ID: 20420802027DW26A
Collection Date: 2/27/2026 6:48:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802027DW26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-28 Client Sample ID: 20420802028BF26A
Collection Date: 2/27/2026 6:49:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802028BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-29 Client Sample ID: 20420802030DW26A
Collection Date: 2/27/2026 6:55:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802030DW26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021108-30 Client Sample ID: 20420802031DW26A
Collection Date: 2/27/2026 6:56:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802031DW26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021108
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021108
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:58:28 AM

Sample Information:

Lab ID: 26021108-31 Client Sample ID: 20420802032BW26A
Collection Date: 2/27/2026 6:57:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420802032BW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst: PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021108

05-Mar-26

Client: Central Point School Dist #6

Project: Crater/Gym Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35904		SampType: MBLK		TestCode: LEAD_SCHO		Units: ppb		Prep Date: 3/2/2026		RunNo: 67879			
Client ID: PBW		Batch ID: 35904		TestNo: E200.8		E200.8		Analysis Date: 3/3/2026		SeqNo: 1112317			
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35904	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: LCSW	Batch ID: 35904	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112318						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.505	100	0	102	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021108-21AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420802021BF26A	Batch ID: 35904	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112320						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.8	0.505	100	0	97.8	70	130				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 26021108-21AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420802021BF26A	Batch ID: 35904	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112321						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.0	0.505	100	0	99.0	70	130	97.8	1.23	20	
------	------	-------	-----	---	------	----	-----	------	------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded
RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021108

05-Mar-26

Client: Central Point School Dist #6

Project: Crater/Gym Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35903		SampType: MBLK		TestCode: LEAD_SCHO		Units: ppb		Prep Date: 3/2/2026		RunNo: 67879			
Client ID: PBW		Batch ID: 35903		TestNo: E200.8		E200.8		Analysis Date: 3/3/2026		SeqNo: 1112381			
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35903	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: LCSW	Batch ID: 35903	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112382						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.505	100	0	100	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021108-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420802001BF26A	Batch ID: 35903	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112384						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.5	0.505	100	0	97.5	70	130				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 26021108-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420802001BF26A	Batch ID: 35903	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112385						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.4	0.505	100	0	97.4	70	130	97.5	0.0885	20	
------	------	-------	-----	---	------	----	-----	------	--------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded
RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26021108

RcptNo: 1

Logged by: Rachel Ueki 2/27/2026 10:56:00 AM

Completed By: Dorie Evans 3/2/2026 11:14:17 AM

Reviewed By: Ashley Spiegelberg 3/5/2026 10:26:17 AM

Rachel Ueki
Dorie Evans
Ashley Spiegelberg

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☒ NA ☐
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☒ No ☐ NA ☐
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☒ NA ☐
Not required
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email:
Phone:
Collected By (Print): MARK LILLICH
Collected By (Sign): *Mark L. Lillich*
Email Report ☒ Mail Report ☐ Fax Report ☐

Section B

Required Project Information

Required Project Information:	
Project Name:	CRATER / GYM
Project Number:	
Report To:	
Copy To:	

Section C
Invoice Information

Invoice Information	
Attention:	
Company Name:	
Address:	
P.O. #	

Section D
Rush Status (Subject to Scheduling)

☒ Standard: 10 Business Days ☐ Priority: 5 Business Days (List $\times$ 1.50) ☐ Express: 3 Business Days (List $\times$ 1.75) ☐ Rush: 2 Business Days (List $\times$ 2.00) ☐ Rush: 1 Business Day (List $\times$ 2.50) ☐ Rush: Same Day (List $\times$ 3.00)	
Authorized ☐ Yes ☐ No	

Section E

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:		Jeff Carr	2-27-26	10:56 AM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	Rachel Ueki	Rachel Ueki	2/27/26	10:56 AM

Section G
Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: ___ Yes ___ No

Received on Ice: ___ Yes ___ No

Number of Bottles Received: ~~20~~ 31

pH Checked: *error RN 2/27*

COC Seals Intact: ___ Yes ___ No ___ NA

Field Blank Included: ___ Yes ___ No

UPS FedEX Other Hand

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

Effective 10/5/2020



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email:
Phone:
Collected By (Print): MARK LILLY
Collected By (Sign): 
Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	CRATER / GYM
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:	
Company Name:	
Address:	
P.O. #	

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)

Authorized	Yes	No
------------	-----	----

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:	<i>Self</i>	Self	2-27-26	10:56 AM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	Rachel Ueki	Rachel Ueki	2/27/26	10:56 AM

Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: ___ Yes ___ No

Received on Ice: ___ Yes ___ No

Number of Bottles Received: 31

pH Checked: ___

COC Seals Intact: ___ Yes ___ No NA

Field Blank Included: ___ Yes ___ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment:	Invoice	Cash	VISA, M/C	Check #	Amount
----------	---------	------	-----------	---------	--------



Page ____ of ____

Section D

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)

	Authorized ____ Yes ____ No
--	-----------------------------

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Time

Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: ___ Yes ___ No

Received on Ice: ___ Yes ___ No

Number of Bottles Received: 31

pH Checked: ___

COC Seals Intact: ___ Yes ___ No NA

Field Blank Included: ___ Yes ___ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Effective 10/5/2020



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 13, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater Land Lab Bathrooms Lead Testing

Order No.: 26030055

Dear Dale Giovannetti:

Neilson Research Corporation received 9 sample(s) on 3/3/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26030055
Date: 3/13/2026

CLIENT: Central Point School Dist #6
Project: Crater Land Lab Bathrooms Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26030055
Date Reported: 3/13/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26030055
Received Date: 3/3/2026 10:34:00 AM
Reported Date: 3/13/2026 3:44:24 PM

Sample Information:

Lab ID: 26030055-01 Client Sample ID: 20420831001DW26A
Collection Date: 3/3/2026 6:57:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420831001DW26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.639		0.515	ppb	1	3/12/2026	15.0	A

Lab ID: 26030055-02 Client Sample ID: 20420831002DW26A
Collection Date: 3/3/2026 6:58:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420831002DW26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/12/2026	15.0	A

Lab ID: 26030055-03 Client Sample ID: 20420831003BF26A
Collection Date: 3/3/2026 6:59:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420831003BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/12/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26030055
Date Reported: 3/13/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26030055
Received Date: 3/3/2026 10:34:00 AM
Reported Date: 3/13/2026 3:44:24 PM

Sample Information:

Lab ID: 26030055-04 Client Sample ID: 20420831004BF26A
Collection Date: 3/3/2026 7:00:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420831004BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/12/2026	15.0	A

Lab ID: 26030055-05 Client Sample ID: 20420831005BF26A
Collection Date: 3/3/2026 7:01:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420831005BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.15		0.515	ppb	1	3/12/2026	15.0	A

Lab ID: 26030055-06 Client Sample ID: 20420831006BF26A
Collection Date: 3/3/2026 7:02:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420831006BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.45		0.515	ppb	1	3/12/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26030055
Date Reported: 3/13/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26030055
Received Date: 3/3/2026 10:34:00 AM
Reported Date: 3/13/2026 3:44:24 PM

Sample Information:

Lab ID: 26030055-07 **Client Sample ID:** 20420831007BF26A
Collection Date: 3/3/2026 7:04:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420831007BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.32		0.515	ppb	1	3/12/2026	15.0	A

Lab ID: 26030055-08 **Client Sample ID:** 20420831008BF26A
Collection Date: 3/3/2026 7:05:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420831008BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/12/2026	15.0	A

Lab ID: 26030055-09 **Client Sample ID:** 20420831009BF26A
Collection Date: 3/3/2026 7:05:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420831009BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.19		0.515	ppb	1	3/12/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26030055

13-Mar-26

Client: Central Point School Dist #6

Project: Crater Land Lab Bathrooms Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36037	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/12/2026	RunNo: 68153						
Client ID: PBW	Batch ID: 36037	TestNo: E200.8	E200.8	Analysis Date: 3/12/2026	SeqNo: 1117693						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-36037	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/12/2026	RunNo: 68153						
Client ID: LCSW	Batch ID: 36037	TestNo: E200.8	E200.8	Analysis Date: 3/12/2026	SeqNo: 1117694						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.8	0.520	100	0	99.8	85	115				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 26030550-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/12/2026	RunNo: 68153						
Client ID: BatchQC	Batch ID: 36037	TestNo: E200.8	E200.8	Analysis Date: 3/12/2026	SeqNo: 1117696						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	94.2	0.520	100	0	94.2	70	130				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 26030550-01AMSD		SampType: MSD		TestCode: LEAD_SCHO		Units: ppb		Prep Date: 3/12/2026		RunNo: 68153			
Client ID: BatchQC		Batch ID: 36037		TestNo: E200.8		E200.8		Analysis Date: 3/12/2026		SeqNo: 1117697			
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.4	0.520	100	0	95.4	70	130	94.2	1.30	20	
------	------	-------	-----	---	------	----	-----	------	------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded
RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26030055

RcptNo: 1

Logged by: Tamra Schmedemann 3/3/2026 10:34:00 AM

Completed By: Dorie Evans 3/6/2026 10:38:34 AM

Reviewed By: Dorie Evans 3/13/2026 3:41:27 PM

Tamra Schmedemann
Dorie Evans
Dorie Evans

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO₃ pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Crater land lab bathrooms</u>		Attention:		☒ Standard: 10 Business Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		____ Priority: 5 Business Days (List x 1.50)	
<u>Central Point, OR 97502</u>		Report To:		Address:		____ Express: 3 Business Days (List x 1.75)	
Email:		Copy To:		P.O. #		____ Rush: 2 Business Days (List x 2.00)	
Phone:						____ Rush: 1 Business Day (List x 2.50)	
Collected By (Print): <u>Jeff Carr</u>						____ Rush: Same Day (List x 3.00)	
Collected By (Sign): <u>[Signature]</u>						Authorized ____ Yes ____ No	
Email Report ☒ Mail Report ____ Fax Report ____							

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>26030055</u>			
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers											Remarks / Field Data	NRC Sample # (Use Only)	(Lab
20420831001DW26A	7938	DW	3-3-26	6:57AM	1	X												01
20420831002DW26A	7941	DW	3-3-26	6:58AM	1	X												02
20420831003BF26A	7942	DW	3-3-26	6:59AM	1	X												03
20420831004BF26A	7933	DW	3-3-26	7:00AM	1	X												04
20420831005BF26A	7931	DW	3-3-26	7:01AM	1	X												05
20420831006BF26A	7925	DW	3-3-26	7:02AM	1	X												06
20420831007BF26A	7927	DW	3-3-26	7:04A	1	X												07
20420831009BF26A	7939	DW	3-3-26	7:05AM	1	X												08
20420831009BF26A	7943	DW	3-3-26	7:05AM	1	X												09

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive				Section G Lab Use Only			
Relinquished By: <u>[Signature]</u>		Received By: <u>Jeff Carr</u>		Temp: <u>amb</u> IR Therm ID:		≤6°C: ____ Yes ____ No	
Relinquished By:		Received By:		Received on Ice: ____ Yes ☒ No		Number of Bottles Received: <u>9</u>	
Relinquished By:		Received By:		pH Checked: <u>N/A</u>		COC Seals Intact: ____ Yes ____ No ☒ NA	
Relinquished By:		Received By:		Field Blank Included: ____ Yes ____ No		Received Via: ____ UPS ____ FedEx ____ Other ☒ Hand	
Received By Laboratory: <u>[Signature]</u>		Received By Laboratory: <u>[Signature]</u>		Date: <u>3/3/26</u>		Time: <u>10:34</u>	
Payment: <u>2</u> Invoice ____ Cash ____ VISA, M/C ____ Check # ____ Amount ____							

Effective 10/5/2020



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 10, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater Main Building Lead Testing

Order No.: 26021114

Dear Dale Giovannetti:

Neilson Research Corporation received 74 sample(s) on 2/27/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26021114
Date: 3/10/2026

CLIENT: Central Point School Dist #6

Project: Crater Main Building Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-01 Client Sample ID: 20420800001DW26A
Collection Date: 2/27/2026 6:06:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800001DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-02 Client Sample ID: 20420800002BW26A
Collection Date: 2/27/2026 6:07:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800002BW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-03 Client Sample ID: 20420800003BF26A
Collection Date: 2/27/2026 6:07:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800003BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-04 **Client Sample ID:** 20420800004BF26A
Collection Date: 2/27/2026 6:08:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800004BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-05 **Client Sample ID:** 20420800005BF26A
Collection Date: 2/27/2026 6:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800005BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-06 **Client Sample ID:** 20420800006BF26A
Collection Date: 2/27/2026 6:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800006BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-07 **Client Sample ID:** 20420800007CF26A
Collection Date: 2/27/2026 6:10:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800007CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-08 **Client Sample ID:** 20420800008BF26A
Collection Date: 2/27/2026 6:12:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800008BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-09 **Client Sample ID:** 20420800009SF26A
Collection Date: 2/27/2026 6:13:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800009SF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-10 **Client Sample ID:** 20420800010BF26A
Collection Date: 2/27/2026 6:14:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800010BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-11 **Client Sample ID:** 20420800011SF26A
Collection Date: 2/27/2026 6:17:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800011SF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.38		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-12 **Client Sample ID:** 20420800012SF26A
Collection Date: 2/27/2026 6:17:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800012SF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-13 **Client Sample ID:** 20420800013CF26A
Collection Date: 2/27/2026 6:21:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800013CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-14 **Client Sample ID:** 20420800014DW26A
Collection Date: 2/27/2026 6:23:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800014DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-15 **Client Sample ID:** 20420800015WB26A
Collection Date: 2/27/2026 6:23:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800015WB26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-16 **Client Sample ID:** 20420800016CF26A
Collection Date: 2/27/2026 6:25:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800016CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.72		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-17 **Client Sample ID:** 20420800017DW26A
Collection Date: 2/27/2026 6:26:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800017DW26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-18 **Client Sample ID:** 20420800018DW26A
Collection Date: 2/27/2026 6:27:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800018DW26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-19 **Client Sample ID:** 20420800019WB26A
Collection Date: 2/27/2026 6:27:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800019WB26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-20 **Client Sample ID:** 20420800020BF26A
Collection Date: 2/27/2026 6:29:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800020BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-21 **Client Sample ID:** 20420800021BF26A
Collection Date: 2/27/2026 6:29:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800021BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-22 **Client Sample ID:** 20420800022BF26A
Collection Date: 2/27/2026 6:30:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800022BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-23 **Client Sample ID:** 20420800023BF26A
Collection Date: 2/27/2026 6:34:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800023BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-24 **Client Sample ID:** 20420800024BF26A
Collection Date: 2/27/2026 6:31:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800024BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-25 Client Sample ID: 20420800025BF26A
Collection Date: 2/27/2026 6:33:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800025BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-26 Client Sample ID: 20420800026BF26A
Collection Date: 2/27/2026 6:34:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800026BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-27 Client Sample ID: 20420800027CF26A
Collection Date: 2/27/2026 6:34:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800027CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.564		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-28 **Client Sample ID:** 20420800028SF26A
Collection Date: 2/27/2026 6:36:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800028SF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-29 **Client Sample ID:** 20420800029WB26A
Collection Date: 2/27/2026 6:39:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800029WB26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-30 **Client Sample ID:** 20420800030DW26A
Collection Date: 2/27/2026 6:39:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800030DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-31 **Client Sample ID:** 20420800031DW26A
Collection Date: 2/27/2026 6:40:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800031DW26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-32 **Client Sample ID:** 20420800032BF26A
Collection Date: 2/27/2026 6:40:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800032BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-33 **Client Sample ID:** 20420800033BF26A
Collection Date: 2/27/2026 6:43:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800033BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.605		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-34 Client Sample ID: 20420800034SF26A
Collection Date: 2/27/2026 6:44:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800034SF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.534		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-35 Client Sample ID: 20420800035SF26A
Collection Date: 2/27/2026 6:49:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800035SF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-36 Client Sample ID: 20420800036BF26A
Collection Date: 2/27/2026 6:50:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800036BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-37 **Client Sample ID:** 20420800037BF26A
Collection Date: 2/27/2026 6:50:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800037BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-38 **Client Sample ID:** 20420800038BF26A
Collection Date: 2/27/2026 6:51:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800038BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-39 **Client Sample ID:** 20420800039BF26A
Collection Date: 2/27/2026 6:52:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800039BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-40 **Client Sample ID:** 20420800040BF26A
Collection Date: 2/27/2026 6:52:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800040BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-41 **Client Sample ID:** 20420800041DW26A
Collection Date: 2/27/2026 6:52:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800041DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-42 **Client Sample ID:** 20420800042DW26A
Collection Date: 2/27/2026 6:54:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800042DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-43 **Client Sample ID:** 20420800043WB26A
Collection Date: 2/27/2026 6:55:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800043WB26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-44 **Client Sample ID:** 20420800044CF26A
Collection Date: 2/27/2026 6:56:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800044CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-45 **Client Sample ID:** 20420800045CF26A
Collection Date: 2/27/2026 6:56:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800045CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-46 **Client Sample ID:** 20420800046CF26A
Collection Date: 2/27/2026 6:57:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800046CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.774		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-47 **Client Sample ID:** 20420800047CF26A
Collection Date: 2/27/2026 6:58:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800047CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.03		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-48 **Client Sample ID:** 20420800048CF26A
Collection Date: 2/27/2026 7:00:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800048CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.52		0.500	ppb	1	3/6/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-49 **Client Sample ID:** 20420800049CF26A
Collection Date: 2/27/2026 7:01:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800049CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-50 **Client Sample ID:** 20420800050CF26A
Collection Date: 2/27/2026 7:01:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800050CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	12.8	1	0.500	ppb	1	3/6/2026	15.0	A

Lab ID: 26021114-51 **Client Sample ID:** 20420800051DW26A
Collection Date: 2/27/2026 7:05:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800051DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-52 **Client Sample ID:** 20420800052DW26A
Collection Date: 2/27/2026 7:06:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800052DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-53 **Client Sample ID:** 20420800053WB26A
Collection Date: 2/27/2026 7:06:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800053WB26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-54 **Client Sample ID:** 20420800054CF26A
Collection Date: 2/27/2026 7:06:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800054CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-55 **Client Sample ID:** 20420800055CF26A
Collection Date: 2/27/2026 7:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800055CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.23		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-56 **Client Sample ID:** 20420800056CF26A
Collection Date: 2/27/2026 7:13:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800056CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-57 **Client Sample ID:** 20420800057CF26A
Collection Date: 2/27/2026 7:13:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800057CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.74		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-58 Client Sample ID: 20420800058CF26A
Collection Date: 2/27/2026 7:14:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800058CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.05		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-59 Client Sample ID: 20420800059CF26A
Collection Date: 2/27/2026 7:15:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800059CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.63		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021114-60 Client Sample ID: 20420800060CF26A
Collection Date: 2/27/2026 7:15:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800060CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.72		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-61 Client Sample ID: 20420800061CF26A
Collection Date: 2/27/2026 7:16:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800061CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.59		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-62 Client Sample ID: 20420800062CF26A
Collection Date: 2/27/2026 7:16:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800062CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.18		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-63 Client Sample ID: 20420800063CF26A
Collection Date: 2/27/2026 7:16:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800063CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	22.4	*1	0.500	ppb	1	3/6/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-64 Client Sample ID: 20420800064BF26A
Collection Date: 2/27/2026 7:21:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800064BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.929		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-65 Client Sample ID: 20420800065SF26A
Collection Date: 2/27/2026 7:22:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800065SF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.28		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-66 Client Sample ID: 20420800066NS26A
Collection Date: 2/27/2026 7:23:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800066NS26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-67 Client Sample ID: 20420800067NS26A
Collection Date: 2/27/2026 7:24:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800067NS26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.40		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-68 Client Sample ID: 20420800068CF26A
Collection Date: 2/27/2026 7:23:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800068CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	26.3	*1	0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-69 Client Sample ID: 20420800069CF26A
Collection Date: 2/27/2026 7:29:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800069CF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	9.81	1	0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-70 **Client Sample ID:** 20420800070CF26A
Collection Date: 2/27/2026 7:31:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800070CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.15		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-71 **Client Sample ID:** 20420800071DW26A
Collection Date: 2/27/2026 7:34:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800071DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-72 **Client Sample ID:** 20420800072DW26A
Collection Date: 2/27/2026 7:36:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800072DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021114
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26021114
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:14:28 AM

Sample Information:

Lab ID: 26021114-73 Client Sample ID: 20420800073WB26A
Collection Date: 2/27/2026 7:37:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800073WB26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021114-74 Client Sample ID: 20420800080SF26A
Collection Date: 2/27/2026 7:38:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800080SF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021114

10-Mar-26

Client: Central Point School Dist #6

Project: Crater Main Building Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35906	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: PBW	Batch ID: 35906	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112245						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35906	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: LCSW	Batch ID: 35906	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112246						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.505	100	0	102	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021114-21AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420800021BF26A	Batch ID: 35906	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112248						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.1	0.505	100	0.0814	99.0	70	130				
------	------	-------	-----	--------	------	----	-----	--	--	--	--

Sample ID: 26021114-21AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420800021BF26A	Batch ID: 35906	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112249						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.9	0.505	100	0.0814	99.8	70	130	99.1	0.819	20	
------	------	-------	-----	--------	------	----	-----	------	-------	----	--

Qualifiers:

- * Value exceeds Maximum or Minimum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

- C1 Sample container temperature is out of limit as specified at testcode
- MI Recovery outside control limits due to Matrix Interference

- DF Dilution Factor
- ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021114

10-Mar-26

Client: Central Point School Dist #6

Project: Crater Main Building Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35908	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: PBW	Batch ID: 35908	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112273						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID: LCS-35908		SampType: LCS		TestCode: LEAD_SCHO		Units: ppb		Prep Date: 3/2/2026			RunNo: 67879			
Client ID: LCSW		Batch ID: 35908		TestNo: E200.8		E200.8		Analysis Date: 3/2/2026			SeqNo: 1112274			
Analyte		Result		PQL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		101		0.505	100	0		101	85	115				

Sample ID: 26021114-61AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420800061CF26A	Batch ID: 35908	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112276						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	99.7	0.505	100	1.59	98.1	70	130				

Sample ID: 26021114-61AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420800061CF26A	Batch ID: 35908	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112277						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	100	0.505	100	1.59	98.4	70	130	99.7	0.277	20	

Qualifiers:

- * Value exceeds Maximum or Minimum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021114

10-Mar-26

Client: Central Point School Dist #6

Project: Crater Main Building Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35905	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: PBW	Batch ID: 35905	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112353						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35905	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: LCSW	Batch ID: 35905	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112354						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.505	100	0	101	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021114-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420800001DW26A	Batch ID: 35905	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112356						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.4	0.505	100	0	99.4	70	130				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 26021114-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: 20420800001DW26A	Batch ID: 35905	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112357						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.6	0.505	100	0	97.6	70	130	99.4	1.73	20	
------	------	-------	-----	---	------	----	-----	------	------	----	--

Qualifiers:

- * Value exceeds Maximum or Minimum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

- C1 Sample container temperature is out of limit as specified at testcode
- MI Recovery outside control limits due to Matrix Interference

- DF Dilution Factor
- ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021114

10-Mar-26

Client: Central Point School Dist #6

Project: Crater Main Building Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35907	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67907						
Client ID: PBW	Batch ID: 35907	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112885						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35907	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67907						
Client ID: LCSW	Batch ID: 35907	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112886						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.505	100	0	100	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021114-41AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67907						
Client ID: 20420800041DW26A	Batch ID: 35907	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112888						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.505	100	0.0937	100	70	130				
------	-----	-------	-----	--------	-----	----	-----	--	--	--	--

Sample ID: 26021114-41AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67907						
Client ID: 20420800041DW26A	Batch ID: 35907	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112889						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.1	0.505	100	0.0937	99.0	70	130	100	1.28	20	
------	------	-------	-----	--------	------	----	-----	-----	------	----	--

Qualifiers:

- * Value exceeds Maximum or Minimum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

- C1 Sample container temperature is out of limit as specified at testcode
- MI Recovery outside control limits due to Matrix Interference

- DF Dilution Factor
- ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021114

10-Mar-26

Client: Central Point School Dist #6

Project: Crater Main Building Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35967	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/6/2026	RunNo: 68005						
Client ID: PBW	Batch ID: 35967	TestNo: E200.8	E200.8	Analysis Date: 3/6/2026	SeqNo: 1114708						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35967	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/6/2026	RunNo: 68005						
Client ID: LCSW	Batch ID: 35967	TestNo: E200.8	E200.8	Analysis Date: 3/6/2026	SeqNo: 1114709						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0	104	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021109-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/6/2026	RunNo: 68005						
Client ID: BatchQC	Batch ID: 35967	TestNo: E200.8	E200.8	Analysis Date: 3/6/2026	SeqNo: 1114711						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.2	0.500	100	0.162	97.1	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 26021109-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/6/2026	RunNo: 68005						
Client ID: BatchQC	Batch ID: 35967	TestNo: E200.8	E200.8	Analysis Date: 3/6/2026	SeqNo: 1114712						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.9	0.500	100	0.162	97.8	70	130	97.2	0.710	20	
------	------	-------	-----	-------	------	----	-----	------	-------	----	--

Qualifiers:

- * Value exceeds Maximum or Minimum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

- C1 Sample container temperature is out of limit as specified at testcode
- MI Recovery outside control limits due to Matrix Interference

- DF Dilution Factor
- ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26021114

RcptNo: 1

Logged by: Ashley Spiegelberg 2/27/2026 10:56:00 AM

Completed By: Dorie Evans 3/2/2026 11:14:51 AM

Reviewed By: Tamra Schmedemann 3/10/2026 9:11:48 AM

Am
Dorie Evans
Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email:
Phone:
Collected By (Print): Jeff Carr
Collected By (Sign): *Jeff Carr*
Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	crater-main bldg.
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:	
Company Name:	
Address:	
P.O. #	

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)

Authorized	Yes	No
------------	-----	----

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Sign

Print

Date _____

Time

Relinquished By:	<i>Jeff Carr</i>	<i>Jeff Carr</i>	<i>2-27-26</i>	<i>10:56 AM</i>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<i>Poss</i>	<i>Ashley S. ...</i>	<i>2/27/26</i>	<i>10:56</i>

Section G

Lab Use Only

Temp: Amb IR Therm ID: NA

≤6°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: 24

pH Checked:

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash VISA, M/C Check # Amount



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Required Client Information

Company:	Central Point School District #6
Address:	300 Ash Street
	Central Point, OR 97502
Email:	
Phone:	
Collected By (Print):	Jeff Carr
Collected By (Sign):	
Email Report ☒	Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	crater-mary bldg
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)
	Authorized ☐ Yes ☐ No

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead											Remarks / Field Data	NRC Sample # (Use Only)	(Lab)
20420800031DW26A	8019	DW	2-27-26	6:40AM	1	X											31		
20420800032BF26A	7984	DW	2-27-26	6:40AM	1	X											32		
20420800033BF26A	7986	DW	2-27-26	6:43AM	1	X											33		
20420800034SF26A	7977	DW	2-27-26	6:44AM	1	✓											34		
20420800035SF26A	7982	DW	2-27-26	6:49AM	1	X											35		
20420800036BF26A	7989	DW	2-27-26	6:50AM	1	X											36		
20420900037BF26A	7991	DW	2-27-26	6:50AM	1	X											37		
20420800038BF26A	7990	DW	2-27-26	6:51AM	1	X											38		
20420800039BF26A	7988	DW	2-27-26	6:52AM	1	X											39		
20420800040BF26A	7981	DW	2-27-26	6:52AM	1	X											40		

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:	<i>Jeff Carr</i>	Jeff Carr	2-27-26	10:56
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<i>Ashley Srieselbus</i>	Ashley Srieselbus	2/27/26	10:56

Lab Use Only

Temp: Amis IR Therm ID: NA

≤6°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: 74

pH Checked:

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash VISA, M/C Check # Amount

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
 - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
 - B Analyte detected in the associated method blank.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
 - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
 - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
 - 1 Value exceeds one half of the Maximum Contaminant Level.



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 10, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater/Music Lead Testing

Order No.: 26021087

Dear Dale Giovannetti:

Neilson Research Corporation received 3 sample(s) on 2/27/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26021087
Date: 3/10/2026

CLIENT: Central Point School Dist #6

Project: Crater/Music Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021087
Date Reported: 3/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021087
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/10/2026 9:13:10 AM

Sample Information:

Lab ID: 26021087-01 Client Sample ID: 20420803001CF26A
Collection Date: 2/27/2026 7:47:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420803001CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.895		0.500	ppb	1	3/6/2026	15.0	A

Lab ID: 26021087-02 Client Sample ID: 20420803002DW26A
Collection Date: 2/27/2026 7:47:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420803002DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/6/2026	15.0	A

Lab ID: 26021087-03 Client Sample ID: 20420803003BF26A
Collection Date: 2/27/2026 7:49:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420803003BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/6/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021087

10-Mar-26

Client: Central Point School Dist #6

Project: Crater/Music Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35967	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/6/2026	RunNo: 68005						
Client ID: PBW	Batch ID: 35967	TestNo: E200.8	E200.8	Analysis Date: 3/6/2026	SeqNo: 1114708						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35967	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/6/2026	RunNo: 68005						
Client ID: LCSW	Batch ID: 35967	TestNo: E200.8	E200.8	Analysis Date: 3/6/2026	SeqNo: 1114709						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0	104	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021109-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/6/2026	RunNo: 68005						
Client ID: BatchQC	Batch ID: 35967	TestNo: E200.8	E200.8	Analysis Date: 3/6/2026	SeqNo: 1114711						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.2	0.500	100	0.162	97.1	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 26021109-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/6/2026	RunNo: 68005						
Client ID: BatchQC	Batch ID: 35967	TestNo: E200.8	E200.8	Analysis Date: 3/6/2026	SeqNo: 1114712						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.9	0.500	100	0.162	97.8	70	130	97.2	0.710	20	
------	------	-------	-----	-------	------	----	-----	------	-------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed
RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26021087

RcptNo: 1

Logged by: Rachel Ueki 2/27/2026 10:56:00 AM

Completed By: Dorie Evans 3/2/2026 10:57:41 AM

Reviewed By: Tamra Schmedemann 3/10/2026 9:09:23 AM

Rachel Ueki

Dorie Evans

Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

The sample submitted for sample ID 26021087-01A contained visible sediment.

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page of

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email:
Phone:
Collected By (Print): Jeff Carr
Collected By (Sign): 
Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	CRATER / MUSIC
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)

Authorized	Yes	No
------------	-----	----

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:	<i>Jeff Carr</i>	Jeff Carr	2-27-26	10:56 AM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	Rachel Ueki	Rachel Ueki	2/27/26	10:56 am

Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: 3

pH Checked: _____

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash VISA, M/C Check # Amount

Effective 10/5/2020



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 05, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater/PAC Lead Testing

Order No.: 26021100

Dear Dale Giovannetti:

Neilson Research Corporation received 14 sample(s) on 2/27/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26021100
Date: 3/5/2026

CLIENT: Central Point School Dist #6

Project: Crater/PAC Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021100
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021100
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:50:37 AM

Sample Information:

Lab ID: 26021100-01 Client Sample ID: 20420811001BF26A
Collection Date: 2/27/2026 8:08:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811001BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/2/2026	15.0	A

Lab ID: 26021100-02 Client Sample ID: 20420811002BF26A
Collection Date: 2/27/2026 8:09:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811002BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021100-03 Client Sample ID: 20420811003BF26A
Collection Date: 2/27/2026 8:10:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811003BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021100
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021100
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:50:37 AM

Sample Information:

Lab ID: 26021100-04 Client Sample ID: 20420811004BF26A
Collection Date: 2/27/2026 8:11:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811004BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021100-05 Client Sample ID: 20420811005BF26A
Collection Date: 2/27/2026 8:02:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811005BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021100-06 Client Sample ID: 20420811006BF26A
Collection Date: 2/27/2026 8:03:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811006BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021100
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021100
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:50:37 AM

Sample Information:

Lab ID: 26021100-07 Client Sample ID: 20420811007BF26A
Collection Date: 2/27/2026 8:04:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811007BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021100-08 Client Sample ID: 20420811008BF26A
Collection Date: 2/27/2026 8:05:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811008BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021100-09 Client Sample ID: 20420811009DW26A
Collection Date: 2/27/2026 8:15:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811009DW26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021100
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021100
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:50:37 AM

Sample Information:

Lab ID: 26021100-10 Client Sample ID: 20420811010CF26A
Collection Date: 2/27/2026 8:16:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811010CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021100-11 Client Sample ID: 20420811011BF26A
Collection Date: 2/27/2026 8:22:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811011BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021100-12 Client Sample ID: 20420811012BF26A
Collection Date: 2/27/2026 8:23:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811012BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021100
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021100
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:50:37 AM

Sample Information:

Lab ID: 26021100-13 Client Sample ID: 20420811013BF26A
Collection Date: 2/27/2026 8:19:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811013BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst: PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021100-14 Client Sample ID: 20420811014BF26A
Collection Date: 2/27/2026 8:20:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420811014BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst: PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021100

05-Mar-26

Client: Central Point School Dist #6

Project: Crater/PAC Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35901	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879
Client ID: PBW	Batch ID: 35901	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112293
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.500			
------	----	-------	--	--	--

Sample ID: LCS-35901	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879
Client ID: LCSW	Batch ID: 35901	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112294
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	100	0.505	100	0	100	85	115			
------	-----	-------	-----	---	-----	----	-----	--	--	--

Sample ID: 26021100-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879
Client ID: 20420811001BF26A	Batch ID: 35901	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112313
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	99.4	0.505	100	0	99.4	70	130			
------	------	-------	-----	---	------	----	-----	--	--	--

Sample ID: 26021100-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879
Client ID: 20420811001BF26A	Batch ID: 35901	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112314
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	99.4	0.505	100	0	99.4	70	130	99.4	0.0649	20	
------	------	-------	-----	---	------	----	-----	------	--------	----	--

Qualifiers:	C1 Sample container temperature is out of limit as specified at testcode	DF Dilution Factor	H Holding times for preparation or analysis exceeded
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26021100

RcptNo: 1

Logged by: Rachel Ueki 2/27/2026 10:56:00 AM

Completed By: Dorie Evans 3/2/2026 11:08:57 AM

Reviewed By: Ashley Spiegelberg 3/5/2026 10:44:04 AM

Rachel Ueki
Dorie Evans
Ashley Spiegelberg

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☒ NA ☐
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☒ No ☐ NA ☐
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☒ NA ☐
Not required
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email:
Phone:
Collected By (Print): MARK LILLION
Collected By (Sign): 
Email Report ☒ Mail Report ☐ Fax Report ☐

Section B

Required Project Information

Project Name:	CRATER / PAC
Project Number:	
Report To:	
Copy To:	

Section C

Invoice Information

Invoice Information:	
Attention:	
Company Name:	
Address:	
P.O. #	

Section D

Rush Status (Subject to Scheduling)

Rush Status (Subject to Scheduling)	
☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)
Authorized ☐ Yes ☐ No	

Section E

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:		Jeff Carr	2-27-26	10:56 AM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	Rachel Ueki	Rachel Ueki	2/27/26	10:56 AM

Section G

Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: ___ Yes ___ No

Received on Ice: ___ Yes ___ No

Number of Bottles Received: 14

pH Checked: ___

COC Seals Intact: ___ Yes ___ No NA

Field Blank Included: ___ Yes ___ No

UPS FedEX Other Hand

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

Effective 10/5/2020



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Required Client Information

Company: Central Point School District #6

Address: 300 Ash Street

Central Point, OR 97502

Email:

Phone:

Collected By (Print): MARK WILLYCH

Collected By (Sign): *Mark Willich*

Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	CRATER / PAC
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)

Authorized	Yes	No
------------	-----	----

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:		Jeff Carr	2-27-26	10:56 AM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	Rachel Ulke	Rachel Ulke	2/27/26	10:56 AM

Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: ___ Yes ___ No

Received on Ice: ___ Yes ___ No

Number of Bottles Received: 14

pH Checked: ___

COC Seals Intact: ___ Yes ___ No NA

Field Blank Included: ___ Yes ___ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash VISA, M/C Check # Amount

Effective 10/5/2020



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

April 07, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater-Softball Field Lead Testing

Order No.: 26031261

Dear Dale Giovannetti:

Neilson Research Corporation received 3 sample(s) on 3/31/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26031261
Date: 4/7/2026

CLIENT: Central Point School Dist #6

Project: Crater-Softball Field Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26031261
Date Reported: 4/7/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26031261
Received Date: 3/31/2026 10:23:00 AM
Reported Date: 4/7/2026 9:20:59 AM

Sample Information:

Lab ID: 26031261-01 Client Sample ID: 20420812001BF26A
Collection Date: 3/31/2026 7:21:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420812001BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.186	J	0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031261-02 Client Sample ID: 20420812002DW26A
Collection Date: 3/31/2026 7:22:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420812002DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.188	J	0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031261-03 Client Sample ID: 20420812003BF26A
Collection Date: 3/31/2026 7:23:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420812003BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.157	J	0.500	ppb	1	4/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26031261

07-Apr-26

Client: Central Point School Dist #6

Project: Crater-Softball Field Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36252	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634						
Client ID: PBW	Batch ID: 36252	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127441						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-36252	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634						
Client ID: LCSW	Batch ID: 36252	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127443						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.500	100	0	103	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26031201-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634						
Client ID: BatchQC	Batch ID: 36252	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127445						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	98.2	0.500	100	0.603	97.6	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 26031201-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634						
Client ID: BatchQC	Batch ID: 36252	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127446						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	96.9	0.500	100	0.603	96.3	70	130	98.2	1.29	20	
------	------	-------	-----	-------	------	----	-----	------	------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	RL	Reporting Limit				

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26031261

RcptNo: 1

Logged by: Dorie Evans 3/31/2026 10:23:00 AM

Completed By: Danielle Garten 4/1/2026 11:03:06 AM

Reviewed By: Tamra Schmedemann 4/7/2026 9:11:20 AM

Dorie Evans
Danielle Garten
Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page of

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email: _____
Phone: _____
Collected By (Print): Jeff Carr
Collected By (Sign): Jeff Carr
Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information

Project Name:	Crater - softball field
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)

Authorized	Yes	No
------------	-----	----

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:		Jeff Carr	3-31-26	10:23 AM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:		Dorle Evans	3/31/26	10:23

Lab Use Only

Temp: AMB IR Therm ID:

≤6°C: ___ Yes ___ No

Received on Ice: ___ Yes ___ No

Number of Bottles Received: 3

pH Checked: ✓

COC Seals Intact: ___ Yes ___ No ___ NA

Field Blank Included: ___ Yes ___ No

UPS FedEX Other Hand

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment:	Invoice	Cash	VISA, M/C	Check #	Amount
----------	---------	------	-----------	---------	--------

Effective 10/5/2020



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

April 07, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater-Stadium Lead Testing

Order No.: 26031272

Dear Dale Giovannetti:

Neilson Research Corporation received 7 sample(s) on 3/31/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26031272
Date: 4/7/2026

CLIENT: Central Point School Dist #6

Project: Crater-Stadium Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26031272
Date Reported: 4/7/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26031272
Received Date: 3/31/2026 10:23:00 AM
Reported Date: 4/7/2026 11:26:12 AM

Sample Information:

Lab ID: 26031272-01 Client Sample ID: 20420801001KF26A
Collection Date: 3/31/2026 7:32:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420801001KF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031272-02 Client Sample ID: 20420801002KF26A
Collection Date: 3/31/2026 7:35:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420801002KF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031272-03 Client Sample ID: 20420801003BF26A
Collection Date: 3/31/2026 7:39:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420801003BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26031272
Date Reported: 4/7/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26031272
Received Date: 3/31/2026 10:23:00 AM
Reported Date: 4/7/2026 11:26:12 AM

Sample Information:

Lab ID: 26031272-04 Client Sample ID: 20420801004BF26A
Collection Date: 3/31/2026 7:38:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420801004BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031272-05 Client Sample ID: 20420801005DW26A
Collection Date: 3/31/2026 7:41:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420801005DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/2/2026	15.0	A

Lab ID: 26031272-06 Client Sample ID: 20420801006BF26A
Collection Date: 3/31/2026 7:45:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420801006BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26031272
Date Reported: 4/7/2026

Central Point School Dist #6
300 Ash St.
Central Point , OR 97502

Lab Order: 26031272
Received Date: 3/31/2026 10:23:00 AM
Reported Date: 4/7/2026 11:26:12 AM

Sample Information:

Lab ID:	26031272-07	Client Sample ID:	20420801007BF26A
Collection Date:	3/31/2026 7:44:00 AM	Collected By:	Jeff Carr
Matrix:	Drinking Water	Sample Location:	20420801007BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.59		0.500	ppb	1	4/2/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26031272
07-Apr-26

Client: Central Point School Dist #6
Project: Crater-Stadium Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36253	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634
Client ID: PBW	Batch ID: 36253	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127464
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.500			
------	----	-------	--	--	--

Sample ID: LCS-36253	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634
Client ID: LCSW	Batch ID: 36253	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127465
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	107	0.500	100	0	107	85	115			
------	-----	-------	-----	---	-----	----	-----	--	--	--

Sample ID: 26031170-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634
Client ID: BatchQC	Batch ID: 36253	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127467
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	105	0.500	100	2.08	103	70	130			
------	-----	-------	-----	------	-----	----	-----	--	--	--

Sample ID: 26031170-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/1/2026	RunNo: 68634
Client ID: BatchQC	Batch ID: 36253	TestNo: E200.8	E200.8	Analysis Date: 4/2/2026	SeqNo: 1127468
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	106	0.500	100	2.08	104	70	130	105	0.779	20	
------	-----	-------	-----	------	-----	----	-----	-----	-------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceeded
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26031272

RcptNo: 1

Logged by: Dorie Evans 3/31/2026 10:23:00 AM

Completed By: Danielle Garten 4/1/2026 11:11:23 AM

Reviewed By: Ashley Spiegelberg 4/7/2026 11:21:51 AM

Dorie Evans
Danielle Garten
Ashley Spiegelberg

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☒ NA ☐
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☒ NA ☐
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 05, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater/Student Center Lead Testing

Order No.: 26021103

Dear Dale Giovannetti:

Neilson Research Corporation received 21 sample(s) on 2/27/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26021103
Date: 3/5/2026

CLIENT: Central Point School Dist #6

Project: Crater/Student Center Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021103
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021103
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 11:00:43 AM

Sample Information:

Lab ID: 26021103-01 Client Sample ID: 20420805012IM26A
Collection Date: 2/27/2026 7:13:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805012IM26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-02 Client Sample ID: 20420805013KF26A
Collection Date: 2/27/2026 7:16:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805013KF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-03 Client Sample ID: 20420805014BF26A
Collection Date: 2/27/2026 7:18:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805014BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021103
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021103
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 11:00:43 AM

Sample Information:

Lab ID: 26021103-04 **Client Sample ID:** 20420805015KF26A
Collection Date: 2/27/2026 7:22:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805015KF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-05 **Client Sample ID:** 20420805016KF26A
Collection Date: 2/27/2026 7:23:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805016KF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-06 **Client Sample ID:** 20420805017KF26A
Collection Date: 2/27/2026 7:25:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805017KF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.18		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021103
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021103
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 11:00:43 AM

Sample Information:

Lab ID: 26021103-07 **Client Sample ID:** 20420805018KF26A
Collection Date: 2/27/2026 7:31:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805018KF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-08 **Client Sample ID:** 20420805019KF26A
Collection Date: 2/27/2026 7:32:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805019KF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-09 **Client Sample ID:** 20420805020KF26A
Collection Date: 2/27/2026 7:30:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805020KF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021103
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021103
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 11:00:43 AM

Sample Information:

Lab ID: 26021103-10 Client Sample ID: 20420805021KF26A
Collection Date: 2/27/2026 7:31:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805021KF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.808		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-11 Client Sample ID: 20420805001BF26A
Collection Date: 2/27/2026 7:40:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805001BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-12 Client Sample ID: 20420805002BF26A
Collection Date: 2/27/2026 7:41:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805002BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021103
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021103
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 11:00:43 AM

Sample Information:

Lab ID: 26021103-13 Client Sample ID: 20420805003BF26A
Collection Date: 2/27/2026 7:42:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805003BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-14 Client Sample ID: 20420805004BF26A
Collection Date: 2/27/2026 7:34:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805004BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-15 Client Sample ID: 20420805005BF26A
Collection Date: 2/27/2026 7:35:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805005BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021103
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021103
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 11:00:43 AM

Sample Information:

Lab ID: 26021103-16 **Client Sample ID:** 20420805006BF26A
Collection Date: 2/27/2026 7:36:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805006BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-17 **Client Sample ID:** 20420805007DW26A
Collection Date: 2/27/2026 7:45:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805007DW26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.27		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-18 **Client Sample ID:** 20420805008CF26A
Collection Date: 2/27/2026 7:49:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420805008CF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021103
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021103
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 11:00:43 AM

Sample Information:

Lab ID: 26021103-19 Client Sample ID: 20420805009CF26A
Collection Date: 2/27/2026 7:49:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805009CF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.545		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-20 Client Sample ID: 20420805010KF26A
Collection Date: 2/27/2026 7:50:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805010KF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021103-21 Client Sample ID: 20420805022KF26A
Collection Date: 2/27/2026 7:32:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420805022KF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021103

05-Mar-26

Client: Central Point School Dist #6

Project: Crater/Student Center Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35901		SampType: MBLK		TestCode: LEAD_SCHO		Units: ppb		Prep Date: 3/2/2026			RunNo: 67879		
Client ID: PBW		Batch ID: 35901		TestNo: E200.8		E200.8		Analysis Date: 3/2/2026			SeqNo: 1112293		
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35901	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: LCSW	Batch ID: 35901	TestNo: E200.8	E200.8	Analysis Date: 3/2/2026	SeqNo: 1112294						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.505	100	0	100	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021100-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: BatchQC	Batch ID: 35901	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112313						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.4	0.505	100	0	99.4	70	130				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 26021100-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67879						
Client ID: BatchQC	Batch ID: 35901	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112314						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.4	0.505	100	0	99.4	70	130	99.4	0.0649	20	
------	------	-------	-----	---	------	----	-----	------	--------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded
RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021103

05-Mar-26

Client: Central Point School Dist #6

Project: Crater/Student Center Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35902		SampType: MBLK		TestCode: LEAD_SCHO		Units: ppb		Prep Date: 3/2/2026		RunNo: 67907			
Client ID: PBW		Batch ID: 35902		TestNo: E200.8		E200.8		Analysis Date: 3/3/2026		SeqNo: 1112857			
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-35902	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67907						
Client ID: LCSW	Batch ID: 35902	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112858						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.520	100	0	102	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 26021103-02AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67907						
Client ID: 20420805013KF26A	Batch ID: 35902	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112860						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.520	100	0.132	101	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Sample ID: 26021103-02AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/2/2026	RunNo: 67907						
Client ID: 20420805013KF26A	Batch ID: 35902	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112861						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.7	0.520	100	0.132	99.5	70	130	101	1.20	20	
------	------	-------	-----	-------	------	----	-----	-----	------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded
RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26021103

RcptNo: 1

Logged by: Rachel Ueki 2/27/2026 10:56:00 AM

Completed By: Dorie Evans 3/2/2026 11:11:29 AM

Reviewed By: Ashley Spiegelberg 3/5/2026 10:35:24 AM

Rachel Ueki
Dorie Evans
Ashley Spiegelberg

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☒ NA ☐
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☒ No ☐ NA ☐
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☒ NA ☐
Not required
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



Section B

Required Project Information

Section C

Invoice Information

Section D
Rush Status (Subject to Scheduling)

Company: Central Point School District #6
Address: 300 Ash Street
Central Point, OR 97502
Email: _____
Phone: _____
Collected By (Print): MARK WILLIAMS
Collected By (Sign): Mark Williams
Email Report ☒ Mail Report ☐ Fax Report ☐

Required Project Information	
Project Name:	Crater- student center
Project Number:	
Report To:	
Copy To:	

Invoice Information	
Attention:	
Company Name:	
Address:	
P.O. #	

Rush Status (Subject to Scheduling)	
☒	Standard: 10 Business Days
☐	Priority: 5 Business Days (List $\times$ 1.50)
☐	Express: 3 Business Days (List $\times$ 1.75)
☐	Rush: 2 Business Days (List $\times$ 2.00)
☐	Rush: 1 Business Day (List $\times$ 2.50)
☐	Rush: Same Day (List $\times$ 3.00)
	Authorized ☐ Yes ☐ No

Section E

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:	<i>Jeff Carr</i>	<i>Jeff Carr</i>	<i>2-27-26</i>	<i>10:56 AM</i>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<i>Rachel Ueki</i>	<i>Rachel Ueki</i>	<i>2/27/26</i>	<i>10:56 AM</i>

Section G

Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: ___ Yes ___ No

Received on Ice: ___ Yes ___ No

Number of Bottles Received: 21

pH Checked: ___

COC Seals Intact: ___ Yes ___ No ___ NA

Field Blank Included: ___ Yes ___ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash VISA, M/C Check # Amount

Section A

Required Client Information

Company: Central Point School District #6

Address: 300 Ash Street
Central Point, OR 97502

Email: _____

Phone: _____

Collected By (Print): MARK LILLICH

Collected By (Sign): [Signature]

Email Report ☒ Mail Report ☐ Fax Report ☐

Section B

Required Project Information

Project Name: Crater - Student Center

Project Number: _____

Report To: _____

Copy To: _____

Section C

Invoice Information

Attention: _____

Company Name: _____

Address: _____

P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard: 10 Business Days

☐ Priority: 5 Business Days (List x 1.50)

☐ Express: 3 Business Days (List x 1.75)

☐ Rush: 2 Business Days (List x 2.00)

☐ Rush: 1 Business Day (List x 2.50)

☐ Rush: Same Day (List x 3.00)

Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks / Field Data	NRC Sample # (Lab Use Only)	(Lab
204209056226F26A	8000	DW	2-27-26	7:32AM	1	X												21	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>2-27-26</u>	<u>10:56AM</u>
Received By: _____				
Relinquished By: _____				
Received By: _____				
Relinquished By: _____				
Received By Laboratory: <u>Rachel Ueki</u>		<u>Rachel Ueki</u>		

Section G

Lab Use Only

Temp: 16.5 IR Therm ID: IR-P

≤6°C: ☐ Yes ☒ No

Received on Ice: ☐ Yes ☒ No

Number of Bottles Received: 21

pH Checked: ☐

COC Seals Intact: ☐ Yes ☐ No ☒ NA

Field Blank Included: ☐ Yes ☐ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 05, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater/Tech Center Lead Testing

Order No.: 26021098

Dear Dale Giovannetti:

Neilson Research Corporation received 9 sample(s) on 2/27/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26021098
Date: 3/5/2026

CLIENT: Central Point School Dist #6
Project: Crater/Tech Center Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021098
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021098
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:55:58 AM

Sample Information:

Lab ID: 26021098-01 Client Sample ID: 20420804001CF26A
Collection Date: 2/27/2026 8:03:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420804001CF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021098-02 Client Sample ID: 20420804002DW26A
Collection Date: 2/27/2026 8:03:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420804002DW26A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021098-03 Client Sample ID: 20420804003WB26A
Collection Date: 2/27/2026 8:04:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420804003WB26A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021098
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021098
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:55:58 AM

Sample Information:

Lab ID: 26021098-04 Client Sample ID: 20420804005CF26A
Collection Date: 2/27/2026 8:13:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420804005CF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021098-05 Client Sample ID: 20420804007BF26A
Collection Date: 2/27/2026 8:17:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420804007BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021098-06 Client Sample ID: 20420804008BF26A
Collection Date: 2/27/2026 8:08:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420804008BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26021098
Date Reported: 3/5/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26021098
Received Date: 2/27/2026 10:56:00 AM
Reported Date: 3/5/2026 10:55:58 AM

Sample Information:

Lab ID: 26021098-07 **Client Sample ID:** 20420804009CF26A
Collection Date: 2/27/2026 8:07:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420804009CF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.43		0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021098-08 **Client Sample ID:** 20420804010CF26A
Collection Date: 2/27/2026 8:07:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420804010CF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.51	1	0.515	ppb	1	3/3/2026	15.0	A

Lab ID: 26021098-09 **Client Sample ID:** 20420804011CF26A
Collection Date: 2/27/2026 8:26:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420804011CF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	25.4	*1	0.515	ppb	1	3/4/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26021098

05-Mar-26

Client: Central Point School Dist #6
Project: Crater/Tech Center Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-35928	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/3/2026	RunNo: 67907
Client ID: PBW	Batch ID: 35928	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112911
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-35928	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/3/2026	RunNo: 67907
Client ID: LCSW	Batch ID: 35928	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112912
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.520 100 0 101 85 115

Sample ID: 26021098-02AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/3/2026	RunNo: 67907
Client ID: 20420804002DW26A	Batch ID: 35928	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112914
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 99.5 0.520 100 0 99.5 70 130

Sample ID: 26021098-02AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 3/3/2026	RunNo: 67907
Client ID: 20420804002DW26A	Batch ID: 35928	TestNo: E200.8	E200.8	Analysis Date: 3/3/2026	SeqNo: 1112915
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 98.6 0.520 100 0 98.6 70 130 99.5 0.960 20

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26021098

RcptNo: 1

Logged by: Rachel Ueki 2/27/2026 10:56:00 AM

Completed By: Dorie Evans 3/2/2026 11:01:02 AM

Reviewed By: Ashley Spiegelberg 3/5/2026 10:53:14 AM

Rachel Ueki
Dorie Evans
Ashley Spiegelberg

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☒ NA ☐
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☒ No ☐ NA ☐
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☒ NA ☐
Not required
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
 - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
 - B Analyte detected in the associated method blank.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
 - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
 - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
 - 1 Value exceeds one half of the Maximum Contaminant Level.



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

April 10, 2026

Dale Giovannetti
Central Point School Dist #6
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater Main Building Lead Testing

Order No.: 26040014

Dear Dale Giovannetti:

Neilson Research Corporation received 10 sample(s) on 4/1/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26040014
Date: 4/10/2026

CLIENT: Central Point School Dist #6

Project: Crater Main Building Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26040014
Date Reported: 4/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26040014
Received Date: 4/1/2026 10:32:00 AM
Reported Date: 4/10/2026 3:16:35 PM

Sample Information:

Lab ID: 26040014-01 Client Sample ID: 20420800074BF26A
Collection Date: 4/1/2026 7:12:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800074BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/3/2026	15.0	A

Lab ID: 26040014-02 Client Sample ID: 20420800075BF26A
Collection Date: 4/1/2026 7:13:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800075BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/3/2026	15.0	A

Lab ID: 26040014-03 Client Sample ID: 20420800076BF26A
Collection Date: 4/1/2026 7:14:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800076BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26040014
Date Reported: 4/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26040014
Received Date: 4/1/2026 10:32:00 AM
Reported Date: 4/10/2026 3:16:35 PM

Sample Information:

Lab ID: 26040014-04 Client Sample ID: 20420800077BF26A
Collection Date: 4/1/2026 7:16:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800077BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/3/2026	15.0	A

Lab ID: 26040014-05 Client Sample ID: 20420800078BF26A
Collection Date: 4/1/2026 7:16:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800078BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/3/2026	15.0	A

Lab ID: 26040014-06 Client Sample ID: 20420800079BF26A
Collection Date: 4/1/2026 7:16:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800079BF26A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26040014
Date Reported: 4/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26040014
Received Date: 4/1/2026 10:32:00 AM
Reported Date: 4/10/2026 3:16:35 PM

Sample Information:

Lab ID: 26040014-07 **Client Sample ID:** 20420800081BF26A
Collection Date: 4/1/2026 7:18:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800081BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.36	1	0.515	ppb	1	4/3/2026	15.0	A

Lab ID: 26040014-08 **Client Sample ID:** 20420800082BF26A
Collection Date: 4/1/2026 7:19:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800082BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	19.4	*1	0.515	ppb	1	4/3/2026	15.0	A

Lab ID: 26040014-09 **Client Sample ID:** 20420800083BF26A
Collection Date: 4/1/2026 7:19:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420800083BF26A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CSB	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	4/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 26040014
Date Reported: 4/10/2026

Central Point School Dist #6
300 Ash St.
Central Point, OR 97502

Lab Order: 26040014
Received Date: 4/1/2026 10:32:00 AM
Reported Date: 4/10/2026 3:16:35 PM

Sample Information:

Lab ID: 26040014-10 Client Sample ID: 20420800084BF26A
Collection Date: 4/1/2026 7:20:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420800084BF26A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CSB		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.15		0.515	ppb	1	4/3/2026	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26040014

10-Apr-26

Client: Central Point School Dist #6

Project: Crater Main Building Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-36295	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/3/2026	RunNo: 68676						
Client ID: PBW	Batch ID: 36295	TestNo: E200.8	E200.8	Analysis Date: 4/3/2026	SeqNo: 1128558						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-36295	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/3/2026	RunNo: 68676						
Client ID: LCSW	Batch ID: 36295	TestNo: E200.8	E200.8	Analysis Date: 4/3/2026	SeqNo: 1128559						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	100	0.520	100	0	100	85	115				

Sample ID: 26040009-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/3/2026	RunNo: 68676						
Client ID: BatchQC	Batch ID: 36295	TestNo: E200.8	E200.8	Analysis Date: 4/3/2026	SeqNo: 1128561						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.6	0.520	100	1.14	97.5	70	130				

Sample ID: 26040009-01AMSD		SampType: MSD	TestCode: LEAD_SCHO		Units: ppb	Prep Date: 4/3/2026			RunNo: 68676		
Client ID: BatchQC		Batch ID: 36295	TestNo: E200.8		E200.8	Analysis Date: 4/3/2026			SeqNo: 1128562		
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.5	0.520	100	1.14	96.4	70	130	98.6	1.11	20	

Qualifiers:

- * Value exceeds Maximum or Minimum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode

MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor

ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26040014

RcptNo: 1

Logged by: Ashley Spiegelberg 4/1/2026 10:32:00 AM

Completed By: Ashley Spiegelberg 4/3/2026 10:43:18 AM

Reviewed By: Dorie Evans 4/10/2026 3:12:19 PM

Am
Am
Dorie

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
 - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
 - B Analyte detected in the associated method blank.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
 - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
 - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
 - 1 Value exceeds one half of the Maximum Contaminant Level.