

Lead in Water Test Results Summary: Crater Works

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red** and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange** and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are **highlighted in yellow** and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are **not highlighted** and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Meeting Room Sink	20421300001CF25A	5/14/2025	ND	Non-Detect			
Metal Shop Sink	20421300002CF25A	5/14/2025	2.65	Low			
Wood Shop Sink	20421300003CF25A	5/15/2025	ND	Non-Detect			
Left Hallway Drinking Fountain	20421300004DW25A	5/14/2025	ND	Non-Detect			
Hallway Bottle Fill	20421300005WB25A	5/14/2025	ND	Non-Detect			
Bathroom Left Sink	20421300006BF25A	5/14/2025	4.23	Low			
Bathroom Left Middle Sink	20421300007BF25A	5/14/2025	5.18	Moderate			
Bathroom Right Middle Sink	20421300008BF25A	5/14/2025	3.56	Low			
Bathroom Right Sink	20421300009BF25A	5/14/2025	2.05	Low			
Sink on South Wall	20421300010KF25A	5/14/2025	ND	Non-Detect			
Sink Middle of Kitchen	20421300011KF25A	5/14/2025	ND	Non-Detect			
Dish Room Sink	20421300012KF25A	5/14/2025	2.15	Low			
Dish Room Sprayer	20421300013KF25A	5/14/2025	ND	Non-Detect			
Right Hallway Drinking Fountain	20421300014DW25A	5/14/2025	ND	Non-Detect			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 13, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Crater Works Lead Testing

Order No.: 25050741

Dear Dale Giovannetti:

Neilson Research Corporation received 14 sample(s) on 5/14/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050741
Date: 6/13/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: Crater Works Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050741
Date Reported: 6/13/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050741
Received Date: 5/14/2025 10:18:00 AM
Reported Date: 6/13/2025 10:26:56 AM

Sample Information:

Lab ID: 25050741-01 Client Sample ID: 20421300001CF25A
Collection Date: 5/14/2025 7:29:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300001CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-02 Client Sample ID: 20421300002CF25A
Collection Date: 5/14/2025 7:30:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300002CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.65		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-03 Client Sample ID: 20421300003CF25A
Collection Date: 5/14/2025 7:31:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300003CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050741
Date Reported: 6/13/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050741
Received Date: 5/14/2025 10:18:00 AM
Reported Date: 6/13/2025 10:26:56 AM

Sample Information:

Lab ID: 25050741-04 Client Sample ID: 20421300004DW25A
Collection Date: 5/14/2025 7:36:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300004DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-05 Client Sample ID: 20421300005WB25A
Collection Date: 5/14/2025 7:36:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300005WB25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-06 Client Sample ID: 20421300006BF25A
Collection Date: 5/14/2025 7:39:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300006BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.23		0.500	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050741
Date Reported: 6/13/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050741
Received Date: 5/14/2025 10:18:00 AM
Reported Date: 6/13/2025 10:26:56 AM

Sample Information:

Lab ID: 25050741-07 Client Sample ID: 20421300007BF25A
Collection Date: 5/14/2025 7:40:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300007BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.18		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-08 Client Sample ID: 20421300008BF25A
Collection Date: 5/14/2025 7:41:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300008BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.56		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-09 Client Sample ID: 20421300009BF25A
Collection Date: 5/14/2025 7:41:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300009BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.05		0.500	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050741
Date Reported: 6/13/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050741
Received Date: 5/14/2025 10:18:00 AM
Reported Date: 6/13/2025 10:26:56 AM

Sample Information:

Lab ID: 25050741-10
Collection Date: 5/14/2025 7:44:00 AM
Matrix: Drinking Water
Client Sample ID: 20421300010KF25A
Collected By: Jeff Carr
Sample Location: 20421300010KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-11
Collection Date: 5/14/2025 7:45:00 AM
Matrix: Drinking Water
Client Sample ID: 20421300011KF25A
Collected By: Jeff Carr
Sample Location: 20421300011KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-12
Collection Date: 5/14/2025 7:46:00 AM
Matrix: Drinking Water
Client Sample ID: 20421300012KF25A
Collected By: Jeff Carr
Sample Location: 20421300012KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.15		0.500	ppb	1	6/10/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050741
Date Reported: 6/13/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050741
Received Date: 5/14/2025 10:18:00 AM
Reported Date: 6/13/2025 10:26:56 AM

Sample Information:

Lab ID: 25050741-13 Client Sample ID: 20421300013KF25A
Collection Date: 5/14/2025 7:47:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300013KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/10/2025	15.0	

Lab ID: 25050741-14 Client Sample ID: 20421300014DW25A
Collection Date: 5/14/2025 8:04:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20421300014DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	6/11/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050741
13-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Crater Works Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31627	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162
Client ID: PBW	Batch ID: 31627	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985351
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.500			
------	----	-------	--	--	--

Sample ID: LCS-31627	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162
Client ID: LCSW	Batch ID: 31627	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985352
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	101	0.500	100	0	101 85 115
------	-----	-------	-----	---	------------

Sample ID: 25050620-22AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162
Client ID: BatchQC	Batch ID: 31627	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985354
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	95.8	0.500	100	0.439	95.4 70 130
------	------	-------	-----	-------	-------------

Sample ID: 25050620-22AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162
Client ID: BatchQC	Batch ID: 31627	TestNo: E200.8	E200.8	Analysis Date: 6/10/2025	SeqNo: 985355
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	98.6	0.500	100	0.439	98.1 70 130 95.8 2.85 20
------	------	-------	-----	-------	--------------------------

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050741
13-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Crater Works Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31628	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162
Client ID: PBW	Batch ID: 31628	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985434
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.500			
------	----	-------	--	--	--

Sample ID: LCS-31628	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162
Client ID: LCSW	Batch ID: 31628	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985435
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	100	0.500	100	0	100	85	115			
------	-----	-------	-----	---	-----	----	-----	--	--	--

Sample ID: 25050741-14AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162
Client ID: 20421300014DW25A	Batch ID: 31628	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985437
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	100	0.500	100	0	100	70	130			
------	-----	-------	-----	---	-----	----	-----	--	--	--

Sample ID: 25050741-14AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/10/2025	RunNo: 60162
Client ID: 20421300014DW25A	Batch ID: 31628	TestNo: E200.8	E200.8	Analysis Date: 6/11/2025	SeqNo: 985438
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	97.4	0.500	100	0	97.4	70	130	100	2.77	20	
------	------	-------	-----	---	------	----	-----	-----	------	----	--

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25050741

RcptNo: 1

Logged by: Danielle Garten 5/14/2025 10:18:00 AM

Completed By: Coni Boyko 5/16/2025 1:33:25 PM

Reviewed By: Ashley Spiegelberg 6/13/2025 10:19:15 AM

Danielle Garten
Coni Boyko
Ashley Spiegelberg

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Craterworks</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>Jeff Carr</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>Jeff Carr</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050741</u>	Remarks/Field Data	NRC Sample # (Lab Use Only)
20421300001CF25A	16697	DW	5-14-25	7:29AM	1	X													01
20421300002CF25A	16652	DW	5-14-25	7:30AM	1	X													02
20421300003CF25A	16709	DW	5-14-25	7:31AM	1	X													03
20421300004DW25A	16650	DW	5-14-25	7:36AM	1	X													04
20421300005WB25A	16765	DW	5-14-25	7:36AM	1	X													05
20421300006BF25A	16724	DW	5-14-25	7:39AM	1	X													06
20421300007BF25A	16768	DW	5-14-25	7:40AM	1	X													07
20421300008BF25A	16664	DW	5-14-25	7:41AM	1	X													08
20421300009BF25A	16698	DW	5-14-25	7:41AM	1	X													09
20421300010KF25A	16694	DW	5-14-25	7:44AM	1	X													10

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By: <u>Jeff Carr</u>	Sign	Print	Date	Time
Received By:		<u>Jeff Carr</u>	<u>5-14-25</u>	<u>10:18AM</u>
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>Danielle Gaiten</u>		<u>Danielle Gaiten</u>	<u>5/14/25</u>	<u>10:18</u>

Section G Lab Use Only

Temp: <u>AMB</u>
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: ☐
COC Seals Intact: ☐ Yes ☒ No
Field Blank Included: ☐ Yes ☒ No
Received Via: ☒ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA/MC ☐ Check # _____ Amount _____



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Crater Works</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>Jeff Carr</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>Jeff Carr</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information					Analysis Requested												NRC Workorder # (Lab Use Only) <u>25050741</u>		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers													Remarks/Field Data	NRC Sample # (Lab Use Only)
20421300011KF25A	16707	DW	5-14-25	7:45AM	1	X													11
20421300012KF25A	16659	DW	5-14-25	7:46AM	1	X													12
20421300013KF25A	16658	DW	5-14-25	7:47AM	1	X													13
20421300014DW25A	33043	DW	5-14-25	8:04AM	1	X													14

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:	<u>Jeff Carr</u>		<u>Jeff Carr</u>	<u>5-14-25</u>	<u>10:18AM</u>
Received By:					
Relinquished By:					
Received By:					
Relinquished By:					
Received By Laboratory:	<u>Danille Barten</u>	<u>Jeff Carr</u>	<u>Danille Barten</u>	<u>5/14/25</u>	<u>10:18</u>

Section G Lab Use Only	
Temp:	<u>AMB</u>
4°C +/- 2°C:	☐ Yes ☒ No
Received on Ice:	☐ Yes ☒ No
Number of Bottles Received:	
pH Checked:	☒
COC Seals Intact:	☐ Yes ☒ No <u>NA</u>
Field Blank Included:	☐ Yes ☒ No
Received Via	☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment:	☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____