

## Lead in Water Test Results Summary: District Office/BOB

### Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.  
*Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.*
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

### Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

| Fixture Location Description                                                   | Fixture ID #     | Initial Test Date | Initial Test Result (ppb) | Initial Level | Final Retest Date | Final Test Result (ppb) | Final Level |
|--------------------------------------------------------------------------------|------------------|-------------------|---------------------------|---------------|-------------------|-------------------------|-------------|
| 1st Floor Womens Bathroom                                                      | 20420000001BF26A | 3/3/2026          | 2.23                      | Low           |                   |                         |             |
| 1st Floor Mens Bathroom                                                        | 20420000002BF26A | 3/3/2026          | 1.73                      | Low           |                   |                         |             |
| Technology Office Sink                                                         | 20420000003SF26A | 3/3/2026          | 22                        | Action Req.   |                   |                         |             |
| 2nd Floor Womens Bathroom                                                      | 20420000004BF26A | 3/3/2026          | 1.58                      | Low           |                   |                         |             |
| 2nd Floor Mens Bathroom                                                        | 20420000005BF26A | 3/3/2026          | 1.91                      | Low           |                   |                         |             |
| 3rd Floor Breakroom Sink                                                       | 20420000006SF26A | 3/3/2026          | 1.59                      | Low           |                   |                         |             |
| 3rd Floor Womens Bathroom                                                      | 20420000007BF26A | 3/3/2026          | 1.22                      | Low           |                   |                         |             |
| 3rd Floor Mens Bathroom                                                        | 20420000008BF26A | 3/3/2026          | 7.4                       | Moderate      |                   |                         |             |
|                                                                                |                  |                   |                           |               |                   |                         |             |
|                                                                                |                  |                   |                           |               |                   |                         |             |
| <b>BOB - Brick Old Building - 615 S. Second St<br/>Central Point, OR 97502</b> |                  |                   |                           |               |                   |                         |             |
| Bathroom South End by Exit                                                     | 20420007001BF26A | 4/1/2026          | 1.14                      | Low           |                   |                         |             |
| Room 1 Sink                                                                    | 20420007002SF26A | 4/1/2026          | 9.05                      | Moderate      |                   |                         |             |
| Southwest Hallway Sink                                                         | 20420007003SF26A | 4/1/2026          | 2.67                      | Low           |                   |                         |             |
| Room 3 Sink                                                                    | 20420007004SF26A | 4/1/2026          | 7.39                      | Moderate      |                   |                         |             |
| Room 4 Sink                                                                    | 20420007005SF26A | 4/1/2026          | 21.7                      | Action Req.   |                   |                         |             |
| Room 5 Sink                                                                    | 20420007006SF26A | 4/1/2026          | 3.36                      | Low           |                   |                         |             |
| Room 6 Sink                                                                    | 20420007007SF26A | 4/1/2026          | 15                        | Action Req.   |                   |                         |             |
| Southeast Hallway Sink                                                         | 20420007008SF26A | 4/1/2026          | 23.3                      | Action Req.   |                   |                         |             |
| Room 8 Sink                                                                    | 20420007009SF26A | 4/1/2026          | 12.6                      | High          |                   |                         |             |
| Room 9 Sink                                                                    | 20420007010SF26A | 4/1/2026          | 12.1                      | High          |                   |                         |             |
| West Hallway by Room 10 Sink                                                   | 20420007011SF26A | 4/1/2026          | 14.6                      | High          |                   |                         |             |
| Room 11 Sink                                                                   | 20420007012SF26A | 4/1/2026          | 169                       | Action Req.   |                   |                         |             |
| Room 12 Sink                                                                   | 20420007013SF26A | 4/1/2026          | 122                       | Action Req.   |                   |                         |             |
| Room 16 Sink                                                                   | 20420007014SF26A | 4/1/2026          | 72                        | Action Req.   |                   |                         |             |
| East Hallway by Room 15 Sink                                                   | 20420007015SF26A | 4/1/2026          | 14                        | High          |                   |                         |             |
| Room 14 Sink                                                                   | 20420007016SF26A | 4/1/2026          | 2.19                      | Low           |                   |                         |             |
| Room 13 Sink                                                                   | 20420007017SF26A | 4/1/2026          | 96.2                      | Action Req.   |                   |                         |             |
| Main Hallway Bathroom by Room 17                                               | 20420007018BF26A | 4/1/2026          | 1.14                      | Low           |                   |                         |             |
| Room 17 Sink                                                                   | 20420007019SF26A | 4/1/2026          | 6.79                      | Moderate      |                   |                         |             |
| Room 18 Sink (Out of Order)                                                    | 20420007020SF    |                   |                           |               |                   |                         |             |
| Main Hall Bathroom by Room 23                                                  | 20420007021BF26A | 4/1/2026          | 77.3                      | Action Req.   |                   |                         |             |
| Room 23 Bathroom                                                               | 20420007022BF26A | 4/1/2026          | 26                        | Action Req.   |                   |                         |             |
| Room 23 Sink                                                                   | 20420007023SF26A | 4/1/2026          | 46.3                      | Action Req.   |                   |                         |             |
| Room 24 Sink                                                                   | 20420007024SF26A | 4/1/2026          | 2570                      | Action Req.   |                   |                         |             |
| Room 25 Sink                                                                   | 20420007025SF26A | 4/1/2026          | 472                       | Action Req.   |                   |                         |             |
| Northwest Hallway Sink                                                         | 20420007026SF26A | 4/1/2026          | 59.4                      | Action Req.   |                   |                         |             |
| Room 27 Sink                                                                   | 20420007027SF26A | 4/1/2026          | 215                       | Action Req.   |                   |                         |             |
| Room 28 Sink                                                                   | 20420007028SF26A | 4/1/2026          | 339                       | Action Req.   |                   |                         |             |
| Northeast Hallway Sink                                                         | 20420007029SF26A | 4/1/2026          | 283                       | Action Req.   |                   |                         |             |
| Room 30 Sink                                                                   | 20420007030SF26A | 4/1/2026          | 155                       | Action Req.   |                   |                         |             |
| Room 31 Sink                                                                   | 20420007031SF26A | 4/1/2026          | 974                       | Action Req.   |                   |                         |             |
|                                                                                |                  |                   |                           |               |                   |                         |             |
|                                                                                |                  |                   |                           |               |                   |                         |             |



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

March 13, 2026

Dale Giovannetti  
Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502  
TEL: (541) 494-6924  
FAX

RE: District Office Lead Testing

Order No.: 26030054

Dear Dale Giovannetti:

Neilson Research Corporation received 8 sample(s) on 3/3/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Director of Project Management  
245 S Grape St  
Medford, OR 97501





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

## Case Narrative

WO#: 26030054  
Date: 3/13/2026

---

**CLIENT:** Central Point School Dist #6

**Project:** District Office Lead Testing

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26030054  
Date Reported: 3/13/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

Lab Order: 26030054  
Received Date: 3/3/2026 10:34:00 AM  
Reported Date: 3/13/2026 11:01:24 AM

Sample Information:

Lab ID: 26030054-01 Client Sample ID: 20420000001BF26A  
Collection Date: 3/3/2026 6:37:00 AM Collected By: Jeff Carr  
Matrix: Drinking Water Sample Location: 20420000001BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 2.23   |      | 0.500 | ppb   | 1  | 3/11/2026     | 15.0         | A            |

Lab ID: 26030054-02 Client Sample ID: 20420000002BF26A  
Collection Date: 3/3/2026 6:37:00 AM Collected By: Jeff Carr  
Matrix: Drinking Water Sample Location: 20420000002BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 1.73   |      | 0.500 | ppb   | 1  | 3/11/2026     | 15.0         | A            |

Lab ID: 26030054-03 Client Sample ID: 20420000003SF26A  
Collection Date: 3/3/2026 6:39:00 AM Collected By: Jeff Carr  
Matrix: Drinking Water Sample Location: 20420000003SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 22.0   | *1   | 0.500 | ppb   | 1  | 3/11/2026     | 15.0         | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |
|            |    |                                                            |    |                                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26030054  
Date Reported: 3/13/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26030054  
**Received Date:** 3/3/2026 10:34:00 AM  
**Reported Date:** 3/13/2026 11:01:24 AM

Sample Information:

**Lab ID:** 26030054-04 **Client Sample ID:** 20420000004BF26A  
**Collection Date:** 3/3/2026 6:41:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420000004BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    | Analyst; CSB  |      |              |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 1.58   |      | 0.500 | ppb   | 1  | 3/11/2026     | 15.0 | A            |

**Lab ID:** 26030054-05 **Client Sample ID:** 20420000005BF26A  
**Collection Date:** 3/3/2026 6:42:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420000005BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    | Analyst; CSB  |      |              |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 1.91   |      | 0.500 | ppb   | 1  | 3/11/2026     | 15.0 | A            |

**Lab ID:** 26030054-06 **Client Sample ID:** 20420000006SF26A  
**Collection Date:** 3/3/2026 6:43:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420000006SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    | Analyst; CSB  |      |              |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 1.59   |      | 0.500 | ppb   | 1  | 3/11/2026     | 15.0 | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26030054  
Date Reported: 3/13/2026

Central Point School Dist #6  
300 Ash St.  
Central Point , OR 97502

**Lab Order:** 26030054  
**Received Date:** 3/3/2026 10:34:00 AM  
**Reported Date:** 3/13/2026 11:01:24 AM

Sample Information:

**Lab ID:** 26030054-07      Client Sample ID: 20420000007BF26A  
Collection Date: 3/3/2026 6:45:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420000007BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    | Analyst; CSB  |      |              |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 1.22   |      | 0.500 | ppb   | 1  | 3/11/2026     | 15.0 | A            |

**Lab ID:** 26030054-08      Client Sample ID: 20420000008BF26A  
Collection Date: 3/3/2026 6:45:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420000008BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    | Analyst; CSB  |      |              |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 7.40   |      | 0.500 | ppb   | 1  | 3/11/2026     | 15.0 | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |
|            |    |                                                            |    |                                                                       |

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 26030054

13-Mar-26

**Client:** Central Point School Dist #6

**Project:** District Office Lead Testing

**TestCode:** LEAD\_SCHOOLS

|                            |                        |                            |                   |                                 |                       |          |           |             |      |          |      |
|----------------------------|------------------------|----------------------------|-------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: <b>MB-35997</b> | SampType: <b>MBLK</b>  | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>3/10/2026</b>     | RunNo: <b>68116</b>   |          |           |             |      |          |      |
| Client ID: <b>PBW</b>      | Batch ID: <b>35997</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>3/11/2026</b> | SeqNo: <b>1116875</b> |          |           |             |      |          |      |
| Analyte                    | Result                 | PQL                        | SPK value         | SPK Ref Val                     | %REC                  | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

|      |    |       |  |  |  |  |  |  |  |  |  |
|------|----|-------|--|--|--|--|--|--|--|--|--|
| Lead | ND | 0.500 |  |  |  |  |  |  |  |  |  |
|------|----|-------|--|--|--|--|--|--|--|--|--|

|                             |                        |                            |                   |                                 |                       |          |           |             |      |          |      |
|-----------------------------|------------------------|----------------------------|-------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: <b>LCS-35997</b> | SampType: <b>LCS</b>   | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>3/10/2026</b>     | RunNo: <b>68116</b>   |          |           |             |      |          |      |
| Client ID: <b>LCSW</b>      | Batch ID: <b>35997</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>3/11/2026</b> | SeqNo: <b>1116876</b> |          |           |             |      |          |      |
| Analyte                     | Result                 | PQL                        | SPK value         | SPK Ref Val                     | %REC                  | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

|      |     |       |     |   |     |    |     |  |  |  |  |
|------|-----|-------|-----|---|-----|----|-----|--|--|--|--|
| Lead | 105 | 0.500 | 100 | 0 | 105 | 85 | 115 |  |  |  |  |
|------|-----|-------|-----|---|-----|----|-----|--|--|--|--|

|                                  |                        |                            |                   |                                 |                       |          |           |             |      |          |      |
|----------------------------------|------------------------|----------------------------|-------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: <b>26030187-01BMS</b> | SampType: <b>MS</b>    | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>3/10/2026</b>     | RunNo: <b>68116</b>   |          |           |             |      |          |      |
| Client ID: <b>BatchQC</b>        | Batch ID: <b>35997</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>3/11/2026</b> | SeqNo: <b>1116878</b> |          |           |             |      |          |      |
| Analyte                          | Result                 | PQL                        | SPK value         | SPK Ref Val                     | %REC                  | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

|      |     |       |     |   |     |    |     |  |  |  |  |
|------|-----|-------|-----|---|-----|----|-----|--|--|--|--|
| Lead | 101 | 0.500 | 100 | 0 | 101 | 70 | 130 |  |  |  |  |
|------|-----|-------|-----|---|-----|----|-----|--|--|--|--|

|                                   |                        |                            |                   |                                 |                       |          |           |             |      |          |      |
|-----------------------------------|------------------------|----------------------------|-------------------|---------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: <b>26030187-01BMSD</b> | SampType: <b>MSD</b>   | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>3/10/2026</b>     | RunNo: <b>68116</b>   |          |           |             |      |          |      |
| Client ID: <b>BatchQC</b>         | Batch ID: <b>35997</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>3/11/2026</b> | SeqNo: <b>1116879</b> |          |           |             |      |          |      |
| Analyte                           | Result                 | PQL                        | SPK value         | SPK Ref Val                     | %REC                  | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

|      |      |       |     |   |      |    |     |     |      |    |  |
|------|------|-------|-----|---|------|----|-----|-----|------|----|--|
| Lead | 99.1 | 0.500 | 100 | 0 | 99.1 | 70 | 130 | 101 | 2.38 | 20 |  |
|------|------|-------|-----|---|------|----|-----|-----|------|----|--|

**Qualifiers:**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

- C1 Sample container temperature is out of limit as specified at testcode
- MI Recovery outside control limits due to Matrix Interference

- DF Dilution Factor
- ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26030054

RcptNo: 1

Logged by: Tamra Schmedemann 3/3/2026 10:34:00 AM

Completed By: Dorie Evans 3/6/2026 10:37:28 AM

Reviewed By: Tamra Schmedemann 3/13/2026 10:56:18 AM

*Tamra Schmedemann*  
*Dorie Evans*  
*Tamra Schmedemann*

### Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐  
2. How was the sample delivered? Client

### Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒  
4. Shipping container/cooler in good condition? Yes ☒ No ☐  
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐  
No. Seal Date: Signed By:  
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒  
6. Were all samples received at a temperature of  $>0^{\circ}\text{C}$  to  $6.0^{\circ}\text{C}$ ? Yes ☐ No ☐ NA ☒  
7. Sample(s) in proper container(s)? Yes ☒ No ☐  
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐  
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐  
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐  
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒  
12. Were any sample containers received broken? Yes ☐ No ☒  
13. Does paperwork match bottle labels?  
(Note discrepancies on chain of custody) Yes ☒ No ☐  
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐  
15. Is it clear what analyses were requested? Yes ☒ No ☐  
16. Were all holding times able to be met?  
(If no, notify customer for authorization.) Yes ☒ No ☐

### Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

|                      |                      |       |                                                                                                                               |
|----------------------|----------------------|-------|-------------------------------------------------------------------------------------------------------------------------------|
| Person Notified:     | <input type="text"/> | Date: | <input type="text"/>                                                                                                          |
| By Whom:             | <input type="text"/> | Via:  | <input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person |
| Regarding:           | <input type="text"/> |       |                                                                                                                               |
| Client Instructions: | <input type="text"/> |       |                                                                                                                               |

18. Additional remarks:

### Cooler Information

| Cooler No | Temp $^{\circ}\text{C}$ | Condition | Seal Intact | Seal No | Seal Date | Signed By |
|-----------|-------------------------|-----------|-------------|---------|-----------|-----------|
|-----------|-------------------------|-----------|-------------|---------|-----------|-----------|



## Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page \_\_\_\_\_ of \_\_\_\_\_

## Section A

### Required Client Information

Company: Central Point School District #6  
Address: 300 Ash Street  
Central Point, OR 97502  
Email:  
Phone:  
Collected By (Print): Jeff Carr  
Collected By (Sign): *Jeff Carr*  
Email Report ☒ Mail Report ☐ Fax Report ☐

## Section B

### Required Project Information

|                 |                 |
|-----------------|-----------------|
| Project Name:   | District Office |
| Project Number: |                 |
| Report To:      |                 |
| Copy To:        |                 |

## Section C

### Invoice Information

|               |
|---------------|
| Attention:    |
| Company Name: |
| Address:      |
|               |
| P.O. #        |

## Section D

## Rush Status (Subject to Scheduling)

|                                     |                                                |
|-------------------------------------|------------------------------------------------|
| <input checked="" type="checkbox"/> | Standard: 10 Business Days                     |
| <input type="checkbox"/>            | Priority: 5 Business Days (List $\times$ 1.50) |
| <input type="checkbox"/>            | Express: 3 Business Days (List $\times$ 1.75)  |
| <input type="checkbox"/>            | Rush: 2 Business Days (List $\times$ 2.00)     |
| <input type="checkbox"/>            | Rush: 1 Business Day (List $\times$ 2.50)      |
| <input type="checkbox"/>            | Rush: Same Day (List $\times$ 3.00)            |

Authorized ☐ Yes ☐ No

## Section E

### Sample Information

[illegible]

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

## Section F

### Relinquish/Receive

|                        | Date                                            | Time         |
|------------------------|-------------------------------------------------|--------------|
| Relinquished By:       | Jef Carr                                        | 10:34 AM     |
| Received By:           |                                                 |              |
| Relinquished By:       |                                                 |              |
| Received By:           |                                                 |              |
| Relinquished By:       |                                                 |              |
| Received By Laboratory | Sims, S. Howard Carr - Turner & Howard Carr Co. | 3/8/76 10:34 |

## Section G

Lab Use Only

Temp: am IR Therm ID: \_\_\_\_\_

$\leq 6^{\circ}\text{C}$ :      Yes      No

Received on Ice:      Yes ✓ No

Number of Bottles Received: 8

pH Checked: N/A

COC Seals Intact:      Yes      No ✓ NA

Field Blank Included:      Yes      No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount

Effective 10/5/2020

- 
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
  - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
  - B Analyte detected in the associated method blank.
  - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
  - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
  - CF Results confirmed by re-analysis.
  - CU Cleanup performed as specified by method.
  - E Estimated value.
  - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
  - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
  - HP Sample re-analysis performed outside of method specified holding time.
  - HR Sample received outside of method specified holding time.
  - HS Sample analyzed for volatile organics contained headspace.
  - HT At the client's request, the sample was analyzed outside of method specified holding time.
  - H Analysis performed outside of method specified holding time.
  - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
  - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
  - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
  - N See Case Narrative on page 2 of report.
  - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
  - R Relative percent difference (RPD) is outside of the accepted recovery limits.
  - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
  - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
  - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
  - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
  - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
  - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
  - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
  - SC Sub-contracted to another laboratory for analysis.
  - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
  - \* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
  - 1 Value exceeds one half of the Maximum Contaminant Level.



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

April 10, 2026

Dale Giovannetti  
Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502  
TEL: (541) 494-6924  
FAX

RE: BOB Building Lead Testing

Order No.: 26040009

Dear Dale Giovannetti:

Neilson Research Corporation received 30 sample(s) on 4/1/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Director of Project Management  
245 S Grape St  
Medford, OR 97501





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Case Narrative

WO#: 26040009  
Date: 4/10/2026

---

**CLIENT:** Central Point School Dist #6

**Project:** BOB Building Lead Testing

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-01 **Client Sample ID:** 20420007001BF26A  
**Collection Date:** 4/1/2026 8:01:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007001BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 1.14   |      | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

**Lab ID:** 26040009-02 **Client Sample ID:** 20420007002SF26A  
**Collection Date:** 4/1/2026 8:02:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007002SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 9.05   | 1    | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

**Lab ID:** 26040009-03 **Client Sample ID:** 20420007003SF26A  
**Collection Date:** 4/1/2026 8:02:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007003SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 2.67   |      | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-04      Client Sample ID: 20420007004SF26A  
Collection Date: 4/1/2026 8:03:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007004SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               |      | Analyst: CSB |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 7.39   |      | 0.515 | ppb   | 1  | 4/3/2026      | 15.0 | A            |

**Lab ID:** 26040009-05      Client Sample ID: 20420007005SF26A  
Collection Date: 4/1/2026 8:04:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007005SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               |      | Analyst: CSB |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 21.7   | *1   | 0.515 | ppb   | 1  | 4/3/2026      | 15.0 | A            |

**Lab ID:** 26040009-06      Client Sample ID: 20420007006SF26A  
Collection Date: 4/1/2026 8:08:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007006SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               |      | Analyst: CSB |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 3.36   |      | 0.515 | ppb   | 1  | 4/3/2026      | 15.0 | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-07 **Client Sample ID:** 20420007007SF26A  
**Collection Date:** 4/1/2026 8:07:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007007SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 15.0   | *1   | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

**Lab ID:** 26040009-08 **Client Sample ID:** 20420007008SF26A  
**Collection Date:** 4/1/2026 8:08:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007008SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 23.3   | *1   | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

**Lab ID:** 26040009-09 **Client Sample ID:** 20420007009SF26A  
**Collection Date:** 4/1/2026 8:08:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007009SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 12.6   | 1    | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-10      Client Sample ID: 20420007010SF26A  
Collection Date: 4/1/2026 8:09:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007010SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |      |       |    | Analyst: PR   |      |              |  |
|----------------------------------|--------|------|------|-------|----|---------------|------|--------------|--|
| Analyses                         | Result | Qual | MRL  | Units | DF | Date Analyzed | MCL  | NELAP Status |  |
| Lead                             | 1210   | *R31 | 10.0 | ppb   | 20 | 4/9/2026      | 15.0 | A            |  |

**Lab ID:** 26040009-11      Client Sample ID: 20420007011SF26A  
Collection Date: 4/1/2026 8:10:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007011SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    | Analyst: CSB  |      |              |  |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|--|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |  |
| Lead                             | 14.6   | 1    | 0.515 | ppb   | 1  | 4/3/2026      | 15.0 | A            |  |

**Lab ID:** 26040009-12      Client Sample ID: 20420007012SF26A  
Collection Date: 4/1/2026 8:11:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007012SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    | Analyst: PR   |      |              |  |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|--|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |  |
| Lead                             | 169    | *1   | 0.500 | ppb   | 1  | 4/8/2026      | 15.0 | A            |  |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-13 **Client Sample ID:** 20420007013SF26A  
**Collection Date:** 4/1/2026 8:12:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007013SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; PR |              |
|----------------------------------|--------|------|-------|-------|----|---------------|-------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL         | NELAP Status |
| Lead                             | 122    | *1   | 0.500 | ppb   | 1  | 4/8/2026      | 15.0        | A            |

**Lab ID:** 26040009-14 **Client Sample ID:** 20420007014SF26A  
**Collection Date:** 4/1/2026 8:14:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007014SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 72.0   | *1   | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

**Lab ID:** 26040009-15 **Client Sample ID:** 20420007015SF26A  
**Collection Date:** 4/1/2026 8:15:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007015SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 14.0   | 1    | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-16      Client Sample ID: 20420007016SF26A  
Collection Date: 4/1/2026 8:15:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007016SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               |      | Analyst: CSB |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 2.19   |      | 0.515 | ppb   | 1  | 4/3/2026      | 15.0 | A            |

**Lab ID:** 26040009-17      Client Sample ID: 20420007017SF26A  
Collection Date: 4/1/2026 8:16:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007017SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               |      | Analyst: CSB |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 96.2   | *1   | 0.515 | ppb   | 1  | 4/3/2026      | 15.0 | A            |

**Lab ID:** 26040009-18      Client Sample ID: 20420007018BF26A  
Collection Date: 4/1/2026 8:17:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007018BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               |      | Analyst: CSB |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 1.14   |      | 0.515 | ppb   | 1  | 4/3/2026      | 15.0 | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-19 **Client Sample ID:** 20420007019SF26A  
**Collection Date:** 4/1/2026 8:18:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007019SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 6.79   |      | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

**Lab ID:** 26040009-20 **Client Sample ID:** 20420007021BF26A  
**Collection Date:** 4/1/2026 8:20:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007021BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 77.3   | *1   | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

**Lab ID:** 26040009-21 **Client Sample ID:** 20420007022BF26A  
**Collection Date:** 4/1/2026 8:21:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007022BF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; CSB |              |
|----------------------------------|--------|------|-------|-------|----|---------------|--------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL          | NELAP Status |
| Lead                             | 26.0   | *1   | 0.515 | ppb   | 1  | 4/3/2026      | 15.0         | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-22      Client Sample ID: 20420007023SF26A  
Collection Date: 4/1/2026 8:22:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007023SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst: PR |              |
|----------------------------------|--------|------|-------|-------|----|---------------|-------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL         | NELAP Status |
| Lead                             | 46.3   | *1   | 0.500 | ppb   | 1  | 4/8/2026      | 15.0        | A            |

**Lab ID:** 26040009-23      Client Sample ID: 20420007024SF26A  
Collection Date: 4/1/2026 8:26:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007024SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |      |       |     |               | Analyst: PR |              |
|----------------------------------|--------|------|------|-------|-----|---------------|-------------|--------------|
| Analyses                         | Result | Qual | MRL  | Units | DF  | Date Analyzed | MCL         | NELAP Status |
| Lead                             | 2570   | *1   | 50.0 | ppb   | 100 | 4/9/2026      | 15.0        | A            |

**Lab ID:** 26040009-24      Client Sample ID: 20420007025SF26A  
Collection Date: 4/1/2026 8:26:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007025SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |      |       |    |               | Analyst: PR |              |
|----------------------------------|--------|------|------|-------|----|---------------|-------------|--------------|
| Analyses                         | Result | Qual | MRL  | Units | DF | Date Analyzed | MCL         | NELAP Status |
| Lead                             | 472    | *1   | 5.00 | ppb   | 10 | 4/9/2026      | 15.0        | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-25      Client Sample ID: 20420007026SF26A  
Collection Date: 4/1/2026 8:27:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007026SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    | Analyst; PR   |      |              |
|----------------------------------|--------|------|-------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 59.4   | *1   | 0.500 | ppb   | 1  | 4/8/2026      | 15.0 | A            |

**Lab ID:** 26040009-26      Client Sample ID: 20420007027SF26A  
Collection Date: 4/1/2026 8:27:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007027SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |      |       |    | Analyst; PR   |      |              |
|----------------------------------|--------|------|------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL  | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 215    | *1   | 5.00 | ppb   | 10 | 4/9/2026      | 15.0 | A            |

**Lab ID:** 26040009-27      Client Sample ID: 20420007028SF26A  
Collection Date: 4/1/2026 8:29:00 AM      Collected By: Jeff Carr  
Matrix: Drinking Water      Sample Location: 20420007028SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |      |       |    | Analyst; PR   |      |              |
|----------------------------------|--------|------|------|-------|----|---------------|------|--------------|
| Analyses                         | Result | Qual | MRL  | Units | DF | Date Analyzed | MCL  | NELAP Status |
| Lead                             | 339    | *1   | 5.00 | ppb   | 10 | 4/9/2026      | 15.0 | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 26040009  
Date Reported: 4/10/2026

Central Point School Dist #6  
300 Ash St.  
Central Point, OR 97502

**Lab Order:** 26040009  
**Received Date:** 4/1/2026 10:32:00 AM  
**Reported Date:** 4/10/2026 3:06:44 PM

Sample Information:

**Lab ID:** 26040009-28 **Client Sample ID:** 20420007029SF26A  
**Collection Date:** 4/1/2026 8:29:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007029SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |      |       |    |               | Analyst; PR |              |
|----------------------------------|--------|------|------|-------|----|---------------|-------------|--------------|
| Analyses                         | Result | Qual | MRL  | Units | DF | Date Analyzed | MCL         | NELAP Status |
| Lead                             | 283    | *1   | 5.00 | ppb   | 10 | 4/9/2026      | 15.0        | A            |

**Lab ID:** 26040009-29 **Client Sample ID:** 20420007030SF26A  
**Collection Date:** 4/1/2026 8:30:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007030SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |       |       |    |               | Analyst; PR |              |
|----------------------------------|--------|------|-------|-------|----|---------------|-------------|--------------|
| Analyses                         | Result | Qual | MRL   | Units | DF | Date Analyzed | MCL         | NELAP Status |
| Lead                             | 155    | *1   | 0.500 | ppb   | 1  | 4/8/2026      | 15.0        | A            |

**Lab ID:** 26040009-30 **Client Sample ID:** 20420007031SF26A  
**Collection Date:** 4/1/2026 8:31:00 AM **Collected By:** Jeff Carr  
**Matrix:** Drinking Water **Sample Location:** 20420007031SF26A

| Trace Metals by EPA 200.8 ICP-MS |        |      |      |       |    |               | Analyst; PR |              |
|----------------------------------|--------|------|------|-------|----|---------------|-------------|--------------|
| Analyses                         | Result | Qual | MRL  | Units | DF | Date Analyzed | MCL         | NELAP Status |
| Lead                             | 974    | *1   | 5.00 | ppb   | 10 | 4/9/2026      | 15.0        | A            |

| QUALIFIERS | *  | Value exceeds Maximum or Minimum Contaminant Level.        | C1 | Sample container temperature is out of limit as specified at testcode |
|------------|----|------------------------------------------------------------|----|-----------------------------------------------------------------------|
|            | DF | Dilution Factor                                            | E  | Value above quantitation range                                        |
|            | H  | Holding times for preparation or analysis exceeded         | J  | Analyte detected below quantitation limits                            |
|            | MI | Recovery outside control limits due to Matrix Interference | ND | Not Detected at the Reporting Limit                                   |
|            | R  | RPD outside accepted recovery limits                       | RL | Reporting Limit                                                       |

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 26040009

10-Apr-26

**Client:** Central Point School Dist #6

**Project:** BOB Building Lead Testing

**TestCode:** LEAD\_SCHOOLS

|                            |                        |                            |                   |                                |                                                        |
|----------------------------|------------------------|----------------------------|-------------------|--------------------------------|--------------------------------------------------------|
| Sample ID: <b>MB-36295</b> | SampType: <b>MBLK</b>  | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/3/2026</b>     | RunNo: <b>68676</b>                                    |
| Client ID: <b>PBW</b>      | Batch ID: <b>36295</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/3/2026</b> | SeqNo: <b>1128558</b>                                  |
| Analyte                    | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |

Lead ND 0.515

|                             |                        |                            |                   |                                |                                                        |
|-----------------------------|------------------------|----------------------------|-------------------|--------------------------------|--------------------------------------------------------|
| Sample ID: <b>LCS-36295</b> | SampType: <b>LCS</b>   | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/3/2026</b>     | RunNo: <b>68676</b>                                    |
| Client ID: <b>LCSW</b>      | Batch ID: <b>36295</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/3/2026</b> | SeqNo: <b>1128559</b>                                  |
| Analyte                     | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |

Lead 100 0.520 100 0 100 85 115

|                                    |                        |                            |                   |                                |                                                        |
|------------------------------------|------------------------|----------------------------|-------------------|--------------------------------|--------------------------------------------------------|
| Sample ID: <b>26040009-01AMS</b>   | SampType: <b>MS</b>    | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/3/2026</b>     | RunNo: <b>68676</b>                                    |
| Client ID: <b>20420007001BF26A</b> | Batch ID: <b>36295</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/3/2026</b> | SeqNo: <b>1128561</b>                                  |
| Analyte                            | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |

Lead 98.6 0.520 100 1.14 97.5 70 130

|                                    |                        |                            |                   |                                |                                                        |
|------------------------------------|------------------------|----------------------------|-------------------|--------------------------------|--------------------------------------------------------|
| Sample ID: <b>26040009-01AMSD</b>  | SampType: <b>MSD</b>   | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/3/2026</b>     | RunNo: <b>68676</b>                                    |
| Client ID: <b>20420007001BF26A</b> | Batch ID: <b>36295</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/3/2026</b> | SeqNo: <b>1128562</b>                                  |
| Analyte                            | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |

Lead 97.5 0.520 100 1.14 96.4 70 130 98.6 1.11 20

**Qualifiers:**  
\* Value exceeds Maximum or Minimum Contaminant Level.  
E Value above quantitation range  
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode  
H Holding times for preparation or analysis exceeded  
RL Reporting Limit

DF Dilution Factor  
MI Recovery outside control limits due to Matrix Int

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 26040009

10-Apr-26

**Client:** Central Point School Dist #6

**Project:** BOB Building Lead Testing

**TestCode:** LEAD\_SCHOOLS

|                            |                        |                            |                   |                                |                                                        |
|----------------------------|------------------------|----------------------------|-------------------|--------------------------------|--------------------------------------------------------|
| Sample ID: <b>MB-36296</b> | SampType: <b>MBLK</b>  | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/3/2026</b>     | RunNo: <b>68676</b>                                    |
| Client ID: <b>PBW</b>      | Batch ID: <b>36296</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/3/2026</b> | SeqNo: <b>1128587</b>                                  |
| Analyte                    | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |

Lead ND 0.515

|                             |                        |                            |                   |                                |                                                        |
|-----------------------------|------------------------|----------------------------|-------------------|--------------------------------|--------------------------------------------------------|
| Sample ID: <b>LCS-36296</b> | SampType: <b>LCS</b>   | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/3/2026</b>     | RunNo: <b>68676</b>                                    |
| Client ID: <b>LCSW</b>      | Batch ID: <b>36296</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/3/2026</b> | SeqNo: <b>1128589</b>                                  |
| Analyte                     | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |

Lead 99.3 0.520 100 0 99.3 85 115

|                                    |                        |                            |                   |                                |                                                        |
|------------------------------------|------------------------|----------------------------|-------------------|--------------------------------|--------------------------------------------------------|
| Sample ID: <b>26040009-06AMS</b>   | SampType: <b>MS</b>    | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/3/2026</b>     | RunNo: <b>68676</b>                                    |
| Client ID: <b>20420007006SF26A</b> | Batch ID: <b>36296</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/3/2026</b> | SeqNo: <b>1128591</b>                                  |
| Analyte                            | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |

Lead 99.8 0.520 100 3.36 96.5 70 130

|                                    |                        |                            |                   |                                |                                                        |
|------------------------------------|------------------------|----------------------------|-------------------|--------------------------------|--------------------------------------------------------|
| Sample ID: <b>26040009-06AMSD</b>  | SampType: <b>MSD</b>   | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/3/2026</b>     | RunNo: <b>68676</b>                                    |
| Client ID: <b>20420007006SF26A</b> | Batch ID: <b>36296</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/3/2026</b> | SeqNo: <b>1128592</b>                                  |
| Analyte                            | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual |

Lead 98.8 0.520 100 3.36 95.4 70 130 99.8 1.06 20

**Qualifiers:**  
\* Value exceeds Maximum or Minimum Contaminant Level.  
E Value above quantitation range  
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode  
H Holding times for preparation or analysis exceeded  
RL Reporting Limit

DF Dilution Factor  
MI Recovery outside control limits due to Matrix Int

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 26040009

10-Apr-26

**Client:** Central Point School Dist #6

**Project:** BOB Building Lead Testing

**TestCode:** LEAD\_SCHOOLS

|                            |                        |                       |                            |             |                   |                                |           |             |      |                       |      |  |
|----------------------------|------------------------|-----------------------|----------------------------|-------------|-------------------|--------------------------------|-----------|-------------|------|-----------------------|------|--|
| Sample ID: <b>MB-36339</b> |                        | SampType: <b>MBLK</b> | TestCode: <b>LEAD_SCHO</b> |             | Units: <b>ppb</b> | Prep Date: <b>4/8/2026</b>     |           |             |      | RunNo: <b>68797</b>   |      |  |
| Client ID: <b>PBW</b>      | Batch ID: <b>36339</b> |                       | TestNo: <b>E200.8</b>      |             | <b>E200.8</b>     | Analysis Date: <b>4/8/2026</b> |           |             |      | SeqNo: <b>1130325</b> |      |  |
| Analyte                    | Result                 | PQL                   | SPK value                  | SPK Ref Val | %REC              | LowLimit                       | HighLimit | RPD Ref Val | %RPD | RPDLimit              | Qual |  |

|      |    |       |  |  |  |  |  |  |  |  |  |
|------|----|-------|--|--|--|--|--|--|--|--|--|
| Lead | ND | 0.500 |  |  |  |  |  |  |  |  |  |
|------|----|-------|--|--|--|--|--|--|--|--|--|

|                             |                        |                            |                   |                                |                       |          |           |             |      |          |      |
|-----------------------------|------------------------|----------------------------|-------------------|--------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: <b>LCS-36339</b> | SampType: <b>LCS</b>   | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/8/2026</b>     | RunNo: <b>68797</b>   |          |           |             |      |          |      |
| Client ID: <b>LCSW</b>      | Batch ID: <b>36339</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/8/2026</b> | SeqNo: <b>1130326</b> |          |           |             |      |          |      |
| Analyte                     | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC                  | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

|      |      |       |     |   |      |    |     |  |  |  |  |
|------|------|-------|-----|---|------|----|-----|--|--|--|--|
| Lead | 99.1 | 0.500 | 100 | 0 | 99.1 | 85 | 115 |  |  |  |  |
|------|------|-------|-----|---|------|----|-----|--|--|--|--|

|                                    |                        |                            |                   |                                |                       |          |           |             |      |          |      |
|------------------------------------|------------------------|----------------------------|-------------------|--------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: <b>26040009-10AMS</b>   | SampType: <b>MS</b>    | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/8/2026</b>     | RunNo: <b>68814</b>   |          |           |             |      |          |      |
| Client ID: <b>20420007010SF26A</b> | Batch ID: <b>36339</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/9/2026</b> | SeqNo: <b>1130725</b> |          |           |             |      |          |      |
| Analyte                            | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC                  | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

|      |      |      |     |      |     |    |     |  |  |  |    |
|------|------|------|-----|------|-----|----|-----|--|--|--|----|
| Lead | 1340 | 10.0 | 100 | 1210 | 132 | 70 | 130 |  |  |  | R3 |
|------|------|------|-----|------|-----|----|-----|--|--|--|----|

|                                    |                        |                            |                   |                                |                       |          |           |             |      |          |      |
|------------------------------------|------------------------|----------------------------|-------------------|--------------------------------|-----------------------|----------|-----------|-------------|------|----------|------|
| Sample ID: <b>26040009-10AMSD</b>  | SampType: <b>MSD</b>   | TestCode: <b>LEAD_SCHO</b> | Units: <b>ppb</b> | Prep Date: <b>4/8/2026</b>     | RunNo: <b>68814</b>   |          |           |             |      |          |      |
| Client ID: <b>20420007010SF26A</b> | Batch ID: <b>36339</b> | TestNo: <b>E200.8</b>      | <b>E200.8</b>     | Analysis Date: <b>4/9/2026</b> | SeqNo: <b>1130726</b> |          |           |             |      |          |      |
| Analyte                            | Result                 | PQL                        | SPK value         | SPK Ref Val                    | %REC                  | LowLimit | HighLimit | RPD Ref Val | %RPD | RPDLimit | Qual |

|      |      |      |     |      |     |    |     |      |       |    |    |
|------|------|------|-----|------|-----|----|-----|------|-------|----|----|
| Lead | 1350 | 10.0 | 100 | 1210 | 138 | 70 | 130 | 1340 | 0.426 | 20 | R3 |
|------|------|------|-----|------|-----|----|-----|------|-------|----|----|

**Qualifiers:**

- \* Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- ND Not Detected at the Reporting Limit

- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

- DF Dilution Factor
- MI Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 26040009

RcptNo: 1

Logged by: Ashley Spiegelberg 4/1/2026 10:32:00 AM

Completed By: Ashley Spiegelberg 4/3/2026 10:43:45 AM

Reviewed By: Dorie Evans 4/10/2026 2:52:46 PM

*Am*  
*Am*  
*Dorie*

### Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐  
2. How was the sample delivered? Client

### Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒  
4. Shipping container/cooler in good condition? Yes ☒ No ☐  
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐  
No. Seal Date: Signed By:  
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒  
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒  
7. Sample(s) in proper container(s)? Yes ☒ No ☐  
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐  
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐  
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐  
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2  
No VOA Vials ☒  
12. Were any sample containers received broken? Yes ☐ No ☒  
13. Does paperwork match bottle labels? Yes ☒ No ☐  
(Note discrepancies on chain of custody)  
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐  
15. Is it clear what analyses were requested? Yes ☒ No ☐  
16. Were all holding times able to be met? Yes ☒ No ☐  
(If no, notify customer for authorization.)

### Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified:  Date:   
By Whom:  Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person  
Regarding:   
Client Instructions:

18. Additional remarks:

### Cooler Information

| Cooler No | Temp °C | Condition | Seal Intact | Seal No | Seal Date | Signed By |
|-----------|---------|-----------|-------------|---------|-----------|-----------|
|-----------|---------|-----------|-------------|---------|-----------|-----------|







- 
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
  - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
  - B Analyte detected in the associated method blank.
  - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
  - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
  - CF Results confirmed by re-analysis.
  - CU Cleanup performed as specified by method.
  - E Estimated value.
  - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
  - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
  - HP Sample re-analysis performed outside of method specified holding time.
  - HR Sample received outside of method specified holding time.
  - HS Sample analyzed for volatile organics contained headspace.
  - HT At the client's request, the sample was analyzed outside of method specified holding time.
  - H Analysis performed outside of method specified holding time.
  - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
  - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
  - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
  - N See Case Narrative on page 2 of report.
  - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
  - R Relative percent difference (RPD) is outside of the accepted recovery limits.
  - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
  - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
  - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
  - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
  - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
  - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
  - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
  - SC Sub-contracted to another laboratory for analysis.
  - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
  - \* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
  - 1 Value exceeds one half of the Maximum Contaminant Level.