

Lead in Water Test Results Summary: Hanby Middle School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
MAIN BUILDING							
RM M1B Sink	20420600001CF25A	5/18/2025	ND	Non-Detect			
Boys Bathroom Left Sink	20420600002BF25A	5/18/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420600003BF25A	5/18/2025	ND	Non-Detect			
La Clinica Bathroom Sink	20420600004BF25A	5/18/2025	4.39	Low			
La Clinica North Exam Room Sink	20420600005NS25A	5/18/2025	ND	Non-Detect			
La Clinica South Exam Room Sink	20420600006NS25A	5/18/2025	1.81	Low			
Hallway Right Drinking Fountain	20420600007DW25A	5/18/2025	ND	Non-Detect			
Hallway Bottle Fill	20420600008WB25A	5/18/2025	ND	Non-Detect			
Hallway Left Drinking Fountain	20420600009DW25A	5/18/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420600010BF25A	5/18/2025	4.57	Low			
Girls Bathroom Right Sink	20420600011BF25A	5/18/2025	ND	Non-Detect			
RM M2 Sink	20420600012CF25A	5/18/2025	1.39	Low			
SECOND FLOOR							
RM MB2 Breakroom Sink	20420600013SF25A	5/18/2025	ND	Non-Detect			
Hallway North Bathroom Sink	20420600014BF25A	5/18/2025	ND	Non-Detect			
Hallway South Bathroom Sink	20420600015BF25A	5/18/2025	ND	Non-Detect			
Hallway Right Drinking Fountain	20420600016DW25A	5/18/2025	ND	Non-Detect			
Hallway Bottle Fill	20420600017WB25A	5/18/2025	ND	Non-Detect			
Hallway Left Drinking Fountain	20420600018DW25A	5/18/2025	ND	Non-Detect			
THIRD FLOOR							
RM M3 Sink	20420600019CF25A	5/18/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420600020BF25A	5/18/2025	ND	Non-Detect			
Girls Bathroom Right Sink	20420600021BF25A	5/18/2025	ND	Non-Detect			
Boys Bathroom Left Sink	20420600022BF25A	5/18/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420600023BF25A	5/18/2025	ND	Non-Detect			
Hallway Left Drinking Fountain	20420600024DW25A	5/18/2025	ND	Non-Detect			
Hallway Bottle Fill	20420600025WB25A	5/18/2025	ND	Non-Detect			
Hallway Right Drinking Fountain	20420600026DW25A	5/18/2025	ND	Non-Detect			
RM M4 Drinking Fountain	20420600027CF25A	5/18/2025	1.95	Low			
RM M5 Drinking Fountain	20420600028CF25A	5/18/2025	ND	Non-Detect			
GYMNASIUM							
Boys Canyon Bathroom	20420601001BF25A	5/18/2025	ND	Non-Detect			
Girls Canyon Bathroom Left Sink	20420601002BF25A	5/18/2025	ND	Non-Detect			
Girls Canyon Bathroom Right Sink	20420601003BF25A	5/18/2025	ND	Non-Detect			
RMG11 North Wall Right Sink	20420601004CF25A	5/18/2025	0.719	Low			
RMG11 North Wall Middle Sink	20420601005CF25A	5/18/2025	0.626	Low			
RMG11 North Wall Left Sink	20420601006CF25A	5/18/2025	1.32	Low			
RMG11 West Wall Right Sink	20420601007CF25A	5/18/2025	1.41	Low			
RMG11 West Wall Middle Sink	20420601008CF25A	5/18/2025	0.678	Low			
RMG11 West Wall Left Sink	20420601009CF25A	5/18/2025	ND	Non-Detect			
MAIN FLOOR							

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Right Single Use Bathroom Sink	20420601010BF25A	5/18/2025	ND	Non-Detect			
Left Single Use Bathroom Sink	20420601011BF25A	5/18/2025	0.629	Low			
Girls Locker Room Left Sink	20420601012BF25A	5/18/2025	7.88	Moderate			
Girls Locker Room Middle Sink	20420601013BF25A	5/18/2025	ND	Non-Detect			
Girls Locker Room Right Sink	20420601014BF25A	5/18/2025	ND	Non-Detect			
West Wall Drinking Fountain	20420601015DW25A	5/18/2025	ND	Non-Detect			
Boys Locker Room Left Sink	20420601016BF25A	5/18/2025	6.22	Moderate			
Boys Locker Room 2nd Toilet Sink	20420601017BF25A	5/18/2025	14	High			
Boys Locker Room 2nd to Right Sink	20420601018BF25A	5/18/2025	0.987	Low			
Boys Locker Room Right Sink	20420601019BF25A	5/18/2025	7.24	Moderate			
<u>2003 BUILDING - FIRST FLOOR</u>							
Music Room Sink	20420602001CF25A	5/18/2025	ND	Non-Detect			
Music Room Drinking Fountain	20420602002DW25A	5/18/2025	ND	Non-Detect			
Kitchen Kettle Fill	20420602003KF25B	5/18/2025	80.4	Action Req.	10/29/2025	11	High
Kitchen Well Fill	20420602004KF25B	5/18/2025	53.8	Action Req.	10/29/2025	8.18	Moderate
Kitchen Prep Sink	20420602005KF25A	5/18/2025	ND	Non-Detect			
Kitchen Handwash Sink	20420602006KF25A	5/18/2025	0.75	Low			
Dish Room Pot Sink Left	20420602007KF25A	5/18/2025	1.29	Low			
Dish Room Pot Sink Right	20420602008KF25A	5/18/2025	1.32	Low			
Dish Room Sprayer North Wall	20420602009KF25A	5/18/2025	4.29	Low			
First Floor Right Drinking Fountain	20420602010DW25A		Out of Serve	-			
First Floor Left Drinking Fountain	20420602011DW25A	5/18/2025	ND	Non-Detect			
First Floor Womens Staff Bathroom Sink	20420602012BF25A	5/18/2025	12.1	High			
First Floor Mens Staff Bathroom Sink	20420602013BF25A	5/18/2025	6.46	Moderate			
Breakroom Sink	20420602014SF25A	5/18/2025	0.581	Low			
RMN11 Drinking Fountain	20420602015DW25A	5/18/2025	ND	Non-Detect			
RMN11 Classroom Sink	20420602016CF25A	5/18/2025	2.17	Low			
RMN12 Classroom Sink	20420602017CF25B	5/18/2025	98.7	Action Req.	10/29/2025	0.59	Low
RMN12 Drinking Fountain	20420602018DW25A	5/18/2025	ND	Non-Detect			
RMN13 Classroom Sink	20420602019CF25A	5/18/2025	1.52	Low			
RMN13 Drinking Fountain	20420602020DW25A	5/18/2025	ND	Non-Detect			
RMN14 Classroom Sink	20420602021CF25A	5/18/2025	10.8	High			
RMN14 Drinking Fountain	20420602022DW25A	5/18/2025	ND	Non-Detect			
<u>2003 BUILDING SECOND FLOOR</u>							
RMN24 Drinking Fountain	20420602023DW25A	5/18/2025	ND	Non-Detect			
RMN24 Classroom Sink	20420602024CF25A	5/18/2025	4.09	Low			
RMN23 Drinking Fountain	20420602025DW25A	5/18/2025	ND	Non-Detect			
RMN23 Classroom Sink	20420602026CF25A	5/18/2025	6.35	Moderate			
RMN22 Classroom Sink	20420602027CF25A	5/18/2025	5.99	Moderate			
RMN22 Drinking Fountain	20420602028DW25A	5/18/2025	ND	Non-Detect			
RMN21 Classroom Sink	20420602029CF25A	5/18/2025	1.45	Low			
RMN21 Drinking Fountain	20420602030DW25A	5/18/2025	ND	Non-Detect			
Girls Bathroom Right Sink	20420602031BF25B	5/18/2025	19.1	Action Req.	10/29/2025	ND	Non-Detect
Girls Bathroom Left Sink	20420602032BF25A	5/18/2025	1.16	Low			
Boys Bathroom Right Sink	20420602033BF25A	5/18/2025	0.915	Low			
Boys Bathroom Left Sink	20420602034BF25A	5/18/2025	1.14	Low			
Sink by Kettle	20420602035KF25A						
Dish Room Sprayer East Wall	20420602036KF25A						
<u>HANBY PORTABLES</u>							
RMP11 Bathroom Sink	20420603001BF25A	5/18/2025	0.804	Low			
RMP12 Sink in Closet	20420603002CF25A	5/18/2025	6.68	Moderate			
RMP13 Sink in Closet	20420604001CF25B	5/18/2025	67	Action Req.	10/29/2025	1.83	Low
RMP14 Bathroom Sink	20420604002BF25A	5/18/2025	8.14	Moderate			
RM21 Classroom Sink	20420605001CF25A	5/18/2025	ND	Non-Detect			
RM21 Drinking Fountain	20420605002DW25A	5/18/2025	ND	Non-Detect			
RM22 Bathroom Sink	20420605003BF25A	5/18/2025	14.6	High			
RM22 Drinking Fountain	20420605004DW25A	5/18/2025	0.589	Low			
RM22 Classroom Sink	20420605005CF25A	5/18/2025	1.31	Low			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
FIELDHOUSE							
Girls Bathroom Right Sink	20420606001BF25A	5/18/2025	3.01	Low			
Girls Bathroom Left Sink	20420606002BF25A	5/18/2025	3.33	Low			
Boys Bathroom Sink	20420606003BF25A	5/18/2025	0.662	Low			
Custodian Sink Boys Bathroom	20420606004OT25A	5/18/2025	2.87	Low			
Concession Sink	20420606005KF25A	5/18/2025	5.72	Moderate			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

May 19, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Hanby Lead Testing-AMENDED

Order No.: 25050379

Dear Dale Giovannetti:

Neilson Research Corporation received 94 sample(s) on 5/8/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050379
Date: 5/19/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-01 **Client Sample ID:** 20420601001BF25A
Collection Date: 5/8/2025 5:07:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601001BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/15/2025	15.0	A

Lab ID: 25050379-02 **Client Sample ID:** 20420601002BF25A
Collection Date: 5/8/2025 5:10:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601002BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/15/2025	15.0	A

Lab ID: 25050379-03 **Client Sample ID:** 20420601003BF25A
Collection Date: 5/8/2025 5:11:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601003BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-04 **Client Sample ID:** 20420601004CF25A
Collection Date: 5/8/2025 5:19:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601004CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.719		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-05 **Client Sample ID:** 20420601005CF25A
Collection Date: 5/8/2025 5:20:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601005CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.626		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-06 **Client Sample ID:** 20420601006CF25A
Collection Date: 5/8/2025 5:21:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601006CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.32		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-07 **Client Sample ID:** 20420601007CF25A
Collection Date: 5/8/2025 5:23:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601007CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.41		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-08 **Client Sample ID:** 20420601008CF25A
Collection Date: 5/8/2025 5:24:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601008CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.678		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-09 **Client Sample ID:** 20420601009CF25A
Collection Date: 5/8/2025 5:25:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601009CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.347	J	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-10 Client Sample ID: 20420601010BF25A
Collection Date: 5/8/2025 5:35:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420601010BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.126	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-11 Client Sample ID: 20420601011BF25A
Collection Date: 5/8/2025 5:36:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420601011BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.629		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-12 Client Sample ID: 20420601012BF25A
Collection Date: 5/8/2025 4:48:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420601012BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.88	1	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-13 Client Sample ID: 20420601013BF25A
Collection Date: 5/8/2025 4:49:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420601013BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.180	J	0.515	ppb	1	5/16/2025	15.0	A	

Lab ID: 25050379-14 Client Sample ID: 20420601014BF25A
Collection Date: 5/8/2025 4:50:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420601014BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.440	J	0.515	ppb	1	5/16/2025	15.0	A	

Lab ID: 25050379-15 Client Sample ID: 20420601015DW25A
Collection Date: 5/8/2025 4:54:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420601015DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.115	J	0.515	ppb	1	5/16/2025	15.0	A	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-16 **Client Sample ID:** 20420601016BF25A
Collection Date: 5/8/2025 4:56:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601016BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.22		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-17 **Client Sample ID:** 20420601017BF25A
Collection Date: 5/8/2025 4:57:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601017BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	14.0	1	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-18 **Client Sample ID:** 20420601018BF25A
Collection Date: 5/8/2025 4:58:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420601018BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.987		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-19 Client Sample ID: 20420601019BF25A
Collection Date: 5/8/2025 4:59:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420601019BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.24		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-20 Client Sample ID: 20420700007DW25A
Collection Date: 5/8/2025 5:53:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420700007DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-21 Client Sample ID: 20420700006NS25A
Collection Date: 5/8/2025 5:49:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420700006NS25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.81		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-22 Client Sample ID: 20420700005NS25A
Collection Date: 5/8/2025 5:48:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420700005NS25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.212	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-23 Client Sample ID: 20420700004BF25A
Collection Date: 5/8/2025 5:47:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420700004BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.39		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-24 Client Sample ID: 20420700003BF25A
Collection Date: 5/8/2025 5:45:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420700003BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.123	J	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-25 Client Sample ID: 20420700002BF25A
Collection Date: 5/8/2025 5:44:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420700002BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.172	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-26 Client Sample ID: 20420700001CF25A
Collection Date: 5/8/2025 5:42:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420700001CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.229	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-27 Client Sample ID: 20420700008WB25A
Collection Date: 5/8/2025 5:54:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420700008WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-28 **Client Sample ID:** 20420700009DW25A
Collection Date: 5/8/2025 5:55:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700009DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-29 **Client Sample ID:** 20420700010BF25A
Collection Date: 5/8/2025 5:56:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700010BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.57		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-30 **Client Sample ID:** 20420700011BF25A
Collection Date: 5/8/2025 5:59:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700011BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.271	J	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-31 **Client Sample ID:** 20420700012CF25A
Collection Date: 5/8/2025 6:00:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700012CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.39		0.500	ppb	1	5/19/2025	15.0	A

Lab ID: 25050379-32 **Client Sample ID:** 20420700013SF25A
Collection Date: 5/8/2025 6:04:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700013SF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.319	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-33 **Client Sample ID:** 20420700014BF25A
Collection Date: 5/8/2025 6:05:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700014BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-34 **Client Sample ID:** 20420700015BF25A
Collection Date: 5/8/2025 6:06:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700015BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.330	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-35 **Client Sample ID:** 20420700016DW25A
Collection Date: 5/8/2025 6:08:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700016DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-36 **Client Sample ID:** 20420700017WB25A
Collection Date: 5/8/2025 6:09:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700017WB25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-37 **Client Sample ID:** 20420700018DW25A
Collection Date: 5/8/2025 6:10:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700018DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-38 **Client Sample ID:** 20420700019CF25A
Collection Date: 5/8/2025 6:10:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700019CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.422	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-39 **Client Sample ID:** 20420700020BF25A
Collection Date: 5/8/2025 6:11:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700020BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.142	J	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-40 **Client Sample ID:** 20420700021BF25A
Collection Date: 5/8/2025 6:12:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700021BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.177	J	0.515	ppb	1	5/16/2025	15.0	A	

Lab ID: 25050379-41 **Client Sample ID:** 20420700022BF25A
Collection Date: 5/8/2025 6:12:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700022BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0649	J	0.515	ppb	1	5/16/2025	15.0	A	

Lab ID: 25050379-42 **Client Sample ID:** 20420700023BF25A
Collection Date: 5/8/2025 6:11:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700023BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0814	J	0.515	ppb	1	5/16/2025	15.0	A	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-43 **Client Sample ID:** 20420700024DW25A
Collection Date: 5/8/2025 6:07:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700024DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-44 **Client Sample ID:** 20420700025WB25A
Collection Date: 5/8/2025 6:06:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700025WB25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-45 **Client Sample ID:** 20420700026DW25A
Collection Date: 5/8/2025 6:05:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700026DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-46 **Client Sample ID:** 20420700027CF25A
Collection Date: 5/8/2025 6:03:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700027CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.95		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-47 **Client Sample ID:** 20420700028CF25A
Collection Date: 5/8/2025 6:03:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420700028CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.351	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-48 **Client Sample ID:** 20420604001CF25A
Collection Date: 5/8/2025 5:41:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420604001CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	67.0	*1	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-49 **Client Sample ID:** 20420604002BF25A
Collection Date: 5/8/2025 5:42:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420604002BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.14	1	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-50 **Client Sample ID:** 20420605001CF25A
Collection Date: 5/8/2025 5:47:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420605001CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.388	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-51 **Client Sample ID:** 20420605002DW25A
Collection Date: 5/8/2025 5:43:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420605002DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.195	J	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-52 Client Sample ID: 20420605003BF25A
Collection Date: 5/8/2025 5:49:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420605003BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	14.6	1	0.515	ppb	1	5/16/2025	15.0	A	

Lab ID: 25050379-53 Client Sample ID: 20420605004DW25A
Collection Date: 5/8/2025 5:50:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420605004DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.589		0.515	ppb	1	5/16/2025	15.0	A	

Lab ID: 25050379-54 Client Sample ID: 20420605005CF25A
Collection Date: 5/8/2025 5:50:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420605005CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.31		0.515	ppb	1	5/16/2025	15.0	A	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-55 Client Sample ID: 20420602032BF25A
Collection Date: 5/8/2025 5:30:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602032BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.16		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-56 Client Sample ID: 20420602033BF25A
Collection Date: 5/8/2025 5:28:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602033BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.915		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-57 Client Sample ID: 20420602034BF25A
Collection Date: 5/8/2025 5:29:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602034BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.14		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-58 Client Sample ID: 20420606001BF25A
Collection Date: 5/8/2025 6:27:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420606001BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.33		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-59 Client Sample ID: 20420606002BF25A
Collection Date: 5/8/2025 6:28:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420606002BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.72		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-60 Client Sample ID: 20420606003BF25A
Collection Date: 5/8/2025 6:28:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420606003BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.662		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-61 **Client Sample ID:** 20420606004OT25A
Collection Date: 5/8/2025 6:29:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420606004OT25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.87		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-62 **Client Sample ID:** 20420606005KF25A
Collection Date: 5/8/2025 6:30:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420606005KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.01		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-63 **Client Sample ID:** 20420603001BF25A
Collection Date: 5/8/2025 5:37:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420603001BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.804		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-64 **Client Sample ID:** 20420603002CF25A
Collection Date: 5/8/2025 5:39:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420603002CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.68		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-65 **Client Sample ID:** 20420602022DW25A
Collection Date: 5/8/2025 5:16:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602022DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.299	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-66 **Client Sample ID:** 20420602023DW25A
Collection Date: 5/8/2025 5:19:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602023DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.511	J	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-67 **Client Sample ID:** 20420602024CF25A
Collection Date: 5/8/2025 5:18:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602024CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.09		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-68 **Client Sample ID:** 20420602025DW25A
Collection Date: 5/8/2025 5:22:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602025DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.288	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-69 **Client Sample ID:** 20420602026CF25A
Collection Date: 5/8/2025 5:22:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602026CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.35		0.500	ppb	1	5/19/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-70 Client Sample ID: 20420602027CF25A
Collection Date: 5/8/2025 5:24:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602027CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.99		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-71 Client Sample ID: 20420602028DW25A
Collection Date: 5/8/2025 5:25:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602028DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.246	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-72 Client Sample ID: 20420602029CF25A
Collection Date: 5/8/2025 5:26:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602029CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.45		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-73 **Client Sample ID:** 20420602030DW25A
Collection Date: 5/8/2025 5:27:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602030DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.407	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-74 **Client Sample ID:** 20420602031BF25A
Collection Date: 5/8/2025 5:31:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602031BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	19.1	*1	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-75 **Client Sample ID:** 20420602012BF25A
Collection Date: 5/8/2025 5:01:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602012BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	12.1	1	0.500	ppb	1	5/19/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-76 **Client Sample ID:** 20420602013BF25A
Collection Date: 5/8/2025 5:03:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602013BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.46		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-77 **Client Sample ID:** 20420602014SF25A
Collection Date: 5/8/2025 5:05:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602014SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.581		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-78 **Client Sample ID:** 20420602015DW25A
Collection Date: 5/8/2025 5:07:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602015DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.386	J	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-79 Client Sample ID: 20420602016CF25A
Collection Date: 5/8/2025 5:08:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602016CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.17		0.500	ppb	1	5/19/2025	15.0	A

Lab ID: 25050379-80 Client Sample ID: 20420602017CF25A
Collection Date: 5/8/2025 5:10:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602017CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	98.7	*1	0.500	ppb	1	5/19/2025	15.0	A

Lab ID: 25050379-81 Client Sample ID: 20420602018DW25A
Collection Date: 5/8/2025 5:11:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602018DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.317	J	0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-82 Client Sample ID: 20420602019CF25A
Collection Date: 5/8/2025 5:12:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602019CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.52		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-83 Client Sample ID: 20420602020DW25A
Collection Date: 5/8/2025 5:14:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602020DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.477	J	0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-84 Client Sample ID: 20420602021CF25A
Collection Date: 5/8/2025 5:15:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602021CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.8	1	0.500	ppb	1	5/19/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-85 Client Sample ID: 20420602001CF25A
Collection Date: 5/8/2025 4:56:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602001CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.484	J	0.500	ppb	1	5/19/2025	15.0	A	

Lab ID: 25050379-86 Client Sample ID: 20420602002DW25A
Collection Date: 5/8/2025 4:57:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602002DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.131	J	0.500	ppb	1	5/19/2025	15.0	A	

Lab ID: 25050379-87 Client Sample ID: 20420602003KF25A
Collection Date: 5/8/2025 5:47:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602003KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	80.4	*1	0.500	ppb	1	5/19/2025	15.0	A	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379

Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-88 **Client Sample ID:** 20420602004KF25A
Collection Date: 5/8/2025 4:45:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602004KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	53.8	*1	0.500	ppb	1	5/19/2025	15.0	A

Lab ID: 25050379-89 **Client Sample ID:** 20420602005KF25A
Collection Date: 5/8/2025 4:50:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602005KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.470	J	0.500	ppb	1	5/19/2025	15.0	A

Lab ID: 25050379-90 **Client Sample ID:** 20420602006KF25A
Collection Date: 5/8/2025 4:51:00 AM **Collected By:** Mark Lillich/Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420602006KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.750		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-91 Client Sample ID: 20420602007KF25A
Collection Date: 5/8/2025 4:52:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602007KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.29		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-92 Client Sample ID: 20420602008KF25A
Collection Date: 5/8/2025 4:53:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602008KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.32		0.515	ppb	1	5/16/2025	15.0	A

Lab ID: 25050379-93 Client Sample ID: 20420602009KF25A
Collection Date: 5/8/2025 4:54:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602009KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.29		0.515	ppb	1	5/16/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050379
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050379
Received Date: 5/8/2025 10:07:00 AM
Reported Date: 5/19/2025 5:31:57 PM

Sample Information:

Lab ID: 25050379-94 Client Sample ID: 20420602011DW25A
Collection Date: 5/8/2025 5:00:00 AM Collected By: Mark Lillich/Jeff Carr
Matrix: Drinking Water Sample Location: 20420602011DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.231	J	0.515	ppb	1	5/16/2025	15.0	A	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050379
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25050320-20AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: BatchQC	Batch ID: 31293	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972356						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	87.4	0.500	100	0.195	87.2	70	130	92.1	5.20	20	
------	------	-------	-----	-------	------	----	-----	------	------	----	--

Sample ID: MB-31293	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: PBW	Batch ID: 31293	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972567						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31293	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: LCSW	Batch ID: 31293	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972568						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.8	0.500	100	0	95.8	85	115				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 25050320-20AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/15/2025	RunNo: 59506						
Client ID: BatchQC	Batch ID: 31293	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972570						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	92.1	0.500	100	0.195	91.9	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
ND	Not Detected at the Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
J	Analyte detected below quantitation limits
RL	Reporting Limit

DF	Dilution Factor
MI	Recovery outside control limits due to Matrix In

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050379
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31313	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544
Client ID: PBW	Batch ID: 31313	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973135
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-31313	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544
Client ID: LCSW	Batch ID: 31313	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973136
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.500 100 0 103 85 115

Sample ID: 25050686-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544
Client ID: BatchQC	Batch ID: 31313	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973138
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.500 100 0 102 70 130

Sample ID: 25050686-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544
Client ID: BatchQC	Batch ID: 31313	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973139
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.500 100 0 102 70 130 102 0.157 20

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
J Analyte detected below quantitation limits
RL Reporting Limit

DF Dilution Factor
MI Recovery outside control limits due to Matrix In

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050379
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31316	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: PBW	Batch ID: 31316	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973244						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: MB-31316	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: PBW	Batch ID: 31316	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973245						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.515

Sample ID: LCS-31316	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: LCSW	Batch ID: 31316	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973246						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 103 0.520 100 0 103 85 115

Sample ID: 25050379-45AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: 20420700026DW25A	Batch ID: 31316	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973248						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.520 100 0 101 70 130

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
J Analyte detected below quantitation limits
RL Reporting Limit

DF Dilution Factor
MI Recovery outside control limits due to Matrix In

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050379
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25050379-45AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: 20420700026DW25A	Batch ID: 31316	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973249						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.520	100	0	103	70	130	101	1.68	20
------	-----	-------	-----	---	-----	----	-----	-----	------	----

Sample ID: MB-31317	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: PBW	Batch ID: 31317	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973273						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515
------	----	-------

Sample ID: LCS-31317	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: LCSW	Batch ID: 31317	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973274						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.520	100	0	100	85	115
------	-----	-------	-----	---	-----	----	-----

Sample ID: 25050379-65AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: 20420602022DW25A	Batch ID: 31317	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973276						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.520	100	0.299	99.8	70	130
------	-----	-------	-----	-------	------	----	-----

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
ND	Not Detected at the Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
J	Analyte detected below quantitation limits
RL	Reporting Limit

DF	Dilution Factor
MI	Recovery outside control limits due to Matrix In

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050379
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25050379-65AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59549						
Client ID: 20420602022DW25A	Batch ID: 31317	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973277						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.520	100	0.299	101	70	130	100	1.55	20
------	-----	-------	-----	-------	-----	----	-----	-----	------	----

Sample ID: MB-31314	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: PBW	Batch ID: 31314	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973303						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515
------	----	-------

Sample ID: LCS-31314	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: LCSW	Batch ID: 31314	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973304						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.9	0.520	100	0	99.9	85	115
------	------	-------	-----	---	------	----	-----

Sample ID: 25050379-04AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: 20420601004CF25A	Batch ID: 31314	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973306						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.520	100	0.719	102	70	130
------	-----	-------	-----	-------	-----	----	-----

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
ND	Not Detected at the Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
J	Analyte detected below quantitation limits
RL	Reporting Limit

DF	Dilution Factor
MI	Recovery outside control limits due to Matrix In

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050379
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25050379-04AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: 20420601004CF25A	Batch ID: 31314	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973307						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.520	100	0.719	99.3	70	130	103	2.98	20
------	-----	-------	-----	-------	------	----	-----	-----	------	----

Sample ID: MB-31315	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: PBW	Batch ID: 31315	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973331						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515
------	----	-------

Sample ID: MB-31315	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: PBW	Batch ID: 31315	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973332						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515
------	----	-------

Sample ID: LCS-31315	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: LCSW	Batch ID: 31315	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973333						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.520	100	0	103	85	115
------	-----	-------	-----	---	-----	----	-----

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
ND	Not Detected at the Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
J	Analyte detected below quantitation limits
RL	Reporting Limit

DF	Dilution Factor
MI	Recovery outside control limits due to Matrix In

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050379
18-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: 25050379-24AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: 20420700003BF25A	Batch ID: 31315	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973335						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.8	0.520	100	0.123	99.7	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 25050379-24AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59550						
Client ID: 20420700003BF25A	Batch ID: 31315	TestNo: E200.8	E200.8	Analysis Date: 5/16/2025	SeqNo: 973336						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.5	0.520	100	0.123	99.4	70	130	99.8	0.288	20	
------	------	-------	-----	-------	------	----	-----	------	-------	----	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
ND	Not Detected at the Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
J	Analyte detected below quantitation limits
RL	Reporting Limit

DF	Dilution Factor
MI	Recovery outside control limits due to Matrix In

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25050379

RcptNo: 1

Logged by: Ashley Spiegelberg 5/8/2025 10:07:00 AM

Completed By: Coni Boyko 5/13/2025 10:06:59 AM

Reviewed By: Tamra Schmedemann 5/19/2025 5:24:15 PM

Coni Boyko
Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO₃ pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): MARK LILICH
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: HANBY
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	LEAD	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420601011BF25A	16732	DW	5-8-25	5:36AM	1	X		25050379		11
20420601012BF25A	16735	DW	5-8-25	4:48AM	1	X				12
20420601013BF25A	16736	DW	5-8-25	4:44AM	1	X				13
20420601014BF25A	16728	DW	5-8-25	4:50AM	1	X				14
20420601015DW25A	16730	DW	5-8-25	4:54AM	1	X				15
20420601016BF25A	16727	DW	5-8-25	4:56AM	1	X				16
20420601017BF25A	16726	DW	5-8-25	4:57AM	1	X				17
20420601018BF25A	16681	DW	5-8-25	4:58AM	1	X				18
20420601019BF25A	16725	DW	5-8-25	4:59AM	1	X				19
20420700007DW25A	16721	DW	5-8-25	5:53AM	1	X				20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Sign	Print	Date	Time
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By Laboratory: <u>[Signature]</u>	<u>Ashley Spradberg</u>	<u>5/8/25</u>	<u>10:07</u>

Section G

Lab Use Only

Temp: Amb
4°C +/- 2°C: ☐ Yes ☒ No NA
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: _____
pH Checked: ☐ _____
COC Seals Intact: ☐ Yes ☒ No NA
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # _____ Amount: _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): MARK LILLY
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: HANBY
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	LEAD	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420700006NS25A	16722	DW	5-8-25	5:49 AM	1	X		25050379		21
20420700005NS25A	16712	DW	5-8-25	5:48 AM	1	X				22
20420700004BF25A	16690	DW	5-8-25	5:47 AM	1	X				23
20420700003BF25A	16700	DW	5-8-25	5:45 AM	1	X				24
20420700002BF25A	16719	DW	5-8-25	5:44 AM	1	X				25
20420700001CF25A	16723	DW	5-8-25	5:42 AM	1	X				26
20420700008WB25A	16711	DW	5-8-25	5:54 AM	1	X				27
20420700009DW25A	16696	DW	5-8-25	5:55 AM	1	X				28
20420700010BF25A	16699	DW	5-8-25	5:56 AM	1	X				29
20420700011BF25A	16702	DW	5-8-25	5:57 AM	1	X				30

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Alley, Spigelberg</u>	<u>5/8/25</u>	<u>10:07</u>

Section G

Lab Use Only

Temp: 8.6
4°C +/- 2°C: ☐ Yes ☐ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: WA
pH Checked: _____
COC Seals Intact: ☐ Yes ☐ No ☐ NA
Field Blank Included: ☐ Yes ☐ No
Received Via: ☐ UPS ☐ FedEx ☒ Other ☐ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA/M/C ☐ Check # _____ Amount: _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>HANBY</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: Fax:			☐ Other
Collected By (Print): <u>MARK LILICH</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420700012 CF 25A	16716	DW	5-8-25	6:00 AM	1	X	25050379		31
20420700013 SF 25A	16715	DW	5-8-25	6:04 AM	1	X			32
20420700014 BF 25A	16701	DW	5-8-25	6:05 AM	1	X			33
20420700015 BF 25A	16692	DW	5-8-25	6:06 AM	1	X			34
20420700016 DW 25A	16681	DW	5-8-25	6:08 AM	1	X			35
20420700017 WB 25A	16718	DW	5-8-25	6:09 AM	1	X			36
20420700018 DW 25A	16706	DW	5-8-25	6:10 AM	1	X			37
20420700019 CF 25A	16705	DW	5-8-25	6:11 AM	1	X			38
20420700020 BF 25A	16695	DW	5-8-25	6:11 AM	1	X			39
20420700021 BF 25A	16717	DW	5-8-25	6:12 AM	1	X			40

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Speights</u>	<u>5/8/25</u>	<u>10:07</u>

Section G Lab Use Only

Temp: <u>Am</u>
4°C +/- 2°C: ☐ Yes ☒ No <u>NA</u>
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received:
pH Checked:
GOC Seals Intact: ☐ Yes ☐ No ☒ NA
Field Blank Included: ☐ Yes ☒ No
Received Via: ☒ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # ☐ Amount

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>HANBY</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>MARK MILLICENT</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420700022BF25A	16680	DW	5-8-25	6:12AM	1	X	25050379		41
20420700023BF25A	16714	DW	5-8-25	6:11AM	1	X			42
20420700024DW25A	16704	DW	5-8-25	6:10AM	1	X			43
20420700025WB25A	16491	DW	5-8-25	6:10AM	1	X			44
20420700026DW25A	16703	DW	5-8-25	6:05AM	1	X			45
20420700027CF25A	16684	DW	5-8-25	6:03AM	1	X			46
20420700028CF25A	16713	DW	5-8-25	6:03AM	1	X			47
		DW	5-8-25		1	X			
		DW	5-8-25		1	X			
		DW	5-8-25		1	X			

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Speerberg</u>	<u>5/8/25</u>	<u>10.07</u>

Section G Lab Use Only

Temp: <u>Am</u>
4°C +/- 2°C: ☐ Yes ☒ No <u>md</u>
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received:
pH Checked:
GOC Seals Intact: ☐ Yes ☐ No ☐ NA
Field Blank Included: ☐ Yes ☐ No
Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA/MC ☐ Check # _____ Amount: _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: HANBY
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Leak	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420604001CF25A	16671	DW	5-8-25	5:41AM	1	X		25050379		48
20420604002BF25A	16675	DW	5-8-25	5:42AM	1	X				49
20420605001CF25A	16677	DW	5-8-25	5:47AM	1	X				50
20420605002DW25A	16673	DW	5-8-25	5:43AM	1	X				51
20420605003BF25A	16674	DW	5-8-25	5:49AM	1	X				52
20420605004DW25A	16672	DW	5-8-25	5:50AM	1	X				53
20420605005CF25A	16676	DW	5-8-25	5:50AM	1	X				54
		DW	5-8-25		1	X				
		DW	5-8-25		1	X				
		DW	5-8-25		1	X				

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley S. Sogelberg</u>	<u>5/8/25</u>	<u>10:07</u>

Section G

Lab Use Only
Temp: AW
4°C +/- 2°C: ☐ Yes ☐ No WPH
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ☐ Yes ☐ No ☐ NA
Field Blank Included: ☐ Yes ☐ No
Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount: _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: HANBY
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420602032BF25A	16737	DW	5-8-25	5:30AM	1	X		25050379		55
20420602033BF25A	16746	DW	5-8-25	5:28AM	1	X				56
20420602034BF25A	16747	DW	5-8-25	5:29AM	1	X				57
20420606001BF25A	16720	DW	5-8-25	6:27AM	1	X				58
20420606002BF25A	16708	DW	5-8-25	6:28AM	1	X				59
20420606003BF25A	16693	DW	5-8-25	6:29AM	1	X				60
20420606004OT25A	16710	DW	5-8-25	6:29AM	1	X				61
20420606005KF25A	16666	DW	5-8-25	6:30AM	1	X				62
20420603001BF25A	16678	DW	5-8-25	5:37AM	1	X				63
20420603002CF25A	16679	DW	5-8-25	5:39AM	1	X				64

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>HSR Spigelberg</u>	<u>5/8/25</u>	<u>10:07</u>

Section G

Lab Use Only

Temp: Am 5
4°C +/- 2°C: ☐ Yes ☐ No NA
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: ☒
GOC Seals Intact: ☐ Yes ☐ No NA
Field Blank Included: ☐ Yes ☐ No NA
Received Via: ☒ UPS ☐ FedEx ☐ Other Hand
Payment: ☐ Invoice ☒ Cash ☐ VISA ☐ MIC ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: HANDY
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Leak	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420602022DW25A	16752	DW	5-8-25	5:16AM	1	X		25050379		65
20420602023DW25A	16742	DW	5-8-25	5:19AM	1	X				66
20420602024CF25A	16743	DW	5-8-25	5:18AM	1	X				67
20420602025DW25A	16750	DW	5-8-25	5:22AM	1	X				68
20420602026CF25A	16741	DW	5-8-25	5:22AM	1	X				69
20420602027CF25A	16749	DW	5-8-25	5:24AM	1	X				70
20420602028DW25A	16740	DW	5-8-25	5:25AM	1	X				71
20420602029CF25A	16739	DW	5-8-25	5:26AM	1	X				72
20420602030DW25A	16748	DW	5-8-25	5:27AM	1	X				73
20420602031BF25A	16733	DW	5-8-25	5:31AM	1	X				74

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegeling</u>	<u>5/8/25</u>	<u>10:07</u>

Section G

Lab Use Only

Temp: AW
4°C +/- 2°C ☐ Yes ☐ No NA
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ☐ Yes ☐ No NA
Field Blank Included: ☐ Yes ☐ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6	
Address: 300 Ash Street	
Central Point OR 97502	
Email:	
Phone:	Fax:
Collected By (Print): Jeff Carr	
Collected By (Sign): <i>Jeff Carr</i>	
Email Report ☒ Yes ☐ No	Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Section B

Required Project Information

Project Name:	HANBY
Project Number:	
Report To:	
Copy To:	

Section C

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
 _____ 5 Business Days (50% surcharge)
 _____ 3 Business Days (75% surcharge)
 _____ 24 - 48 hours (100% surcharge)
 _____ Other _____

Authorized _____ Yes _____ No _____

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of C	Level
20420602012BF25A	16764	DW	5-8-25	5:01AM	1	X
20420602013BF25A	16651	DW	5-8-25	5:03AM	1	X
20420602014BF25A	16767	DW	5-8-25	5:05AM	1	X
20420602015DW25A	16755	DW	5-8-25	5:07AM	1	X
20420602016CF25A	16756	DW	5-8-25	5:08AM	1	X
20420602017CF25A	16754	DW	5-8-25	5:10AM	1	X
20420602018DW25A	16745	DW	5-8-25	5:11AM	1	X
20420602019CF25A	16753	DW	5-8-25	5:12AM	1	X
20420602020DW25A	16744	DW	5-8-25	5:14AM	1	X
20420602021CF25A	16751	DW	5-8-25	5:15AM	1	X

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Print	Date	Time
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	H Sherry Spiegelberg	5/8/25	11:07

Section G

Lab Use Only

Temp: Am 5
4°C +/- 2°C: Yes No NA
Received on Ice: Yes No
Number of Bottles Received: 1
pH Checked: 1
COC Seals Intact: Yes No NA
Field Blank Included: Yes No
UPS FedEX Other Hand
M/C Check # Amount

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: HANBY
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420602001KF25A	16656	DW	5-8-25	4:56AM	1	X												85
20420602002DW25A	16653	DW	5-8-25	4:57AM	1	X												86
20420602003KF25A	16663	DW	5-8-25	5:47AM	1	X												87
20420602004KF25A	16657	DW	5-8-25	5:45AM	1	X												88
20420602005KF25A	16759	DW	5-8-25	4:50AM	1	X												89
20420602006KF25A	16758	DW	5-8-25	4:51AM	1	X												90
20420602007KF25A	16757	DW	5-8-25	4:52AM	1	X												91
20420602008KF25A	16762	DW	5-8-25	4:53AM	1	X												92
20420602009KF25A	16761	DW	5-8-25	4:54AM	1	X												93
20420602011DW25A	16763	DW	5-8-25	5:00AM	1	X												94

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Sporelling</u>	<u>5/8/25</u>	<u>10:07</u>

Section G

Lab Use Only

Temp: Am5
4°C +/- 2°C: ☐ Yes ☒ No NA
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: _____
GOC Seals Intact: ☐ Yes ☐ No ☒ NA
Field Blank Included: ☐ Yes ☐ No
Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☐ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # _____ Amount: _____

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
 - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
 - B Analyte detected in the associated method blank.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
 - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
 - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
 - 1 Value exceeds one half of the Maximum Contaminant Level.



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

October 30, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Hanby Lead Testing

Order No.: 25101190

Dear Dale Giovannetti:

Neilson Research Corporation received 5 sample(s) on 10/27/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25101190
Date: 10/30/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25101190

Date Reported: 10/30/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25101190
Received Date: 10/27/2025 9:55:00 AM
Reported Date: 10/30/2025 2:51:18 PM

Sample Information:

Lab ID: 25101190-01 **Client Sample ID:** 20420602003KF25B
Collection Date: 10/25/2025 7:12:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** 20420602003KF25B

Trace Metals by EPA 200.8 ICP-MS						Analyst; KHG		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	11.0	1	0.500	ppb	1	10/29/2025	15.0	A

Lab ID: 25101190-02 **Client Sample ID:** 20420602004KF25B
Collection Date: 10/25/2025 7:19:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** 20420602004KF25B

Trace Metals by EPA 200.8 ICP-MS						Analyst; KHG		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.18	1	0.500	ppb	1	10/29/2025	15.0	A

Lab ID: 25101190-03 **Client Sample ID:** 20420602017CF25B
Collection Date: 10/25/2025 7:25:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** 20420602017CF25B

Trace Metals by EPA 200.8 ICP-MS						Analyst; KHG		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.590		0.500	ppb	1	10/29/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25101190

Date Reported: 10/30/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25101190
Received Date: 10/27/2025 9:55:00 AM
Reported Date: 10/30/2025 2:51:18 PM

Sample Information:

Lab ID: 25101190-04 Client Sample ID: 20420602031BF25B
Collection Date: 10/25/2025 7:23:00 AM Collected By:
Matrix: Drinking Water Sample Location: 20420602031BF25B

Trace Metals by EPA 200.8 ICP-MS						Analyst; KHG		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	10/29/2025	15.0	A

Lab ID: 25101190-05 Client Sample ID: 20420604001CF25B
Collection Date: 10/25/2025 7:28:00 AM Collected By:
Matrix: Drinking Water Sample Location: 20420604001CF25B

Trace Metals by EPA 200.8 ICP-MS						Analyst; KHG		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.83		0.500	ppb	1	10/29/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25101190
30-Oct-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Hanby Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-33461	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: PBW	Batch ID: 33461	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058408
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-33461	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: LCSW	Batch ID: 33461	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058409
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.500 100 0 101 85 115

Sample ID: 25101135-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: BatchQC	Batch ID: 33461	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058425
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 98.2 0.500 100 0.0690 98.2 70 130

Sample ID: 25101135-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: BatchQC	Batch ID: 33461	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058426
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 97.3 0.500 100 0.0690 97.2 70 130 98.2 1.00 20

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Original

Sample Log-In Check List

Client Name: **CentralPtSchDist**

Work Order Number: **25101190**

RcptNo: **1**

Logged by: **Ashley Spiegelberg** **10/27/2025 9:55:00 AM**
Completed By: **Kyler Woolsey** **10/29/2025 11:57:14 AM**
Reviewed By: **Ashley Spiegelberg** **10/30/2025 2:48:18 PM**

Am
Kyler Woolsey
Am

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☐ NA ☒
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>HANBY</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): _____						Authorized ☐ Yes ☐ No	
Collected By (Sign): _____							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
2042060200315F25B	16211	DW	10-25-25	7:12AM	1	X											25101190	01	
20420602004KF25B	17326	DW	10-25-25	7:19AM	1	X												02	
20420602017CF25B	26759	DW	10-25-25	7:25AM	1	X												03	
20420602031BF25B	26842	DW	10-25-25	7:23AM	1	X												04	
20420604001CF25B	17325	DW	10-25-25	7:28AM	1	X												05	
		DW			1	X													
		DW			1	X													
		DW			1	X													
		DW			1	X													
		DW			1	X													

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
<u>[Signature]</u>		<u>Jeff Carr</u>	<u>10-27-25</u>	<u>9:55AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spigelberg</u>	<u>10/27/25</u>	<u>9:55</u>

Section G Lab Use Only

Temp:	<u>Amis</u>
4°C +/- 2°C:	☐ Yes ☐ No
Received on Ice:	☐ Yes ☒ No
Number of Bottles Received:	
pH Checked:	☐
COC Seals Intact:	☐ Yes ☐ No ☒ NA
Field Blank Included:	☐ Yes ☐ No
Received Via	☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment:	☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
 - A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
 - B Analyte detected in the associated method blank.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
 - R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
 - R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
 - 1 Value exceeds one half of the Maximum Contaminant Level.