

Lead in Water Test Results Summary: Jewett Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Bathroom Sink Across from Kitchen	20420200001BF25A	4/29/2025	ND	Non-Detect			
Kitchen Sink by Door	20420200002KF25A	4/29/2025	4.05	Low			
Kitchen Sink East Wall	20420200003KF25A	4/29/2025	5.05	Moderate			
Kettle Fill Sprayer Kitchen	20420200004KF25A	4/29/2025	ND	Non-Detect			
Kitchen Sink by Dish Room Left Sink	20420200005KF25A	4/29/2025	0.622	Low			
Kitchen Sink by Dish Room Right Sink	20420200006KF25A	4/29/2025	ND	Non-Detect			
Kitchen Dish Room Sprayer	20420200007KF25A	4/29/2025	ND	Non-Detect			
Staff Room Sink	20420200008SF25A	4/29/2025	ND	Non-Detect			
Staff Bathroom Sink	20420200009BF25A	4/29/2025	ND	Non-Detect			
Health RM Sink	20420200010NS25A	4/29/2025	1.48	Low			
Health RM Bathroom Sink	20420200011BF25A	4/29/2025	ND	Non-Detect			
Principal's Office Bathroom Sink	20420200012BF25A	4/29/2025	ND	Non-Detect			
Left Drinking Fountain by Entrance	20420200013DW25A	4/29/2025	ND	Non-Detect			
Right Drinking Fountain by Entrance	20420200014DW25A	4/29/2025	ND	Non-Detect			
Bottle Fill by Entrance	20420200015WB25A	4/29/2025	ND	Non-Detect			
La Clinica Bathroom Sink	20420200016BF25A	4/29/2025	ND	Non-Detect			
La Clinica Nurse Office Sink	20420200017NS25A	4/29/2025	1.74	Low			
RM1 Bathroom Sink	20420200018BF25A	4/29/2025	ND	Non-Detect			
RM1 Drinking Fountain	20420200019DW25A	4/29/2025	ND	Non-Detect			
RM1 Classroom Sink	20420200020CF25A	4/29/2025	0.619	Low			
RM2 Bathroom Sink	20420200021BF25A	4/29/2025	ND	Non-Detect			
RM2 Drinking Fountain	20420200022DW25A	4/29/2025	ND	Non-Detect			
RM2 Classroom Sink	20420200023CF25A	4/29/2025	ND	Non-Detect			
RM3 Bathroom Sink	20420200024BF25A	4/29/2025	ND	Non-Detect			
RM3 Drinking Fountain	20420200025DW25A	4/29/2025	ND	Non-Detect			
RM3 Classroom Sink	20420200026CF25A	4/29/2025	ND	Non-Detect			
RM4 Bathroom Sink	20420200027BF25A	4/29/2025	ND	Non-Detect			
RM4 Drinking Fountain	20420200028DW25A	4/29/2025	ND	Non-Detect			
RM4 Classroom Sink	20420200029CF25A	4/29/2025	ND	Non-Detect			
Playground Left Drinking Fountain	20420200030DW25A	4/29/2025	ND	Non-Detect			
Playground Bottle Fill	20420200031BW25A	4/29/2025	ND	Non-Detect			
Playground Right Drinking Fountain	20420200032DW25A	4/29/2025	ND	Non-Detect			
Right Bathroom Sink	20420200033BF25A	4/29/2025	ND	Non-Detect			
Left Bathroom Sink	20420200034BF25A	4/29/2025	1.33	Low			
RM7 Bathroom Sink	20420200035BF25A	4/29/2025	ND	Non-Detect			
RM7 Drinking Fountain	20420200036DW25A	4/29/2025	ND	Non-Detect			
RM7 Classroom Sink	20420200037CF25A	4/29/2025	ND	Non-Detect			
RM8 Bathroom Sink	20420200038BF25A	4/29/2025	ND	Non-Detect			
RM8 Drinking Fountain	20420200039DW25A	4/29/2025	ND	Non-Detect			
RM8 Classroom Sink	20420200040CF25A	4/29/2025	ND	Non-Detect			
RM9 Drinking Fountain	20420200041DW25A	4/29/2025	ND	Non-Detect			
RM9 Classroom Sink	20420200042CF25A	4/29/2025	0.894	Low			
RM10 Drinking Fountain	20420200043DW25A	4/29/2025	ND	Non-Detect			
RM10 Classroom Sink	20420200044CF25A	4/29/2025	0.851	Low			
RM11 Drinking Fountain	20420200045DW25A	4/29/2025	ND	Non-Detect			
RM11 Classroom Sink	20420200046CF25A	4/29/2025	0.779	Low			
Girls Bathroom Right Sink	20420200047BF25A	4/29/2025	ND	Non-Detect			
Girls Bathroom 2nd to Right Sink	20420200048BF25A	4/29/2025	ND	Non-Detect			
Girls Bathroom 2nd to Left Sink	20420200049BF25A	4/29/2025	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Girls Bathroom Left Sink	20420200050BF25A	4/29/2025	ND	Non-Detect			
Drinking Fountain by Bathrooms	20420200051DW25A	4/29/2025	ND	Non-Detect			
Bottle Fill by Bathroom	20420200052WB25A	4/29/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420200053BF25A	4/29/2025	ND	Non-Detect			
Boys Bathroom 2nd to Right Sink	20420200054BF25A	4/29/2025	ND	Non-Detect			
Boys Bathroom 2nd to Left Sink	20420200055BF25A	4/29/2025	ND	Non-Detect			
Boys Bathroom Left Sink	20420200056BF25A	4/29/2025	ND	Non-Detect			
Hallway Staff Restroom	20420200057BF25A	4/29/2025	ND	Non-Detect			
RM12 Drinking Fountain	20420200058DW25A	4/29/2025	ND	Non-Detect			
RM12 Classroom Sink	20420200059CF25A	4/29/2025	0.73	Low			
RM13 Drinking Fountain	20420200060DW25A	4/29/2025	ND	Non-Detect			
RM13 Classroom Sink	20420200061CF25A	4/29/2025	ND	Non-Detect			
RM14 Drinking Fountain	20420200062DW25A	4/29/2025	ND	Non-Detect			
RM14 Classroom Sink	20420200063CF25A	4/29/2025	ND	Non-Detect			
ROOMS 5 AND 6							
RM5 Bathroom Sink	20420202001BF25A	5/13/2025	ND	Non-Detect			
RM5 Classroom Sink	20420202002CF25A	5/13/2025	0.632	Low			
RM5 Drinking Fountain	20420202003DW25A	5/13/2025	ND	Non-Detect			
RM6 Classroom Sink	20420202004CF25A	5/13/2025	ND	Non-Detect			
RM6 Drinking Fountain	20420202005DW25A	5/13/2025	ND	Non-Detect			
RM6 Bathroom Sink	20420202006BF25A	5/13/2025	ND	Non-Detect			
GYMNASIUM							
Lobby Drinking Fountain	20420209001DW25A	4/29/2025	ND	Non-Detect			
Lobby Bottle Fill	20420209002WB25A	4/29/2025	ND	Non-Detect			
Maker Space Sink	20420209003CF25A	4/29/2025	0.542	Low			
Boys Bathroom Left Sink	20420209004BF25A	4/29/2025	ND	Non-Detect			
Boys Bathroom Middle Sink	20420209005BF25A	4/29/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420209006BF25A	4/29/2025	ND	Non-Detect			
Girls Bathroom Right Sink	20420209007BF25A	4/29/2025	ND	Non-Detect			
Girls Bathroom Middle Sink	20420209008BF25A	4/29/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420209009BF25A	4/29/2025	ND	Non-Detect			
Gym Bottle Fill	20420209010WB25A	4/29/2025	ND	Non-Detect			
Gym Left Drinking Fountain	20420209011DW25A	4/29/2025	ND	Non-Detect			
Gym Right Drinking Fountain	20420209012DW25A	4/29/2025	ND	Non-Detect			
Girls Handicap Bathroom Sink	20420209013BF25A	4/29/2025	ND	Non-Detect			
Boys Handicap Bathroom Sink	20420209014BF25A	4/29/2025	ND	Non-Detect			
BACK WING							
RM22 Drinking Fountain	20420201001DW25A	4/29/2025	ND	Non-Detect			
RM22 Classroom Sink	20420201002CF25A	4/29/2025	ND	Non-Detect			
RM21 Drinking Fountain	20420201003DW25A	4/29/2025	ND	Non-Detect			
RM21 Classroom Sink	20420201004CF25A	4/29/2025	1.2	Low			
RM20 Drinking Fountain	20420201005DW25A	4/29/2025	ND	Non-Detect			
RM20 Classroom Sink	20420201006CF25A	4/29/2025	ND	Non-Detect			
Outside Staff Bathroom Sink	20420201007BF25A	4/29/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420201008BF25A	4/29/2025	ND	Non-Detect			
Boys Bathroom Middle Sink	20420201009BF25A	4/29/2025	ND	Non-Detect			
Boys Bathroom Left Sink	20420201010BF25A	4/29/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420201011BF25A	4/29/2025	ND	Non-Detect			
Girls Bathroom Middle Sink	20420201012BF25A	4/29/2025	ND	Non-Detect			
Girls Bathroom Right Sink	20420201013BF25A	4/29/2025	ND	Non-Detect			
Playground Drinking Fountain Right	20420201014DW25A	4/29/2025	ND	Non-Detect			
Playground Drinking Fountain Middle	20420201015DW25A	4/29/2025	ND	Non-Detect			
Playground Drinking Fountain Left	20420201016DW25A	4/29/2025	ND	Non-Detect			
RM19 Drinking Fountain	20420201017DW25A	4/29/2025	ND	Non-Detect			
RM19 Classroom Sink	20420201018CF25A	4/29/2025	ND	Non-Detect			
RM18 Drinking Fountain	20420201019DW25A	4/29/2025	ND	Non-Detect			
RM18 Classroom Sink	20420201020CF25A	4/29/2025	ND	Non-Detect			
RM17 Drinking Fountain	20420201021DW25A	4/29/2025	ND	Non-Detect			
RM17 Classroom Sink	20420201022CF25A	4/29/2025	0.549	Low			
RM16 Drinking Fountain	20420201023DW25A	4/29/2025	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
RM16 Classroom Sink	20420201024CF25A	4/29/2025	0.716	Low			
RM15 Drinking Fountain	20420201025DW25A	4/29/2025	ND	Non-Detect			
RM15 Classroom Sink	20420201026CF25A	4/29/2025	ND	Non-Detect			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

May 09, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Jewett Elem Lead Testing-AMENDED

Order No.: 25041295

Dear Dale Giovannetti:

Neilson Research Corporation received 63 sample(s) on 4/29/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25041295
Date: 5/9/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem

Project: Jewett Elem Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-01 Client Sample ID: 20420200001BF25A
Collection Date: 4/29/2025 4:35:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200001BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-02 Client Sample ID: 20420200002KF25A
Collection Date: 4/29/2025 4:36:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200002KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.05		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-03 Client Sample ID: 20420200003KF25A
Collection Date: 4/29/2025 4:38:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200003KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.50		0.500	ppb	1	4/30/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-04 **Client Sample ID:** 20420200004KF25A
Collection Date: 4/29/2025 4:40:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200004KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-05 **Client Sample ID:** 20420200005KF25A
Collection Date: 4/29/2025 4:43:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200005KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.622		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-06 **Client Sample ID:** 20420200006KF25A
Collection Date: 4/29/2025 4:44:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200006KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-07 **Client Sample ID:** 20420200007KF25A
Collection Date: 4/29/2025 4:45:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200007KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-08 **Client Sample ID:** 20420200008SF25A
Collection Date: 4/29/2025 4:48:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200008SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-09 **Client Sample ID:** 20420200009BF25A
Collection Date: 4/29/2025 4:50:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200009BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-10 Client Sample ID: 20420200010NS25A
Collection Date: 4/29/2025 4:53:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200010NS25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.48		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-11 Client Sample ID: 20420200011BF25A
Collection Date: 4/29/2025 4:52:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200011BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-12 Client Sample ID: 20420200012BF25A
Collection Date: 4/29/2025 4:55:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200012BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-13 **Client Sample ID:** 20420200013DW25A
Collection Date: 4/29/2025 4:56:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200013DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-14 **Client Sample ID:** 20420200014DW25A
Collection Date: 4/29/2025 4:57:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200014DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-15 **Client Sample ID:** 20420200015BW25A
Collection Date: 4/29/2025 4:58:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200015BW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-16 **Client Sample ID:** 20420200016BF25A
Collection Date: 4/29/2025 4:59:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200016BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-17 **Client Sample ID:** 20420200017NS25A
Collection Date: 4/29/2025 5:00:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200017NS25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.74		0.500	ppb	1	4/30/2025	15.0	A

Lab ID: 25041295-18 **Client Sample ID:** 20420200018BF25A
Collection Date: 4/29/2025 5:02:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200018BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-19 **Client Sample ID:** 20420200019DW25A
Collection Date: 4/29/2025 5:03:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200019DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-20 **Client Sample ID:** 20420200020CF25A
Collection Date: 4/29/2025 5:04:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200020CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.619		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-21 **Client Sample ID:** 20420200021BF25A
Collection Date: 4/29/2025 5:04:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200021BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-22 **Client Sample ID:** 20420200022DW25A
Collection Date: 4/29/2025 5:05:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200022DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-23 **Client Sample ID:** 20420200023CF25A
Collection Date: 4/29/2025 5:07:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200023CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-24 **Client Sample ID:** 20420200024BF25A
Collection Date: 4/29/2025 5:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200024BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-25 Client Sample ID: 20420200025DW25A
Collection Date: 4/29/2025 5:10:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200025DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-26 Client Sample ID: 20420200026CF25A
Collection Date: 4/29/2025 5:11:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200026CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-27 Client Sample ID: 20420200027BF25A
Collection Date: 4/29/2025 5:13:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200027BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-28 **Client Sample ID:** 20420200028DW25A
Collection Date: 4/29/2025 5:14:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200028DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-29 **Client Sample ID:** 20420200029CF25A
Collection Date: 4/29/2025 5:15:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200029CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-30 **Client Sample ID:** 20420200030DW25A
Collection Date: 4/29/2025 5:18:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200030DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-31 **Client Sample ID:** 20420200031WB25A
Collection Date: 4/29/2025 5:19:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200031WB25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-32 **Client Sample ID:** 20420200032DW25A
Collection Date: 4/29/2025 5:20:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200032DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-33 **Client Sample ID:** 20420200033BF25A
Collection Date: 4/29/2025 5:21:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200033BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-34 Client Sample ID: 20420200034BF25A
Collection Date: 4/29/2025 5:22:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200034BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.33		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-35 Client Sample ID: 20420200035BF25A
Collection Date: 4/29/2025 5:25:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200035BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-36 Client Sample ID: 20420200036DW25A
Collection Date: 4/29/2025 5:26:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200036DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-37 **Client Sample ID:** 20420200037CF25A
Collection Date: 4/29/2025 5:26:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 204202000337CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-38 **Client Sample ID:** 20420200038BF25A
Collection Date: 4/29/2025 5:28:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200038BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-39 **Client Sample ID:** 20420200039DW25A
Collection Date: 4/29/2025 5:29:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200039DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-40 **Client Sample ID:** 20420200040CF25A
Collection Date: 4/29/2025 5:30:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200040CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-41 **Client Sample ID:** 20420200041DW25A
Collection Date: 4/29/2025 5:32:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200041DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-42 **Client Sample ID:** 20420200042CF25A
Collection Date: 4/29/2025 5:32:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200042CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.894		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-43 **Client Sample ID:** 20420200043DW25A
Collection Date: 4/29/2025 5:35:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200043DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-44 **Client Sample ID:** 20420200044CF25A
Collection Date: 4/29/2025 5:36:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200044CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.851		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-45 **Client Sample ID:** 20420200045DW25A
Collection Date: 4/29/2025 5:37:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200045DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-46 **Client Sample ID:** 20420200046CF25A
Collection Date: 4/29/2025 5:38:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200046CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.779		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-47 **Client Sample ID:** 20420200047BF25A
Collection Date: 4/29/2025 5:43:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200047BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

Lab ID: 25041295-48 **Client Sample ID:** 20420200048BF25A
Collection Date: 4/29/2025 5:42:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200048BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/1/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-49 Client Sample ID: 20420200049BF25A
Collection Date: 4/29/2025 5:42:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200049BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-50 Client Sample ID: 20420200050BF25A
Collection Date: 4/29/2025 5:43:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200050BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-51 Client Sample ID: 20420200051DW25A
Collection Date: 4/29/2025 5:44:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200051DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-52 Client Sample ID: 20420200052WB25A
Collection Date: 4/29/2025 5:45:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200052WB25A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-53 Client Sample ID: 20420200053BF25A
Collection Date: 4/29/2025 5:46:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200053BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-54 Client Sample ID: 20420200054BF25A
Collection Date: 4/29/2025 5:47:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200054BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst: CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-55 Client Sample ID: 20420200055BF25A
Collection Date: 4/29/2025 5:48:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200055BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-56 Client Sample ID: 20420200056BF25A
Collection Date: 4/29/2025 5:48:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200056BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-57 Client Sample ID: 20420200057BF25A
Collection Date: 4/29/2025 5:50:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200057BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-58 **Client Sample ID:** 20420200058DW25A
Collection Date: 4/29/2025 5:51:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200058DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-59 **Client Sample ID:** 20420200059CF25A
Collection Date: 4/29/2025 5:53:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200059CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.730		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-60 **Client Sample ID:** 20420200060DW25A
Collection Date: 4/29/2025 5:54:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420200060DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041295
Date Reported: 5/9/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041295
Received Date: 4/29/2025 9:18:00 AM
Reported Date: 5/9/2025 1:26:49 PM

Sample Information:

Lab ID: 25041295-61 Client Sample ID: 20420200061CF25A
Collection Date: 4/29/2025 5:56:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200061CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-62 Client Sample ID: 20420200062DW25A
Collection Date: 4/29/2025 5:58:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200062DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

Lab ID: 25041295-63 Client Sample ID: 20420200063CF25A
Collection Date: 4/29/2025 5:58:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420200063CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/5/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041295
16-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Jewett Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31077	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/30/2025	RunNo: 59067						
Client ID: PBW	Batch ID: 31077	TestNo: E200.8	E200.8	Analysis Date: 4/30/2025	SeqNo: 964178						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID: LCS-31077	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/30/2025	RunNo: 59067						
Client ID: LCSW	Batch ID: 31077	TestNo: E200.8	E200.8	Analysis Date: 4/30/2025	SeqNo: 964179						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.500	100	0	104	85	115				

Sample ID: 25041295-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/30/2025	RunNo: 59067						
Client ID: 20420200001BF25A	Batch ID: 31077	TestNo: E200.8	E200.8	Analysis Date: 4/30/2025	SeqNo: 964181						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.500	100	0.156	102	70	130				

Sample ID: 25041295-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 4/30/2025	RunNo: 59067						
Client ID: 20420200001BF25A	Batch ID: 31077	TestNo: E200.8	E200.8	Analysis Date: 4/30/2025	SeqNo: 964182						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.500	100	0.156	101	70	130	102	0.228	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041295
16-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Jewett Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31099	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/1/2025	RunNo: 59095						
Client ID: PBW	Batch ID: 31099	TestNo: E200.8	E200.8	Analysis Date: 5/1/2025	SeqNo: 964608						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31099	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/1/2025	RunNo: 59095						
Client ID: LCSW	Batch ID: 31099	TestNo: E200.8	E200.8	Analysis Date: 5/1/2025	SeqNo: 964609						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.500	100	0	103	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25041374-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/1/2025	RunNo: 59095						
Client ID: BatchQC	Batch ID: 31099	TestNo: E200.8	E200.8	Analysis Date: 5/1/2025	SeqNo: 964611						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.8	0.500	100	0	99.8	70	130				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 25041374-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/1/2025	RunNo: 59095						
Client ID: BatchQC	Batch ID: 31099	TestNo: E200.8	E200.8	Analysis Date: 5/1/2025	SeqNo: 964612						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.500	100	0	100	70	130	99.8	0.574	20	
------	-----	-------	-----	---	-----	----	-----	------	-------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041295
16-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Jewett Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31100	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/1/2025	RunNo: 59095						
Client ID: PBW	Batch ID: 31100	TestNo: E200.8	E200.8	Analysis Date: 5/1/2025	SeqNo: 964630						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31100	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/1/2025	RunNo: 59095						
Client ID: LCSW	Batch ID: 31100	TestNo: E200.8	E200.8	Analysis Date: 5/1/2025	SeqNo: 964631						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0	104	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25041295-29AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/1/2025	RunNo: 59095						
Client ID: 20420200029CF25A	Batch ID: 31100	TestNo: E200.8	E200.8	Analysis Date: 5/1/2025	SeqNo: 964633						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.500	100	0.372	102	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Sample ID: 25041295-29AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/1/2025	RunNo: 59095						
Client ID: 20420200029CF25A	Batch ID: 31100	TestNo: E200.8	E200.8	Analysis Date: 5/1/2025	SeqNo: 964634						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.500	100	0.372	102	70	130	102	0.274	20	
------	-----	-------	-----	-------	-----	----	-----	-----	-------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041295
16-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Jewett Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31116	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/2/2025	RunNo: 59169						
Client ID: PBW	Batch ID: 31116	TestNo: E200.8	E200.8	Analysis Date: 5/5/2025	SeqNo: 965709						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31116	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/2/2025	RunNo: 59169						
Client ID: LCSW	Batch ID: 31116	TestNo: E200.8	E200.8	Analysis Date: 5/5/2025	SeqNo: 965710						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.500	100	0	101	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050009-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/2/2025	RunNo: 59169						
Client ID: BatchQC	Batch ID: 31116	TestNo: E200.8	E200.8	Analysis Date: 5/5/2025	SeqNo: 965712						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	103	0.500	100	7.74	94.8	70	130				
------	-----	-------	-----	------	------	----	-----	--	--	--	--

Sample ID: 25050009-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/2/2025	RunNo: 59169						
Client ID: BatchQC	Batch ID: 31116	TestNo: E200.8	E200.8	Analysis Date: 5/5/2025	SeqNo: 965713						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.6	0.500	100	7.74	91.8	70	130	103	2.95	20	
------	------	-------	-----	------	------	----	-----	-----	------	----	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit	RL	Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041295
16-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Jewett Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31117	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/2/2025	RunNo: 59169						
Client ID: PBW	Batch ID: 31117	TestNo: E200.8	E200.8	Analysis Date: 5/5/2025	SeqNo: 965724						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID: LCS-31117		SampType: LCS		TestCode: LEAD_SCHO		Units: ppb		Prep Date: 5/2/2025			RunNo: 59169			
Client ID: LCSW		Batch ID: 31117		TestNo: E200.8		E200.8		Analysis Date: 5/5/2025			SeqNo: 965725			
Analyte		Result		PQL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		104		0.500	100	0		104	85	115				

Sample ID: 25041295-54AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/2/2025	RunNo: 59169						
Client ID: 20420200054BF25A	Batch ID: 31117	TestNo: E200.8	E200.8	Analysis Date: 5/5/2025	SeqNo: 965727						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	99.4	0.500	100	0.229	99.2	70	130				

Sample ID: 25041295-54AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/2/2025	RunNo: 59169						
Client ID: 20420200054BF25A	Batch ID: 31117	TestNo: E200.8	E200.8	Analysis Date: 5/5/2025	SeqNo: 965728						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.500	100	0.229	100	70	130	99.4	1.10	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25041295

RcptNo: 1

Logged by: Ashley Spiegelberg 4/29/2025 9:18:00 AM

Completed By: Coni Boyko 5/1/2025 11:39:15 AM

Reviewed By: Ashley Spiegelberg 5/9/2025 1:17:22 PM

Am
Coni Boyko
Am

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

The sample fractions -02A, -06A, and -10A contained visible sediments.

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

Page 1 of 7

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Jewett</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>Jeff Carr</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only)		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead										Remarks/Field Data	NRC Sample # (Lab Use Only)
Bathroom sink across from kitchen	130456	DW	4-29-25	4:37AM	1	X										2042020001BF25A	01
Kitchen sink by door	130460	DW	4-29-25	4:36AM	1	X										2042020002KF25A	02
Kitchen sink East wall	130459	DW	4-29-25	4:39AM	1	X										2042020003KF25A	03
Kettle fill sprayer	130470	DW	4-29-25	4:40AM	1	X										2042020004KF25A	04
Sink by Dishroom left	130469	DW	4-29-25	4:43AM	1	X										2042020005KF25A	05
Sink by Dishroom Right	130462	DW	4-29-25	4:44AM	1	X										2042020006KF25A	06
Dishroom sprayer	130466	DW	4-29-25	4:45AM	1	X										2042020007KF25A	07
Staffroom sink	130461	DW	4-29-25	4:49AM	1	X										2042020008SF25A	08
Staff bathroom	130467	DW	4-29-25	4:50AM	1	X										2042020009BF25A	09
Healthroom 9th Bath	130465	DW	4-29-25	4:53AM	1	X										2042020000NS25A	10

*Matrix DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign		Print		Date		Time	
Relinquished By: <u>[Signature]</u>				<u>Jeff Carr</u>		<u>4-29-25</u>		<u>9:18AM</u>	
Received By:									
Relinquished By:									
Received By:									
Relinquished By:									
Received By Laboratory: <u>[Signature]</u>				<u>Ashley Siegelburg</u>		<u>4/29/25</u>		<u>9:18</u>	

Section G Lab Use Only	
Temp: <u>4°C</u>	Yes ☐ No ☒
Received on Ice: <u>No</u>	Yes ☐ No ☒
Number of Bottles Received: <u>10</u>	
RFI Checked: <u>Yes</u>	
COO Seal Intact: <u>Yes</u>	Yes ☐ No ☒
Field Blank Included: <u>No</u>	Yes ☐ No ☒
Received Via: <u>UPS</u>	UPS ☒ FedEx ☐ Other ☐ Hand ☐
Payment: <u>Invoice</u>	Cash ☐ VISA/M/C ☐ Check # ☐ Amount ☐

Chain of Custody Record

Page 2 of 7

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>Sewett</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: Fax:			☐ Other
Collected By (Print): <u>Jeff Carr</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>Jeff Carr</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Healthroom sink	130469	DW	4-29-25	4:52AM	1	lead										250412	95
Principal's Office Bathroom sink	130469	DW	4-29-25	4:55AM	1											20430200011REFA	11
Left Drinking Fountain by entrance	130514	DW	4-29-25	4:56AM	1											20470200012B-25A	12
Right Drinking Fountain by entrance	130507	DW	4-29-25	4:57AM	1											20420200013D-25A	13
Bottle Fill by entrance	130477	DW	4-29-25	4:58AM	1											20420200014D-25A	14
La Clinica Bathroom sink	130478	DW	4-29-25	4:59AM	1											20420200015B-25A	15
La Clinica Nurse Office sink	130464	DW	4-29-25	5:00AM	1											20420200016RF25A	16
Room 1 Bathroom sink	130516	DW	4-29-25	5:02AM	1											20420200017NS25A	17
Room 1 Drinking Fountain	130519	DW	4-29-25	5:03AM	1											20420200018RF25A	18
Room 1 Classroom sink	130517	DW	4-29-25	5:04AM	1											20420200019D-25A	19
																20420200020CF25A	20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>4/29/25</u>	<u>9:18</u>

Section G Lab Use Only

Temp:	<u>4°C</u>	Yes	No
Received on (ice):		Yes	No
Number of Bottles Received:			
PH Checked:			
COC Seal Intact:		Yes	No
Field Blank Included:		Yes	No

Received Via:	<u>UPS</u>	FedEx	Other	Hand
---------------	------------	-------	-------	------

Payment:	Invoice	Cash	VISA	M/C	Check #	Amount
----------	---------	------	------	-----	---------	--------

Chain of Custody Record

Page 4 of 7

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>Sewett</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:		☐ 24 - 48 hours (100% surcharge)
Phone: Fax:		P.O. #	☐ Other
Collected By (Print): <u>Jeff Carr</u>	Authorized ☐ Yes ☐ No		
Collected By (Sign): <u>Jeff Carr</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
Playground Bottle Fill	130525	DW	4-29-25	5:19 AM	1	X			20420200031W825A	31
Playground Right Drinking Fountain	130526	DW	4-29-25	5:20 AM	1	X			20420200032DW25A	32
Playground Right Bathroom	130513	DW	4-29-25	5:21 AM	1	X			20420200033BF25A	33
Playground Left Bathroom sink	130512	DW	4-29-25	5:22 AM	1	X			20420200034BF25A	34
Room 7 Bathroom sink	130505	DW	4-29-25	5:25 AM	1	X			20420200035BF25A	35
Room 7 Drinking Fountain	130510	DW	4-29-25	5:26 AM	1	X			20420200036DW25A	36
Room 7 Classroom sink	130508	DW	4-29-25	5:26 AM	1	X			20420200037CF25A	37
Room 8 Bathroom sink	130500	DW	4-29-25	5:28 AM	1	X			20420200038BF25A	38
Room 8 Drinking Fountain	130509	DW	4-29-25	5:29 AM	1	X			20420200039DW25A	39
Room 9 Classroom sink	130502	DW	4-29-25	5:30 AM	1	X			20420200040CF25A	40

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Siegelberg</u>	<u>4/29/25</u>	<u>9:18</u>

Section G Lab Use Only
Temp: <u>4°C</u>
4°C +/- 2°C: ☒ Yes ☐ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: <u>40</u>
PI Checked: ☒
GOC Seals Intact: ☒ Yes ☐ No ☐ N/A
Field Blank Included: ☐ Yes ☒ No
Received Via: ☒ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☐ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # ☐ Amount

Chain of Custody Record

Page 5 of 7

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>Jewett</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:		☐ 24 - 48 hours (100% surcharge)
Phone: Fax:		P.O. #	☐ Other
Collected By (Print): <u>Jeff Carr</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
Room 9 Drinking Fountain	130490	DW	4-29-25	5:32 AM	1	X										20420200041DW25A	41	
Room 9 Classroom Sink	130497	DW	4-29-25	5:32 AM	1	X										20420200042CF25A	42	
Room 10 Drinking Fountain	130496	DW	4-29-25	5:35 AM	1	X										20420200043DW25A	43	
Room 10 Classroom Sink	130495	DW	4-29-25	5:36 AM	1	X										20420200044CF25A	44	
Room 11 Drinking Fountain	130491	DW	4-29-25	5:37 AM	1	X										20420200045DW25A	45	
Room 11 Classroom Sink	130497	DW	4-29-25	5:38 AM	1	X										20420200046CF25A	46	
Girls Bathroom Right Sink	130499	DW	4-29-25	5:43 AM	1	X										20420200047BP25A	47	
Girls Bathroom Right Sink	130506	DW	4-29-25	5:42 AM	1	X										20420200048BF25A	48	
Girls Bathroom 2nd to right	130504	DW	4-29-25	5:42 AM	1	X										20420200049BF25A	49	
Girls Bathroom left sink	130498	DW	4-29-25	5:43 AM	1	X										20420200050CF25A	50	

*Matrix DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Achey Spiegelberg</u>	<u>4/29/25</u>	<u>7:18</u>

Section G Lab Use Only

Temp:	<u>72.6</u>
4°C/41°F	☐ Yes ☒ No
Received on Ice	☐ Yes ☒ No
Number of Bottles Received	
PF Checked	
GOC Seal Intact	☐ Yes ☒ No ☐ NA
Field Blank Included	☐ Yes ☒ No

Received Via ☒ UPS ☐ FedEx ☐ Other ☐ Hand

Payment: ☐ Invoice ☐ Cash ☐ VISA/M/C ☐ Check # ☐ Amount

Chain of Custody Record

Page 10 of 12

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Jewett</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: Fax:						☐ Other	
Collected By (Print): <u>Jeff Carr</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>Jeff Carr</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
Drinking Fountain by bathroom	130494	DW	4-29-25	5:44AM	1	X											20420200051DW25A	51
Bottle fill by bathroom	130493	DW	4-29-25	5:45AM	1	X											20420200052DW25A	52
Boys bathroom right sink	130499	DW	4-29-25	5:46AM	1	X											20420200053BF25A	53
Boys bathroom 2nd to right sink	130498	DW	4-29-25	5:47AM	1	X											20420200054BF25A	54
Boys bathroom 2nd to left sink	130492	DW	4-29-25	5:48AM	1	X											20420200055BF25A	55
Boys bathroom left sink	130490	DW	4-29-25	5:49AM	1	X											20420200056BF25A	56
Itallway staff bathroom	130483	DW	4-29-25	5:50AM	1	X											20420200057BF25A	57
Room 12 Drinking Fountain	130482	DW	4-29-25	5:51AM	1	X											20420200058DW25A	58
Room 12 Classroom Sink	130481	DW	4-29-25	5:53AM	1	X											20420200059CF25A	59
Room 13 Drinking Fountain	130480	DW	4-29-25	5:54AM	1	X											20420200060DW25A	60

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>4/29/25</u>	<u>9:18</u>

Section G Lab Use Only

Temp:	<u>72°F</u>
4°C ± 0.2°C:	☐ Yes ☒ No
Received on Ice:	☐ Yes ☒ No
Number of Bottles Received:	<u>6</u>
pH Checked:	☐ Yes ☒ No
GOC/Seals Intact:	☐ Yes ☒ No ☐ NA
Field Blank Included:	☐ Yes ☒ No

Received Via ☒ UPS ☐ FedEx ☐ Other Hand

Payment: ☐ Invoice ☐ Cash ☐ VISA ☐ MC ☐ Check # ☐ Amount

Chain of Custody Record

Page 7 of 7

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District</u>	Project Name: <u>Jewett</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: Fax:			☐ Other
Collected By (Print): <u>Jeff Carr</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>Jeff Carr</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
Room 14 Drinking Fountain	130485	DW	4-29-25	5:56 AM	1	X											25041295	25041295
Room 14 Classroom Sink	130486	DW	4-29-25	5:58 AM	1	X											25041295	25041295
20420200063 CE25A		DW	4/29/25	5:58	1	X											25041295	25041295

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>4/29/25</u>	<u>9:18</u>

Section G Lab Use Only

Temp:	<u>4°C</u>	Yes	No
4°C/22°C			
Received on Ice		Yes	No
Number of Bottles Received			
pH Checked			
GOC Seal Intact		Yes	No
Field Blank Included		Yes	No

Received Via ☒ UPS ☐ FedEx ☐ Other ☐ Hand

Payment: ☐ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # ☐ Amount