

Lead in Water Test Results Summary: Mae Richardson Elementary

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Principal's Office Sink	20420400001SF25A	4/30/2025	1.56	Low			
Work Room Sink	20420400002SF25A	4/30/2025	0.541	Low			
Staffroom Sink	20420400003SF25A	4/30/2025	ND	Non-Detect			
Staff Mens Bathroom Sink	20420400004BF25A	4/30/2025	ND	Non-Detect			
Staff Womens Bathroom Sink	20420400005BF25A	4/30/2025	ND	Non-Detect			
RM1 Drinking Fountain	20420400006DW25A	4/30/2025	ND	Non-Detect			
RM1 Classroom Sink	20420400007CF25A	4/30/2025	ND	Non-Detect			
RM2 Drinking Fountain	20420400008DW25A	4/30/2025	ND	Non-Detect			
RM2 Classroom Sink	20420400009CF25A	4/30/2025	ND	Non-Detect			
RM3 Drinking Fountain (Not in service)	20420400010DW						
RM3 Classroom Sink	20420400011CF25A	4/30/2025	ND	Non-Detect			
RM4 Drinking Fountain	20420400012DW25A	4/30/2025	ND	Non-Detect			
RM4 Classroom Sink	20420400013CF25A	4/30/2025	ND	Non-Detect			
RM5 Classroom Sink	20420400014CF25A	4/30/2025	ND	Non-Detect			
RM5 Drinking Fountain	20420400015DW25A	4/30/2025	ND	Non-Detect			
RM6 Classroom Sink	20420400016CF25A	4/30/2025	ND	Non-Detect			
RM6 Drinking Fountain	20420400017DW25A	4/30/2025	ND	Non-Detect			
RM7 Classroom Sink	20420400018CF25A	4/30/2025	ND	Non-Detect			
RM7 Drinking Fountain	20420400019DW25A	4/30/2025	ND	Non-Detect			
RM8 Classroom Sink	20420400020CF25A	4/30/2025	ND	Non-Detect			
RM8 Drinking Fountain	20420400021DW25A	4/30/2025	ND	Non-Detect			
RM9 Classroom Sink	20420400022CF25A	4/30/2025	ND	Non-Detect			
RM9 Drinking Fountain	20420400023DW25A	4/30/2025	ND	Non-Detect			
RM11 Drinking Fountain	20420400024DW25A	4/30/2025	ND	Non-Detect			
RM11 Classroom Sink	20420400025CF25A	4/30/2025	ND	Non-Detect			
RM10 Classroom Sink	20420400026CF25A	4/30/2025	1.17	Low			
RM10 Drinking Fountain	20420400027DW25A	4/30/2025	ND	Non-Detect			
Library Sink Behind Desk	20420400028CF25A	4/30/2025	1.54	Low			
Health RM Bathroom Sink	20420400029BF25A	4/30/2025	ND	Non-Detect			
RM12 Drinking Fountain	20420400030DW25A	4/30/2025	ND	Non-Detect			
RM12 Classroom Sink	20420400031CF25A	4/30/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420400032BF25A	4/30/2025	ND	Non-Detect			
Girls Bathroom 2nd from Left Sink	20420400033BF25A	4/30/2025	ND	Non-Detect			
Girls Bathroom 2nd from Right Sink	20420400034BF25A	4/30/2025	ND	Non-Detect			
Girls Bathroom Right Sink	20420400035BF25A	4/30/2025	ND	Non-Detect			
East Lobby Drinking Fountain	20420400036DW25A	4/30/2025	ND	Non-Detect			
East Lobby Single Bathroom Sink	20420400037BF25A	4/30/2025	ND	Non-Detect			
Boys Bathroom Right Sink (Not in Service)	20420400038BF						
Boys Bathroom Middle Sink	20420400039BF25A	4/30/2025	ND	Non-Detect			
Boys Bathroom Left Sink	20420400040BF25A	4/30/2025	ND	Non-Detect			
Vice Principal's Office Sink	20420400041SF25A	4/30/2025	3.63	Low			
Title I Classroom Sink	20420400042CF25A	4/30/2025	1.74	Low			
RM13 Classroom Sink	20420400043CF25A	4/30/2025	ND	Non-Detect			
RM13 Drinking Fountain	20420400044DW25A	4/30/2025	ND	Non-Detect			
RM14 Classroom Sink	20420400045CF25A	4/30/2025	ND	Non-Detect			
RM14 Drinking Fountain	20420400046DW25A	4/30/2025	ND	Non-Detect			
RM15 Classroom Sink	20420400047CF25A	4/30/2025	ND	Non-Detect			
RM15 Drinking Fountain	20420400048DW25A	4/30/2025	ND	Non-Detect			
RM16 Classroom Sink	20420400049CF25A	4/30/2025	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
RM16 Drinking Fountain	20420400050DW25A	4/30/2025	ND	Non-Detect			
RM17 Drinking Fountain	20420400051DW25A	4/30/2025	ND	Non-Detect			
RM17 Classroom Sink	20420400052CF25A	4/30/2025	ND	Non-Detect			
RM18 Classroom Sink	20420400053CF25A	4/30/2025	ND	Non-Detect			
RM18 Drinking Fountain	20420400054DW25A	4/30/2025	ND	Non-Detect			
RM19 Classroom Sink	20420400055CF25A	4/30/2025	ND	Non-Detect			
RM19 Drinking Fountain	20420400056DW25A	4/30/2025	ND	Non-Detect			
RM20 Classroom Sink	20420400057CF25A	4/30/2025	ND	Non-Detect			
RM20 Drinking Fountain	20420400058DW25A	4/30/2025	ND	Non-Detect			
RM21 Classroom Sink	20420400059CF25A	4/30/2025	ND	Non-Detect			
RM21 Drinking Fountain	20420400060DW25A	4/30/2025	ND	Non-Detect			
RM22 Classroom Sink	20420400061CF25A	4/30/2025	ND	Non-Detect			
RM22 Drinking Fountain	20420400062DW25A	4/30/2025	ND	Non-Detect			
Kitchen Left Faucet Double Sink	20420400063KF25B	4/30/2025	46.7	Action Req.	10/29/2025	0.975	Low
Kitchen Right Faucet Double Sink	20420400064KF25A	4/30/2025	0.532	Low			
Kitchen Bathroom Sink	20420400065BF25A	4/30/2025	ND	Non-Detect			
Kitchen Dish Room Sprayer	20420400066KF25A	4/30/2025	ND	Non-Detect			
Gym Womens Outside Bathroom Sink	20420400067BF25A	4/30/2025	ND	Non-Detect			
Gym Mens Outside Bathroom Sink	20420400068BF25A	4/30/2025	ND	Non-Detect			
Gym Left Drinking Fountain	20420400069DW25A	4/30/2025	ND	Non-Detect			
Gym Right Drinking Fountain	20420400070DW25A	4/30/2025	ND	Non-Detect			
Gym Bottle Fill	20420400071WB25A	4/30/2025	ND	Non-Detect			
Sensory Room Bathroom Sink	20420400072BF25A	4/30/2025	6.4	Moderate			
Playground Girls Bathroom Left Sink	20420400073BF25A	4/30/2025	ND	Non-Detect			
Playground Girls Bathroom Right Sink	20420400074BF25A	4/30/2025	ND	Non-Detect			
Playground Drinking Fountain	20420400075DW25A	4/30/2025	ND	Non-Detect			
Playground Boys Bathroom Left Sink	20420400076BF25A	4/30/2025	ND	Non-Detect			
Playground Boys Bathroom Right Sink	20420400077BF25A	4/30/2025	ND	Non-Detect			
Vice Principal's Office Drinking Fountain	20420400078DW25A	5/13/2025	1.84	Low			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

May 15, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Mae Richardson Elem Lead Testing

Order No.: 25041373

Dear Dale Giovannetti:

Neilson Research Corporation received 75 sample(s) on 4/30/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25041373
Date: 5/15/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: Mae Richardson Elem Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-01 Client Sample ID: 20420400001SF25A
Collection Date: 4/30/2025 5:06:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400001SF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.56		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-02 Client Sample ID: 20420400002SF25A
Collection Date: 4/30/2025 5:08:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400002SF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.541		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-03 Client Sample ID: 20420400003SF25A
Collection Date: 4/30/2025 5:18:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400003SF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373

Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-04 Client Sample ID: 20420400004BF25A
Collection Date: 4/30/2025 5:20:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400004BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-05 Client Sample ID: 20420400005BF25A
Collection Date: 4/30/2025 5:23:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400005BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-06 Client Sample ID: 20420400006DW25A
Collection Date: 4/30/2025 5:27:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400006DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373

Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-07 **Client Sample ID:** 20420400007CF25A
Collection Date: 4/30/2025 5:28:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400007CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-08 **Client Sample ID:** 20420400008DW25A
Collection Date: 4/30/2025 5:30:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400008DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-09 **Client Sample ID:** 20420400009CF25A
Collection Date: 4/30/2025 5:31:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400009CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-10 **Client Sample ID:** 20420400011CF25A
Collection Date: 4/30/2025 5:39:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400011CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-11 **Client Sample ID:** 20420400012DW25A
Collection Date: 4/30/2025 5:41:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400012DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-12 **Client Sample ID:** 20420400013CF25A
Collection Date: 4/30/2025 5:42:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400013CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-13 Client Sample ID: 20420400014CF25A
Collection Date: 4/30/2025 5:46:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400014CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-14 Client Sample ID: 20420400015DW25A
Collection Date: 4/30/2025 5:48:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400015DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

Lab ID: 25041373-15 Client Sample ID: 20420400016CF25A
Collection Date: 4/30/2025 5:50:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400016CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst: CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/7/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-16 **Client Sample ID:** 20420400017DW25A
Collection Date: 4/30/2025 5:51:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400017DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-17 **Client Sample ID:** 20420400018CF25A
Collection Date: 4/30/2025 5:53:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400018CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-18 **Client Sample ID:** 20420400019DW25A
Collection Date: 4/30/2025 5:54:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400019DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-19 Client Sample ID: 20420400020CF25A
Collection Date: 4/30/2025 5:56:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400020CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-20 Client Sample ID: 20420400021DW25A
Collection Date: 4/30/2025 5:57:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400021DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-21 Client Sample ID: 20420400024DW25A
Collection Date: 4/30/2025 6:02:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400024DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373

Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-22 Client Sample ID: 20420400025CF25A
Collection Date: 4/30/2025 6:02:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400025CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-23 Client Sample ID: 20420400028CF25A
Collection Date: 4/30/2025 5:48:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400028CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.54		0.515	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-24 Client Sample ID: 20420400029BF25A
Collection Date: 4/30/2025 6:00:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400029BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373

Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-25 Client Sample ID: 20420400030DW25A
Collection Date: 4/30/2025 5:42:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400030DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-26 Client Sample ID: 20420400031CF25A
Collection Date: 4/30/2025 5:49:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400031CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

Lab ID: 25041373-27 Client Sample ID: 20420400032BF25A
Collection Date: 4/30/2025 5:52:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400032BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-28 **Client Sample ID:** 20420400033BF25A
Collection Date: 4/30/2025 5:52:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400033BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

Lab ID: 25041373-29 **Client Sample ID:** 20420400034BF25A
Collection Date: 4/30/2025 5:53:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400034BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

Lab ID: 25041373-30 **Client Sample ID:** 20420400035BF25A
Collection Date: 4/30/2025 5:53:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400035BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-31 **Client Sample ID:** 20420400036DW25A
Collection Date: 4/30/2025 5:54:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400036DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

Lab ID: 25041373-32 **Client Sample ID:** 20420400037BF25A
Collection Date: 4/30/2025 5:15:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400037BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

Lab ID: 25041373-33 **Client Sample ID:** 20420400039BF25A
Collection Date: 4/30/2025 5:36:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400039BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-34 Client Sample ID: 20420400040BF25A
Collection Date: 4/30/2025 5:25:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400040BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

Lab ID: 25041373-35 Client Sample ID: 20420400041SF25A
Collection Date: 4/30/2025 5:23:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400041SF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.63		0.500	ppb	1	5/8/2025	15.0		

Lab ID: 25041373-36 Client Sample ID: 20420400042CF25A
Collection Date: 4/30/2025 5:21:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400042CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.74		0.500	ppb	1	5/8/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-37 Client Sample ID: 20420400043CF25A
Collection Date: 4/30/2025 5:14:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400043CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/8/2025	15.0		

Lab ID: 25041373-38 Client Sample ID: 20420400044DW25A
Collection Date: 4/30/2025 5:14:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400044DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-39 Client Sample ID: 20420400045CF25A
Collection Date: 4/30/2025 5:12:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400045CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-40 **Client Sample ID:** 20420400047CF25A
Collection Date: 4/30/2025 5:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400047CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-41 **Client Sample ID:** 20420400048DW25A
Collection Date: 4/30/2025 5:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400048DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-42 **Client Sample ID:** 20420400049CF25A
Collection Date: 4/30/2025 5:02:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400049CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-43 **Client Sample ID:** 20420400050DW25A
Collection Date: 4/30/2025 5:06:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400050DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-44 **Client Sample ID:** 20420400051DW25A
Collection Date: 4/30/2025 5:03:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400051DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-45 **Client Sample ID:** 20420400052CF25A
Collection Date: 4/30/2025 5:02:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400052CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-46 **Client Sample ID:** 20420400053CF25A
Collection Date: 4/30/2025 4:58:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400053CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-47 **Client Sample ID:** 20420400054DW25A
Collection Date: 4/30/2025 4:58:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400054DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-48 **Client Sample ID:** 20420400055CF25A
Collection Date: 4/30/2025 4:57:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400055CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-49 **Client Sample ID:** 20420400056DW25A
Collection Date: 4/30/2025 4:57:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400056DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-50 **Client Sample ID:** 20420400057CF25A
Collection Date: 4/30/2025 4:55:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400057CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-51 **Client Sample ID:** 20420400058DW25A
Collection Date: 4/30/2025 5:54:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400058DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-52 Client Sample ID: 20420400059CF25A
Collection Date: 4/30/2025 4:53:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400059CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-53 Client Sample ID: 20420400060DW25A
Collection Date: 4/30/2025 4:49:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400060DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-54 Client Sample ID: 20420400061CF25A
Collection Date: 4/30/2025 4:49:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400061CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-55 **Client Sample ID:** 20420400062DW25A
Collection Date: 4/30/2025 4:48:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400062DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-56 **Client Sample ID:** 20420400063KF25A
Collection Date: 4/30/2025 4:35:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400063KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	46.7	*1	0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-57 **Client Sample ID:** 20420400064KF25A
Collection Date: 4/30/2025 4:37:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400064KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.532		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-58 Client Sample ID: 20420400065BF25A
Collection Date: 4/30/2025 4:38:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400065BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-59 Client Sample ID: 20420400066KF25A
Collection Date: 4/30/2025 4:38:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400066KF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-60 Client Sample ID: 20420400067BF25A
Collection Date: 4/30/2025 4:40:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400067BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-61 **Client Sample ID:** 20420400068BF25A
Collection Date: 4/30/2025 4:41:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400068BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-62 **Client Sample ID:** 20420400069DW25A
Collection Date: 4/30/2025 4:43:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400069DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-63 **Client Sample ID:** 20420400070DW25A
Collection Date: 4/30/2025 4:43:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400070DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-64 **Client Sample ID:** 20420400071BF25A
Collection Date: 4/30/2025 4:44:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400071BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-65 **Client Sample ID:** 20420400072BF25A
Collection Date: 4/30/2025 4:45:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400072BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	6.40		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-66 **Client Sample ID:** 20420400073BF25A
Collection Date: 4/30/2025 5:53:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400073BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-67 Client Sample ID: 20420400074BF25A
Collection Date: 4/30/2025 5:33:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400074BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-68 Client Sample ID: 20420400076BF25A
Collection Date: 4/30/2025 5:36:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400076BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-69 Client Sample ID: 20420400075DW25A
Collection Date: 4/30/2025 5:34:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420400075DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-70 **Client Sample ID:** 20420400077BF25A
Collection Date: 4/30/2025 5:36:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420400077BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-71 **Client Sample ID:** 20420400022CF25A
Collection Date: 4/30/2025 5:59:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400022CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-72 **Client Sample ID:** 20420400023DW25A
Collection Date: 4/30/2025 6:00:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420400023DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25041373
Date Reported: 5/15/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25041373
Received Date: 4/30/2025 9:52:00 AM
Reported Date: 5/15/2025 10:25:29 AM

Sample Information:

Lab ID: 25041373-73 Client Sample ID: 20420400026DW25A
Collection Date: 4/30/2025 6:03:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400026DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.17		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-74 Client Sample ID: 20420400027DW25A
Collection Date: 4/30/2025 6:04:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400027DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

Lab ID: 25041373-75 Client Sample ID: 20420400046DW25A
Collection Date: 4/30/2025 5:11:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420400046DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.500	ppb	1	5/9/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041373

15-May-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Mae Richardson Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31147	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/7/2025	RunNo: 59246						
Client ID: PBW	Batch ID: 31147	TestNo: E200.8	E200.8	Analysis Date: 5/7/2025	SeqNo: 967551						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31147	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/7/2025	RunNo: 59246						
Client ID: LCSW	Batch ID: 31147	TestNo: E200.8	E200.8	Analysis Date: 5/7/2025	SeqNo: 967552						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0	104	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25041307-22AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/7/2025	RunNo: 59246						
Client ID: BatchQC	Batch ID: 31147	TestNo: E200.8	E200.8	Analysis Date: 5/7/2025	SeqNo: 967554						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.500	100	0.549	101	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Sample ID: 25041307-22AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/7/2025	RunNo: 59246						
Client ID: BatchQC	Batch ID: 31147	TestNo: E200.8	E200.8	Analysis Date: 5/7/2025	SeqNo: 967555						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.500	100	0.549	101	70	130	101	0.136	20	
------	-----	-------	-----	-------	-----	----	-----	-----	-------	----	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
RL	Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
MI	Recovery outside control limits due to Matrix Interference

DF	Dilution Factor
ND	Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041373

15-May-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Mae Richardson Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31183	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59279						
Client ID: PBW	Batch ID: 31183	TestNo: E200.8	E200.8	Analysis Date: 5/8/2025	SeqNo: 968011						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31183	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59279						
Client ID: LCSW	Batch ID: 31183	TestNo: E200.8	E200.8	Analysis Date: 5/8/2025	SeqNo: 968012						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	102	0.500	100	0	102	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050336-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59279						
Client ID: BatchQC	Batch ID: 31183	TestNo: E200.8	E200.8	Analysis Date: 5/8/2025	SeqNo: 968014						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.5	0.500	100	0.120	99.4	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 25050336-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59279						
Client ID: BatchQC	Batch ID: 31183	TestNo: E200.8	E200.8	Analysis Date: 5/8/2025	SeqNo: 968015						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0.120	103	70	130	99.5	4.06	20	
------	-----	-------	-----	-------	-----	----	-----	------	------	----	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
RL	Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
MI	Recovery outside control limits due to Matrix Interference

DF	Dilution Factor
ND	Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041373

15-May-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Mae Richardson Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31185	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59297						
Client ID: PBW	Batch ID: 31185	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968505						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31185	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59297						
Client ID: LCSW	Batch ID: 31185	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968506						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.500	100	0	100	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25041373-38AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59297						
Client ID: 20420400044DW25A	Batch ID: 31185	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968508						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.8	0.500	100	0.294	97.5	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 25041373-38AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59297						
Client ID: 20420400044DW25A	Batch ID: 31185	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968509						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	104	0.500	100	0.294	104	70	130	97.8	6.27	20	
------	-----	-------	-----	-------	-----	----	-----	------	------	----	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
RL	Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
MI	Recovery outside control limits due to Matrix Interference

DF	Dilution Factor
ND	Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041373

15-May-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Mae Richardson Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31186	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59297						
Client ID: PBW	Batch ID: 31186	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968533						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31186	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59297						
Client ID: LCSW	Batch ID: 31186	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968534						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.500	100	0	101	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25041373-58AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59297						
Client ID: 20420400065BF25A	Batch ID: 31186	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968536						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	98.4	0.500	100	0.359	98.1	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 25041373-58MSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/8/2025	RunNo: 59297						
Client ID: 20420400065BF25A	Batch ID: 31186	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968537						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.4	0.500	100	0.359	95.0	70	130	98.4	3.13	20	
------	------	-------	-----	-------	------	----	-----	------	------	----	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
H	Holding times for preparation or analysis exceeded
RL	Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
MI	Recovery outside control limits due to Matrix Interference

DF	Dilution Factor
ND	Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25041373

15-May-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Mae Richardson Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31207	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/9/2025	RunNo: 59327						
Client ID: PBW	Batch ID: 31207	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968972						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31207	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/9/2025	RunNo: 59327						
Client ID: LCSW	Batch ID: 31207	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968973						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.8	0.520	100	0	95.8	85	115				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: 25041373-16AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/9/2025	RunNo: 59327						
Client ID: 20420400017DW25A	Batch ID: 31207	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968975						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.1	0.520	100	0.183	94.9	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 25041373-16AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/9/2025	RunNo: 59327						
Client ID: 20420400017DW25A	Batch ID: 31207	TestNo: E200.8	E200.8	Analysis Date: 5/9/2025	SeqNo: 968976						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.8	0.520	100	0.183	95.6	70	130	95.1	0.817	20	
------	------	-------	-----	-------	------	----	-----	------	-------	----	--

Qualifiers:

- * Value exceeds Maximum or Minimum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

- C1 Sample container temperature is out of limit as specified at testcode
- MI Recovery outside control limits due to Matrix Interference

- DF Dilution Factor
- ND Not Detected at the Reporting Limit

Original

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25041373

RcptNo: 1

Logged by: Ashley Spiegelberg 4/30/2025 9:52:00 AM

Completed By: Coni Boyko 5/5/2025 10:17:55 AM

Reviewed By: Tamra Schmedemann 5/13/2025 11:23:24 AM

Am
Coni Boyko
Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☒ No ☐ NA ☐
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): MARK LILLIG
Collected By (Sign): [Signature]
Email Report ☒ Yes ___ No ___ Mail Report ___ Yes ___ No
Fax Report ___ Yes ___ No

Section B

Required Project Information

Project Name: MAE RICHARDSON
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
___ 5 Business Days (50% surcharge)
___ 3 Business Days (75% surcharge)
___ 24 - 48 hours (100% surcharge)
___ Other _____
Authorized ___ Yes ___ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420400012DW25A	112097	DW	4-30-25	5:41AM	1	X	25041373		11
20420400013CF25A	130224	DW	4-30-25	5:42AM	1	X			12
20420400014CF25A	130229	DW	4-30-25	5:46AM	1	X			13
20420400015DW25A	130223	DW	4-30-25	5:48AM	1	X			14
20420400016CF25A	130256	DW	4-30-25	5:50AM	1	X			15
20420400017DW25A	112094	DW	4-30-25	5:51AM	1	X			16
20420400018CF25A	130249	DW	4-30-25	5:53AM	1	X			17
20420400019DW25A	130237	DW	4-30-25	5:54AM	1	X			18
20420400020CF25A	130250	DW	4-30-25	5:56AM	1	X			19
20420400021DW25A	130238	DW	4-30-25	5:57AM	1	X			20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Sign	Print	Date	Time
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By Laboratory: <u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>4/30/25</u>	<u>9:52</u>

Section G

Lab Use Only

Temp: Am 5
4°C +/- 2°C: ___ Yes ___ No ___
Received on Ice: ___ Yes ___ No ___
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ___ Yes ___ No ___ (NA)
Field Blank Included: ___ Yes ___ No ___



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email:
Phone: Fax:
Collected By (Print): Jeff Carr
Collected By (Sign): *Jeff Carr*
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name:	Mae Richardson
Project Number:	
Report To:	
Copy To:	

Section C

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Section D

Rush Status (Subject to Scheduling)

☒	Standard 10-14 Days
☐	5 Business Days (50% surcharge)
☐	3 Business Days (75% surcharge)
☐	24 - 48 hours (100% surcharge)
☐	Other _____
Authorized ☐ Yes ☐ No	

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of	Lea											(Lab Use Only)	25041373
							Remarks/Field Data	NRC Sample # (Lab Use Only)										
20420400024DW25A	130227	DW	4-30-25	6:02 AM	1	X												
20420400025CF25A	130228	DW	4-30-25	6:02 AM	1	X											21	
20420400028CF25A	130233	DW	4-30-25	5:48 AM	1	X											22	
20420400029BF25A	112096	DW	4-30-25	6:00 AM	1	X											23	
20420400030DW25A	130253	DW	4-30-25	5:49 AM	1	X											24	
20420400031CF25A	130234	DW	4-30-25	5:49 AM	1	X											25	
20420400032BF25A	130251	DW	4-30-25	5:52 AM	1	X											26	
20420400033BF25A	130252	DW	4-30-25	5:52 AM	1	X											27	
20420400034BF25A	120003	DW	4-30-25	5:53 AM	1	X											28	
20420400035BF25A	120015	DW	4-30-25	5:53 AM	1	X											29	
																	30	

*Matrix: DW - Drinking Water, WW - Wastewater, W - Water, S - Solid, CL - Chlorine, C - Chlorine, M - Manganese

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

	Print	Date	Time
Relinquished By:			
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	Ashley Spiegelberg	4/20/25	9:52

Section G

Lab Use Only

Temp:	Am5	
4°C +/- 2°C:	Yes	No NA
Received on Ice:	Yes	No
Number of Bottles Received:		
pH Checked:		
COC Seals Intact:	Yes	No NA
Field Blank Included:	Yes	No

Received Via ☐ UPS ☐ FedEx ☐ Other ☐ Hand

Payment: Invoice Cash VISA, M/C Check # Amount



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: Mae Richardson
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420400036DW25A	120010	DW	4-30-25	5:54AM	1	X	25041373		31
20420400037BF25A	120009	DW	4-30-25	5:16AM	1	X			32
20420400039BF25A	121829	DW	4-30-25	5:36AM	1	X			33
20420400040BF25A	112288	DW	4-30-25	5:25AM	1	X			34
20420400041SF25A	112289	DW	4-30-25	5:23AM	1	X			35
20420400042CF25A	112266	DW	4-30-25	5:21AM	1	X			36
20420400043CF25A	112300	DW	4-30-25	5:14AM	1	X			37
20420400044DW25A	120020	DW	4-30-25	5:14AM	1	X			38
20420400045CF25A	120025	DW	4-30-25	5:12AM	1	X			39
20420400047CF25A	120021	DW	4-30-25	5:09AM	1	X			40

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Sign	Print	Date	Time
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By Laboratory: <u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>4/30/25</u>	<u>9:52</u>

Section G

Lab Use Only

Temp: Amb
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ☐ Yes ☐ No ☒ NA
Field Blank Included: ☐ Yes ☒ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☐ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: Mae Richardson
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420400043DW25A	120026	DW	4-30-25	5:09 AM	1	X												41
20420400049CF25A	120011	DW	4-30-25	5:02 AM	1	X												42
20420400050DW25A	120008	DW	4-30-25	5:06 AM	1	X												43
20420400051DW25A	120006	DW	4-30-25	5:03 AM	1	X												44
20420400052CF25A	120012	DW	4-30-25	5:02 AM	1	X												45
20420400053CF25A	120022	DW	4-30-25	4:58 AM	1	X												46
20420400054DW25A	120017	DW	4-30-25	4:58 AM	1	X												47
20420400055CF25A	120001	DW	4-30-25	4:57 AM	1	X												48
20420400056DW25A	120002	DW	4-30-25	4:57 AM	1	X												49
20420400057CF25A	120018	DW	4-30-25	4:55 AM	1	X												50

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Sign	Print	Date	Time
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By Laboratory: <u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>4/30/25</u>	<u>9:52</u>

Section G

Lab Use Only

Temp: Amb
4°C +/- 2°C: ☐ Yes ☒ No NA
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: ☐ Yes ☒ No
COC Seals Intact: ☐ Yes ☒ No NA
Field Blank Included: ☐ Yes ☒ No



245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6	
Address: 300 Ash Street	
Central Point OR 97502	
Email:	
Phone:	Fax:
Collected By (Print): Jeff Carr	
Collected By (Sign): 	
Email Report ☒ Yes ☐ No	Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Section B

Required Project Information

Project Name:	Mae Richardson
Project Number:	
Report To:	
Copy To:	

Section C

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Section D

Rush Status (Subject to Scheduling)

☒	Standard 10-14 Days
☐	5 Business Days (50% surcharge)
☐	3 Business Days (75% surcharge)
☐	24 - 48 hours (100% surcharge)
☐	Other _____

Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of	(Lab Use Only)										Remarks/Field Data	NRC Sample # (Lab Use Only)
20420400058DW25A	120000	DW	4-30-25	5:54AM	1	X										51	
20420400059CF25A	120013	DW	4-30-25	4:53AM	1	X										52	
20420400060DW25A	120007	DW	4-30-25	4:49AM	1	X										53	
20420400061CF25A	120023	DW	4-30-25	4:49AM	1	X										54	
20420400062DW25A	120028	DW	4-30-25	4:48AM	1	X										55	
20420400063KF25A	120005	DW	4-30-25	4:35AM	1	X										56	
20420400064KF25A	120014	DW	4-30-25	4:37AM	1	X										57	
20420400065BF25A	120019	DW	4-30-25	4:38AM	1	X										58	
20420400066KF25A	120024	DW	4-30-25	4:38AM	1	X										59	
20420400067BF25A	120029	DW	4-30-25	4:40AM	1	X										60	

*Matrix: DW = Drinking Water; WW = Wastewater; IS = Industrial Solids; S = Sewage Sludge

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Signature	Print	Date	Time
Relinquished By:			
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: 	Ashley Spiesberg	4/30/25	9:52

Section G

Lab Use Only

Temp: Amb
4°C +/- 2°C: Yes No NA
Received on Ice: Yes No
Number of Bottles Received:
pH Checked:
COC Seals Intact: Yes No NA
Field Blank Included: Yes No

Received Via ☐ UPS ☐ FedEx ☐ Other ☐ Hand

Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # Amount

Chain of Custody Record

Page ____ of ____

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>Mae Richardson</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: Fax:			☐ Other
Collected By (Print): <u>Jeff Carr</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420400068BF25A	120027	DW	4-30-25	4:41AM	1	X												61
20420400069DW25A	119990	DW	4-30-25	4:43AM	1	X												62
20420400070DW25A	119989	DW	4-30-25	4:43AM	1	X												63
20420400071BF25A	119995	DW	4-30-25	4:44AM	1	X												64
20420400072BF25A	119993	DW	4-30-25	4:45AM	1	X												65
20420400073BF25A	119985	DW	4-30-25	5:33AM	1	X												66
20420400074BF25A	119984	DW	4-30-25	5:33AM	1	X												67
20420400076BF25A	119978	DW	4-30-25	5:36AM	1	X												68
20420400075DW25A	119979	DW	4-30-25	5:34AM	1	X												69
20420400077BF25A	119976	DW	4-30-25	5:36AM	1	X												70

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>4/30/25</u>	<u>9:52</u>

Section G Lab Use Only

Temp: <u>Am5</u>
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received:
pH Checked: <u>—</u>
COC Seals Intact: ☐ Yes ☐ No ☒ NA
Field Blank Included: ☐ Yes ☒ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6	
Address: 300 Ash Street	
Central Point OR 97502	
Email:	
Phone:	Fax:
Collected By (Print): MARK WILLICH	
Collected By (Sign): <i>Mark Willich</i>	
Email Report ☒ Yes ___ No	Mail Report ___ Yes ___ No
Fax Report ___ Yes ___ No	

Section B

Required Project Information

Project Name:	MAE RICHARDSON
Project Number:	
Report To:	
Copy To:	

Section C
Invoice Information

Attention:
Company Name:
Address:
P.O. #

Section D
Rush Status (Subject to Scheduling)

☒	Standard 10-14 Days	
☐	5 Business Days (50% surcharge)	
☐	3 Business Days (75% surcharge)	
☐	24 - 48 hours (100% surcharge)	
☐	Other _____	
	Authorized _____	Yes No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of								(Lab Use Only)	NRC Sample # (Lab Use Only)
													Remarks/Field Data	
20420400022CF25A	112100	DW	4-30-25	5:59AM	1	X								71
20420400023DW25A	112095	DW	4-30-25	6:00 AM	1	X								72
20420400026 DW25A	130231	DW	4-30-25	6:03AM	1	X								73
20420400027 DW 25A	130232	DW	4-30-25	6:104A-M	1	X								74
20420400046 DW 25A	120016	DW	4-30-25	5:11AM	1	X								75

*Matrix: DW - Drinking Water; WW - Wastewater; W - Water; C - Cooling Water; S - Sewage; L - Leachate

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By:	Print	Date	Time
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	Ashley Spieselberg	4/30/25	9:52

Section G
Lab Use Only

Temp: 4°C

4°C +/- 2°C: Yes No NA

Received on Ice: Yes No

Number of Bottles Received:

pH Checked:

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

 UPS FedEx Other Hand

M/C Check # Amount

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
- A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
- B Analyte detected in the associated method blank.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
- R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
- R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
- 1 Value exceeds one half of the Maximum Contaminant Level.



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

October 31, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Mae Richardson Elem Lead Testing

Order No.: 25101198

Dear Dale Giovannetti:

Neilson Research Corporation received 1 sample(s) on 10/27/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25101198
Date: 10/31/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem

Project: Mae Richardson Elem Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25101198

Date Reported: 10/31/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25101198
Received Date: 10/27/2025 9:55:00 AM
Reported Date: 10/31/2025 10:33:39 AM

Sample Information:

Lab ID: 25101198-01 Client Sample ID: 2042040063KF25B
Collection Date: 10/25/2025 6:57:00 AM Collected By:
Matrix: Drinking Water Sample Location: 2042040063KF25B

Trace Metals by EPA 200.8 ICP-MS							Analyst: KHG	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.975		0.500	ppb	1	10/29/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25101198
31-Oct-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Mae Richardson Elem Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-33462	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: PBW	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058429
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.500			

Sample ID: LCS-33462	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: LCSW	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058430
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	102	0.500	100	0	102 85 115

Sample ID: 25101193-04AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: BatchQC	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058432
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	101	0.500	100	0.869	100 70 130

Sample ID: 25101193-04AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: BatchQC	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058433
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	101	0.500	100	0.869	101 70 130 101 0.346 20

Qualifiers:
* Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25101198

RcptNo: 1

Logged by: Ashley Spiegelberg 10/27/2025 9:55:00 AM
Completed By: Kyler Woolsey 10/29/2025 11:51:18 AM
Reviewed By: Dorie Evans 10/31/2025 10:29:50 AM

Am
Kyler Woolsey
Dorie Evans

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☐ NA ☒
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

