

Lead in Water Test Results Summary: Patrick Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
GYMNASIUM							
Kitchen Sink by Door	20420301001KF25A	5/2/2025	6.03	Moderate			
Kitchen Dish Room Sprayer	20420301002KF25A	5/2/2025	ND	Non-Detect			
Kitchen Sink by Gym Door	20420301003KF25A	5/2/2025	0.536	Low			
Kitchen Sink Beneath Window	20420301004KF25A	5/2/2025	0.626	Low			
Gym Girls Bathroom Left Sink	20420301005BF25A	5/2/2025	ND	Non-Detect			
Gym Girls Bathroom Right Sink	20420301006BF25A	5/2/2025	ND	Non-Detect			
Gym Boys Bathroom Left Sink	20420301007BF25A	5/2/2025	ND	Non-Detect			
Gym Boys Bathroom Right Sink	20420301008BF25A	5/2/2025	ND	Non-Detect			
Gym Left Drinking Fountain	20420301009DW25A	5/2/2025	ND	Non-Detect			
Gym Right Drinking Fountain	20420301010DW25A	5/2/2025	ND	Non-Detect			
Gym Bottle Fill	20420301011WB25A	5/2/2025	ND	Non-Detect			
Smart Room Sink	20420301012CF25A	5/2/2025	1.35	Low			
Kitchen Kettle Fill	20420301013KF25A	5/14/2025	0.145	Low			
SECOND WING							
RM5 Classroom Sink	20420302001CF25A	5/2/2025	ND	Non-Detect			
RM5 Drinking Fountain	20420302002DW25A	5/2/2025	ND	Non-Detect			
RM6 Classroom Sink	20420302003CF25A	5/2/2025	ND	Non-Detect			
RM6 Drinking Fountain	20420302004DW25A	5/2/2025	ND	Non-Detect			
RM7 Classroom Sink	20420302005CF25A	5/2/2025	ND	Non-Detect			
RM7 Drinking Fountain	20420302006DW25A	5/2/2025	ND	Non-Detect			
RM8 Classroom Sink	20420302007CF25A	5/2/2025	ND	Non-Detect			
RM8 Drinking Fountain	20420302008DW25A	5/2/2025	ND	Non-Detect			
THIRD WING							
Staffroom Sink by Library	20420303001SF25A	5/2/2025	ND	Non-Detect			
Womens Staff Bathroom Sink	20420303002BF25A	5/2/2025	ND	Non-Detect			
Mens Staff Bathroom Sink	20420303003BF25A	5/2/2025	ND	Non-Detect			
RM9 Drinking Fountain	20420303004DW25A	5/2/2025	ND	Non-Detect			
RM9 Classroom Sink	20420303005CF25A	5/2/2025	ND	Non-Detect			
RM9 Bathroom Sink	20420303006BF25A	5/2/2025	1.42	Low			
RM10 Drinking Fountain	20420303007DW25A	5/2/2025	ND	Non-Detect			
RM10 Classroom Sink	20420303008CF25A	5/2/2025	ND	Non-Detect			
RM10 Bathroom Sink	20420303009BF25A	5/2/2025	3.73	Low			
RM11 Drinking Fountain	20420303010DW25A	5/2/2025	ND	Non-Detect			
RM11 Classroom Sink	20420303011CF25A	5/2/2025	ND	Non-Detect			
RM11 Bathroom Sink	20420303012BF25A	5/2/2025	3.83	Low			
RM13 Classroom Sink	20420303013CF25A	5/2/2025	ND	Non-Detect			
RM13 Drinking Fountain	20420303014DW25A	5/2/2025	ND	Non-Detect			
RM13 Bathroom Sink	20420303015BF25A	5/2/2025	1.31	Low			
RM12 Classroom Sink	20420303016CF25A	5/2/2025	ND	Non-Detect			
RM12 Drinking Fountain	20420303017DW25A	5/2/2025	ND	Non-Detect			
RM12 Bathroom Sink	20420303018BF25A	5/2/2025	0.525	Low			
FOURTH WING							
Boys Bathroom Left Sink	20420304001BF25A	5/2/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420304002BF25A	5/2/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420304003BF25A	5/2/2025	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Girls Bathroom Right Sink	20420304004BF25A	5/2/2025	ND	Non-Detect			
RM14 Drinking Fountain	20420304005DW25A	5/2/2025	ND	Non-Detect			
RM14 Classroom Sink	20420304006CF25A	5/2/2025	ND	Non-Detect			
RM15 Drinking Fountain	20420304007DW25A	5/2/2025	ND	Non-Detect			
RM15 Classroom Sink	20420304008CF25A	5/2/2025	ND	Non-Detect			
RM16 Drinking Fountain	20420304009DW25A	5/2/2025	ND	Non-Detect			
RM16 Classroom Sink	20420304010CF25A	5/2/2025	ND	Non-Detect			
RM19 Classroom Sink	20420304011CF25A	5/2/2025	ND	Non-Detect			
RM19 Drinking Fountain	20420304012DW25A	5/2/2025	ND	Non-Detect			
RM18 Classroom Sink	20420304013CF25A	5/2/2025	ND	Non-Detect			
RM18 Drinking Fountain	20420304014DW25A	5/2/2025	ND	Non-Detect			
RM17 Classroom Sink	20420304015CF25A	5/2/2025	ND	Non-Detect			
RM17 Drinking Fountain	20420304016DW25A	5/2/2025	ND	Non-Detect			
FRONT WING							
La Clinica Nurse Sink	20420300001NS25A	5/2/2025	5.42	Moderate			
Principal's Office Sink	20420300003SF25A	5/2/2025	ND	Non-Detect			
RM1 Bathroom Sink	20420300004BF25A	5/2/2025	ND	Non-Detect			
RM1 Classroom Sink	20420300005CF25A	5/2/2025	ND	Non-Detect			
RM1 Drinking Fountain	20420300006DW25A	5/2/2025	ND	Non-Detect			
RM2 Bathroom Sink	20420300007BF25A	5/2/2025	ND	Non-Detect			
RM2 Classroom Sink	20420300008CF25A	5/2/2025	ND	Non-Detect			
RM2 Drinking Fountain	20420300009DW25A	5/2/2025	ND	Non-Detect			
RM3 Bathroom Sink	20420300010BF25A	5/2/2025	0.521	Low			
RM3 Classroom Sink	20420300011CF25A	5/2/2025	ND	Non-Detect			
RM3 Drinking Fountain	20420300012DW25A	5/2/2025	ND	Non-Detect			
RM4 Bathroom Sink	20420300013BF25A	5/2/2025	ND	Non-Detect			
RM4 Classroom Sink	20420300014CF25A	5/2/2025	ND	Non-Detect			
RM4 Drinking Fountain	20420300015DW25A	5/2/2025	ND	Non-Detect			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

May 16, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Patrick Elem Lead Testing-AMENDED

Order No.: 25050084

Dear Dale Giovannetti:

Neilson Research Corporation received 68 sample(s) on 5/2/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050084
Date: 5/16/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem

Project: Patrick Elem Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-01 Client Sample ID: 20420302001CF25A
Collection Date: 5/2/2025 5:07:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420302001CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-02 Client Sample ID: 20420302002DW25A
Collection Date: 5/2/2025 5:08:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420302002DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-03 Client Sample ID: 20420302003CF25A
Collection Date: 5/2/2025 5:11:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420302003CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-04 **Client Sample ID:** 20420302004DW25A
Collection Date: 5/2/2025 5:12:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420302004DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-05 **Client Sample ID:** 20420302005CF25A
Collection Date: 5/2/2025 5:12:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420302005CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-06 **Client Sample ID:** 20420302006DW25A
Collection Date: 5/2/2025 5:16:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420302006DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-07 **Client Sample ID:** 20420302007CF25A
Collection Date: 5/2/2025 5:18:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420302007CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-08 **Client Sample ID:** 20420302008DW25A
Collection Date: 5/2/2025 5:19:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420302008DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-09 **Client Sample ID:** 20420303001SF25A
Collection Date: 5/2/2025 5:23:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420303001SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-10 Client Sample ID: 20420303002BF25A
Collection Date: 5/2/2025 5:25:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303002BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-11 Client Sample ID: 20420303003BF25A
Collection Date: 5/2/2025 5:26:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303003BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-12 Client Sample ID: 20420303004DW25A
Collection Date: 5/2/2025 5:28:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303004DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-13 Client Sample ID: 20420303005CF25A
Collection Date: 5/2/2025 5:29:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303005CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-14 Client Sample ID: 20420303006BF25A
Collection Date: 5/2/2025 5:31:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303006BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.42		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-15 Client Sample ID: 20420303007DW25A
Collection Date: 5/2/2025 5:33:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303007DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-16 **Client Sample ID:** 20420303008CF25A
Collection Date: 5/2/2025 5:34:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420303008CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-17 **Client Sample ID:** 20420303009BF25A
Collection Date: 5/2/2025 5:35:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420303009BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.73		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-18 **Client Sample ID:** 20420303010DW25A
Collection Date: 5/2/2025 5:38:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420303010DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-19 Client Sample ID: 20420303011CF25A
Collection Date: 5/2/2025 5:39:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303011CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-20 Client Sample ID: 20420303012BF25A
Collection Date: 5/2/2025 5:39:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303012BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.83		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-21 Client Sample ID: 20420303013CF25A
Collection Date: 5/2/2025 5:43:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303013CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-22 Client Sample ID: 20420303014DW25A
Collection Date: 5/2/2025 5:44:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303014DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-23 Client Sample ID: 20420303015BF25A
Collection Date: 5/2/2025 5:45:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303015BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.31		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-24 Client Sample ID: 20420303016CF25A
Collection Date: 5/2/2025 5:49:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303016CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-25 Client Sample ID: 20420303017DW25A
Collection Date: 5/2/2025 5:50:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303017DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-26 Client Sample ID: 20420303018BF25A
Collection Date: 5/2/2025 5:51:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420303018BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.525		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-27 Client Sample ID: 20420304015CF25A
Collection Date: 5/2/2025 5:56:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420304015CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-28 Client Sample ID: 20420304016DW25A
Collection Date: 5/2/2025 5:56:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420304016DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-29 Client Sample ID: 20420304005DW25A
Collection Date: 5/2/2025 5:44:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304005DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-30 Client Sample ID: 20420304006CF25A
Collection Date: 5/2/2025 5:45:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304006CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-31 Client Sample ID: 20420304007DW25A
Collection Date: 5/2/2025 5:46:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304007DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-32 Client Sample ID: 20420304008CF25A
Collection Date: 5/2/2025 5:46:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304008CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-33 Client Sample ID: 20420304009DW25A
Collection Date: 5/2/2025 5:49:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304009DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-34 Client Sample ID: 20420304010CF25A
Collection Date: 5/2/2025 5:50:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304010CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-35 Client Sample ID: 20420304011CF25A
Collection Date: 5/2/2025 5:51:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304011CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-36 Client Sample ID: 20420304012DW25A
Collection Date: 5/2/2025 5:51:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304012DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-37 Client Sample ID: 20420304013CF25A
Collection Date: 5/2/2025 5:54:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304013CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-38 Client Sample ID: 20420304014DW25A
Collection Date: 5/2/2025 5:54:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420304014DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	5/12/2025	15.0	A

Lab ID: 25050084-39 Client Sample ID: 20420301007BF25A
Collection Date: 5/2/2025 5:28:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420301007BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-40 **Client Sample ID:** 20420301008BF25A
Collection Date: 5/2/2025 5:29:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420301008BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-41 **Client Sample ID:** 20420301009DW25A
Collection Date: 5/2/2025 5:31:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420301009DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-42 **Client Sample ID:** 20420301010DW25A
Collection Date: 5/2/2025 5:32:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420301010DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-43 **Client Sample ID:** 20420301011WB25A
Collection Date: 5/2/2025 5:33:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420301011WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-44 **Client Sample ID:** 20420301012CF25A
Collection Date: 5/2/2025 5:34:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420301012CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.35		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-45 **Client Sample ID:** 20420304001BF25A
Collection Date: 5/2/2025 5:39:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420304001BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-46 **Client Sample ID:** 20420304002BF25A
Collection Date: 5/2/2025 5:40:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420304002BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-47 **Client Sample ID:** 20420304003BF25A
Collection Date: 5/2/2025 5:41:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420304003BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-48 **Client Sample ID:** 20420304004BF25A
Collection Date: 5/2/2025 5:41:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420304004BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-49 Client Sample ID: 20420300012DW25A
Collection Date: 5/2/2025 5:10:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420300012DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-50 Client Sample ID: 20420300013BF25A
Collection Date: 5/2/2025 5:19:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420300013BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-51 Client Sample ID: 20420300014CF25A
Collection Date: 5/2/2025 5:19:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420300014CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-52 Client Sample ID: 20420300015DW25A
Collection Date: 5/2/2025 5:20:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420300015DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-53 Client Sample ID: 20420301001KF25A
Collection Date: 5/2/2025 5:22:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420301001KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.03		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-54 Client Sample ID: 20420301002KF25A
Collection Date: 5/2/2025 5:23:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420301002KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-55 Client Sample ID: 20420301003KF25A
Collection Date: 5/2/2025 5:24:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420301003KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.536		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-56 Client Sample ID: 20420301004KF25A
Collection Date: 5/2/2025 5:25:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420301004KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.626		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-57 Client Sample ID: 20420301005BF25A
Collection Date: 5/2/2025 5:27:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420301005BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-58 Client Sample ID: 20420301006BF25A
Collection Date: 5/2/2025 5:28:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420301006BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-59 Client Sample ID: 20420300001NS25A
Collection Date: 5/2/2025 5:02:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420300001NS25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.42		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-60 Client Sample ID: 20420300003SF25A
Collection Date: 5/2/2025 5:06:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420300003SF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-61 **Client Sample ID:** 20420300004BF25A
Collection Date: 5/2/2025 5:07:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420300004BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-62 **Client Sample ID:** 20420300005CF25A
Collection Date: 5/2/2025 5:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420300005CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-63 **Client Sample ID:** 20420300006DW25A
Collection Date: 5/2/2025 5:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420300006DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084

Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-64 **Client Sample ID:** 20420300007BF25A
Collection Date: 5/2/2025 5:09:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420300007BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-65 **Client Sample ID:** 20420300008CF25A
Collection Date: 5/2/2025 5:11:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420300008CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-66 **Client Sample ID:** 20420300009DW25A
Collection Date: 5/2/2025 5:12:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420300009DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050084
Date Reported: 5/16/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050084
Received Date: 5/2/2025 9:22:00 AM
Reported Date: 5/16/2025 12:26:14 PM

Sample Information:

Lab ID: 25050084-67 **Client Sample ID:** 20420300010BF25A
Collection Date: 5/2/2025 5:14:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420300010BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.521		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050084-68 **Client Sample ID:** 20420300011CF25A
Collection Date: 5/2/2025 5:15:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420300011CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050084
17-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Patrick Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31225	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2025	RunNo: 59366
Client ID: PBW	Batch ID: 31225	TestNo: E200.8	E200.8	Analysis Date: 5/12/2025	SeqNo: 969947
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.500			
------	----	-------	--	--	--

Sample ID: LCS-31225	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2025	RunNo: 59366
Client ID: LCSW	Batch ID: 31225	TestNo: E200.8	E200.8	Analysis Date: 5/12/2025	SeqNo: 969948
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	96.8	0.500	100	0	96.8 85 115
------	------	-------	-----	---	-------------

Sample ID: 25050486-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2025	RunNo: 59366
Client ID: BatchQC	Batch ID: 31225	TestNo: E200.8	E200.8	Analysis Date: 5/12/2025	SeqNo: 969950
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	89.6	0.500	100	0	89.6 70 130
------	------	-------	-----	---	-------------

Sample ID: 25050486-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2025	RunNo: 59366
Client ID: BatchQC	Batch ID: 31225	TestNo: E200.8	E200.8	Analysis Date: 5/12/2025	SeqNo: 969951
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	91.7	0.500	100	0	91.7 70 130 89.6 2.30 20
------	------	-------	-----	---	--------------------------

Qualifiers:	C1 Sample container temperature is out of limit as specified at testcode	DF Dilution Factor	H Holding times for preparation or analysis exceed
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050084
17-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Patrick Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31227	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2025	RunNo: 59366						
Client ID: PBW	Batch ID: 31227	TestNo: E200.8	E200.8	Analysis Date: 5/12/2025	SeqNo: 969973						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31227	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2025	RunNo: 59366						
Client ID: LCSW	Batch ID: 31227	TestNo: E200.8	E200.8	Analysis Date: 5/12/2025	SeqNo: 969974						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.520	100	0	102	85	115				

Sample ID: 25050029-51AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2025	RunNo: 59366						
Client ID: BatchQC	Batch ID: 31227	TestNo: E200.8	E200.8	Analysis Date: 5/12/2025	SeqNo: 969976						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	95.4	0.520	100	0.440	94.9	70	130				

Sample ID: 25050029-51AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/12/2025	RunNo: 59366						
Client ID: BatchQC	Batch ID: 31227	TestNo: E200.8	E200.8	Analysis Date: 5/12/2025	SeqNo: 969977						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	95.4	0.520	100	0.440	94.9	70	130	95.4	0.00109	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed
RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050084
17-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Patrick Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31253	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59420						
Client ID: PBW	Batch ID: 31253	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970883						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31253	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59420						
Client ID: LCSW	Batch ID: 31253	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970884						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.8	0.520	100	0	97.8	85	115				

Sample ID: 25050084-14AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59420						
Client ID: 20420303006BF25A	Batch ID: 31253	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970886						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.1	0.520	100	1.42	96.6	70	130				

Sample ID: 25050084-14AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59420						
Client ID: 20420303006BF25A	Batch ID: 31253	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970887						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	96.1	0.520	100	1.42	94.6	70	130	98.1	2.05	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed
RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050084
17-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Patrick Elem Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31254	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424
Client ID: PBW	Batch ID: 31254	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970995
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31254	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424
Client ID: LCSW	Batch ID: 31254	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970996
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.520 100 0 103 85 115

Sample ID: 25050084-50AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424
Client ID: 20420300013BF25A	Batch ID: 31254	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970998
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.520 100 0.202 103 70 130

Sample ID: 25050084-50AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424
Client ID: 20420300013BF25A	Batch ID: 31254	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 970999
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.520 100 0.202 102 70 130 103 1.18 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25050084

RcptNo: 1

Logged by: Ashley Spiegelberg 5/2/2025 9:22:00 AM
Completed By: Coni Boyko 5/7/2025 5:03:38 PM
Reviewed By: Tamra Schmedemann 5/16/2025 12:22:44 PM

Am
Coni Boyko
Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

25050084-59A The sample submitted contained visible sediments and was tan in color.

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 2 of 7

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>PATRICK ELEM</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: Fax:						☐ Other	
Collected By (Print): <u>MARK LILLICH</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420303003BF25A	130538	DW	5-2-25	5:26AM	1	LEAD	25050084		11
20420303004DW25A	130539	DW	5-2-25	5:28AM	1				12
20420303005CF25A	130546	DW	5-2-25	5:29AM	1				13
20420303006BF25A	130548	DW	5-2-25	5:31AM	1				14
20420303007DW25A	130547	DW	5-2-25	5:33AM	1				15
20420303008CF25A	130451	DW	5-2-25	5:34AM	1				16
20420303009BF25A	130535	DW	5-2-25	5:35AM	1				17
20420303010DW25A	130527	DW	5-2-25	5:38AM	1				18
20420303011CF25A	130528	DW	5-2-25	5:39AM	1				19
20420303012BF25A	130529	DW	5-2-25	5:39AM	1				20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>6/2/25</u>	<u>9:22</u>

Section G Lab Use Only

Temp: <u>Amb</u>
4°C +/- 2°C: ☐ Yes ☒ No <u>NA</u>
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received:
pH Checked:
COC Seals Intact: ☐ Yes ☐ No ☒ NA
Field Blank Included: ☐ Yes ☐ No

Chain of Custody Record

Page 3 of 7

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>PATRICK ELEM.</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:		☐ 24 - 48 hours (100% surcharge)
Phone: Fax:		P.O. #	☐ Other
Collected By (Print): <u>MARK LILLICH</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050084</u>	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420303013 CF25A	130530	DW	5-2-25	5:43 AM	1	X												21
20420303014 DW25A	130531	DW	5-2-25	5:44 AM	1	X												22
20420303015 BF25A	130452	DW	5-2-25	5:45 AM	1	X												23
20420303016 CF25A	130439	DW	5-2-25	5:49 AM	1	X												24
20420303017 DW25A	130440	DW	5-2-25	5:50 AM	1	X												25
20420303018 BF25A	130441	DW	5-2-25	5:51 AM	1	X												26
20420304015 CF25A	130454	DW	5-2-25	5:56 AM	1	X												27
20420304016 DW25A	130458	DW	5-2-25	5:56 AM	1	X												28
		DW	5-2-25		1	X												
		DW	5-2-25		1	X												

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>5/2/25</u>	<u>9:22</u>

Section G Lab Use Only

Temp:	<u>Amb</u>
4°C +/- 2°C:	☐ Yes ☒ No <u>NA</u>
Received on Ice:	☐ Yes ☐ No
Number of Bottles Received:	
pH Checked:	
COC Seals Intact:	☐ Yes ☐ No ☐ NA
Field Blank Included:	☐ Yes ☐ No
Received Via	☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment:	☐ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount



Chain of Custody Record

Page 4 of 7

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>Patricis</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:		☐ 24 - 48 hours (100% surcharge)
Phone: Fax:		P.O. #	☐ Other
Collected By (Print): <u>Jeff Carr</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050084</u>		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers											Remarks/Field Data	NRC Sample # (Lab Use Only)
20420304005DW25A	130543	DW	5-2-25	5:44AM	1	X											29
20420304006CF25A	130541	DW	5-2-25	5:45AM	1	X											30
20420304007DW25A	130533	DW	5-2-25	5:46AM	1	X											31
20420304008CF25A	130558	DW	5-2-25	5:46AM	1	X											32
20420304009DW25A	130545	DW	5-2-25	5:49AM	1	X											33
20420304010CF25A	130542	DW	5-2-25	5:50AM	1	X											34
20420304011CF25A	130457	DW	5-2-25	5:51AM	1	X											35
20420304012DW25A	130534	DW	5-2-25	5:51AM	1	X											36
20420304013CF25A	130446	DW	5-2-25	5:54AM	1	X											37
20420304014DW25A	130445	DW	5-2-25	5:54AM	1	X											38

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelburg</u>	<u>5/2/25</u>	<u>9:22</u>

Section G Lab Use Only
Temp: <u>Amb</u>
4°C +/- 2°C: ☐ Yes ☒ No <u>N/A</u>
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received:
pH Checked:
COC Seals Intact: ☐ Yes ☐ No ☐ NA
Field Blank Included: ☐ Yes ☐ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 5 of 7

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>Patricia's</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: Fax:			☐ Other
Collected By (Print): <u>Jeff Carr</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420301007BF25A	112006	DW	5-2-25	5:29AM	1	X		25050084		39
20420301008BF25A	130553	DW	5-2-25	5:29AM	1	X				40
20420301009DW25A	130551	DW	5-2-25	5:31AM	1	X				41
20420301010DW25A	130554	DW	5-2-25	5:32AM	1	X				42
20420301011WB25A	112003	DW	5-2-25	5:33AM	1	X				43
20420301012LF25A	111972	DW	5-2-25	5:34AM	1	X				44
20420304001BF25A	130532	DW	5-2-25	5:39AM	1	X				45
20420304002BF25A	130544	DW	5-2-25	5:40AM	1	X				46
20420304003BF25A	130540	DW	5-2-25	5:41AM	1	X				47
20420304004BF25A	130557	DW	5-2-25	5:41AM	1	X				48

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spigelberg</u>	<u>5/2/25</u>	<u>9:22</u>

Section G Lab Use Only

Temp: <u>Amb</u>
4°C +/- 2°C: ☐ Yes ☒ No <u>NA</u>
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received:
pH Checked:
COC Seals Intact: ☐ Yes ☒ No <u>NA</u>
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☒ Other <u>Hand</u>
Payment: ☒ Invoice ☐ Cash ☐ VISA/M/C ☐ Check # ☐ Amount



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 6 of 7

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Patricia's</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>Jeff Carr</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050084</u>	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420300012 DW25A	112023	DW	5-2-25	5:10AM	1	X												49
20420300013 BF25A	112062	DW	5-2-25	5:19AM	1	X												50
20420300014 CF25A	112025	DW	5-2-25	5:19AM	1	X												51
20420300015 DW25A	130555	DW	5-2-25	5:20AM	1	X												52
20420301001 KF25A	130549	DW	5-2-25	5:22AM	1	X												53
20420301002 KF25A	130550	DW	5-2-25	5:23AM	1	X												54
20420301003 KF25A	111984	DW	5-2-25	5:24AM	1	X												55
20420301004 KF25A	111974	DW	5-2-25	5:25AM	1	X												56
20420301005 BF25A	130556	DW	5-2-25	5:27AM	1	X												57
20420301006 BF25A	130552	DW	5-2-25	5:28AM	1	X												58

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>5/2/25</u>	<u>9:22</u>

Section G

Lab Use Only	
Temp: <u>AmB</u>	
4°C +/- 2°C: ☐ Yes ☒ No <u>NA</u>	
Received on Ice: ☐ Yes ☒ No	
Number of Bottles Received:	
pH Checked:	
COC Seals Intact: ☐ Yes ☒ No <u>NA</u>	
Field Blank Included: ☐ Yes ☒ No	
Received Via: ☒ UPS ☐ FedEx ☐ Other <u>Hand</u>	
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____	



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 7 of 7

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>Patricia's</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: Fax:			Other _____
Collected By (Print): <u>Jeff Carr</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	lead	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420300001NS25A	111993	DW	5-2-25	5:02AM	1	X		25050084		59
20420300003SF25A	112022	DW	5-2-25	5:06AM	1	X				60
20420300004BF25A	112036	DW	5-2-25	5:07AM	1	X				61
20420300005CF25A	111996	DW	5-2-25	5:09AM	1	X				62
20420300006DW25A	111994	DW	5-2-25	5:09AM	1	X				63
20420300007BF25A	112004	DW	5-2-25	5:09AM	1	X				64
20420300008CF25A	111971	DW	5-2-25	5:11AM	1	X				65
20420300009DW25A	111981	DW	5-2-25	5:12AM	1	X				66
20420300010BF25A	111982	DW	5-2-25	5:14AM	1	X				67
20420300011CF25A	111995	DW	5-2-25	5:15AM	1	X				68

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Ashley Spiegelberg</u>	<u>5/2/25</u>	<u>902</u>

Section G Lab Use Only

Temp: <u>4°C</u>
4°C +/- 2°C: ☒ Yes ☐ No <u>NA</u>
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ☐ Yes ☐ No <u>NA</u>
Field Blank Included: ☐ Yes ☐ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment ☐ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

May 19, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Patrick Lead Testing

Order No.: 25050744

Dear Dale Giovannetti:

Neilson Research Corporation received 1 sample(s) on 5/14/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050744
Date: 5/19/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: Patrick Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050744
Date Reported: 5/19/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050744
Received Date: 5/14/2025 10:18:00 AM
Reported Date: 5/19/2025 8:32:37 PM

Sample Information:

Lab ID: 25050744-01 Client Sample ID: 20420301013KF25A
Collection Date: 5/14/2025 5:05:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420301013KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.145	J	0.500	ppb	1	5/19/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050744

19-May-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Patrick Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31312	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544						
Client ID: PBW	Batch ID: 31312	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973121						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.500									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31312	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544						
Client ID: LCSW	Batch ID: 31312	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973122						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	112	0.500	100	0	112	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: LCS-31312	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544						
Client ID: LCSW	Batch ID: 31312	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973123						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	113	0.500	100	0	113	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: 25050683-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544						
Client ID: BatchQC	Batch ID: 31312	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973125						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	105	0.500	100	0.118	105	70	130				
------	-----	-------	-----	-------	-----	----	-----	--	--	--	--

Qualifiers:	C1	Sample container temperature is out of limit as specified at testcode	DF	Dilution Factor	H	Holding times for preparation or analysis exceed
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	RL	Reporting Limit				

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050744

19-May-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Patrick Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050683-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/16/2025	RunNo: 59544						
Client ID: BatchQC	Batch ID: 31312	TestNo: E200.8	E200.8	Analysis Date: 5/19/2025	SeqNo: 973126						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	105	0.500	100	0.118	105	70	130	105	0.0200	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
J Analyte detected below quantitation limits
RL Reporting Limit

DF Dilution Factor
MI Recovery outside control limits due to Matrix Interference

H Holding times for preparation or analysis exceed
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25050744

RcptNo: 1

Logged by: Danielle Garten 5/14/2025 10:18:00 AM

Danielle Garten

Completed By: Coni Boyko 5/16/2025 1:34:02 PM

Coni Boyko

Reviewed By: Tamra Schmedemann 5/19/2025 7:50:52 PM

Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels?
(Note discrepancies on chain of custody) Yes ☒ No ☐
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met?
(If no, notify customer for authorization.) Yes ☒ No ☐

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified:

Date:

By Whom:

Via:

☐ eMail

☐ Phone

☐ Fax

☐ In Person


Regarding:

Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section D
Rush Status (Subject to Scheduling)

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days

☐ 5 Business Days (50% surcharge)

☐ 3 Business Days (75% surcharge)

☐ 24 - 48 hours (100% surcharge)

☐ Other _____

Authorized ☐ Yes ☐ No

Analysis Requested

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Time

Relinquished By:	Print	Date	Time
Relinquished By: <i>Jeff Carr</i>	<i>Jeff Carr</i>	<i>10-5-14-25</i>	<i>10:18 AM</i>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: <i>Danielle Gault</i>	<i>Danielle Gault</i>	<i>5/14/15</i>	<i>12:00</i>

Temp: AMB
4°C +/- 2°C: Yes No
Received on Ice: Yes No
Number of Bottles Received:
pH Checked:
COC Seals Intact: Yes No NA
Field Blank Included: Yes NO
 UPS FedEx Other Hand
 M/C Check # Amount

Received Via UPS FedEX Other Hand

Payment: Invoice Cash VISA, M/C Check # Amount