

Lead in Water Test Results Summary: Rogue Primary

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Staff Lounge Sink	204209000015F25A	5/6/2026	ND	Non-Detect			
Bathroom by Staff Lounge Sink	20420900002BF25A	5/6/2026	ND	Non-Detect			
Health Room Sink	20420900003NS25A	5/6/2026	1.05	Low			
Health Room Bathroom	20420900004BF25A	5/6/2026	ND	Non-Detect			
Bathroom Across from Elevator Room	20420900005BF25A	5/6/2026	ND	Non-Detect			
Right Sink Outside Boys' Bathroom	20420900006BF25A	5/6/2026	ND	Non-Detect			
Left Sink Outside Boys' Bathroom	20420900007BF25A	5/6/2026	ND	Non-Detect			
Boys Bathroom Right Sink	20420900008BF25A	5/6/2026	ND	Non-Detect			
Boys Bathroom Left Sink	20420900009BF25A	5/6/2026	ND	Non-Detect			
Right Sink Outside Girls Bathroom	20420900010BF25A	5/6/2026	ND	Non-Detect			
Left Sink Outside Girls Bathroom	20420900011BF25A	5/6/2026	ND	Non-Detect			
Girls Bathroom Left Sink	20420900012BF25A	5/6/2026	ND	Non-Detect			
Girls Bathroom Right Sink	20420900013BF25A	5/6/2026	ND	Non-Detect			
Common Area Right Drinking Fountain	20420900014DW25A	5/6/2026	ND	Non-Detect			
Common Area Left Drinking Fountain	20420900015DW25A	5/6/2026	ND	Non-Detect			
Dish Room Hand Sink	20420900016KF25A	5/6/2026	ND	Non-Detect			
Dish Room Left Pot Sink	20420900017KF25A	5/6/2026	ND	Non-Detect			
Dish Room Right Pot Sink	20420900018KF25A	5/6/2026	1.66	Low			
Dish Room Sprayer	20420900019KF25A	5/6/2026	ND	Non-Detect			
Ice Machine NW Corner	20420900020KF25A	5/6/2026	1.06	Low			
Hand Sink Across from Ice Machine	20420900021KF25A	5/6/2026	ND	Non-Detect			
Kettle Fill	20420900022KF25A	5/6/2026	1.55	Low			
Prep Sink South Wall	20420900023KF25A	5/6/2026	ND	Non-Detect			
Hand Sink South Wall	20420900024KF25A	5/6/2026	ND	Non-Detect			
Kitchen Bathroom	20420900025BF25A	5/6/2026	ND	Non-Detect			
South Wall Single Use Bathroom	20420900026BF25A	5/6/2026	ND	Non-Detect			
RM146 Sink	20420900027CF25A	5/6/2026	ND	Non-Detect			
RM146 Bathroom Sink	20420900028BF25A	5/6/2026	ND	Non-Detect			
RM144 Bathroom	20420900029BF25A	5/6/2026	ND	Non-Detect			
RM144 Classroom Sink	20420900030CF25A	5/6/2026	0.771	Low			
RM142 Classroom Sink	20420900031CF25A	5/6/2026	ND	Non-Detect			
RM142 Bathroom Sink	20420900032BF25A	5/6/2026	ND	Non-Detect			
RM140 Classroom Sink	20420900033CF25A	5/6/2026	ND	Non-Detect			
RM140 Drinking Fountain	20420900034DW25A	5/6/2026	ND	Non-Detect			
RM140 Bathroom Sink	20420900035BF25A	5/6/2026	ND	Non-Detect			
RM138 Classroom Sink	20420900036CF25A	5/6/2026	ND	Non-Detect			
RM138 Classroom Drinking Fountain	20420900037DW25A	5/6/2026	0.736	Low			
RM138 Bathroom Sink	20420900038BF25A	5/6/2026	ND	Non-Detect			
RM136 Classroom Sink	20420900039CF25A	5/6/2026	ND	Non-Detect			
RM136 Drinking Fountain	20420900040DW25A	5/6/2026	1.18	Low			
RM136 Bathroom Sink	20420900041BF25A	5/6/2026	ND	Non-Detect			
RM134 Classroom Sink	20420900042CF25A	5/6/2026	0.543	Low			
RM134 Drinking Fountain	20420900043DW25A	5/6/2026	1.91	Low			
RM134 Bathroom Sink	20420900044BF25A	5/6/2026	ND	Non-Detect			
RM132 Classroom Sink	20420900045CF25A	5/6/2026	ND	Non-Detect			
RM132 Drinking Fountain	20420900046DW25A	5/6/2026	ND	Non-Detect			
RM132 Bathroom Sink	20420900047BF25A	5/6/2026	ND	Non-Detect			
RM130 Classroom Sink	20420900048CF25A	5/6/2026	ND	Non-Detect			
RM130 Drinking Fountain	20420900049DW25A	5/6/2026	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
RM130 Bathroom Sink	20420900050BF25A	5/6/2026	ND	Non-Detect			
RM128 Classroom Sink	20420900051CF25A	5/6/2026	ND	Non-Detect			
RM128 Drinking Fountain	20420900052DW25A	5/6/2026	ND	Non-Detect			
RM128 Bathroom Sink	20420900053BF25A	5/6/2026	ND	Non-Detect			
RM126 Classroom Sink	20420900054CF25A	5/6/2026	ND	Non-Detect			
RM126 Drinking Fountain	20420900055DW25A	5/6/2026	ND	Non-Detect			
RM126 Bathroom Sink	20420900056BF25A	5/6/2026	ND	Non-Detect			
RM124 Classroom Sink	20420900057CF25A	5/6/2026	ND	Non-Detect			
RM124 Drinking Fountain	20420900058DW25A	5/6/2026	ND	Non-Detect			
RM124 Bathroom Sink	20420900059BF25A	5/6/2026	ND	Non-Detect			
Playground Hand Pump	20420900060OT25A	5/6/2026	ND	Non-Detect			
<u>SECOND FLOOR</u>							
2nd Floor Left Drinking Fountain	20420900061DW25A	5/6/2026	ND	Non-Detect			
2nd Floor Right Drinking Fountain	20420900062DW25A	5/6/2026	ND	Non-Detect			
2nd Floor Girls Bathroom Left Sink	20420900063BF25A	5/6/2026	ND	Non-Detect			
2nd Floor Girls Bathroom Right Sink	20420900064BF25A	5/6/2026	ND	Non-Detect			
2nd Floor Boys Bathroom Left Sink	20420900065BF25A	5/6/2026	ND	Non-Detect			
2nd Floor Boys Bathroom Right Sink	20420900066BF25A	5/6/2026	ND	Non-Detect			
<u>STRIP MALL</u>							
Custodial Room Bathroom Sink	20420901001BF25A	5/6/2026	ND	Non-Detect			
Playlab Sink	20420901002CF25A	5/6/2026	ND	Non-Detect			
Playlab Bathroom Sink	20420901003BF25A	5/6/2026	ND	Non-Detect			
La Clinica Bathroom	20420901004BF25A	5/6/2026	ND	Non-Detect			
La Clinica Lab 3 Right Sink	20420901005NS25A	5/6/2026	ND	Non-Detect			
La Clinica Lab 3 Back Sink	20420901006NS25A	5/6/2026	0.518	Low			
RM5 Sink	20420901007NS25A	5/6/2026	1.07	Low			
RM6 Sink	20420901008NS25A	5/6/2026	ND	Non-Detect			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

May 18, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Rogue Primary Lead Testing-AMENDED

Order No.: 25050174

Dear Dale Giovannetti:

Neilson Research Corporation received 74 sample(s) on 5/6/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050174
Date: 5/18/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: Rogue Primary Lead Testing-AMENDED

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

The report has been amended to include the accreditation status, which was omitted from the original version due to a clerical error. Neilson Research Corporation is, and has been, accredited by ORELAP for the analysis of lead in drinking water.

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-01 Client Sample ID: 20420900001SF25A
Collection Date: 5/6/2025 5:00:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900001SF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-02 Client Sample ID: 20420900002BF25A
Collection Date: 5/6/2025 5:03:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900002BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-03 Client Sample ID: 20420900003NS25A
Collection Date: 5/6/2025 5:06:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900003NS25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.05		0.515	ppb	1	5/14/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-04 **Client Sample ID:** 20420900004BF25A
Collection Date: 5/6/2025 5:08:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900004BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-05 **Client Sample ID:** 20420900005BF25A
Collection Date: 5/6/2025 5:10:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900005BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-06 **Client Sample ID:** 20420900006BF25A
Collection Date: 5/6/2025 5:12:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900006BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-07 Client Sample ID: 20420900007BF25A
Collection Date: 5/6/2025 5:13:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900007BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-08 Client Sample ID: 20420900008BF25A
Collection Date: 5/6/2025 5:14:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900008BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-09 Client Sample ID: 20420900009BF25A
Collection Date: 5/6/2025 5:15:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900009BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-10 **Client Sample ID:** 20420900010BF25A
Collection Date: 5/6/2025 5:17:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900010BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-11 **Client Sample ID:** 20420900011BF25A
Collection Date: 5/6/2025 5:17:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900011BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-12 **Client Sample ID:** 20420900012BF25A
Collection Date: 5/6/2025 5:19:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900012BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-13 **Client Sample ID:** 20420900013BF25A
Collection Date: 5/6/2025 5:20:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900013BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-14 **Client Sample ID:** 20420900014DW25A
Collection Date: 5/6/2025 5:21:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900014DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-15 **Client Sample ID:** 20420900015DW25A
Collection Date: 5/6/2025 5:22:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900015DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-16 **Client Sample ID:** 20420900045CF2A
Collection Date: 5/6/2025 5:34:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900045CF2A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-17 **Client Sample ID:** 20420900046DW25A
Collection Date: 5/6/2025 5:35:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900046DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-18 **Client Sample ID:** 20420900047BF25A
Collection Date: 5/6/2025 5:37:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900047BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-19 **Client Sample ID:** 20420900048CF25A
Collection Date: 5/6/2025 5:41:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900048CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-20 **Client Sample ID:** 20420900049DW25A
Collection Date: 5/6/2025 5:42:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900049DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-21 **Client Sample ID:** 20420900050BF25A
Collection Date: 5/6/2025 5:43:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900050BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-22 Client Sample ID: 20420900051CF25A
Collection Date: 5/6/2025 5:46:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900051CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-23 Client Sample ID: 20420900052DW25A
Collection Date: 5/6/2025 5:47:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900052DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-24 Client Sample ID: 20420900053BF25A
Collection Date: 5/6/2025 5:48:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900053BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-25 Client Sample ID: 20420900054CF25A
Collection Date: 5/6/2025 5:52:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900054CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-26 Client Sample ID: 20420900055DW25A
Collection Date: 5/6/2025 5:53:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900055DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-27 Client Sample ID: 20420900056BF25A
Collection Date: 5/6/2025 5:54:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900056BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-28 Client Sample ID: 20420900057CF25A
Collection Date: 5/6/2025 5:57:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900057CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-29 Client Sample ID: 20420900058DW25A
Collection Date: 5/6/2025 5:58:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900058DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

Lab ID: 25050174-30 Client Sample ID: 20420900059BF25A
Collection Date: 5/6/2025 5:59:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420900059BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/13/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-31 **Client Sample ID:** 20420900060OT25A
Collection Date: 5/6/2025 5:39:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420900060OT25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-32 **Client Sample ID:** 20420901006NS25A
Collection Date: 5/6/2025 5:49:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420901006NS25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.518		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-33 **Client Sample ID:** 20420901007NS25A
Collection Date: 5/6/2025 5:55:00 AM **Collected By:** Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420901007NS25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.07		0.515	ppb	1	5/14/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-34 Client Sample ID: 20420901008NS25A
Collection Date: 5/6/2025 5:47:00 AM Collected By: Mark Lillich
Matrix: Drinking Water Sample Location: 20420901008NS25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-35 Client Sample ID: 20420900016KF25A
Collection Date: 5/6/2025 4:46:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900016KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-36 Client Sample ID: 20420900017KF25A
Collection Date: 5/6/2025 4:46:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900017KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-37 Client Sample ID: 20420900018KF25A
Collection Date: 5/6/2025 4:47:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900018KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.66		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-38 Client Sample ID: 20420900019KF25A
Collection Date: 5/6/2025 4:49:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900019KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-39 Client Sample ID: 20420900020KF25A
Collection Date: 5/6/2025 4:45:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900020KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.06		0.515	ppb	1	5/14/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-40 **Client Sample ID:** 20420900021KF25A
Collection Date: 5/6/2025 4:50:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900021KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/14/2025	15.0	A

Lab ID: 25050174-41 **Client Sample ID:** 20420900022KF25A
Collection Date: 5/6/2025 4:51:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900022KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.55		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-42 **Client Sample ID:** 20420900023KF25A
Collection Date: 5/6/2025 4:52:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900023KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-43 **Client Sample ID:** 20420900024KF25A
Collection Date: 5/6/2025 4:54:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900024KF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-44 **Client Sample ID:** 20420900025BF25A
Collection Date: 5/6/2025 4:56:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900025BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-45 **Client Sample ID:** 20420900026BF25A
Collection Date: 5/6/2025 4:57:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900026BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-46 **Client Sample ID:** 20420900027CF25A
Collection Date: 5/6/2025 4:59:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900027CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-47 **Client Sample ID:** 20420900028BF25A
Collection Date: 5/6/2025 4:59:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900028BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-48 **Client Sample ID:** 20420900029BF25A
Collection Date: 5/6/2025 5:03:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900029BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-49 **Client Sample ID:** 20420900030CF25A
Collection Date: 5/6/2025 5:04:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900030CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.771		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-50 **Client Sample ID:** 20420900031CF25A
Collection Date: 5/6/2025 5:06:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900031CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-51 **Client Sample ID:** 20420900032BF25A
Collection Date: 5/6/2025 5:06:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900032BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-52 Client Sample ID: 20420900033CF25A
Collection Date: 5/6/2025 5:08:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900033CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-53 Client Sample ID: 20420900034DW25A
Collection Date: 5/6/2025 5:09:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900034DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-54 Client Sample ID: 20420900035BF25A
Collection Date: 5/6/2025 5:10:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900035BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-55 Client Sample ID: 20420900036CF25A
Collection Date: 5/6/2025 5:13:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900036CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-56 Client Sample ID: 20420900037DW25A
Collection Date: 5/6/2025 5:14:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900037DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.736		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-57 Client Sample ID: 20420900038BF25A
Collection Date: 5/6/2025 5:14:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900038BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-58 Client Sample ID: 20420900039CF25A
Collection Date: 5/6/2025 5:17:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900039CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-59 Client Sample ID: 20420900040CF25A
Collection Date: 5/6/2025 5:18:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900040CF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.18		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-60 Client Sample ID: 20420900041BF25A
Collection Date: 5/6/2025 5:18:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420900041BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-61 **Client Sample ID:** 20420900042CF25A
Collection Date: 5/6/2025 5:21:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900042CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.543		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-62 **Client Sample ID:** 20420900043DW25A
Collection Date: 5/6/2025 5:22:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900043DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.91		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-63 **Client Sample ID:** 20420900044BF25A
Collection Date: 5/6/2025 5:23:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900044BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-64 **Client Sample ID:** 20420900061DW25A
Collection Date: 5/6/2025 5:31:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900061DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-65 **Client Sample ID:** 20420900062DW25A
Collection Date: 5/6/2025 5:32:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900062DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-66 **Client Sample ID:** 20420900063BF25A
Collection Date: 5/6/2025 5:32:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900063BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174

Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-67 **Client Sample ID:** 20420900064BF25A
Collection Date: 5/6/2025 5:33:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900064BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-68 **Client Sample ID:** 20420900065BF25A
Collection Date: 5/6/2025 5:34:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900065BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-69 **Client Sample ID:** 20420900066BF25A
Collection Date: 5/6/2025 5:36:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420900066BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-70 **Client Sample ID:** 20420901001BF25A
Collection Date: 5/6/2025 5:42:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420901001BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-71 **Client Sample ID:** 20420901002BF25A
Collection Date: 5/6/2025 5:44:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420901002BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-72 **Client Sample ID:** 20420901003BF25A
Collection Date: 5/6/2025 5:49:00 AM **Collected By:** Jeff Carr
Matrix: Drinking Water **Sample Location:** 20420901003BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050174
Date Reported: 5/18/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050174
Received Date: 5/6/2025 10:25:00 AM
Reported Date: 5/18/2025 7:53:44 AM

Sample Information:

Lab ID: 25050174-73 Client Sample ID: 20420901004BF25A
Collection Date: 5/6/2025 5:51:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420901004BF25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/15/2025	15.0	A

Lab ID: 25050174-74 Client Sample ID: 20420901005NS25A
Collection Date: 5/6/2025 5:52:00 AM Collected By: Jeff Carr
Matrix: Drinking Water Sample Location: 20420901005NS25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.615		0.515	ppb	1	5/15/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050174
17-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Rogue Primary Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31252	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424
Client ID: PBW	Batch ID: 31252	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 971022
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31252	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424
Client ID: LCSW	Batch ID: 31252	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 971023
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.520 100 0 103 85 115

Sample ID: 25050174-11AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424
Client ID: 20420900011BF25A	Batch ID: 31252	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 971025
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.520 100 0.107 101 70 130

Sample ID: 25050174-11AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/13/2025	RunNo: 59424
Client ID: 20420900011BF25A	Batch ID: 31252	TestNo: E200.8	E200.8	Analysis Date: 5/13/2025	SeqNo: 971026
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 103 0.520 100 0.107 103 70 130 101 2.25 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050174
17-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Rogue Primary Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31273	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59458
Client ID: PBW	Batch ID: 31273	TestNo: E200.8	E200.8	Analysis Date: 5/14/2025	SeqNo: 971556
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31273	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59458
Client ID: LCSW	Batch ID: 31273	TestNo: E200.8	E200.8	Analysis Date: 5/14/2025	SeqNo: 971557
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.520 100 0 101 85 115

Sample ID: 25050174-01AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59458
Client ID: 20420900001SF25A	Batch ID: 31273	TestNo: E200.8	E200.8	Analysis Date: 5/14/2025	SeqNo: 971559
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 93.0 0.520 100 0.303 92.7 70 130

Sample ID: 25050174-01AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59458
Client ID: 20420900001SF25A	Batch ID: 31273	TestNo: E200.8	E200.8	Analysis Date: 5/14/2025	SeqNo: 971560
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 97.5 0.520 100 0.303 97.2 70 130 93.0 4.66 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050174
17-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Rogue Primary Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31274	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506
Client ID: PBW	Batch ID: 31274	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972367
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.515			

Sample ID: LCS-31274	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506
Client ID: LCSW	Batch ID: 31274	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972368
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	95.8	0.520	100	0	95.8 85 115

Sample ID: 25050174-41AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506
Client ID: 20420900022KF25A	Batch ID: 31274	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972370
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	99.1	0.520	100	1.55	97.5 70 130

Sample ID: 25050174-41MSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506
Client ID: 20420900022KF25A	Batch ID: 31274	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972371
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	98.5	0.520	100	1.55	97.0 70 130 99.1 0.552 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050174
17-Jul-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Rogue Primary Lead Testing-AMENDED

TestCode: LEAD_SCHOOLS

Sample ID: MB-31275	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506
Client ID: PBW	Batch ID: 31275	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972413
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-31275	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506
Client ID: LCSW	Batch ID: 31275	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972414
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 98.1 0.520 100 0 98.1 85 115

Sample ID: 25050174-61AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506
Client ID: 20420900042CF25A	Batch ID: 31275	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972416
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 92.7 0.520 100 0.543 92.1 70 130

Sample ID: 25050174-61AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/14/2025	RunNo: 59506
Client ID: 20420900042CF25A	Batch ID: 31275	TestNo: E200.8	E200.8	Analysis Date: 5/15/2025	SeqNo: 972417
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 97.7 0.520 100 0.543 97.2 70 130 92.7 5.31 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Revision v1



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25050174

RcptNo: 1

Logged by: Dorie Evans 5/6/2025 10:25:00 AM

Completed By: Coni Boyko 5/9/2025 12:20:03 PM

Reviewed By: Tamra Schmedemann 5/18/2025 7:17:29 AM

Dorie Evans

Coni Boyko

Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO₃ pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 2 of 8

Section A Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): MARK LILLICH
Collected By (Sign): Mark Lillich
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B Required Project Information

Project Name: ROGUE PRIMARY
Project Number: _____
Report To: _____
Copy To: _____

Section C Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420900011 BF25A	119824	DW	5-6-25	5:17 AM	1	X			11
20420900012 BF25A	119836	DW	5-6-25	5:19 AM	1	X			12
20420900013 BF25A	119793	DW	5-6-25	5:20 AM	1	X			13
20420900014 DW25A	119827	DW	5-6-25	5:21 AM	1	X			14
20420900015 DW25A	119831	DW	5-6-25	5:22 AM	1	X			15
20420900045 CF25A	119903	DW	5-6-25	5:34 AM	1	X			16
20420900046 DW25A	119868	DW	5-6-25	5:35 AM	1	X			17
20420900047 BF25A	119800	DW	5-6-25	5:37 AM	1	X			18
20420900048 CF25A	119819	DW	5-6-25	5:41 AM	1	X			19
20420900049 DW25A	119799	DW	5-6-25	5:42 AM	1	X			20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>Jeff Carr</u>	<u>5-6-25</u>	<u>10:25 AM</u>
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By: _____	_____	_____	_____
Relinquished By: _____	_____	_____	_____
Received By Laboratory: _____	_____	_____	_____

Section G Lab Use Only

Temp: _____
4°C +/- 2°C: ☐ Yes ☐ No
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact ☐ Yes ☐ No ☐ NA
Field Blank Included: ☐ Yes ☐ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☐ Hand
Payment: ☐ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 3 of 8

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>ROGUE PRIMARY</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: Fax:			☐ Other
Collected By (Print): <u>MARK WILLIAMS</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>[Signature]</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only)		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	LEAD										Remarks/Field Data	NRC Sample # (Lab Use Only)
20420900050 BF25A	119798	DW	5-6-25	5:43 AM	1	X											21
20420900051 CF25A	119847	DW	5-6-25	5:46 AM	1	X											22
20420900052 DW25A	119833	DW	5-6-25	5:47 AM	1	X											23
20420900053 BF25A	119834	DW	5-6-25	5:48 AM	1	X											24
20420900054 CF25A	119817	DW	5-6-25	5:52 AM	1	X											25
20420900055 DW25A	119805	DW	5-6-25	5:53 AM	1	X											26
20420900056 BF25A	119796	DW	5-6-25	5:54 AM	1	X											27
20420900057 CF25A	119797	DW	5-6-25	5:57 AM	1	X											28
20420900058 DW25A	119831	DW	5-6-25	5:58 AM	1	X											29
20420900059 BF25A	119832	DW	5-6-25	5:59 AM	1	X											30

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-6-25</u>	<u>10:25 AM</u>
Received By:					
Relinquished By:					
Received By:					
Relinquished By:					
Received By Laboratory:					

Section G Lab Use Only	
Temp:	
4°C +/- 2°C:	☐ Yes ☐ No
Received on Ice:	☐ Yes ☐ No
Number of Bottles Received:	
pH Checked:	
COC Seals Intact:	☐ Yes ☐ No ☐ NA
Field Blank Included:	☐ Yes ☐ No
Received Via:	☐ UPS ☐ FedEx ☐ Other ☐ Hand
Payment:	☐ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 4 of 8

Section A

Required Client Information

Company: Central Point School District #6	
Address: 300 Ash Street	
Central Point OR 97502	
Email:	
Phone:	Fax:
Collected By (Print): MARK LILICH	
Collected By (Sign): M. LILICH	
Email Report ☒ Yes ☐ No	Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Section B

Required Project Information

Project Name:	ROGUE PRIMARY
Project Number:	
Report To:	
Copy To:	

Section C

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Section D

Rush Status (Subject to Scheduling)

☒	Standard 10-14 Days		
☐	5 Business Days (50% surcharge)		
☐	3 Business Days (75% surcharge)		
☐	24 - 48 hours (100% surcharge)		
☐	Other _____		
	Authorized _____	Yes _____	No _____

Section E

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Signature	Print	Date	Time
Relinquished By: <i>Jeff Carr</i>	Jeff Carr	5-6-25	10:25AM
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:			

Section G

Lab Use Only

Temp:	
4°C +/- 2°C:	Yes No
Received on Ice:	Yes No
Number of Bottles Received:	
pH Checked:	
GOC Seals Intact:	Yes No NA
Field Blank Included:	Yes No
UPS FedEX Other Hand	
M/C	Check # Amount



Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 5 of 8

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Cair
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: Rogue Primary
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420900016KF25A	119828	DW	5-6-25	4:46 AM	1	X				35
20420900017KF25A	119856	DW	5-6-25	4:46 AM	1	X				36
20420900018KF25A	119826	DW	5-6-25	4:47 AM	1	X				37
20420900019KF25A	119814	DW	5-6-25	4:49 AM	1	X				38
20420900020KF25A	119815	DW	5-6-25	4:45 AM	1	X				39
20420900021KF25A	119833	DW	5-6-25	4:50 AM	1	X				40
20420900022KF25A	119802	DW	5-6-25	4:51 AM	1	X				41
20420900023KF25A	119839	DW	5-6-25	4:52 AM	1	X				42
20420900024KF25A	119900	DW	5-6-25	4:54 AM	1	X				43
20420900025BF25A	119791	DW	5-6-25	4:56 AM	1	X				44

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F


Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>Jeff Cair</u>		<u>5-6-25</u>	<u>10:25 AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:				

Section G

Lab Use Only

Temp: _____
4°C +/- 2°C: ☐ Yes ☐ No
Received on Ice: ☐ Yes ☐ No
Number of Bottles Received: _____
pH Checked: _____
COC Seals Intact: ☐ Yes ☐ No ☐ NA
Field Blank Included: ☐ Yes ☐ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☐ Hand
Payment: ☐ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____



Page 6 of 8

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Required Client Information

Company: Central Point School District #6	
Address: 300 Ash Street	
Central Point OR 97502	
Email:	
Phone:	Fax:
Collected By (Print): Jeff Carr	
Collected By (Sign): <i>Jeff Carr</i>	
Email Report ☒ Yes ☐ No	Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Required Project Information

Project Name:	Rogue Primary
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard 10-14 Days
☐	5 Business Days (50% surcharge)
☐	3 Business Days (75% surcharge)
☐	24 - 48 hours (100% surcharge)
☐	Other

Authorized _____ Yes No

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Signature	Print	Date	Time
Relinquished By: <i>Jeff Carr</i>	Jeff Carr	5-6-25	10:25 AM
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:			

Lab Use Only

Temp:	
4°C +/- 2°C:	___ Yes ___ No
Received on Ice:	___ Yes ___ No
Number of Bottles Received:	
pH Checked:	
COC Seals Intact:	___ Yes ___ No ___ NA
Field Blank Included:	___ Yes ___ No

Received Via ☒ UPS ☐ FedEx ☐ Other ☐ Hand


Payment: ☐ Invoice ☐ Cash ☐ VISA, M/C ☐ Check #	Amount
--	-----------------------------



Page 7 of 8

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Required Client Information

Company: Central Point School District #6	
Address: 300 Ash Street	
Central Point OR 97502	
Email:	
Phone:	Fax:
Collected By (Print): Jeff Carr	
Collected By (Sign): 	
Email Report ☒ Yes ☒ No	Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Required Project Information

Project Name:	Rogue Primary
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard 10-14 Days		
☐	5 Business Days (50% surcharge)		
☐	3 Business Days (75% surcharge)		
☐	24 - 48 hours (100% surcharge)		
☐	Other _____		

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquished By:	Date	Time
Jeff Carr	5-6-25	10:25A
Received By:		
Relinquished By:		
Received By:		
Relinquished By:		
Received By Laboratory: <u>[Signature]</u>	5/6/25	10:25

Lab Use Only

Temp: AMB
4°C +/− 2°C: Yes No
Received on Ice: Yes No
Number of Bottles Received: N/A
pH Checked: —
COC Seals Intact: Yes No NA
Field Blank Included: Yes No

Received Via UPS FedEX Other Hand

Payment: Invoice Cash VISA, M/C Check # Amount

