

Lead in Water Test Results Summary: Scenic Middle School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
A WING							
Staff Sink in RM Next to A2	20420701001SF25A	5/9/2025	0.646	Low			
Staff Sink in RM Next to A6	20420701002SF25A	5/9/2025	10.8	High			
A4 Classroom Sink	20420701003CF25A	5/9/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420701004BF25A	5/9/2025	ND	Non-Detect			
Boys Bathroom Left Sink	20420701005BF25A	5/9/2025	ND	Non-Detect			
Single Use Bathroom Sink	20420701006BF25A	5/9/2025	ND	Non-Detect			
Left Drinking Fountain	20420701007DW25A	5/9/2025	ND	Non-Detect			
Right Drinking Fountain	20420701008DW25A	5/9/2025	ND	Non-Detect			
Bottle Fill	20420701009WB25A	5/9/2025	ND	Non-Detect			
Girls Bathroom Right Sink	20420701010BF25A	5/9/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420701011BF25A		Out of Serve	-			
B WING							
B2 Classroom Sink	20420702001CF25A	5/9/2025	ND	Non-Detect			
Sink in Room Between B2 and B3	20420702002SF25A	5/9/2025	ND	Non-Detect			
C, D, E, WING							
Sink in Room Next to C2	20420703001SF25A	5/9/2025	ND	Non-Detect			
Sink in Room Next to C6	20420703002SF25A	5/9/2025	ND	Non-Detect			
C4 Classroom Sink	20420703003CF25A	5/9/2025	1.84	Low			
Boys Bathroom Sink	20420703004BF25A	5/9/2025	ND	Non-Detect			
Single Use Bathroom Sink	20420703005BF25A	5/9/2025	ND	Non-Detect			
Left Drinking Fountain	20420703006DW25A	5/9/2025	ND	Non-Detect			
Bottle Fill	20420703007WB25A	5/9/2025	ND	Non-Detect			
Right Drinking Fountain	20420703008DW25A	5/9/2025	ND	Non-Detect			
Girls Bathroom Left Sink	20420703009BF25A	5/9/2025	ND	Non-Detect			
Girls Bathroom Right Sink	20420703010BF25A	5/9/2025	ND	Non-Detect			
D1 Left Sink	20420703011CF25A	5/9/2025	ND	Non-Detect			
D1 Right Sink	20420703012CF25A	5/9/2025	ND	Non-Detect			
D2 Left Sink	20420703013CF25A	5/9/2025	ND	Non-Detect			
D2 Right Sink	20420703014CF25A	5/9/2025	ND	Non-Detect			
E1 Left Sink East Wall	20420703015CF25A	5/9/2025	ND	Non-Detect			
E1 Right Sink East Wall	20420703016CF25A	5/9/2025	ND	Non-Detect			
E1 Left Sink South Wall	20420703017CF25A	5/9/2025	ND	Non-Detect			
E1 Right Sink South Wall	20420703018CF25A	5/9/2025	ND	Non-Detect			
E2 Right Drinking Fountain	20420703019DW25A	5/9/2025	ND	Non-Detect			
E2 Left Drinking Fountain	20420703020DW25A	5/9/2025	ND	Non-Detect			
E2 Bottle Fill	20420703021WB25A	5/9/2025	ND	Non-Detect			
E2 Dark Room Sink	20420703022CF25A	5/9/2025	2.89	Low			
E2 NE Corner Right Sink	20420703023CF25A	5/9/2025	ND	Non-Detect			
E2 NE Corner Left Sink	20420703024CF25A	5/9/2025	ND	Non-Detect			
E3 La Clinica Bathroom Sink	20420703025BF25A	5/9/2025	ND	Non-Detect			
E3 La Clinica South Nurse Office	20420703026NS25A	5/9/2025	ND	Non-Detect			
E3 La Clinica North Nurse Office	20420703027NS25A	5/9/2025	2.06	Low			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Outside E-Wing Left Drinking Fountain	20420703028DW25A	5/9/2025	ND	Non-Detect			
Outside E-Wing Right Drinking Fountain	20420703029DW25A	5/9/2025	ND	Non-Detect			
Outside Bottle Fill	20420703030WB25A	5/9/2025	ND	Non-Detect			
<u>GYMNASIUM</u>							
Drinking Fountain Outside East Gym	20420700001DW25A	5/9/2025	ND	Non-Detect			
Bottle Fill Outside East Gym	20420700002WB25A		Out of Serve	-			
East Gym Bottle Fill	20420700003WB25A	5/9/2025	ND	Non-Detect			
East Gym Right Drinking Fountain	20420700004DW25A	5/9/2025	ND	Non-Detect			
East Gym Left Drinking Fountain	20420700005DW25A	5/9/2025	ND	Non-Detect			
Boys Bathroom Right Sink	20420700006BF25A	5/9/2025	ND	Non-Detect			
Boys Bathroom Left Sink	20420700007BF25A	5/9/2025	ND	Non-Detect			
Boys Locker Room Bottle Fill	20420700008BW25A	5/9/2025	ND	Non-Detect			
Boys Locker Room Left Drinking Fountain	20420700009DW25A	5/9/2025	ND	Non-Detect			
Boys Locker Room Right Drinking Fountain	20420700010DW25A	5/9/2025	ND	Non-Detect			
Boys Coaches Bathroom Sink	20420700011BF25A	5/9/2025	ND	Non-Detect			
Boys Locker Room Right Bathroom Sink	20420700012BF25A	5/9/2025	ND	Non-Detect			
Boys Locker Room Left Bathroom Sink	20420700013BF25A	5/9/2025	ND	Non-Detect			
Girls Bathroom Left Bathroom Sink	20420700014BF25A	5/9/2025	ND	Non-Detect			
Girls Bathroom Right Bathroom Sink	20420700015BF25A	5/9/2025	ND	Non-Detect			
Girls Locker Room Bottle Fill	20420700016BW25A	5/9/2025	ND	Non-Detect			
Girls Locker Room Right Drinking Fountain	20420700017DW25A	5/9/2025	ND	Non-Detect			
Girls Locker Room Left Drinking Fountain	20420700018DW25A	5/9/2025	ND	Non-Detect			
Girls Coaches Bathroom Sink	20420700019BF25B	5/9/2025	20.9	Action Req.	10/29/2025	ND	Non-Detect
Girls Locker Room Right Bathroom Sink	20420700020BF25A	5/9/2025	ND	Non-Detect			
Girls Locker Room Left Bathroom Sink	20420700021BF25A	5/9/2025	ND	Non-Detect			
West Gym Bottle Fill	20420700022WB25A	5/9/2025	ND	Non-Detect			
West Gym Left Drinking Fountain	20420700023DW25A	5/9/2025	ND	Non-Detect			
West Gym Right Drinking Fountain	20420700024DW25A	5/9/2025	ND	Non-Detect			
Weight Room Right Drinking Fountain	20420700025DW25A	5/9/2025	ND	Non-Detect			
Weight Room Left Drinking Fountain	20420700026DW25A	5/9/2025	ND	Non-Detect			
Weight Room Bottle Fill	20420700027WB25A	5/9/2025	ND	Non-Detect			
Team Room Right Drinking Fountain	20420700028DW25A	5/9/2025	ND	Non-Detect			
Team Room Left Drinking Fountain	20420700029DW25A	5/9/2025	0.589	Low			
Team Room Bottle Fill	20420700030BW25A	5/9/2025	ND	Non-Detect			
Team Room Right Bathroom Sink	20420700031BF25A	5/9/2025	ND	Non-Detect			
Team Room Left Bathroom Sink	20420700032BF25A	5/9/2025	1.21	Low			
Team Room Coaches Bathroom Sink	20420700033BF25A	5/9/2025	ND	Non-Detect			
<u>G WING</u>							
RMG1 Classroom Sink	20420704001CF25A	5/9/2025	ND	Non-Detect			
RMG2 Classroom Sink	20420704002CF25A	5/9/2025	ND	Non-Detect			
Concession Stand Sink	20420704003KF25A	5/9/2025	1.8	Low			
Concession Stand Ice Machine	20420704004IM25A	5/9/2025	ND	Non-Detect			
Cafeteria Left Drinking Fountain	20420704005DW25A	5/9/2025	ND	Non-Detect			
Cafeteria Right Drinking Fountain	20420704006DW25A	5/9/2025	ND	Non-Detect			
Cafeteria Bottle Fill	20420704007WB25A	5/9/2025	ND	Non-Detect			
Kitchen Dish Room Sprayer	20420704008KF25A	5/9/2025	ND	Non-Detect			
Kitchen Hand Sink North Wall	20420704009KF25A	5/9/2025	0.831	Low			
Kitchen Prep Sink North Wall	20420704010KF25A	5/9/2025	ND	Non-Detect			
Kitchen Kettle Filler	20420704011KF25A	5/9/2025	ND	Non-Detect			
Kitchen Kettle Sprayer	20420704012KF25A	5/9/2025	ND	Non-Detect			
Kitchen Right Prep Sink Faucet	20420704013KF25A	5/9/2025	ND	Non-Detect			
Kitchen Left Prep Sink Faucet	20420704014KF25A	5/9/2025	2.37	Low			
Kitchen Bathroom Sink	20420704015BF25A	5/9/2025	3.56	Low			
Outside G-Wing Left Drinking Fountain	20420704016DW25A	5/9/2025	ND	Non-Detect			
Outside G-Wing Right Drinking Fountain	20420704017DW25A	5/9/2025	ND	Non-Detect			
Outside Water Bottle Fill	20420704018WB25A	5/9/2025	ND	Non-Detect			
<u>J BUILDING</u>							
RMJ1 Classroom Sink	20420709001CF25A	5/9/2025	ND	Non-Detect			
RMJ1 Bathroom Sink	20420709002BF25A	5/9/2025	ND	Non-Detect			
RMJ2 Bathroom Sink	20420709003BF25A	5/9/2025	ND	Non-Detect			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
<u>OFFICE WING</u>							
Office North Wall Outside Drinking Fountain	20420707001DW25A	5/9/2025	ND	Non-Detect			
Office North Wall Outside Bottle Fill	20420707002WB25A	5/9/2025	ND	Non-Detect			
Office Health Room Bathroom Sink	20420707003BF25A	5/9/2025	ND	Non-Detect			
Office Womens Staff Bathroom Sink	20420707004BF25A	5/9/2025	ND	Non-Detect			
Office Mens Staff Bathroom Sink	20420707005BF25A	5/9/2025	ND	Non-Detect			
Office Production Room Sink	20420707006SF25A	5/9/2025	3.59	Low			
Office Staff Room Sink	20420707007SF25A	5/9/2025	0.552	Low			
<u>LIBRARY WING</u>							
H1 Staff Sink	20420706001SF25A	5/9/2025	ND	Non-Detect			
Middle Office Behind Librarian Sink	20420706002SF25A	5/9/2025	ND	Non-Detect			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 06, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX (541) 665-6000

RE: Scenic Middle School Lead Testing

Order No.: 25050454

Dear Dale Giovannetti:

Neilson Research Corporation received 104 sample(s) on 5/9/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25050454
Date: 6/6/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-001 **Client Sample ID:** 20420703001SF25A
Collection Date: 5/9/2025 5:20:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703001SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

Lab ID: 25050454-002 **Client Sample ID:** 20420703002SF25A
Collection Date: 5/9/2025 5:20:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703002SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

Lab ID: 25050454-003 **Client Sample ID:** 20420703003CF25A
Collection Date: 5/9/2025 5:22:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703003CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.84		0.515	ppb	1	5/27/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-004 Client Sample ID: 20420703004BF25A
Collection Date: 5/9/2025 5:25:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703004BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

Lab ID: 25050454-005 Client Sample ID: 20420703005BF25A
Collection Date: 5/9/2025 5:25:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703005BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

Lab ID: 25050454-006 Client Sample ID: 20420703006DW25A
Collection Date: 5/9/2025 5:26:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703006DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-007 Client Sample ID: 20420703007WB25A
Collection Date: 5/9/2025 5:27:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703007WB25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

Lab ID: 25050454-008 Client Sample ID: 20420703008DW25A
Collection Date: 5/9/2025 5:28:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703008DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

Lab ID: 25050454-009 Client Sample ID: 20420703009BF25A
Collection Date: 5/9/2025 5:29:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703009BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-010 **Client Sample ID:** 20420703010BF25A
Collection Date: 5/9/2025 5:29:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703010BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/27/2025	15.0		

Lab ID: 25050454-011 **Client Sample ID:** 20420703011CF25A
Collection Date: 5/9/2025 5:31:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703011CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/27/2025	15.0		

Lab ID: 25050454-012 **Client Sample ID:** 20420703012CF25A
Collection Date: 5/9/2025 5:31:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703012CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/27/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-013 Client Sample ID: 20420703013CF25A
Collection Date: 5/9/2025 5:33:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703013CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/27/2025	15.0		

Lab ID: 25050454-014 Client Sample ID: 20420703014CF25A
Collection Date: 5/9/2025 5:34:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703014CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/27/2025	15.0		

Lab ID: 25050454-015 Client Sample ID: 20420703015CF25A
Collection Date: 5/9/2025 5:37:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703015CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	5/27/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-016 Client Sample ID: 20420703016CF25A
Collection Date: 5/9/2025 5:38:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703016CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	5/27/2025	15.0	

Lab ID: 25050454-017 Client Sample ID: 20420703017CF25A
Collection Date: 5/9/2025 5:38:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703017CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-018 Client Sample ID: 20420703018CF25A
Collection Date: 5/9/2025 5:40:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703018CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-019 Client Sample ID: 20420703019DW25A
Collection Date: 5/9/2025 5:42:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703019DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-020 Client Sample ID: 20420703020DW25A
Collection Date: 5/9/2025 5:43:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703020DW25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-021 Client Sample ID: 20420703021WB25A
Collection Date: 5/9/2025 5:44:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703021WB25A

Trace Metals by EPA 200.8 ICP-MS						Analyst; CJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-022 Client Sample ID: 20420703022CF25A
Collection Date: 5/9/2025 5:45:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703022CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.89		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-023 Client Sample ID: 20420703023CF25A
Collection Date: 5/9/2025 5:47:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703023CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-024 Client Sample ID: 20420703024CF25A
Collection Date: 5/9/2025 5:47:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703024CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-025 Client Sample ID: 20420703025BF25A
Collection Date: 5/9/2025 5:50:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703025BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-026 Client Sample ID: 20420703026NS25A
Collection Date: 5/9/2025 5:49:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703026NS25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-027 Client Sample ID: 20420703027NS25A
Collection Date: 5/9/2025 5:51:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420703027NS25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.06		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-028 **Client Sample ID:** 20420703028DW25A
Collection Date: 5/9/2025 6:29:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703028DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-029 **Client Sample ID:** 20420703029DW25A
Collection Date: 5/9/2025 6:29:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703029DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-030 **Client Sample ID:** 20420703030WB25A
Collection Date: 5/9/2025 6:30:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420703030WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-031 **Client Sample ID:** 20420706002SF25A
Collection Date: 5/9/2025 4:47:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420706002SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-032 **Client Sample ID:** 20420706001SF25A
Collection Date: 5/9/2025 4:45:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420706001SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-033 **Client Sample ID:** 20420709001CF25A
Collection Date: 5/9/2025 4:49:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420709001CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-034 **Client Sample ID:** 20420709002BF25A
Collection Date: 5/9/2025 4:50:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420709002BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-035 **Client Sample ID:** 20420709003BF25A
Collection Date: 5/9/2025 4:51:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420709003BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-036 **Client Sample ID:** 20420707001DW25A
Collection Date: 5/9/2025 4:53:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420707001DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-037 Client Sample ID: 20420707002WB25A
Collection Date: 5/9/2025 4:54:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420707002WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-038 Client Sample ID: 20420707003BF25A
Collection Date: 5/9/2025 4:55:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420707003BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-039 Client Sample ID: 20420707004BF25A
Collection Date: 5/9/2025 4:56:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420707004BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-040 **Client Sample ID:** 20420707005BF25A
Collection Date: 5/9/2025 4:57:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420707005BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-041 **Client Sample ID:** 20420707006SF25A
Collection Date: 5/9/2025 4:58:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420707006SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.59		0.500	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-042 **Client Sample ID:** 20420707007SF25A
Collection Date: 5/9/2025 4:59:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420707007SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.552		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-043 **Client Sample ID:** 20420701001SF25A
Collection Date: 5/9/2025 5:02:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420701001SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.646		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-044 **Client Sample ID:** 20420701002SF25A
Collection Date: 5/9/2025 5:03:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420701002SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.8		0.500	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-045 **Client Sample ID:** 20420701003CF25A
Collection Date: 5/9/2025 5:05:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420701003CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-046 **Client Sample ID:** 20420701004BF25A
Collection Date: 5/9/2025 5:07:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420701004BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-047 **Client Sample ID:** 20420701005BF25A
Collection Date: 5/9/2025 5:07:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420701005BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-048 **Client Sample ID:** 20420701006BF25A
Collection Date: 5/9/2025 5:08:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420701006BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-049 Client Sample ID: 20420701007DW25A
Collection Date: 5/9/2025 5:09:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420701007DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-050 Client Sample ID: 20420701008DW25A
Collection Date: 5/9/2025 5:10:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420701008DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-051 Client Sample ID: 20420701009WB25A
Collection Date: 5/9/2025 5:10:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420701009WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-052 Client Sample ID: 20420701010BF25A
Collection Date: 5/9/2025 5:11:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420701010BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/2/2025	15.0		

Lab ID: 25050454-053 Client Sample ID: 20420702001CF25A
Collection Date: 5/9/2025 5:15:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420702001CF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/2/2025	15.0		

Lab ID: 25050454-054 Client Sample ID: 20420702002SF25A
Collection Date: 5/9/2025 5:16:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420702002SF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/2/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-055 Client Sample ID: 20420700001DW25A
Collection Date: 5/9/2025 5:17:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700001DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-056 Client Sample ID: 20420700003WB25A
Collection Date: 5/9/2025 5:23:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700003WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-057 Client Sample ID: 20420700004DW25A
Collection Date: 5/9/2025 5:24:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700004DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-058 Client Sample ID: 20420700005DW25A
Collection Date: 5/9/2025 5:25:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700005DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-059 Client Sample ID: 20420700006BF25A
Collection Date: 5/9/2025 5:28:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700006BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-060 Client Sample ID: 20420700007BF25A
Collection Date: 5/9/2025 5:29:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700007BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-061 **Client Sample ID:** 20420700008WB25A
Collection Date: 5/9/2025 5:31:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700008WB25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/2/2025	15.0		

Lab ID: 25050454-062 **Client Sample ID:** 20420700009DW25A
Collection Date: 5/9/2025 5:32:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700009DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/2/2025	15.0		

Lab ID: 25050454-063 **Client Sample ID:** 20420700010DW25A
Collection Date: 5/9/2025 5:32:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700010DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	6/2/2025	15.0		

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-064 **Client Sample ID:** 20420700011BF25A
Collection Date: 5/9/2025 5:35:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700011BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-065 **Client Sample ID:** 20420700012BF25A
Collection Date: 5/9/2025 5:37:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700012BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-066 **Client Sample ID:** 20420700013BF25A
Collection Date: 5/9/2025 5:38:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700013BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-067 **Client Sample ID:** 20420700014BF25A
Collection Date: 5/9/2025 5:43:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700014BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-068 **Client Sample ID:** 20420700015BF25A
Collection Date: 5/9/2025 5:44:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700015BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-069 **Client Sample ID:** 20420700016WB25A
Collection Date: 5/9/2025 5:46:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700016WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-070 **Client Sample ID:** 20420700017DW25A
Collection Date: 5/9/2025 5:47:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700017DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-071 **Client Sample ID:** 20420700018DW25A
Collection Date: 5/9/2025 5:48:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700018DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-072 **Client Sample ID:** 20420700019BF25A
Collection Date: 5/9/2025 5:49:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700019BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	20.9	*	0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-073 Client Sample ID: 20420700020BF25A
Collection Date: 5/9/2025 5:59:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700020BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-074 Client Sample ID: 20420700021BF25A
Collection Date: 5/9/2025 6:00:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700021BF25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-075 Client Sample ID: 20420700022WB25A
Collection Date: 5/9/2025 6:04:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700022WB25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-076 **Client Sample ID:** 20420700023DW25A
Collection Date: 5/9/2025 6:05:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700023DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-077 **Client Sample ID:** 20420700024DW25A
Collection Date: 5/9/2025 6:06:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700024DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-078 **Client Sample ID:** 20420700025DW25A
Collection Date: 5/9/2025 6:07:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420700025DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-079 Client Sample ID: 20420700026DW25A
Collection Date: 5/9/2025 6:08:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700026DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-080 Client Sample ID: 20420700027WB25A
Collection Date: 5/9/2025 6:08:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700027WB25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-081 Client Sample ID: 20420700028DW25A
Collection Date: 5/9/2025 6:03:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700028DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-082 Client Sample ID: 20420700029DW25A
Collection Date: 5/9/2025 6:04:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700029DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.598		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-083 Client Sample ID: 20420700030BW25A
Collection Date: 5/9/2025 6:04:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700030BW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-084 Client Sample ID: 20420700031BF25A
Collection Date: 5/9/2025 6:02:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700031BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-085 Client Sample ID: 20420700032BF25A
Collection Date: 5/9/2025 6:02:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700032BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.21		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-086 Client Sample ID: 20420700033BF25A
Collection Date: 5/9/2025 5:45:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420700033BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-087 Client Sample ID: 20420704001CF25A
Collection Date: 5/9/2025 4:45:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704001CF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-088 Client Sample ID: 20420704002BF25A
Collection Date: 5/9/2025 4:48:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704002BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-089 Client Sample ID: 20420704003KF25A
Collection Date: 5/9/2025 4:57:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704003KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.80		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-090 Client Sample ID: 20420704004IM25A
Collection Date: 5/9/2025 5:52:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704004IM25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-091 **Client Sample ID:** 20420704005DW25A
Collection Date: 5/9/2025 5:13:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420704005DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-092 **Client Sample ID:** 20420704006DW25A
Collection Date: 5/9/2025 5:14:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420704006DW25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-093 **Client Sample ID:** 20420704007WB25A
Collection Date: 5/9/2025 5:15:00 AM **Collected By:** Jeff Carr/Mark Lillich
Matrix: Drinking Water **Sample Location:** 20420704007WB25A

Trace Metals by EPA 200.8 ICP-MS								Analyst; CJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-094 Client Sample ID: 20420704008KF25A
Collection Date: 5/9/2025 4:58:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704008KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-095 Client Sample ID: 20420704009KF25A
Collection Date: 5/9/2025 5:00:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704009KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.831		0.515	ppb	1	6/2/2025	15.0	

Lab ID: 25050454-096 Client Sample ID: 20420704010KF25A
Collection Date: 5/9/2025 5:01:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704010KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/2/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-097 Client Sample ID: 20420704011KF25A
Collection Date: 5/9/2025 5:03:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704011KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	

Lab ID: 25050454-098 Client Sample ID: 20420704012KF25A
Collection Date: 5/9/2025 5:04:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704012KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	

Lab ID: 25050454-099 Client Sample ID: 20420704013KF25A
Collection Date: 5/9/2025 5:07:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704013KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-100 Client Sample ID: 20420704014KF25A
Collection Date: 5/9/2025 5:08:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704014KF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.37		0.515	ppb	1	6/4/2025	15.0	

Lab ID: 25050454-101 Client Sample ID: 20420704015BF25A
Collection Date: 5/9/2025 5:10:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704015BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.56		0.515	ppb	1	6/4/2025	15.0	

Lab ID: 25050454-102 Client Sample ID: 20420704016DW25A
Collection Date: 5/9/2025 5:29:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704016DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25050454
Date Reported: 6/6/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25050454
Received Date: 5/9/2025 10:08:00 AM
Reported Date: 6/6/2025 12:00:42 PM

Sample Information:

Lab ID: 25050454-103 Client Sample ID: 20420704017DW25A
Collection Date: 5/9/2025 5:28:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704017DW25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	

Lab ID: 25050454-104 Client Sample ID: 20420704018WB25A
Collection Date: 5/9/2025 5:27:00 AM Collected By: Jeff Carr/Mark Lillich
Matrix: Drinking Water Sample Location: 20420704018WB25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; CJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	6/4/2025	15.0	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050454
06-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31419	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/23/2025	RunNo: 59781						
Client ID: PBW	Batch ID: 31419	TestNo: E200.8	E200.8	Analysis Date: 5/27/2025	SeqNo: 978272						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31419	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/23/2025	RunNo: 59781						
Client ID: LCSW	Batch ID: 31419	TestNo: E200.8	E200.8	Analysis Date: 5/27/2025	SeqNo: 978273						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	0	104	85	115				

Sample ID: 25050660-55AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/23/2025	RunNo: 59781						
Client ID: BatchQC	Batch ID: 31419	TestNo: E200.8	E200.8	Analysis Date: 5/27/2025	SeqNo: 978275						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	103	0.520	100	2.70	101	70	130				

Sample ID: 25050660-55AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/23/2025	RunNo: 59781						
Client ID: BatchQC	Batch ID: 31419	TestNo: E200.8	E200.8	Analysis Date: 5/27/2025	SeqNo: 978276						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.520	100	2.70	101	70	130	103	0.118	20	

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
E Value above quantitation range
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
H Holding times for preparation or analysis exceeded
RL Reporting Limit

DF Dilution Factor
MI Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050454
06-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-31487	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939
Client ID: PBW	Batch ID: 31487	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981137
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: MB-31487	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939
Client ID: PBW	Batch ID: 31487	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981138
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-31487	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939
Client ID: LCSW	Batch ID: 31487	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981139
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.500 100 0 101 85 115

Sample ID: 25050454-044AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939
Client ID: 20420701002SF25A	Batch ID: 31487	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981142
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 110 0.500 100 10.8 99.4 70 130

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
E Value above quantitation range
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
H Holding times for preparation or analysis exceeded
RL Reporting Limit

DF Dilution Factor
MI Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050454
06-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050454-044AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/30/2025	RunNo: 59939						
Client ID: 20420701002SF25A	Batch ID: 31487	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981143						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	110	0.500	100	10.8	98.8	70	130	110	0.513	20
------	-----	-------	-----	------	------	----	-----	-----	-------	----

Sample ID: MB-31456	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2025	RunNo: 59939						
Client ID: PBW	Batch ID: 31456	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981174						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515
------	----	-------

Sample ID: LCS-31456	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2025	RunNo: 59939						
Client ID: LCSW	Batch ID: 31456	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981175						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.520	100	0	101	85	115
------	-----	-------	-----	---	-----	----	-----

Sample ID: 25050454-017AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2025	RunNo: 59939						
Client ID: 20420703017CF25A	Batch ID: 31456	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981177						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	96.1	0.520	100	0.163	95.9	70	130
------	------	-------	-----	-------	------	----	-----

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
E	Value above quantitation range
ND	Not Detected at the Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
H	Holding times for preparation or analysis exceeded
RL	Reporting Limit

DF	Dilution Factor
MI	Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050454
06-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050454-017AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2025	RunNo: 59939						
Client ID: 20420703017CF25A	Batch ID: 31456	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981178						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.520	100	0.163	101	70	130	96.1	4.92	20	

Sample ID: MB-31457	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2025	RunNo: 59939						
Client ID: PBW	Batch ID: 31457	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981202						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31457	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2025	RunNo: 59939						
Client ID: LCSW	Batch ID: 31457	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981203						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.1	0.520	100	0	98.1	85	115				

Sample ID: 25050454-037AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2025	RunNo: 59939						
Client ID: 20420707002WB25A	Batch ID: 31457	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981205						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.1	0.520	100	0.139	98.0	70	130				

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
E Value above quantitation range
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
H Holding times for preparation or analysis exceeded
RL Reporting Limit

DF Dilution Factor
MI Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050454
06-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050454-037AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/28/2025	RunNo: 59939						
Client ID: 20420707002WB25A	Batch ID: 31457	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981206						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	93.7	0.520	100	0.139	93.6	70	130	98.1	4.57	20	

Sample ID: MB-31469	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: PBW	Batch ID: 31469	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981230						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31469	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: LCSW	Batch ID: 31469	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981231						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	96.9	0.520	100	0	96.9	85	115				

Sample ID: 25050454-076AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: 20420700023DW25A	Batch ID: 31469	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981252						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	78.5	0.520	100	0.0886	78.4	70	130				

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
E Value above quantitation range
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
H Holding times for preparation or analysis exceeded
RL Reporting Limit

DF Dilution Factor
MI Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050454
06-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050454-076AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: 20420700023DW25A	Batch ID: 31469	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981253						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	78.3	0.520	100	0.0886	78.2	70	130	78.5	0.260	20	

Sample ID: MB-31470	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: PBW	Batch ID: 31470	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981256						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: MB-31470	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: PBW	Batch ID: 31470	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981257						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: LCS-31470	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: LCSW	Batch ID: 31470	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981258						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	96.8	0.520	100	0	96.8	85	115				

Qualifiers: * Value exceeds Maximum or Minimum Contaminant Level.
E Value above quantitation range
ND Not Detected at the Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
H Holding times for preparation or analysis exceeded
RL Reporting Limit

DF Dilution Factor
MI Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050454

06-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Scenic Middle School Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050454-077AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: 20420700024DW25A	Batch ID: 31470	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981260						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	94.9	0.520	100	0.0711	94.8	70	130				
------	------	-------	-----	--------	------	----	-----	--	--	--	--

Sample ID: 25050454-077AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 59939						
Client ID: 20420700024DW25A	Batch ID: 31470	TestNo: E200.8	E200.8	Analysis Date: 6/2/2025	SeqNo: 981261						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	96.9	0.520	100	0.0711	96.8	70	130	94.9	2.03	20	
------	------	-------	-----	--------	------	----	-----	------	------	----	--

Sample ID: MB-31471	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 60020						
Client ID: PBW	Batch ID: 31471	TestNo: E200.8	E200.8	Analysis Date: 6/4/2025	SeqNo: 982658						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-31471	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 60020						
Client ID: LCSW	Batch ID: 31471	TestNo: E200.8	E200.8	Analysis Date: 6/4/2025	SeqNo: 982659						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	100	0.520	100	0	100	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Qualifiers:

- * Value exceeds Maximum or Minimum Contaminant Level.
- E Value above quantitation range
- ND Not Detected at the Reporting Limit

- C1 Sample container temperature is out of limit as specified at testcode
- H Holding times for preparation or analysis exceeded
- RL Reporting Limit

- DF Dilution Factor
- MI Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25050454
06-Jun-25

Client: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Middle School Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: 25050454-097AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 60020						
Client ID: 20420704011KF25A	Batch ID: 31471	TestNo: E200.8	E200.8	Analysis Date: 6/4/2025	SeqNo: 982661						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	99.4	0.520	100	0.165	99.3	70	130				
------	------	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: 25050454-097AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 5/29/2025	RunNo: 60020						
Client ID: 20420704011KF25A	Batch ID: 31471	TestNo: E200.8	E200.8	Analysis Date: 6/4/2025	SeqNo: 982662						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	98.5	0.520	100	0.165	98.3	70	130	99.4	0.979	20	
------	------	-------	-----	-------	------	----	-----	------	-------	----	--

Qualifiers:

*	Value exceeds Maximum or Minimum Contaminant Level.
E	Value above quantitation range
ND	Not Detected at the Reporting Limit

C1	Sample container temperature is out of limit as specified at testcode
H	Holding times for preparation or analysis exceeded
RL	Reporting Limit

DF	Dilution Factor
MI	Recovery outside control limits due to Matrix In

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25050454

RcptNo: 1

Logged by: Dorie Evans 5/9/2025 10:08:00 AM

Completed By: Coni Boyko 5/13/2025 1:17:27 PM

Reviewed By: Tamra Schmedemann 6/6/2025 11:52:05 AM

Dorie Evans

Coni Boyko

Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO₃ pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified:

Date:

By Whom:

Via:

☐ eMail

☐ Phone

☐ Fax

☐ In Person


Regarding:

Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Required Client Information

Company: Central Point School District #6	
Address: 300 Ash Street	
Central Point OR 97502	
Email:	
Phone:	Fax:
Collected By (Print): Jeff Carr	
Collected By (Sign): <i>Jeff Carr</i>	
Email Report ☒ Yes ___ No	Mail Report ___ Yes ___ No
Fax Report ___ Yes ___ No	

Required Project Information

Project Name:	Scenic
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:
Company Name:
Address:
P.O. #

Rush Status (Subject to Scheduling)

☒	Standard 10-14 Days
☐	5 Business Days (50% surcharge)
☐	3 Business Days (75% surcharge)
☐	24 - 48 hours (100% surcharge)
☐	Other

Authorized _____ Yes _____ No _____

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of	Lead											(Lab Use Only)	NRC Sample # (Lab Use Only)
							Remarks/Field Data											
20420703001SF 25A	119913	DW	5-9-25	5:20AM	1	X											01	
20420703002SF 25A	119950	DW	5-9-25	5:20AM	1	X											02	
20420703003CF 25A	119936	DW	5-9-25	5:22AM	1	X											03	
20420703004BF 25A	119923	DW	5-9-25	5:25AM	1	X											04	
20420703005BF 25A	119911	DW	5-9-25	5:25AM	1	X											05	
20420703006DW 25A	119999	DW	5-9-25	5:26AM	1	X											06	
20420703007WB 25A	119934	DW	5-9-25	5:27AM	1	X											07	
20420703008DW 25A	119932	DW	5-9-25	5:28AM	1	X											08	
20420703009BF 25A	119910	DW	5-9-25	5:29AM	1	X											09	
20420703010BF 25A	119992	DW	5-9-25	5:29AM	1	X											10	

*Matrix: DW - Drinking Water, WW - Wastewater, W - Water, S - Soil, SL - Solid, CL - Clay, G - Gravel, M - Mud, P - Petroleum, L - Liquid, V - Volatile, N - Non, O - Organic, I - Inorganic, A - Air, B - Biological, C - Chemical, E - Electrical, F - Fluid, H - Heat, J - Joint, K - Key, L - Label, M - Material, N - Name, O - Oil, P - Paper, Q - Quantity, R - Rate, S - Size, T - Temperature, U - Unit, V - Value, W - Weight, X - X-ray, Y - Year, Z - Zone

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Signature	Print	Date	Time
Relinquished By: Jeff Carr	Jeff Carr	5-9-25	10:09am
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: D. Eve	NORIE EVANS	5/9/25	10:08

Lab Use Only

Temp: AMR
4°C +/- 2°C: Yes No
Received on Ice: Yes No
Number of Bottles Received: 104
pH Checked: -
COC Seals Intact: Yes No NA
Field Blank Included: Yes No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment:	Invoice	Cash	VISA, M/C	Check #	Amount
----------	---------	------	-----------	---------	--------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Central Point School District #6</u>	Project Name: <u>Scenic</u>	Attention:	☒ Standard 10-14 Days
Address: <u>300 Ash Street</u>	Project Number:	Company Name:	☐ 5 Business Days (50% surcharge)
<u>Central Point OR 97502</u>	Report To:	Address:	☐ 3 Business Days (75% surcharge)
Email:	Copy To:	P.O. #	☐ 24 - 48 hours (100% surcharge)
Phone: _____ Fax: _____			☐ Other _____
Collected By (Print): <u>Jeff Carr</u>			Authorized ☐ Yes ☐ No
Collected By (Sign): <u>Jeff Carr</u>			
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No			
Fax Report ☐ Yes ☐ No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only) <u>75050454</u>	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420703011CF25A	119994	DW	5-9-25	5:31AM	1	X													11
20420703012CF25A	119996	DW	5-9-25	5:31AM	1	X													12
20420703013CF25A	119981	DW	5-9-25	5:33AM	1	X													13
20420703014CF25A	119997	DW	5-9-25	5:34AM	1	X													14
20420703015CF25A	119957	DW	5-9-25	5:37AM	1	X													15
20420703016CF25A	119940	DW	5-9-25	5:38AM	1	X													16
20420703017CF25A	119943	DW	5-9-25	5:38AM	1	X													17
20420703018CF25A	119939	DW	5-9-25	5:40AM	1	X													18
20420703019DW25A	119938	DW	5-9-25	5:42AM	1	X													19
20420703020DW25A	119919	DW	5-9-25	5:43AM	1	X													20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>Jeff Carr</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:08AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>Dorie Evans</u>		<u>Dorie Evans</u>	<u>5/9/25</u>	<u>10:08</u>

Section G Lab Use Only

Temp: <u>AMB</u>
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: <u>104</u>
pH Checked: ☐
COC Seals Intact: ☐ Yes ☐ No ☒ NA
Field Blank Included: ☐ Yes ☒ No
Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Scenic</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>Jeff Carr</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050454</u>		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead										Remarks/Field Data	NRC Sample # (Lab Use Only)
20420703021WB25A	119928	DW	5-9-25	5:44AM	1	X											21
20420703022CF25A	119944	DW	5-9-25	5:45AM	1	X											22
20420703023CF25A	119914	DW	5-9-25	5:47AM	1	X											23
20420703024CF25A	119959	DW	5-9-25	5:47AM	1	X											24
20420703025BF25A	119930	DW	5-9-25	5:50AM	1	X											25
20420703026NS25A	119958	DW	5-9-25	5:49AM	1	X											26
20420703027NS25A	119941	DW	5-9-25	5:51AM	1	X											27
20420703028DW25A	16660	DW	5-9-25	6:29AM	1	X											28
20420703029DW25A	16668	DW	5-9-25	6:29AM	1	X											29
20420703030WB25A	16667	DW	5-9-25	6:30AM	1	X											30

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:09AM</u>
Received By:					
Relinquished By:					
Received By:					
Relinquished By:					
Received By Laboratory:	<u>[Signature]</u>		<u>Dorie Evans</u>	<u>5/9/25</u>	<u>10:08</u>

Section G Lab Use Only	
Temp:	<u>AMB</u>
4°C +/- 2°C:	☐ Yes ☒ No
Received on Ice:	☐ Yes ☒ No
Number of Bottles Received:	<u>104</u>
pH Checked:	☐ Yes ☒ No
COC Seals Intact:	☐ Yes ☒ No
Field Blank Included:	☐ Yes ☒ No
Received Via	☐ UPS ☐ FedEx ☒ Other ☐ Hand
Payment:	☒ Invoice ☐ Cash ☐ VISA/M/C ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Scenic</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>Jeff Carr</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050454</u>		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead										Remarks/Field Data	NRC Sample # (Lab Use Only)
204207060025F25A	119882	DW	5-9-25	4:47AM	1	X											31
204207060015F25A	119859	DW	5-9-25	4:45AM	1	X											32
20420709001CF25A	119899	DW	5-9-25	4:49AM	1	X											33
20420709002BF25A	119877	DW	5-9-25	4:50AM	1	X											34
20420709003BF25A	119904	DW	5-9-25	4:51AM	1	X											35
20420709001DW25A	119906	DW	5-9-25	4:53AM	1	X											36
20420709002WB25A	119862	DW	5-9-25	4:54AM	1	X											37
20420707003BF25A	119908	DW	5-9-25	4:55AM	1	X											38
20420707004BF25A	119907	DW	5-9-25	4:56AM	1	X											39
20420707005BF25A	119873	DW	5-9-25	4:57AM	1	X											40

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:08AM</u>
Received By:					
Relinquished By:					
Received By:					
Relinquished By:					
Received By Laboratory:	<u>[Signature]</u>		<u>DORIE EVANS</u>	<u>5/9/25</u>	<u>10:08</u>

Section G Lab Use Only	
Temp:	<u>AMB</u>
4°C +/- 2°C:	☐ Yes ☒ No
Received on Ice:	☐ Yes ☒ No
Number of Bottles Received:	<u>104</u>
pH Checked:	☐ Yes ☒ No
COC Seals Intact:	☐ Yes ☒ No
Field Blank Included:	☐ Yes ☒ No
Received Via	☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment:	☐ Invoice ☐ Cash ☐ VISA/MC ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District</u>		Project Name: <u>Scenic</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>Jeff Carr</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>Jeff Carr</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420707006SF25A	119872	DW	5-9-25	4:58AM	1	X											25050454		41
20420707007SF25A	119861	DW	5-9-25	4:59AM	1	X													42
20420701001SF25A	119977	DW	5-9-25	5:02AM	1	X													43
20420701002SF25A	119991	DW	5-9-25	5:03AM	1	X													44
20420701003CF25A	119987	DW	5-9-25	5:05AM	1	X													45
20420701004BF25A	119922	DW	5-9-25	5:07AM	1	X													46
20420701005BF25A	119912	DW	5-9-25	5:07AM	1	X													47
20420701006BF25A	119982	DW	5-9-25	5:09AM	1	X													48
20420701007DW25A	119983	DW	5-9-25	5:09AM	1	X													49
20420701008DW25A	119988	DW	5-9-25	5:10AM	1	X													50

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>Jeff Carr</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:08AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>Dorie Evans</u>		<u>DORIE EVANS</u>	<u>5/9/25</u>	<u>10:08</u>

Section G Lab Use Only

Temp: <u>AMB</u>
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: <u>104</u>
pH Checked: <u>-</u>
COC Seals Intact: ☐ Yes ☒ No <u>NA</u>
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☒ Other <u>Hand</u>
Payment: ☒ Invoice ☐ Cash ☐ VISA/MC ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): Jeff Carr
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: Scenic
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420701009WB25A	11998	DW	5-9-25	5:10AM	1	X											25050454		
20420701010BF25A	119921	DW	5-9-25	5:11AM	1	X													51
20420702001CF25A	119924	DW	5-9-25	5:15AM	1	X													52
204207020025F25A	119935	DW	5-9-25	5:16AM	1	X													53
		DW			1	X													54
		DW			1	X													
		DW			1	X													
		DW			1	X													
		DW			1	X													
		DW			1	X													
		DW			1	X													

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:09 AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>DORIE EVANS</u>	<u>5/9/25</u>	<u>10:08</u>

Section G

Lab Use Only

Temp: AMB
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: 104
pH Checked: —
COC Seals Intact: ☐ Yes ☒ No
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # ☐ Amount

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>SCENIC</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>MARK LILLICH</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420700001 DW 25A	119925	DW	5-9-25	5:17 AM	1	X											25050454		55
20420700003 WB 25A	119917	DW	5-9-25	5:23 AM	1	X													56
20420700004 DW 25A	119929	DW	5-9-25	5:24 AM	1	X													57
20420700005 DW 25A	119920	DW	5-9-25	5:25 AM	1	X													58
20420700006 BF 25A	119942	DW	5-9-25	5:28 AM	1	X													59
20420700007 BF 25A	119946	DW	5-9-25	5:29 AM	1	X													60
20420700008 WB 25A	119933	DW	5-9-25	5:31 AM	1	X													61
20420700009 DW 25A	119931	DW	5-9-25	5:32 AM	1	X													62
20420700010 DW 25A	119937	DW	5-9-25	5:32 AM	1	X													63
20420700011 BF 25A	119918	DW	5-9-25	5:35 AM	1	X													64

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:09 AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By: <u>[Signature]</u>		<u>DORLE EVANS</u>	<u>5/9/25</u>	<u>10:08</u>
Received By Laboratory:				

Section G Lab Use Only

Temp: <u>AMB</u>	4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No	
Number of Bottles Received: <u>104</u>	
pH Checked: <u>-</u>	
COC Seals Intact: ☐ Yes ☒ No	
Field Blank Included: ☐ Yes ☒ No	
Received Via: ☒ UPS ☐ FedEx ☐ Other ☒ Hand	
Payment: ☒ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # _____ Amount _____	

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>SCENIC</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>MARK LILLIA</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420700012 BF25A	119947	DW	5-9-25	5:37AM	1	X											25050454		65
20420700013 BF25A	119915	DW	5-9-25	5:38AM	1	X													66
20420700014 BF25A	119952	DW	5-9-25	5:43AM	1	X													67
20420700015 BF25A	119951	DW	5-9-25	5:44AM	1	X													68
20420700016 WB25A	119950	DW	5-9-25	5:46AM	1	X													69
20420700017 DW25A	119949	DW	5-9-25	5:47AM	1	X													70
20420700018 DW25A	119954	DW	5-9-25	5:48AM	1	X													71
20420700019 BF25A	119948	DW	5-9-25	5:49AM	1	X													72
20420700020 BF25A	119955	DW	5-9-25	5:51AM	1	X													73
20420700021 BF25A	119968	DW	5-9-25	6:00AM	1	X													74

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>Jeff Carr</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:08AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u> <u>EVANS</u>		<u>DORR EVANS</u>	<u>5/9/25</u>	<u>10:08</u>

Section G Lab Use Only

Temp: <u>AMB</u>	
4°C +/- 2°C: ☐ Yes ☒ No	
Received on Ice: ☐ Yes ☒ No	
Number of Bottles Received: <u>104</u>	
pH Checked: <u>-</u>	
COC Seals Intact: ☐ Yes ☒ No	
Field Blank Included: ☐ Yes ☒ No	
Received Via: <u>UPS</u> <u>FedEx</u> <u>Other</u> <u>Hand</u>	
Payment: <u>Invoice</u> <u>Cash</u> <u>VISA</u> <u>M/C</u> <u>Check</u> <u>#</u> <u>Amount</u>	

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>SCENIC</u>		Attention:		☒ Standard 10-14 Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ 5 Business Days (50% surcharge)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ 3 Business Days (75% surcharge)	
Email:		Copy To:		P.O. #		☐ 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						☐ Other _____	
Collected By (Print): <u>MARK LILICH</u>						Authorized ☐ Yes ☐ No	
Collected By (Sign): <u>[Signature]</u>							
Email Report ☒ Yes ☐ No		Mail Report ☐ Yes ☐ No					
Fax Report ☐ Yes ☐ No							

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only) <u>25050454</u>	
																	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420700022WB25A	119953	DW	5-9-25	6:04AM	1	X												75
20420700023DW25A	119961	DW	5-9-25	6:05AM	1	X												76
20420700024DW25A	119960	DW	5-9-25	6:06AM	1	X												77
20420700025DW25A	119963	DW	5-9-25	6:07AM	1	X												78
20420700026DW25A	119962	DW	5-9-25	6:08AM	1	X												79
20420700027WB25A	119926	DW	5-9-25	6:08AM	1	X												80
20420700028DW25A	119916	DW	5-9-25	6:03AM	1	X												81
20420700029DW25A	119965	DW	5-9-25	6:04AM	1	X												82
20420700030BW25A	119964	DW	5-9-25	6:04AM	1	X												83
20420700031BF25A	119966	DW	5-9-25	6:02AM	1	X												84

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:09AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>DORIE EVANS</u>	<u>5/9/25</u>	<u>10:08</u>

Section G Lab Use Only

Temp: <u>AMB</u>	4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No	Number of Bottles Received: <u>104</u>
pH Checked: <u>-</u>	COC Seals Intact: ☐ Yes ☒ No
Field Blank Included: ☐ Yes ☒ No	Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash	VISA M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): MARK LILLICH
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: SCENIC
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420700032 BF25A	119975	DW	5-9-25	6:02AM	1	X											25050451		85
20420700033 BF25A	119971	DW	5-9-25	5:45AM	1	X													86
20420704001 CF25A	122433	DW	5-9-25	4:45AM	1	X													87
20420704002 BF25A	112349	DW	5-9-25	4:48AM	1	X													88
20420704003 KF25A	135738	DW	5-9-25	4:57AM	1	X													89
20420704004 IM25A	112270	DW	5-9-25	5:52AM	1	X													90
20420704005 DW25A	112261	DW	5-9-25	5:13AM	1	X													91
20420704006 DW25A	119927	DW	5-9-25	5:14AM	1	X													92
20420704007 WB25A	119969	DW	5-9-25	5:15AM	1	X													93
20420704008 KF25A	119956	DW	5-9-25	4:58AM	1	X													94

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:08AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>DORIE EVANS</u>	<u>5/9/25</u>	<u>10:08</u>

Section G

Lab Use Only

Temp: AMB
4°C +/- 2°C: ☐ Yes ☒ No
Received on ice: ☐ Yes ☒ No
Number of Bottles Received: 104
pH Checked: -
COC Seals Intact: ☐ Yes ☒ No NA
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☐ Other ☒ Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6
Address: 300 Ash Street
Central Point OR 97502
Email: _____
Phone: _____ Fax: _____
Collected By (Print): MARK LILICH
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No

Section B

Required Project Information

Project Name: SCENIC
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other _____
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
20420704009 KF25A	119974	DW	5-9-25	5:00AM	1	X		25050454		95
20420704010 KF25A	119972	DW	5-9-25	5:01AM	1	X				96
20420704011 KF25A	119970	DW	5-9-25	5:03AM	1	X				97
20420704012 KF25A	119967	DW	5-9-25	5:04AM	1	X				98
20420704013 KF25A	119973	DW	5-9-25	5:07AM	1	X				99
20420704014 KF25A	119879	DW	5-9-25	5:08AM	1	X				100
20420704015 BF25A	119830	DW	5-9-25	5:10AM	1	X				101
20420704016 DW25A	116669	DW	5-9-25	5:29AM	1	X				102
20420704017 DW25A	116662	DW	5-9-25	5:28AM	1	X				103
20420704018 WB25A	116661	DW	5-9-25	5:27AM	1	X				104

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
<u>[Signature]</u>		<u>Jeff Carr</u>	<u>5-9-25</u>	<u>10:08AM</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>DORIE EVANS</u>	<u>5/9/25</u>	<u>10:08</u>

Section G

Lab Use Only

Temp: AMB
4°C +/- 2°C: ☐ Yes ☒ No
Received on Ice: ☐ Yes ☒ No
Number of Bottles Received: 104
pH Checked: -
COC Seals Intact: ☐ Yes ☒ No NA
Field Blank Included: ☐ Yes ☒ No
Received Via: ☐ UPS ☐ FedEx ☒ Other Hand
Payment: ☒ Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # _____ Amount _____

- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
- A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
- B Analyte detected in the associated method blank.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
- R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
- R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
- 1 Value exceeds one half of the Maximum Contaminant Level.



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

October 31, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Scenic Lead Testing

Order No.: 25101199

Dear Dale Giovannetti:

Neilson Research Corporation received 1 sample(s) on 10/27/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25101199
Date: 10/31/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: Scenic Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25101199

Date Reported: 10/31/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25101199
Received Date: 10/27/2025 9:55:00 AM
Reported Date: 10/31/2025 10:39:40 AM

Sample Information:

Lab ID: 25101199-01 Client Sample ID: 20420700019BF
Collection Date: 10/25/2025 6:24:00 AM Collected By:
Matrix: Drinking Water Sample Location: 20420700019BF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KHG	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	10/29/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25101199
31-Oct-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Scenic Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-33462	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: PBW	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058429
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-33462	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: LCSW	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058430
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.500 100 0 102 85 115

Sample ID: 25101193-04AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: BatchQC	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058432
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.500 100 0.869 100 70 130

Sample ID: 25101193-04AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: BatchQC	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058433
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.500 100 0.869 101 70 130 101 0.346 20

Qualifiers:
* Value exceeds Maximum or Minimum Contaminant Level.
H Holding times for preparation or analysis exceeded
RL Reporting Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: CentralPtSchDist

Work Order Number: 25101199

RcptNo: 1

Logged by: Ashley Spiegelberg 10/27/2025 9:55:00 AM
Completed By: Kyler Woolsey 10/29/2025 11:52:09 AM
Reviewed By: Dorie Evans 10/31/2025 10:36:58 AM

Am
Kyler Woolsey
Dorie Evans

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☐ NA ☒
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A

Required Client Information

Company: Central Point School District #6

Address: 300 Ash Street
Central Point, OR 97502

Email: _____

Phone: _____

Collected By (Print): _____

Collected By (Sign): _____

Email Report ☒ Mail Report ☐ Fax Report ☐

Section B

Required Project Information

Project Name: Scenic

Project Number: _____

Report To: _____

Copy To: _____

Section C

Invoice Information

Attention: _____

Company Name: _____

Address: _____

P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard: 10 Business Days

☐ Priority: 5 Business Days (List × 1.50)

☐ Express: 3 Business Days (List × 1.75)

☐ Rush: 2 Business Days (List × 2.00)

☐ Rush: 1 Business Day (List × 2.50)

☐ Rush: Same Day (List × 3.00)

Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks / Field Data	NRC Sample # (Lab Use Only)	(Lab
20420700019BF	119887	DW	10-25-25	6:24 AM	1	X										25101199			

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Jeff Carr</u>	<u>10-27-25</u>	<u>9:55 AM</u>
Received By: _____				
Relinquished By: _____				
Received By: _____				
Relinquished By: _____				
Received By Laboratory: <u>[Signature]</u>		<u>Ashley Spiegelberg</u>	<u>10/27/25</u>	<u>9:55</u>

Section G

Lab Use Only

Temp: Amb IR Therm ID: NA

≤6°C: ☐ Yes ☐ No

Received on Ice: ☐ Yes ☒ No

Number of Bottles Received: _____

pH Checked: ☒

COC Seals Intact: ☐ Yes ☐ No ☒ NA

Field Blank Included: ☐ Yes ☐ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: ☒ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # _____ Amount _____

Effective 10/5/2020