

Lead in Water Test Results Summary: Support Services/Maintenance and Food Svcs

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **1 ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red** and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 10 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange** and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5.01 ppb to 9.99 ppb** are **highlighted in yellow** and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than or equal to 5 ppb** are **not highlighted** and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Office Bathroom Sink	20420002001BF25A	10/25/2025	1.56	Low			
Breakroom Bathroom Sink	20420002002BF25A	10/25/2025	0.873	Low			
Breakroom Sink	20420002003SF25A	10/25/2025	1.64	Low			
Shop Sink	20420002004OT25A	10/25/2025	0.869	Low			



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

October 30, 2025

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502
TEL: (541) 494-6924
FAX

RE: Support Services Lead Testing

Order No.: 25101193

Dear Dale Giovannetti:

Neilson Research Corporation received 4 sample(s) on 10/27/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 25101193
Date: 10/30/2025

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: Support Services Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25101193

Date Reported: 10/30/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point , OR 97502

Lab Order: 25101193
Received Date: 10/27/2025 9:55:00 AM
Reported Date: 10/30/2025 2:57:34 PM

Sample Information:

Lab ID: 25101193-01 **Client Sample ID:** 20420002001BF25A
Collection Date: 10/25/2025 8:13:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** 20420002001BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KHG	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.56		0.500	ppb	1	10/29/2025	15.0	A

Lab ID: 25101193-02 **Client Sample ID:** 20420002002BF25A
Collection Date: 10/25/2025 8:16:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** 20420002002BF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KHG	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.873		0.500	ppb	1	10/29/2025	15.0	A

Lab ID: 25101193-03 **Client Sample ID:** 20420002003SF25A
Collection Date: 10/25/2025 8:19:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** 20420002003SF25A

Trace Metals by EPA 200.8 ICP-MS							Analyst; KHG	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.64		0.500	ppb	1	10/29/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 25101193

Date Reported: 10/30/2025

Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

Lab Order: 25101193
Received Date: 10/27/2025 9:55:00 AM
Reported Date: 10/30/2025 2:57:34 PM

Sample Information:

Lab ID: 25101193-04 **Client Sample ID:** 20420002004OT25A
Collection Date: 10/25/2025 8:20:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** 20420002004OT25A

Trace Metals by EPA 200.8 ICP-MS						Analyst: KHG		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.869		0.500	ppb	1	10/29/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	DF	Dilution Factor	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	MI	Recovery outside control limits due to Matrix Interference	ND	Not Detected at the Reporting Limit
	R	RPD outside accepted recovery limits	RL	Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25101193
30-Oct-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Support Services Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-33461	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938						
Client ID: PBW	Batch ID: 33461	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058408						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID: LCS-33461	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938						
Client ID: LCSW	Batch ID: 33461	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058409						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.500	100	0	101	85	115				

Sample ID: 25101135-01BMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938						
Client ID: BatchQC	Batch ID: 33461	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058425						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.2	0.500	100	0.0690	98.2	70	130				

Sample ID: 25101135-01BMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938						
Client ID: BatchQC	Batch ID: 33461	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058426						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.3	0.500	100	0.0690	97.2	70	130	98.2	1.00	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference

DF Dilution Factor
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed
RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 25101193
30-Oct-25

Client: Central Point Sch. Dist/Sams Valley Elem

Project: Support Services Lead Testing

TestCode: LEAD_SCHOOLS

Sample ID: MB-33462	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: PBW	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058429
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: LCS-33462	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: LCSW	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058430
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.500 100 0 102 85 115

Sample ID: 25101193-04AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: 20420002004OT25A	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058432
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.500 100 0.869 100 70 130

Sample ID: 25101193-04AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 10/28/2025	RunNo: 63938
Client ID: 20420002004OT25A	Batch ID: 33462	TestNo: E200.8	E200.8	Analysis Date: 10/29/2025	SeqNo: 1058433
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.500 100 0.869 101 70 130 101 0.346 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode DF Dilution Factor H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit RL Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Sample Log-In Check List

Client Name: **CentralPtSchDist**

Work Order Number: **25101193**

RcptNo: **1**

Logged by: **Ashley Spiegelberg** **10/27/2025 9:55:00 AM**
Completed By: **Kyler Woolsey** **10/29/2025 11:56:27 AM**
Reviewed By: **Ashley Spiegelberg** **10/30/2025 2:54:31 PM**

Am
Kyler Woolsey
Am

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☐ NA ☒
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO₃ pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ____ of ____

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Central Point School District #6</u>		Project Name: <u>Support Services</u>		Attention:		☒ Standard: 10 Business Days	
Address: <u>300 Ash Street</u>		Project Number:		Company Name:		☐ Priority: 5 Business Days (List x 1.50)	
<u>Central Point OR 97502</u>		Report To:		Address:		☐ Express: 3 Business Days (List x 1.75)	
Email:		Copy To:		P.O. #		☐ Rush: 2 Business Days (List x 2.00)	
Phone: Fax:						☐ Rush: 1 Business Day (List x 2.50)	
Collected By (Print):						☐ Rush: Same Day (List x 3.00)	
Collected By (Sign):						Authorized ☐ Yes ☐ No	
Email Report ☒ Mail Report ☐ Fax Report ☐							

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>25101193</u>				
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead											Remarks / Field Data	NRC Sample # (Use Only)	(Lab)
<u>20420002001BF25A</u>	<u>119852</u>	<u>DW</u>	<u>10-25-25</u>	<u>8:13AM</u>	<u>1</u>	<u>X</u>												<u>01</u>	
<u>20420002002DF25A</u>	<u>119850</u>	<u>DW</u>	<u>10-25-25</u>	<u>8:16AM</u>	<u>1</u>	<u>X</u>												<u>02</u>	
<u>20420002003SF25A</u>	<u>119848</u>	<u>DW</u>	<u>10-25-25</u>	<u>8:19AM</u>	<u>1</u>	<u>X</u>												<u>03</u>	
<u>20420002004OT25A</u>	<u>119851</u>	<u>DW</u>	<u>10-25-25</u>	<u>8:20AM</u>	<u>1</u>	<u>X</u>												<u>04</u>	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign		Print		Date		Time	
Relinquished By:	<u>[Signature]</u>			<u>Jeff Carr</u>			<u>10-27-25</u>		<u>9:55am</u>
Received By:									
Relinquished By:									
Received By:									
Relinquished By:									
Received By Laboratory:	<u>[Signature]</u>			<u>Ashley Grigelberg</u>			<u>10/27/25</u>		<u>9:55</u>

Section G Lab Use Only	
Temp:	<u>Amb</u>
≤6°C: Yes No	
Received on Ice: Yes No	<u>(No)</u>
Number of Bottles Received:	
pH Checked:	
COC Seals Intact: Yes No	<u>NA</u>
Field Blank Included: Yes No	
Received Via: UPS FedEx Other	<u>(Hand)</u>
Payment: <u>(Invoice)</u> Cash VISA, M/C Check #	Amount

Effective 6/19/2020