


2025 Tools for Schools Survey Results

Overview: This survey is a collection of questions crafted over time by our long standing Tools for Schools Committee at Beecher Road School. This year the survey was sent out on September 30th 2025 and left open 14 days. We had 66 responses which is an increase of 18 completed responses. Upon review of this survey 2 separate building walkthroughs will be conducted by the committee to inspect and evaluate concerns.

I understand where fresh air enters my room, and I am keeping it free from obstruction
66 responses




NOTES: The 4 "no" respondents have been visited and shown where fresh air enters their space. All 4 spaces are serviced by similar ceiling mounted FCU units that pull fresh air from ERVs located on various locations on the roof of the building. Fresh air enters via ceiling vents.

2025 Tools for Schools Survey Results

Classroom sink is cleaned daily?


66 responses



NOTES: The 5 “no” responses were located in various areas of the building. The custodians in affected areas were alerted to the concern.

Trash receptacles are emptied daily.

66 responses




NOTES: The 2 “no” responses were from two separate people inhabiting the same space. Upon investigation it seems on a singular evening in question the receptacles were missed.

2025 Tools for Schools Survey Results

Classroom carpets and floor areas are vacuumed and swept daily.


66 responses



NOTES: The “4” no responses were from 2 separate custodial areas. The area custodians were alerted to the issue. Our custodial crew has discussed the pros and cons of backpack vacuum versus upright vacuums with brushes.

Classroom lavatories are free of leaks and odors

66 responses




NOTES: The 7 “no” responses were located in various areas throughout the building. 4 of 7 “no” responses were located in the K-Wing closest to the bathrooms utilized by the cafeteria. The other 3 were spread throughout the building.

2025 Tools for Schools Survey Results

Areas around and under classroom sinks are free of leaks


66 responses



NOTES: The 1 “no” response is from the STEM room.

I understand which areas (i.e. desks) are not cleaned by custodians, and I maintain them regularly

66 responses




NOTES: The 3 “no” responses were forwarded previously provided literature on the custodial cleaning specifications within the building.

2025 Tools for Schools Survey Results

Classroom is free of odor


66 responses



NOTES: Out of 8 “no” responses all but two were located south of the C-Wing. Multiple rooms are located in the interior of the Rotunda area. It has been expressed that food odor from the teacher’s lounge often circulates throughout the spaces serviced by AHU6. The remaining responses showed minor room location correlation.

Halls are free of odor

66 responses




NOTES: The 3 “no” responses also responded “no” to classrooms being free of odor. This should be investigated further during our walkthroughs.

2025 Tools for Schools Survey Results

Ceiling tiles and walls are free of active leaks (discoloration may indicate periodic leaks or condensation drip)


66 responses



NOTES: The 5 “no” responses were all investigated. 4 of 5 were not active leaks. The 5th space has a periodic roof leak that seems to cause tile spotting in windy or heavy rain conditions. Our roof vendor was alerted to the issue prior to their inspection on 11/2/25.

I have seen evidence of pests or vermin in my space during September 2025

66 responses




NOTES: We have 18 “yes” responses. Generally the sightings were spread throughout the building with most areas having 1-2 respondents answer yes. The S-Wing/South in particular are responsible for half of the “yes” responses.

2025 Tools for Schools Survey Results

My room is free of clutter


66 responses



NOTES: The 4 "no" responses were 3 in MAG and the library.

All food is stored in tightly sealed containers

66 responses




NOTES: The 1 "no" response was from the kitchen, but generally the kitchen is an area of little to no mouse activity.

2025 Tools for Schools Survey Results

Classroom supplies are stored according to manufacturers' recommendations (i.e. paints, dry erase cleaners)


66 responses



NOTES: None

Exposure to hazardous materials (i.e., used non-hazardous materials and pre-mixed products) is minimized

66 responses




NOTES: None.

2025 Tools for Schools Survey Results

Only school-supplied cleaners are used in my classroom.


66 responses



NOTES: None

Are your area rugs less than 6 years old?

66 responses




NOTES: We are still re-establishing our pre-COVID rug replacement cycle. All school supplied rugs should currently be under 6 years old as all were purchased after COVID.

2025 Tools for Schools Survey Results

Potential allergies of students are identified and Nursing Staff are consulted as appropriate.


66 responses



NOTES: None

I am aware the use of chemical air fresheners and scented plug-ins is highly discouraged and can trigger asthma symptoms in students and staff members.

66 responses




Notes: None

2025 Tools for Schools Survey Results

Do you utilize the "Fix It" work order system to report issues within your space?

66 responses



Notes: The 2 "no" responses were from new employees. They have been forwarded literature about utilizing FixIt.