Environmental Control Systems, Inc.

Environmental Engineers and Management Consultants

June 8, 2026

Mr. Brian Russell
Director of Facilities
Wissahickon School District
601 Knight Road
Ambler, Pennsylvania 19002

Re: Lead in Drinking Water Sampling Results

Dear Mr. Russell:

Various drinking water outlets in the Wissahickon School District were tested for Lead in Drinking Water on May 19, 2026. Samples were collected from outlets in accordance with EPA protocol listed in the 3T's for Reducing Lead in Drinking Water in Schools, revised October 2018.

The analysis was performed by EMSL Analytical, Cinnaminson, NJ, an EPA accredited laboratory. Results are based on EPA recommended action level which is 15 ppb for lead in schools based on a 250 ml sample analysis method for Metals by ICP-MS-EPA 200.8.

The results from various outlets tested are Non-Detect which is under the PA Act 39, EPA action limit of 15 ppb. Lead in Drinking Water Testing fulfills your 2025-2026 obligation Under PA Act 39 of 2018, to test for or discuss lead levels annually in the drinking water of any facility where children attend school.

Please let us know if you have any questions.

Cordially,

Barbara Lippmann
President

950 Sussex Boulevard, Broomall, PA 19008
Ph: 610-328-2880 • www.ecsinfo.net • ecs_pa@hotmail.com

Lead in Drinking Water Results for Wissahickon School District buildings on 5/19/2026.

The Environmental Protection Agency's (EPA) action level for lead in drinking water is 15 parts per billion.

All areas sampled on May 19, 2026 are within those guidelines.

Facility Name	Location	Result	PDE/EPA Limit
Wissahickon HS	Bottle Filler in Natatorium/Gym Lobby	ND	15 ppb
	Bottle Filler outside J04	ND	15 ppb
Wissahickon MS	Bottle Filler outside Gym	ND	15 ppb
	Bottle Filler outside Cafeteria	ND	15 ppb
Admin Building	Kitchen Faucet in Kitchenette	ND	15 ppb
Blue Bell	Bottle Filler outside Room 32	ND	15 ppb
Elementary School	Bottle Filler outside Gym/Cafeteria	ND	15 ppb
Lower Gwynedd	Bottle Filler in Main Lobby	ND	15 ppb
Elementary School	Bottle Filler outside Library	ND	15 ppb
Shady Grove	Bottle Filler outside Library	ND	15 ppb
Elementary School	Bottle Filler inside Cafeteria	ND	15 ppb
Stony Creek	Bottle Filler on Gym side	ND	15 ppb
Elementary School	Bottle Filler on Cafeteria side	ND	15 ppb

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012621756
LIMS Reference ID: AE21756
EMSL Customer ID: ECSPA30

Attention: Barb Lippmann
Environmental Control Systems [ECSPA30]
950 Sussex Blvd.
Broomall, PA 19008
(610) 587-6016
barblippmann@hotmail.com

Project Name: Wissahickon SD - Wissahickon High School
Project ID: _Master Project-ECSPA30
Customer PO: 6832
Sales Rep: Gillian Egiazarov
Received: 05/21/2026 09:00
Reported: 06/05/2026 13:01

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WHS-051926-01/Bottle Filler in Natatorium/Gym Lobby						**Lims Reference ID: AE21756-01**	**Matrix: Drinking Water**		**Sampled: 05/19/26 06:45:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WHS-051926-02/Bottle Filler Outside JO4						**Lims Reference ID: AE21756-02**	**Matrix: Drinking Water**		**Sampled: 05/19/26 06:50:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:25	PL	EPA 200.8 (DA)/EPA 200.8

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only: AE21756

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: CinnaminsonLeadLab@emsl.com

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information

Customer ID:	ECSPA30
Company Name:	Environmental Control Systems Inc.
Contact Name:	Barb Lippmann
Street Address:	
City, State, Zip:	Country:
Phone:	610-587-6016
Email(s) for Report:	ecs_pa@hotmail.com

Billing Information

Billing ID:	
Company Name:	
Billing Contact:	
Street Address:	
City, State, Zip:	Country:
Phone:	
Email(s) for Invoice:	

Project Information

Project Name/No:	Wissahickon SD - Wissahickon High School
Purchase Order:	6832
EMSL LIMS Project ID: (If applicable, EMSL will provide)	
US State where samples collected:	
State of Connecticut (CT) must select project location:	☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Sampled By Name:	
Sampled By Signature:	
No. of Samples in Shipment	

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☑ 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm² *Sample Area Required below for mg/cm² *Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended.	SW 846-7000B	Flame Atomic Absorption	*Please select reporting on left. - 0.0064% - 64 ppm - mg/cm2 - RL is Variable	☐
	SW 846-6010D	ICP-OES	*Please select reporting on left. - 0.0004% - 4 ppm - mg/cm2 - RL is Variable	☐
AIR	NIOSH 7082	Flame Atomic Absorption	3.2 µg/filter	☐
	NIOSH 7303M	ICP-OES	1.0µ g/filter	☐
	NIOSH 7303M	ICP-MS	0.05 µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B*	Flame Atomic Absorption	8 µg/wipe	☐
*If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D*	ICP-OES	1.0 µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☐ PH<2	EPA 200.7 / 6010D	ICP-OES	0.020 mg/L (ppm)	☐
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☑ PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
		ICP-MS	0.6 µg/filter	☐
Other:				

	Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1	WHS-051926-01	Bottle Filler in Natatorium/Gym Lobby		5/19/26 6:45am
2	WHS-051926-02	Bottle Filler outside J04		5/19/26 6:50am

EMSL Cinnaminson Received Preserved
Date 5/21/26
Initials

Method of Shipment:		Sample Condition Upon Receipt:	5/21/26 900
Relinquished by:	Date/Time:	Received by:	Date/Time 5/19/26 10:00PM
Relinquished by:	Date/Time:	Received by: RN	Date/Time 5/20/26 3:35

Rec'd: David Stem EC 5-20-26 6:30pm

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

10.19[T-195

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012621757
LIMS Reference ID: AE21757
EMSL Customer ID: ECSPA30

Attention: Barb Lippmann
Environmental Control Systems [ECSPA30]
950 Sussex Blvd.
Broomall, PA 19008
(610) 587-6016
barblippmann@hotmail.com

Project Name: Wissahickon SD - Wissahickon Middle School
Project ID: _Master Project-ECSPA30
Customer PO: 6832
Sales Rep: Gillian Egiazarov
Received: 05/21/2026 09:00
Reported: 06/05/2026 12:16

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WMS-051926-01/Bottle Filler Outside Gym			**Lims Reference ID: AE21757-01**		**Matrix: Drinking Water**				**Sampled: 05/19/26 07:00:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WMS-051926-02/Bottle Filler Outside Caf			**Lims Reference ID: AE21757-02**		**Matrix: Drinking Water**				**Sampled: 05/19/26 07:05:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:33	PL	EPA 200.8 (DA)/EPA 200.8

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

AE21757

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: CinnaminsonLeadLab@emsl.com

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information		Billing Information	
Customer ID:	ECSPA30	Billing ID:	
Company Name:	Environmental Control Systems Inc.	Company Name:	
Contact Name:	Barb Lippmann	Billing Contact:	
Street Address:		Street Address:	
City, State, Zip:	Country:	City, State, Zip:	Country:
Phone:	610-587-6016	Phone:	
Email(s) for Report:	ecs_pa@hotmail.com	Email(s) for Invoice:	

Project Information

Project Name/No:	Wissahickon SD - Wissahickon Middle School	Purchase Order:	6832
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where samples collected:	State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Sampled By Name:	Sampled By Signature:		No. of Samples in Shipment

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☑ 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm² *Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended. *Sample Area Required below for mg/cm²	SW 846-7000B	Flame Atomic Absorption	*Please select reporting on left. - 0.0064% - 64 ppm - mg/cm2 - RL is Variable	☐
	SW 846-6010D	ICP-OES	*Please select reporting on left. - 0.0004% - 4 ppm - mg/cm2 - RL is Variable	☐
AIR	NIOSH 7082	Flame Atomic Absorption	3.2 µg/filter	☐
	NIOSH 7303M	ICP-OES	1.0µ g/filter	☐
	NIOSH 7303M	ICP-MS	0.05 µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B*	Flame Atomic Absorption	8 µg/wipe	☐
*If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D*	ICP-OES	1.0 µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
Unpreserved ☐ Preserved with HNO3 ☐ PH<2	EPA 200.7 / 6010D	ICP-OES	0.020 mg/L (ppm)	☐
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Unpreserved ☐ Preserved with HNO3 ☑ PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
		ICP-MS	0.6 µg/filter	☐
Other:				

	Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1	WMS-051926-01	Bottle Filler outside Gym	EMSL Cinnaminson Received Preserved	5/19/26 7:00am
2	WMS-051926-02	Bottle Filler outside Caf	Date 5/21/26	5/19/26 7:05am
			Initials	

Method of Shipment:		Sample Condition Upon Receipt:	5/21/26 900
Relinquished by:	Date/Time:	Received by:	Date/Time 5/19/26 10:00am
Relinquished by:	Date/Time:	Received by: DN	Date/Time 3:35 5/20/26

Rec: David Stelp EC 5-20-26 6:00pm

10.1°C/T-185

Controlled Document COC-25 Lead R22 03/28/2025

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012621752
LIMS Reference ID: AE21752
EMSL Customer ID: ECSPA30

Attention: Barb Lippmann
Environmental Control Systems [ECSPA30]
950 Sussex Blvd.
Broomall, PA 19008
(610) 587-6016
barblippmann@hotmail.com

Project Name: Wissahickon SD - Admin Building
Project ID: _Master Project-ECSPA30
Customer PO: 6832
Sales Rep: Gillian Egiazarov
Received: 05/21/2026 09:00
Reported: 06/05/2026 13:18

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: Admin-051926-01/KF in Kitchenette						**Lims Reference ID: AE21752-01**	**Matrix: Drinking Water**		**Sampled: 05/19/26 07:20:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:27	05/28/26 12:58	PL	EPA 200.8 (DA)/EPA 200.8

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

AE21752

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: CinnaminsonLeadLab@emsl.com

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information		Billing Information	
Customer ID:	ECSPA30	Billing ID:	
Company Name:	Environmental Control Systems Inc.	Company Name:	
Contact Name:	Barb Lippmann	Billing Contact:	
Street Address:		Street Address:	
City, State, Zip:	Country:	City, State, Zip:	Country:
Phone:	610-587-6016	Phone:	
Email(s) for Report:	ecs_pa@hotmail.com	Email(s) for Invoice:	

Project Information

Project Name/No:	Wissahickon SD - Admin Building	Purchase Order:	6832
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where samples collected:	State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Sampled By Name:		Sampled By Signature:	No. of Samples in Shipment

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☑ 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm² *Sample Area Required below for mg/cm² *Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended.	SW 846-7000B	Flame Atomic Absorption	*Please select reporting on left. - 0.0064% - 64 ppm - mg/cm2 - RL is Variable	☐
	SW 846-6010D	ICP-OES	*Please select reporting on left. - 0.0004% - 4 ppm - mg/cm2 - RL is Variable	☐
AIR	NIOSH 7082	Flame Atomic Absorption	3.2 µg/filter	☐
	NIOSH 7303M	ICP-OES	1.0µ g/filter	☐
	NIOSH 7303M	ICP-MS	0.05 µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B*	Flame Atomic Absorption	8 µg/wipe	☐
*If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D*	ICP-OES	1.0 µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
Wastewater Unpreserved ☐ Preserved with HNO3 ☐ PH<2	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	EPA 200.7 / 6010D	ICP-OES	0.020 mg/L (ppm)	☐
Drinking Water Unpreserved ☐ Preserved with HNO3 ☑ PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
		ICP-MS	0.6 µg/filter	☐
Other:				

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1 Admin-051926-01	KF in Kitchenette	EMSL Cinnaminson Received Preserved Date 5/21/26 Initials	5/19/26 7:20am

Method of Shipment:

Sample Condition Upon Receipt: 5/21/26 900

Relinquished by:	Date/Time:	Received by:	Date/Time 5/21/26 1000 AM
Relinquished by:	Date/Time:	Received by:	Date/Time 5/20/26 3:35

Rec: David Stepp EC 5-20-26 6:00pm

Controlled Document COC-25 Lead R22 03/28/2025

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

10.1°C | T-195

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012621754
LIMS Reference ID: AE21754
EMSL Customer ID: ECSPA30

Attention: Barb Lippmann
Environmental Control Systems [ECSPA30]
950 Sussex Blvd.
Broomall, PA 19008
(610) 587-6016
barblippmann@hotmail.com

Project Name: Wissahickon SD - Blue Bell Elementary School
Project ID: _Master Project-ECSPA30
Customer PO: 6832
Sales Rep: Gillian Egiazarov
Received: 05/21/2026 09:00
Reported: 06/05/2026 13:12

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BBES-051926-01/Bottle Filler Outside Rm 32						**Lims Reference ID: AE21754-01**	**Matrix: Drinking Water**		**Sampled: 05/19/26 07:45:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BBES-051926-02/Bottle Filler Outside Gym/Caf						**Lims Reference ID: AE21754-02**	**Matrix: Drinking Water**		**Sampled: 05/19/26 07:50:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:18	PL	EPA 200.8 (DA)/EPA 200.8

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

AE21754

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: CinnaminsonLeadLab@emsl.com

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information		Billing Information	
Customer ID:	ECSPA30	Billing ID:	
Company Name:	Environmental Control Systems Inc.	Company Name:	
Contact Name:	Barb Lippmann	Billing Contact:	
Street Address:		Street Address:	
City, State, Zip:	Country:	City, State, Zip:	Country:
Phone:	610-587-6016	Phone:	
Email(s) for Report:	ecs_pa@hotmail.com	Email(s) for Invoice:	

Project Information

Project Name/No: Wissahickon SD - Blue Bell Elementary School
Purchase Order: 6832

EMSL LIMS Project ID: (If applicable, EMSL will provide)
US State where samples collected:
State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)

Sampled By Name:
Sampled By Signature:
No. of Samples in Shipment

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☑ 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm² *Sample Area Required below for mg/cm²	SW 846-7000B	Flame Atomic Absorption	*Please select reporting on left. - 0.0064% - 64 ppm - mg/cm2 - RL is Variable	☐
*Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended.	SW 846-6010D	ICP-OES	*Please select reporting on left. - 0.0004% - 4 ppm - mg/cm2 - RL is Variable	☐
AIR	NIOSH 7082	Flame Atomic Absorption	3.2 µg/filter	☐
	NIOSH 7303M	ICP-OES	1.0µ g/filter	☐
	NIOSH 7303M	ICP-MS	0.05 µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B*	Flame Atomic Absorption	8 µg/wipe	☐
*If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D*	ICP-OES	1.0 µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☐ PH<2	EPA 200.7 / 6010D	ICP-OES	0.020 mg/L (ppm)	☐
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☑ PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
		ICP-MS	0.6 µg/filter	☐
Other:				

	Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1	BBES-051926-01	Bottle Filler outside Rm 32	EMSL Cinnaminson Received Preserved	5/19/26 7:45am
2	BBES-051926-02	Bottle Filler outside Gym/Caf	Date 5/4/26	5/19/26 7:50am
			Initials	

Method of Shipment:
Sample Condition Upon Receipt: 5/4/26 900am

Relinquished by:	Date/Time:	Received by:	Date/Time
			5/19/26 1000 BW
Relinquished by:	Date/Time:	Received by:	Date/Time
		AN	5/20/26 3:35
		Mai. Dennis Stelf EL	5-20-26 6:00pm

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012621753
LIMS Reference ID: AE21753
EMSL Customer ID: ECSPA30

Attention: Barb Lippmann
Environmental Control Systems [ECSPA30]
950 Sussex Blvd.
Broomall, PA 19008
(610) 587-6016
barblippmann@hotmail.com

Project Name: Wissahickon SD - Lower Gwynedd Elementary School
Project ID: _Master Project-ECSPA30
Customer PO: 6832
Sales Rep: Gillian Egiazarov
Received: 05/21/2026 09:00
Reported: 06/05/2026 13:15

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LGES-051926-01/Bottle Filler in Main Lobby			**Lims Reference ID: AE21753-01**		**Matrix: Drinking Water**				**Sampled: 05/19/26 07:10:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:27	05/28/26 13:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGES-051926-02/Bottle Filler Outside Library			**Lims Reference ID: AE21753-02**		**Matrix: Drinking Water**				**Sampled: 05/19/26 07:15:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:27	05/28/26 13:02	PL	EPA 200.8 (DA)/EPA 200.8

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

AE21753

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: CinnaminsonLeadLab@emsl.com

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information

Customer ID: ECSPA30
Company Name: Environmental Control Systems Inc.
Contact Name: Barb Lippmann
Street Address:
City, State, Zip: Country:
Phone: 610-587-6016
Email(s) for Report: ecs_pa@hotmail.com

Billing Information

Billing ID:
Company Name:
Billing Contact:
Street Address:
City, State, Zip: Country:
Phone:
Email(s) for Invoice:

Project Information

Project Name/No: Wissahickon SD - Lower Gwynedd Elementary School
Purchase Order: 6832
EMSL LIMS Project ID: (If applicable, EMSL will provide)
US State where samples collected:
State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Sampled By Name:
Sampled By Signature:
No. of Samples in Shipment

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☑ 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm² *Sample Area Required below for mg/cm² *Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended.	SW 846-7000B	Flame Atomic Absorption	*Please select reporting on left. - 0.0064% - 64 ppm - mg/cm2 - RL is Variable	☐
	SW 846-6010D	ICP-OES	*Please select reporting on left. - 0.0004% - 4 ppm - mg/cm2 - RL is Variable	☐
AIR	NIOSH 7082	Flame Atomic Absorption	3.2 µg/filter	☐
	NIOSH 7303M	ICP-OES	1.0µ g/filter	☐
	NIOSH 7303M	ICP-MS	0.05 µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B*	Flame Atomic Absorption	8 µg/wipe	☐
*If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D*	ICP-OES	1.0 µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☐ PH<2	EPA 200.7 / 6010D	ICP-OES	0.020 mg/L (ppm)	☐
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☑ PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
		ICP-MS	0.6 µg/filter	☐
Other:				

	Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1	LGES-051926-01	Bottle Filler in Main Lobby	EMSL Cinnaminson Received Preserved 5/21/26 Date	5/19/26 7:10am
2	LGES-051926-02	Bottle Filler outside Library	Initials	5/19/26 7:15am

Method of Shipment:
Sample Condition Upon Receipt: 5/21/26 900am

Relinquished by:	Date/Time:	Received by:	Date/Time
			5/19/26 10:00am
Relinquished by:	Date/Time:	Received by: DN	Date/Time 5/20/26 3:35
		Rec: David Stelle EC	5-20-26 6:00am

10.1°C / T-195

Controlled Document COC-25 Lead R22 03/28/2025

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012621755
LIMS Reference ID: AE21755
EMSL Customer ID: ECSPA30

Attention: Barb Lippmann
Environmental Control Systems [ECSPA30]
950 Sussex Blvd.
Broomall, PA 19008
(610) 587-6016
barblippmann@hotmail.com

Project Name: Wissahickon SD - Shady Grove Elementary School
Project ID: _Master Project-ECSPA30
Customer PO: 6832
Sales Rep: Gillian Egiazarov
Received: 05/21/2026 09:00
Reported: 06/05/2026 13:06

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SGES-051926-01/Bottle Filler Outside Library			**Lims Reference ID: AE21755-01**		**Matrix: Drinking Water**				**Sampled: 05/19/26 07:30:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SGES-051926-02/Bottle Filler in Caf			**Lims Reference ID: AE21755-02**		**Matrix: Drinking Water**				**Sampled: 05/19/26 07:35:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:21	PL	EPA 200.8 (DA)/EPA 200.8

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

AE21755

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: CinnaminsonLeadLab@emsl.com

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information

Customer ID: ECSPA30
Company Name: Environmental Control Systems Inc.
Contact Name: Barb Lippmann
Street Address:
City, State, Zip: Country:
Phone: 610-587-6016
Email(s) for Report: ecs_pa@hotmail.com

Billing Information

Billing ID:
Company Name:
Billing Contact:
Street Address:
City, State, Zip: Country:
Phone:
Email(s) for Invoice:

Project Information

Project Name/No: Wissahickon SD - Shady Grove Elementary School
Purchase Order: 6832
EMSL LIMS Project ID: (If applicable, EMSL will provide)
US State where samples collected:
State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)
Sampled By Name:
Sampled By Signature:
No. of Samples in Shipment

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☑ 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm² *Sample Area Required below for mg/cm² *Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended.	SW 846-7000B	Flame Atomic Absorption	*Please select reporting on left. - 0.0064% - 64 ppm - mg/cm2 - RL is Variable	☐
	SW 846-6010D	ICP-OES	*Please select reporting on left. - 0.0004% - 4 ppm - mg/cm2 - RL is Variable	☐
AIR	NIOSH 7082	Flame Atomic Absorption	3.2 µg/filter	☐
	NIOSH 7303M	ICP-OES	1.0µ g/filter	☐
	NIOSH 7303M	ICP-MS	0.05 µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B*	Flame Atomic Absorption	8 µg/wipe	☐
*If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D*	ICP-OES	1.0 µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☐ PH<2	EPA 200.7 / 6010D	ICP-OES	0.020 mg/L (ppm)	☐
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☑ PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
		ICP-MS	0.6 µg/filter	☐
Other:				

	Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1	SGES-051926-01	Bottle Filler outside Library	EMSL Cinnaminson Received Preserved	5/19/26 7:30am
2	SGES-051926-02	Bottle Filler in Caf	Date 5/21/26 Initials	5/19/26 7:35am

Method of Shipment:
Sample Condition Upon Receipt: 5/21/26 9:00am

Relinquished by: Date/Time:
Received by: Date/Time 5/19/26 10:00 AM

Relinquished by: Date/Time:
Received by: AN Date/Time 5/20/26 3:35

Rec: David Stemp 5-20-26 6:00pm

Controlled Document COC-25 Lead R22 03/28/2025

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

10.1°C / T-195

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012621758
LIMS Reference ID: AE21758
EMSL Customer ID: ECSPA30

Attention: Barb Lippmann
Environmental Control Systems [ECSPA30]
950 Sussex Blvd.
Broomall, PA 19008
(610) 587-6016
barblippmann@hotmail.com

Project Name: Wissahickon SD - Stony Creek Elementary School
Project ID: _Master Project-ECSPA30
Customer PO: 6832
Sales Rep: Gillian Egiazarov
Received: 05/21/2026 09:00
Reported: 06/05/2026 12:06

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SCES-051926-01/Bottle Filler on Gym Side			**Lims Reference ID:**	**AE21758-01**	**Matrix: Drinking Water**				**Sampled: 05/19/26 08:00:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SCES-051926-02/Bottle Filler on Caf Side			**Lims Reference ID:**	**AE21758-02**	**Matrix: Drinking Water**				**Sampled: 05/19/26 08:05:00**
Metals									
Lead	**ND**		1	1.00	ppb	05/27/26 13:21	05/28/26 13:37	PL	EPA 200.8 (DA)/EPA 200.8

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

AE21758

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: CinnaminsonLeadLab@emsl.com

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer Information		Billing Information	
Customer ID:	ECSPA30	Billing ID:	
Company Name:	Environmental Control Systems Inc.	Company Name:	
Contact Name:	Barb Lippmann	Billing Contact:	
Street Address:		Street Address:	
City, State, Zip:	Country:	City, State, Zip:	Country:
Phone:	610-587-6016	Phone:	
Email(s) for Report:	ecs_pa@hotmail.com	Email(s) for Invoice:	

Project Information

Project Name/No: Wissahickon SD - Stony Creek Elementary School
Purchase Order: 6832

EMSL LIMS Project ID: (If applicable, EMSL will provide)
US State where samples collected:
State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)

Sampled By Name:
Sampled By Signature:
No. of Samples in Shipment

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☑ 2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm² *Sample Area Required below for mg/cm² *Chips reporting Limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles - XRF is recommended.	SW 846-7000B	Flame Atomic Absorption	*Please select reporting on left. - 0.0064% - 64 ppm - mg/cm2 - RL is Variable	☐
	SW 846-6010D	ICP-OES	*Please select reporting on left. - 0.0004% - 4 ppm - mg/cm2 - RL is Variable	☐
AIR	NIOSH 7082	Flame Atomic Absorption	3.2 µg/filter	☐
	NIOSH 7303M	ICP-OES	1.0µ g/filter	☐
	NIOSH 7303M	ICP-MS	0.05 µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B*	Flame Atomic Absorption	8 µg/wipe	☐
*If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D*	ICP-OES	1.0 µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	32 mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2 mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.32 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☐ PH<2	EPA 200.7 / 6010D	ICP-OES	0.020 mg/L (ppm)	☐
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Unpreserved ☐ / Preserved with HNO3 ☑ PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
		ICP-MS	0.6 µg/filter	☐
Other:				

	Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1	SCES-051926-01	Bottle Filler on Gym side	EMSL Cinnaminson Received Preserved	5/19/26 8:00am
2	SCES-051926-02	Bottle Filler on Caf side	Date 5/21/26	5/19/26 8:05am
			Initials	

Method of Shipment:
Sample Condition Upon Receipt: 5/21/26 TOV

Relinquished by:	Date/Time:	Received by:	Date/Time
			5/19/26 10:00 PM
Relinquished by:	Date/Time:	Received by:	Date/Time
		RN	5/20/26 3:35
		Mel David Stell EL	5-20-26 6:00pm

Controlled Document COC-25 Lead R22 03/28/2025

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety.
Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

10.1°C IT-195