

2025 Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outlet 5.0 parts per billion >	Resampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 parts per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2025-SO-HS-1	Tappan Zee High School	1	Library Office Sink Faucet	11/22/2025	4.7	Not Required	Not Required	4.7	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-2	Tappan Zee High School	1	300's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-3	Tappan Zee High School	1	300's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-4	Tappan Zee High School	1	Teacher's Lounge Room 304	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-5	Tappan Zee High School	1	400's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-6	Tappan Zee High School	1	400's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-7	Tappan Zee High School	1	500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-8	Tappan Zee High School	1	500's Wing Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-9	Tappan Zee High School	1	500's Wing Hallway Water Cooler Fountain next to Gender Neutral Bathroom & Elevator (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-10	Tappan Zee High School	1	500's Wing Hallway Water Cooler Fountain next to Gender Neutral Bathroom & Elevator (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-11	Tappan Zee High School	1	Main Office Hallway across from SRO office / 600's Wing - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-12	Tappan Zee High School	1	Main Office Hallway across from SRO office / 600's Wing - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-13	Tappan Zee High School	1	1ST Floor C-13 - School Store Kitchen Faucet	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-14	Tappan Zee High School	1	Classroom 950 (Testing Room) Sink Faucet	11/22/2025	4.4	Not Required	Not Required	4.4	Yes	11/22/2025	<i>Not Applicable</i>

2025-SO-HS-15	Tappan Zee High School	1	Auditorium Hallway - Water Cooler Fountain (Combo Unit) - Mouth	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-16	Tappan Zee High School	1	Auditorium Hallway - Water Cooler Fountain (Combo Unit) - Bottle Filler	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-17	Tappan Zee High School	1	Kitchen Prep Double Sink Faucet 1 (by Refrigerator Wall & Eyewash - Left When Facing)	11/22/2025	5.4	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice. New Water filter and aerator installed and resampled; it has passed as of 12/19/26.</i>	12/19/2025	2.1	Yes	12/19/2025	<i>Not Applicable</i>
2025-SO-HS-18	Tappan Zee High School	1	Kitchen Prep Double Sink Faucet 2 (by Refrigerator Wall & Eyewash - Right When Facing)	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-19	Tappan Zee High School	1	Kitchen Single Hand Washing (White) Sink Faucet	11/22/2025	2.5	Not Required	Not Required	2.5	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-20	Tappan Zee High School	1	Kitchen Single Sink Faucet (by Window Wall)	11/22/2025	2	Not Required	Not Required	2	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-21	Tappan Zee High School	1	Kitchen Double Sink (by Window Wall & Detergent Dispensers) Faucet 2 (Right When Facing)	11/22/2025	3	Not Required	Not Required	3	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-22	Tappan Zee High School	1	Kitchen Island Sink by Stove	11/22/2025	7	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice. New Water filter and aerator installed and resampled; it has passed as of 12/19/26.</i>	12/19/2025	4.4	Yes	12/19/2025	<i>Not Applicable</i>
2025-SO-HS-23	Tappan Zee High School	1	Kitchen Ice Machine	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-24	Tappan Zee High School	1	Kitchen Sink Faucet by Pizza Serving Line	11/22/2025	9.0	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice. New Water filter and aerator installed and resampled; it has passed as of 12/19/26.</i>	12/19/2025	4.6	Yes	12/19/2025	<i>Not Applicable</i>
2025-SO-HS-25	Tappan Zee High School	1	Kitchen Sink Faucet by Deli Serving Line	11/22/2025	3.7	Not Required	Not Required	3.7	Yes	11/22/2025	<i>Not Applicable</i>
2025-SO-HS-33	Tappan Zee High School	L	Boy's Locker Room Ice Machine	12/19/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	12/19/2025	<i>Not Applicable</i>
2025-SO-HS-26	Tappan Zee High School	L	Trainer's Room Sink	11/22/2025	< 1.0	Not Required	Not Required	< 1.0	Yes	11/22/2025	

<i>Not Sampled</i>	Tappan Zee High School	1	400'S Wing Faculty Women's Bathroom Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Applicable</i>
<i>Not Sampled</i>	Tappan Zee High School	1	500's Wing Hallway Sink Faucet in Women's Staff Bathroom	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Applicable</i>
<i>Not Sampled</i>	Tappan Zee High School	1	C-Wing Boys Bathroom Sink Faucet 2 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Applicable</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Main Office South Bathroom Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Applicable</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Main Office North Bathroom Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Applicable</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Guidance Office Bathroom Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Applicable</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Kitchen Ladies Room Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Applicable</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Girl's Locker Room Athletic Office Bathroom Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Applicable</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables by Window- Front- Back Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables by Window- Middle- Front Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables by Window- Middle- Back Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Middle Front - Front Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Middle Front - Back Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Middle Back - Front Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room C8- Lab Tables- Middle Back - Back Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>

<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Right Wall Front Desk- LT	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Right Wall Front Desk- RT	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Right Wall Back Desk- LT	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 324-Lab Table-Right Wall Back Desk- RT	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 324- Fume Hood Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 325- Middle Island- Lab Sink by Door	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 325- Middle Island- Lab Sink by Window	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 325- Lab Sink by Hallway Wall	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 325- Lab Sink by Window	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Classroom 702 (Art Room) Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Classroom 704 (Art Storage) Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 705 (Art Room)- Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Classroom (Science Room) 706 Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Classroom (Science Room) 706 Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 706 (Art Room)- Sink by Door-Faucet by Eye Wash	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>

<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 706- (Art Room) Sink away from Door- Faucet by Eye Wash Station	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 706 (Art Room)- Sink away from Door- Middle Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 706 (Art Room)- Sink away from Door-Faucet by Hallway Side	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Classroom 707 (Art Room) Sink Faucet 1(left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Classroom 707 (Art Room) Sink Faucet 2(right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 712 (Art Room)- Sink by Door- LT Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 712 (Art Room)- Sink by Door- Middle Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 712 (Art Room)- Sink by Door- RT Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 712 (Art Room) - Sink away from Door- LT Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 712 Art Room)- Sink away from Door- Middle Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 712 (Art Room)- Sink away from Door- RT Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 707 (Art Room)- Sink Faucet RT Door Side	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 707 (Art Room)- Sink Faucet LT Window Side	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 800-Teachers Lab Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	1ST Floor Room 800-Lab Sink- LT Front Desk-LT	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>

<i>Not Sampled</i>	Tappan Zee High School	L	100's Wing - Records/BOCES Room- Bathroom Sink <i>Tempered</i> Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Boiler Room Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	100's Hallway Custodial Closet Slop Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Girl's Bathroom Sink <i>Tempered</i> Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Girl's Bathroom Sink <i>Tempered</i> Faucet 2 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Girl's Bathroom Sink <i>Tempered</i> Faucet 3 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Boy's Bathroom Sink <i>Tempered</i> Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby- Boy's Bathroom Sink <i>Tempered</i> Faucet 2 (middle when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby - Boy's Bathroom Sink <i>Tempered</i> Faucet 3 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Gymnasium/Hall of Fame Lobby Custodial Closet Slop Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Boy's Locker Room Bathroom Gang Sink <i>Tempered</i> Faucet 1 (Left When facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Boy's Locker Room Bathroom Gang Sink <i>Tempered</i> Faucet 2 (Middle When facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Boy's Locker Room Bathroom Gang Sink <i>Tempered</i> Faucet 1 (Right When facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Girl's Locker Room Bubbler Water Fountain	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Girl's Locker Room Bathroom Gang Sink <i>Tempered</i> Faucet 1 (Left When facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Tappan Zee High School	L	Girl's Locker Room Bathroom Gang Sink <i>Tempered</i> Faucet 2 (Left When facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Girl's Locker Room Bathroom Gang Sink <i>Tempered</i> Faucet 3 (Left When facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	L	Boy's and Girl's Locker Rooms -- All Showers	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Girl's Locker Room Gender Neutral Bathroom Sink <i>Tempered</i> Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Girl's Locker Room Gender Neutral Bathroom Sink <i>Tempered</i> Faucet 2 (middle when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Girl's Locker Room Gender Neutral Bathroom Sink <i>Tempered</i> Faucet 3 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Kitchen Custodial Room Slop Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Auditorium Hallway Boys Bathroom <i>Tempered</i> Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Auditorium Hallway Boys Bathroom <i>Tempered</i> Faucet 2 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Auditorium Hallway Boys Bathroom <i>Tempered</i> Faucet 3 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Auditorium Hallway Girls Bathroom <i>Tempered</i> Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Auditorium Hallway Girls Bathroom <i>Tempered</i> Faucet 2 (middle when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Auditorium Hallway Girls Bathroom <i>Tempered</i> Faucet 3 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Main Office 1 Water Cooler Fountain (Permanently Removed From Service)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Tappan Zee High School	1	Clasroom 712 (Science) Sink 1 Tall Faucets B (right facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Tappan Zee High School	1	300's Hallway Boys Gang Bathroom Sink Tempered Faucet 6	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	200's Hallway Slop Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	L	100's Wing - Records/BOCES Room- Bathroom Sink <i>Tempered</i> Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	All Eyewash Stations in the School	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Fieldhouse/Snackbar (by Football Field) Men's Bathroom Sink Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Fieldhouse/Snackbar (by Football Field) Men's Bathroom Sink Faucet 2 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Fieldhouse/Snackbar (by Football Field) Women's Bathroom Sink Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Fieldhouse/Snackbar (by Football Field) Women's Bathroom Sink Faucet 2 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Room 419- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Room 411- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Room 401- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Room 607- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Room Auditorium Entrance- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	West Wall Outside by Stage- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Loading Dock by Stairs- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>

<i>Not Sampled</i>	Tappan Zee High School	Exterior	Directly Outside Kitchen - South Wall - Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Kitchen West- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Kitchen East- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	In Courtyard by Teacher's Lounge- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	In Courtyard by Cafeteria East- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Room Boys Locker Room- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	Exterior	Outside Courtyard by Library- Exterior Hose Bib	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Nurse's Office Main Room Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Nurse's Office Recovery Room (with Curtain) Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Nurse's Office Recovery Room (without Curtain) Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Classroom 951 (Music Room) Sink Faucet 2 (Right When Facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	1	Kitchen Double Sink (by Window Wall & Detergent Dispensers) Faucet 1 (Left When Facing)- Dishwasher Sprayer	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	L	Boy's Physical Education Office (Next to Main Gym) Bathroom Sink Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>
<i>Not Sampled</i>	Tappan Zee High School	L	Classroom 118 (Art Room) Triple Sink- Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.</i>

Not Sampled	Tappan Zee High School	L	Classroom 118 (Art Room) Triple Sink- Faucet 2 (middle when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
Not Sampled	Tappan Zee High School	L	Classroom 118 (Art Room) Triple Sink- Faucet 3 (right when facing)	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.