

Sample Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results in parts per billion)	Remediation Action - Required for any Outlet > 5.0 parts per billion	Resampling Dates - Required After Remediation Action	Passing/Clearance Results; must be ≤ per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2025-SO-WS-1	Wm O'Schaefer	1	Kitchen - Triple Sink/Double Faucet - Faucet 1 (left when facing)	11/15/25	8.8	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.</i>	12/19/2025 5/21/2026	10.7 3.84	Yes	5/21/26	Not Applicable
2025-SO-WS-2	Wm O'Schaefer	1	Kitchen - Triple Sink/Double Faucet - Faucet 2 (right when facing)	11/15/25	12	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.</i>	12/19/2025 5/21/2026	17.6 3.99	Yes	5/21/26	Not Applicable
2025-SO-WS-3	Wm O'Schaefer	1	Small/Single Kitchen Handwashing Sink Faucet	11/15/25	5.1	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.</i>	12/19/2025	< 1.0	Yes	12/19/2025	Not Applicable
2025-SO-WS-4	Wm O'Schaefer	1	Hallway Across from Rooms 40/42 - Water Cooler (Combo Unit) - Mouth (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-5	Wm O'Schaefer	1	Hallway Across from Rooms 40/42 - Water Cooler (Combo Unit) - Bottle Filler (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-6	Wm O'Schaefer	1	Hallway Across from Rooms 40/42 - Water Cooler (Combo Unit) - Mouth (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-7	Wm O'Schaefer	1	Hallway Across from Rooms 40/42 - Water Cooler (Combo Unit) - Bottle Filler (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-8	Wm O'Schaefer	1	Classroom 44 Faucet	11/15/25	27.3	<i>DO NOT DRINK signage displayed; Staff will be advised to use alternate means for cooking and/or drinking until further notice.</i>	Not Required	Not Required	N/A	Not Required	Not Applicable
2025-SO-WS-9	Wm O'Schaefer	1	Hallway by Room 57 - Water Cooler (Combo Unit) - Mouth (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable

2025-SO-WS-10	Wm O'Schaefer	1	Hallway by Room 57 - Water Cooler (Combo Unit) - Bottle Filler (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0		11/15/25	Not Applicable
2025-SO-WS-11	Wm O'Schaefer	1	Hallway by Room 57 - Water Cooler (Combo Unit) - Mouth (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-12	Wm O'Schaefer	1	Hallway by Room 57 - Water Cooler (Combo Unit) - Bottle Filler (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-13	Wm O'Schaefer	1	Classroom 69 Faucet	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-14	Wm O'Schaefer	1	Classroom 71 Faucet	11/15/25	1.6	Not Required	Not Required	1.6	Yes	11/15/25	Not Applicable
2025-SO-WS-15	Wm O'Schaefer	1	Classroom 72 Faucet	11/15/25	2.2	Not Required	Not Required	2.2	Yes	11/15/25	Not Applicable
2025-SO-WS-16	Wm O'Schaefer	1	Outside Room 67 Boy's Bathroom - Water Cooler (Combo Unit) - Mouth	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-17	Wm O'Schaefer	1	Outside Room 67 Boy's Bathroom - Water Cooler (Combo Unit) - Bottle Filler	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-18	Wm O'Schaefer	1	Outside Room 67 Girl's Bathroom - Water Cooler (Combo Unit) - Mouth	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-19	Wm O'Schaefer	1	Outside Room 67 Girl's Bathroom - Water Cooler (Combo Unit) - Bottle Filler	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-20	Wm O'Schaefer	1	Classroom 101 Faucet	11/15/25	1.6	Not Required	Not Required	1.3	Yes	11/15/25	Not Applicable
2025-SO-WS-21	Wm O'Schaefer	1	Classroom 102 Faucet	11/15/25	1.4	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-22	Wm O'Schaefer	1	Classroom 103 Faucet	11/15/25	2.8	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-23	Wm O'Schaefer	1	Across from Library Between Rooms 6 & 16 - Water Cooler (Combo Unit) - Mouth (left when facing)	11/8/23	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-24	Wm O'Schaefer	1	Across from Library Between Rooms 6 & 16 - Water Cooler (Combo Unit) - Bottle Filler (left when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-25	Wm O'Schaefer	1	Across from Library Between Rooms 6 & 16 - Water Cooler (Combo Unit) - Mouth (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable
2025-SO-WS-26	Wm O'Schaefer	1	Across from Library Between Rooms 6 & 16 - Water Cooler (Combo Unit) - Bottle Filler (right when facing)	11/15/25	< 1.0	Not Required	Not Required	< 1.0	Yes	11/15/25	Not Applicable

Non Applicable Outlets - these are outlets that were determined by the District to not be used for cooking or drinking by staff or students.

<i>Not Sampled</i>	Wm O'Schaefer	1	Gender Neutral Staff bathroom across from Room 103 - Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 105 (OT/PT Rm) Bathroom Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Coach Office (in Gym) Bathroom Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Boys Bathroom Outside Rooms 67/69 - Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Boys Bathroom Outside Rooms 67/69 - Faucet 2 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 - Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 - Faucet 2 (middle when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 - Faucet 1 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Student Enrichment (Room 20 B) (across hallway from Main Office) bathroom Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Outside Room 56 - Boy's Bathroom Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Outside Room 56 - Boy's Bathroom Faucet 2 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Outside Rm 54 Girl's Bathroom Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Outside Rm 54 Girl's Bathroom Faucet 2 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Custodial Office Bathroom Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Wm O'Schaefer	1	Next to Room 40 Gender Neutral Bathroom Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Next to Room 40 Gender Neutral Bathroom Faucet 2 (right when facing)	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Nurse's Office Bathroom Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Custodial Closet by Room 60 Slop Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Boys bathroom between Rooms 6 and 16 - <i>Tempered</i> Faucet to the left when facing	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Boys bathroom between Rooms 6 and 16 - <i>Tempered</i> Faucet to the right when facing	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Girls bathroom between Rooms 6 and 16 - <i>Tempered</i> Faucet to the left when facing	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Wm O'Schaefer	1	Girls bathroom between Rooms 6 and 16 - Tempered Faucet to the right when facing	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Boiler Room Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Custodial Closet Across from Library- Slop Sink	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall to left of Main Entrance	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall to right of Main Entrance	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	Exterior	Exterior Hose Bib- by Staff Parking lot/South Playground	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	Exterior	Exterior Hose Bib- wall by South playground	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall outside Room 68	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall outside Room 100	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 1 <i>Tempered</i> Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 2 <i>Tempered</i> Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 3 (Tech. Office) <i>Tempered</i> Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 4 <i>Tempered</i> Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 6 <i>Tempered</i> Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Teacher's Lounge (Room 5) <i>Tempered</i> Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Wm O'Schaefer	1	Nurse's Office (Main Room) <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Nurse's Office Recovery Room <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Nurse's Bathroom <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 15 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 17 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 19 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 21 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 24 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 26 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 30 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 32 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 57 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 59 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 61 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 62 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 63 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 64 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 65 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 66 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 67 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 68 <i>Tempered Faucet</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 70 Tempered Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 74 Tempered Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 100 Tempered Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 104 Tempered Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
<i>Not Sampled</i>	Wm O'Schaefer	1	Classroom 105 Tempered Faucet	<i>Not Sampled</i>	<i>Not Sampled</i>	Not Required	Not Required	<i>Not Sampled</i>	<i>Not Sampled</i>	<i>Not Sampled</i>	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.