

Mill Creek Middle School

2025-2026 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 20.5 ppb AL?
Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 5.5 ppb AL?
Water Testing Laboratory of MD	Mill Creek Middle School	5/20/26	1	43	HE	Front far right faucet in 120	FD	5/6/26	3:20pm	5/7/26	6:15am	5/15/26	<1.0	No
Water Testing Laboratory of MD	Mill Creek Middle School	5/20/26	1	44	HE	Back far right faucet in 120	FD	5/6/26	3:20pm	5/7/26	6:16am	5/15/26	5.8	Yes