

Calvert Middle School

2025-2026 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 5.5 ppb AL?
Water Testing Laboratory of MD	Calvert Middle School	5/20/26	2	48	HE	Left middle faucet in Room 201	FD	5/6/26	3:30pm	5/7/26	6:20am	5/15/26	<1.0	NO
Water Testing Laboratory of MD	Calvert Middle School	5/20/26	2	54	CR	Front faucet in Room 203	FD	5/6/26	3:30pm	5/7/26	6:21am	5/15/26	1.5	NO
Water Testing Laboratory of MD	Calvert Middle School	5/20/26	2	55	CR	Back faucet in Room 203	FD	5/7/26	3:45pm	5/8/26	6:45am	5/15/26	1.9	NO
Water Testing Laboratory of MD	Calvert Middle School	5/20/26	2	64	HE	Ice machine in Room 201	FD	5/6/26	3:30pm	5/7/26	6:22am	5/15/26	<1.0	NO