



Report of Analysis

Mail to: Elizabethtown Area School District
Attention: Accounts Payable
600 E. High St.
Elizabethtown PA 17022

Lab Number: **477192**
Date Reported: 06/15/2026

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis Date	Time	Analyst	Method	Reporting Limit
477192-01 Sampled: 05/21/2026 05:41 Sampler: Brian Miller Source: Bainbridge - Kitchen Elizabethtown Area School District								
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-02 Sampled: 05/21/2026 05:48 Sampler: Brian Miller Source: Bainbridge - Room 131 Elizabethtown Area School District								
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-03 Sampled: 05/26/2026 05:41 Sampler: Brian Miller Source: Bear Creek - Kitchen Elizabethtown Area School District								
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-04 Sampled: 05/26/2026 05:44 Sampler: Brian Miller Source: Bear Creek - Room 13 Elizabethtown Area School District								
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-05 Sampled: 05/21/2026 06:05 Sampler: Brian Miller Source: East High - Kitchen Elizabethtown Area School District								
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-06 Sampled: 05/21/2026 06:09 Sampler: Brian Miller Source: East High - Room 500 Elizabethtown Area School District								
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-07 Sampled: 05/21/2026 06:13 Sampler: Brian Miller Source: East High - Room 556 Elizabethtown Area School District								
Lead	0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-08 Sampled: 05/27/2026 05:39 Sampler: Brian Miller Source: High School - Office Elizabethtown Area School District								
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-09 Sampled: 05/27/2026 05:34 Sampler: Brian Miller Source: High School - Room 1360 Elizabethtown Area School District								
Lead	0.002 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001
This sample meets state and federal standards for safe drinking water, for the parameters reported.								
This sample was not collected by a lab-authorized sampler.								
477192-10 Sampled: 05/27/2026 05:29 Sampler: Brian Miller Source: High/Middle School - Kitchen Elizabethtown Area School District								



Report of Analysis

Mail to: Elizabethtown Area School District
Attention: Accounts Payable
600 E. High St.
Elizabethtown PA 17022

Lab Number: **477192**
Date Reported: 06/15/2026

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001

This sample meets state and federal standards for safe drinking water, for the parameters reported.

This sample was not collected by a lab-authorized sampler.



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL.
Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:

Andrew T Heist, Lab Technician



Report of Analysis

Mail to: Elizabethtown Area School District
Attention: Accounts Payable
600 E. High St.
Elizabethtown PA 17022

Lab Number: **477193**
Date Reported: 06/15/2026

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis Date	Time	Analyst	Method	Reporting Limit
477193-01	Sampled: 05/27/2026 05:45 Sampler: Brian Miller Source: High School - Bus Lobby Elizabethtown Area School District							
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001

This sample meets state and federal standards for safe drinking water, for the parameters reported.

This sample was not collected by a lab-authorized sampler.

477193-02	Sampled: 05/29/2026 05:28 Sampler: Brian Miller Source: High School - Room 2625 Elizabethtown Area School District							
Lead	0.004 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001

This sample meets state and federal standards for safe drinking water, for the parameters reported.

This sample was not collected by a lab-authorized sampler.

477193-03	Sampled: 05/29/2026 05:30 Sampler: Brian Miller Source: HS/MS - Spilt Level - Teachers Lounge Elizabethtown Area School District							
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001

This sample meets state and federal standards for safe drinking water, for the parameters reported.

This sample was not collected by a lab-authorized sampler.

477193-04	Sampled: 05/29/2026 05:50 Sampler: Brian Miller Source: Middle School - Room 117 Elizabethtown Area School District							
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001

This sample meets state and federal standards for safe drinking water, for the parameters reported.

This sample was not collected by a lab-authorized sampler.

477193-05	Sampled: 05/29/2026 05:46 Sampler: Brian Miller Source: Middle School - Room 1311 Elizabethtown Area School District							
Lead	0.002 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001

This sample meets state and federal standards for safe drinking water, for the parameters reported.

This sample was not collected by a lab-authorized sampler.

477193-06	Sampled: 05/29/2026 05:41 Sampler: Brian Miller Source: Middle School - Room 2730 Elizabethtown Area School District							
Lead	<0.001 mg/L	Pass	0.015 mg/L	06/11/2026		bfm	EPA 200.8	0.001

This sample meets state and federal standards for safe drinking water, for the parameters reported.

This sample was not collected by a lab-authorized sampler.



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL.
Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:

Andrew T Heist, Lab Technician