



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 25, 2026

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: High School Lead Retests

Order No.: 26060787

Dear John Harding:

Neilson Research Corporation received 13 sample(s) on 6/16/2026 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. Testing was completed in accordance with the laboratory's established quality system and standard operating procedures. For the current scope of NELAP-accredited analytes and certifications, please refer to the Certifications section at www.nrclabs.com. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Director of Project Management
245 S Grape St
Medford, OR 97501





Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 26060787
Date: 6/25/2026

CLIENT: Eagle Point School District #9
Project: High School Lead Retests

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26060787
 Date Reported: 6/25/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26060787
Received Date: 6/16/2026 8:41:00 AM
Reported Date: 6/25/2026 9:43:49 AM

Sample Information:

Lab ID: 26060787-01 Client Sample ID: 022SF
 Collection Date: 6/16/2026 6:12:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 022SF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	14.3	1	0.500	ppb	1	6/23/2026	15.0	A	

Lab ID: 26060787-02 Client Sample ID: 023CF
 Collection Date: 6/16/2026 6:14:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 023CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.72		0.500	ppb	1	6/23/2026	15.0	A	

Lab ID: 26060787-03 Client Sample ID: 024CF
 Collection Date: 6/16/2026 6:15:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 024CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.01		0.500	ppb	1	6/23/2026	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26060787
 Date Reported: 6/25/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26060787
Received Date: 6/16/2026 8:41:00 AM
Reported Date: 6/25/2026 9:43:49 AM

Sample Information:

Lab ID: 26060787-04 Client Sample ID: 025CF
 Collection Date: 6/16/2026 6:16:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 025CF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	24.0	*1	0.500	ppb	1	6/23/2026	15.0	A	

Lab ID: 26060787-05 Client Sample ID: 027SF
 Collection Date: 6/16/2026 6:17:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 027SF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.26		0.500	ppb	1	6/23/2026	15.0	A	

Lab ID: 26060787-06 Client Sample ID: 026SF
 Collection Date: 6/16/2026 6:19:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 026SF

Trace Metals by EPA 200.8 ICP-MS							Analyst; PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	6.04		0.500	ppb	1	6/23/2026	15.0	A	

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26060787
 Date Reported: 6/25/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26060787
Received Date: 6/16/2026 8:41:00 AM
Reported Date: 6/25/2026 9:43:49 AM

Sample Information:

Lab ID: 26060787-07 Client Sample ID: 014BF
 Collection Date: 6/16/2026 6:20:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 014BF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.47		0.500	ppb	1	6/23/2026	15.0	A

Lab ID: 26060787-08 Client Sample ID: 004NS
 Collection Date: 6/16/2026 6:22:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 004NS

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.39		0.500	ppb	1	6/23/2026	15.0	A

Lab ID: 26060787-09 Client Sample ID: 020CF
 Collection Date: 6/16/2026 6:24:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 020CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.48		0.500	ppb	1	6/23/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26060787
 Date Reported: 6/25/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26060787
Received Date: 6/16/2026 8:41:00 AM
Reported Date: 6/25/2026 9:43:49 AM

Sample Information:

Lab ID: 26060787-10 Client Sample ID: 019CF
 Collection Date: 6/16/2026 6:26:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 019CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.39		0.500	ppb	1	6/23/2026	15.0	A

Lab ID: 26060787-11 Client Sample ID: 018CF
 Collection Date: 6/16/2026 6:28:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 018CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.10		0.500	ppb	1	6/23/2026	15.0	A

Lab ID: 26060787-12 Client Sample ID: 036CF
 Collection Date: 6/16/2026 6:33:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 036CF

Trace Metals by EPA 200.8 ICP-MS								Analyst; PR
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.832		0.500	ppb	1	6/23/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 26060787
 Date Reported: 6/25/2026

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 26060787
Received Date: 6/16/2026 8:41:00 AM
Reported Date: 6/25/2026 9:43:49 AM

Sample Information:

Lab ID: 26060787-13 Client Sample ID: 038CF
 Collection Date: 6/16/2026 6:42:00 AM Collected By: Loni O'Connor
 Matrix: Drinking Water Sample Location: 038CF

Trace Metals by EPA 200.8 ICP-MS						Analyst: PR		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.827		0.500	ppb	1	6/23/2026	15.0	A

QUALIFIERS	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	DF Dilution Factor	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
	R RPD outside accepted recovery limits	RL Reporting Limit

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 26060787
 25-Jun-26

Client: Eagle Point School District #9
Project: High School Lead Retests

TestCode: LEAD_SCHOOLS

Sample ID: MB-37309	SampType: MBLK	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2026	RunNo: 70679						
Client ID: PBW	Batch ID: 37309	TestNo: E200.8	E200.8	Analysis Date: 6/23/2026	SeqNo: 1169047						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.500									

Sample ID: LCS-37309	SampType: LCS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2026	RunNo: 70679						
Client ID: LCSW	Batch ID: 37309	TestNo: E200.8	E200.8	Analysis Date: 6/23/2026	SeqNo: 1169048						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	102	0.500	100	0	102	85	115				

Sample ID: 26060787-02AMS	SampType: MS	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2026	RunNo: 70679						
Client ID: 023CF	Batch ID: 37309	TestNo: E200.8	E200.8	Analysis Date: 6/23/2026	SeqNo: 1169066						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	104	0.500	100	4.72	99.4	70	130				

Sample ID: 26060787-02AMSD	SampType: MSD	TestCode: LEAD_SCHO	Units: ppb	Prep Date: 6/23/2026	RunNo: 70679						
Client ID: 023CF	Batch ID: 37309	TestNo: E200.8	E200.8	Analysis Date: 6/23/2026	SeqNo: 1169068						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	105	0.500	100	4.72	100	70	130	104	0.737	20	

Qualifiers:
 * Value exceeds Maximum or Minimum Contaminant Level.
 E Value above quantitation range
 ND Not Detected at the Reporting Limit

CI Sample container temperature is out of limit as specified at testcode
 H Holding times for preparation or analysis exceeded
 RL Reporting Limit

DF Dilution Factor
 MI Recovery outside control limits due to Matrix Int

Original



Sample Log-In Check List

Client Name: EAGLEPTSCHOOL

Work Order Number: 26060787

RcptNo: 1

Logged by: Dorie Evans	6/16/2026 8:41:00 AM	
Completed By: Ashley Spiegelberg	6/19/2026 3:08:01 PM	
Reviewed By: Dorie Evans	6/25/2026 8:16:13 AM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
 2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
 4. Shipping container/cooler in good condition? Yes No
 Custody seals intact on shipping container/cooler? Yes No Not Present NA
 No. Seal Date: Signed By:
 5. Was an attempt made to cool the samples? Yes No NA
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
 7. Sample(s) in proper container(s)? Yes No
 8. Sufficient sample volume for indicated test(s)? Yes No
 9. Are samples (except VOA and ONG) properly preserved? Yes No
 10. Was preservative added to bottles? Yes No NA
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
 12. Were any sample containers received broken? Yes No
 13. Does paperwork match bottle labels? Yes No
 (Note discrepancies on chain of custody)
 14. Are matrices correctly identified on Chain of Custody? Yes No
 15. Is it clear what analyses were requested? Yes No
 16. Were all holding times able to be met? Yes No
 (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: <u>JCSO9</u> Address: <u>P.O. Box 548</u> Email: Phone: _____ Fax: _____ Collected By (Print): <u>Loni O'Connor</u> Collected By (Sign): <u>[Signature]</u> Email Report <input type="checkbox"/> Mail Report <input type="checkbox"/> Fax Report <input type="checkbox"/>	Section B Required Project Information Project Name: <u>High School Releasts</u> Project Number: Report To: Copy To:	Section C Invoice Information Attention: <u>John Harding</u> Company Name: Address: P.O. #	Section D Rush Status (Subject to Scheduling) <input type="checkbox"/> Standard: 10 Business Days <input type="checkbox"/> Priority: 5 Business Days (List x 1.50) <input type="checkbox"/> Express: 3 Business Days (List x 1.75) <input type="checkbox"/> Rush: 2 Business Days (List x 2.00) <input type="checkbox"/> Rush: 1 Business Day (List x 2.50) <input type="checkbox"/> Rush: Same Day (List x 3.00) Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
---	---	---	---

Analysis Requested									
No. of Containers									
1									
1									
1									

Section E Sample Information					NRC Workorder # (Lab Use Only)			
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Remarks / Field Data	NRC Sample # (Lab Use Only)	(Lab)
<u>018CF BT14</u>			<u>6/16</u>	<u>6:28</u>	1		<u>26060787</u>	
<u>036CF 3347</u>				<u>6:33</u>	1			<u>11</u>
<u>038CF 5056</u>				<u>6:42</u>	1			<u>12</u>
								<u>13</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive			
Relinquished By:	Print	Date	Time
<u>[Signature]</u>	<u>Loni O'Connor</u>	<u>6/16/26</u>	<u>8:41</u>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	<u>Dorie Evans</u>	<u>6/16/26</u>	<u>8:41</u>

Section G Lab Use Only	
Temp: <u>AMB</u>	IR Therm ID: <u>-</u>
≤6°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Number of Bottles Received: <u>13</u>	
pH Checked: <u>-</u>	
COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>(NA)</u>	
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Received Via <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand	
Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # _____ Amount _____	

-
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
- A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
- B Analyte detected in the associated method blank.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
- R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
- R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- * Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
- 1 Value exceeds one half of the Maximum Contaminant Level.