

Lead in Water Test Results Summary: Ridgeview Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes
Entrance Drinking Fountain	05530700-001DW	2/27/23	ND	Non-Detect	[enter date]	[enter result]	[autofill]	
Room # 1 Classroom Faucet	05530700-002CF	2/27/23	3.48	Low				
Room # 1 Drinking Fountain	05530700-003DW	2/27/23	ND	Non-Detect				
Room # 2 Classroom Faucet	05530700-004CF	2/27/23	ND	Non-Detect				
Room # 2 Drinking Fountain	05530700-005DW	2/27/23	ND	Non-Detect				
Room # 3 Classroom Faucet	05530700-006CF	2/27/23	5.31	Moderate				
Room # 3 Drinking Fountain	05530700-007DW	2/27/23	2.97	Low				
Room # 4 Classroom Faucet	05530700-008CF	2/27/23	2.73	Low				
Room # 4 Drinking Fountain	05530700-009DW	2/27/23	2.29	Low				
Room # 5 Classroom Faucet	05530700-010DW	2/27/23	3.66	Low				
Room # 5 Classroom Faucet	05530700-010.5CF	2/27/23	ND	Non-Detect				
Room # 6 Drinking Fountain	05530700-011DW	2/27/23	4.45	Low				
Room # 6 Classroom Faucet	05530700-012CF	2/27/23	ND	Non-Detect				
Room # 7 Drinking Fountain	05530700-013DW	2/27/23	3.28	Low				
Room # 7 Classroom Faucet	05530700-014CF	2/27/23	3.22	Low				
Room # 8 Drinking Fountain	05530700-015DW	2/27/23	2.67	Low				
Room # 8 Classroom Faucet	05530700-016CF	2/27/23	ND	Non-Detect				
Room # 9 Drinking Fountain	05530700-017DW	2/27/23	4.52	Low				
Room # 9 Classroom Faucet	05530700-018CF	2/27/23	ND	Non-Detect				
Room # 10 Drinking Fountain	05530700-019DW	2/27/23	ND	Non-Detect				
Room # 10 Classroom Faucet	05530700-020CF	2/27/23	ND	Non-Detect				
Room # 11 Drinking Fountain	05530700-021DW	2/27/23	3.37	Low				
Room # 11 Classroom Faucet	05530700-022CF	2/27/23	ND	Non-Detect				
Room # 12 Drinking Fountain	05530700-023DW	2/27/23	ND	Non-Detect				
Room # 12 Classroom Faucet	05530700-024CF	2/27/23	ND	Non-Detect				
Room # 13 Drinking Fountain	05530700-025DW	2/27/23	ND	Non-Detect				
Room # 13 Classroom Faucet	05530700-026CF	2/27/23	ND	Non-Detect				
Room # 14 Drinking Fountain	05530700-027DW	2/27/23	ND	Non-Detect				
Room # 14 Classroom Faucet	05530700-028CF	2/27/23	ND	Non-Detect				
Room # 15 Drinking Fountain	05530700-029DW	2/27/23	ND	Non-Detect				
Room # 15 Classroom Faucet	05530700-030CF	2/27/23	ND	Non-Detect				
Room # 16 Drinking Fountain	05530700-031DW	2/27/23	ND	Non-Detect				
Room # 16 Classroom Faucet	05530700-032CF	2/27/23	ND	Non-Detect				
Room # 17 Drinking Fountain	05530700-033DW	2/27/23	ND	Non-Detect				
Room # 17 Classroom Faucet	05530700-034CF	2/27/23	ND	Non-Detect				
Room # 18 Drinking Fountain	05530700-035DW	2/27/23	ND	Non-Detect				
Room # 18 Classroom Faucet	05530700-036CF	2/27/23	ND	Non-Detect				
Room # 19 Drinking Fountain	05530700-037DW	2/27/23	ND	Non-Detect				
Room # 19 Classroom Faucet	05530700-038CF	2/27/23	ND	Non-Detect				
Room # 20 Drinking Fountain	05530700-039DW	2/27/23	ND	Non-Detect				
Room # 20 Classroom Faucet	05530700-040CF	2/27/23	ND	Non-Detect				
Drinking fountain	05530700-041DW	2/27/23	3.42	Low				
room 20	05530700-042BF	2/27/23	ND	Non-Detect				
West Girls bathroom faucet (middle)	05530700-043BF	2/27/23	2.75	Low				
West Girls bathroom faucet (south)	05530700-044BF	2/27/23	2.57	Low				
West Boys bathroom faucet (north)	05530700-045BF	2/27/23	2.15	Low				
West Boys bathroom faucet (middle)	05530700-046BF	2/27/23	ND	Non-Detect				
West Boys bathroom faucet (south)	05530700-047BF	2/27/23	ND	Non-Detect				
Single Restroom	05530700-048BF	2/27/23	ND	Non-Detect				
from room 17	05530700-049BF	2/27/23	ND	Non-Detect				
North West Girls Bathroom Faucet (middle)	05530700-050BF	2/27/23	2.36	Low				
North West Girls Bathroom Faucet (south)	05530700-051BF	2/27/23	ND	Non-Detect				
North West Boys Bathroom Faucet (north)	05530700-052BF	2/27/23	ND	Non-Detect				
North West Boys Bathroom Faucet (middle)	05530700-053BF	2/27/23	ND	Non-Detect				
North West Boys Bathroom Faucet (south)	05530700-054BF	2/27/23	ND	Non-Detect				
North room in Library	05530700-055CF	2/27/23	44.3	Action Req.	5/29/25	ND	Non-Detect	
South room in Library	05530700-056CF	2/27/23	33.5	Action Req.	5/29/25	32.8	Action Req.	Fixture Removed
Drinking water fountain outside custodial room	05530700-057DW	2/27/23	ND	Non-Detect				
Water Bottle filler on drinking fountain	05530700-058WB	2/27/23	ND	Non-Detect				
room 9	05530700-059BF	2/27/23	7.49	Moderate				
North Girls Bathroom Faucet (south)	05530700-060BF	2/27/23	6.2	Moderate				
North Boys Bathroom Faucet (north)	05530700-061BF	2/27/23	8.63	Moderate				

North Boys Bathroom Faucet (south)	05530700-062BF	2/27/23	8.87	Moderate				
Gym Drinking Water Fountain	05530700-063DW	2/27/23	8.41	Moderate				
Music room Drinking water fountain (south)	05530700-064DW	2/27/23	ND	Non-Detect				
Music room Classroom Faucet (south)	05530700-065CF	2/27/23	2.17	Low				
Music room Drinking water fountain (north)	05530700-066DW	2/27/23	ND	Non-Detect				
Music room Classroom Faucet (north)	05530700-067CF	2/27/23	ND	Non-Detect				
Drinking water fountain across from room 6	05530700-068DW	2/27/23	6.65	Moderate				
room 6	05530700-069BF	2/27/23	5.24	Moderate				
North Girls Bathroom Faucet (south)	05530700-070BF	2/27/23	4.57	Low				
North Boys Bathroom Faucet (north)	05530700-071BF	2/27/23	5.06	Moderate				
North Boys Bathroom Faucet (south)	05530700-072BF	2/27/23	6.52	Moderate				
Faucet)	05530700-075KF	2/27/23	2.46	Low				
Kitchen Kettle Fill (Kitchen /Food Prep Faucet)	05530700-076KF	2/27/23	3.01	Low				
Kitchen Hand Wash Station	05530700-077SF	2/27/23	3.32	Low				
Kitchen staff Restroom bathroom faucet	05530700-078BF	2/27/23	5.73	Moderate				
Dump station (North)(Kitchen /Food Prep Faucet)	05530700-079KF	2/27/23	ND	Non-Detect				
Faucet)	05530700-080KF	2/27/23	2.38	Low				
Faucet)	05530700-081KF	2/27/23	ND	Non-Detect				
Staff room (front office) Staff faucet	05530700-082SF	2/27/23	ND	Non-Detect				
office)	05530700-083BF	2/27/23	10.9	High				
office)	05530700-084BF	2/27/23	4.76	Low				
Nurses room restroom Bathroom Faucet	05530700-085BF	2/27/23	22.2	Action Req.	9/6/24	2.13	Low	
Nurses office Faucet	05530700-086NS	2/27/23	23.6	Action Req.	9/6/24	2.29	Low	
Bottle Fill station at main entrance	05530700-087BF	2/27/23	ND	Non-Detect				



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

March 10, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2302878

Dear Terry Rutledge:

Analytical Laboratory Group received 50 sample(s) on 2/27/2023 for the analyses presented in the following report.

A handwritten signature in black ink, reading 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

A handwritten signature in red ink, reading 'Ridgeview'.



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2302878

Date: 3/10/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Date Reported: 3/10/2023

WO#: 2302878
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302878-001 **Client Sample ID:** 05530700-001DW **Collection Date:** 2/20/2023 6:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-002 **Client Sample ID:** 05530700-002CF **Collection Date:** 2/20/2023 6:50:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.48	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-003 **Client Sample ID:** 05530700-003DW **Collection Date:** 2/20/2023 6:50:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-004 **Client Sample ID:** 05530700-004CF **Collection Date:** 2/20/2023 6:51:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-005 **Client Sample ID:** 05530700-005DW **Collection Date:** 2/20/2023 6:52:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-006 **Client Sample ID:** 05530700-006CF **Collection Date:** 2/20/2023 6:52:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.31	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-007 **Client Sample ID:** 05530700-007DW **Collection Date:** 2/20/2023 6:53:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.97	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/10/2023

WO#: 2302878
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302878-008 **Client Sample ID:** 05530700-008CF **Collection Date:** 2/20/2023 6:54:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.73	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-009 **Client Sample ID:** 05530700-009DW **Collection Date:** 2/20/2023 6:56:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.29	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-010 **Client Sample ID:** 05530700-010DW **Collection Date:** 2/20/2023 6:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.66	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-011 **Client Sample ID:** 05530700-010.5CF **Collection Date:** 2/20/2023 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-012 **Client Sample ID:** 05530700-011DW **Collection Date:** 2/20/2023 7:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.45	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-013 **Client Sample ID:** 05530700-012CF **Collection Date:** 2/20/2023 7:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Lab ID: 2302878-014 **Client Sample ID:** 05530700-013DW **Collection Date:** 2/20/2023 7:04:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.28	15.0	2.00		ppb	3/2/2023 6:11:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/10/2023

WO#: 2302878
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302878-015 **Client Sample ID:** 05530700-014CF **Collection Date:** 2/20/2023 7:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.22	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-016 **Client Sample ID:** 05530700-015DW **Collection Date:** 2/20/2023 7:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.67	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-017 **Client Sample ID:** 05530700-016CF **Collection Date:** 2/20/2023 7:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-018 **Client Sample ID:** 05530700-017DW **Collection Date:** 2/20/2023 7:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.52	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-019 **Client Sample ID:** 05530700-018CF **Collection Date:** 2/20/2023 7:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-020 **Client Sample ID:** 05530700-019DW **Collection Date:** 2/20/2023 7:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-021 **Client Sample ID:** 05530700-020CF **Collection Date:** 2/20/2023 7:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Original
Page 5 of 18

Date Reported: 3/10/2023

WO#: 2302878
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302878-022 **Client Sample ID** 05530700-021DW **Collection Date:** 2/20/2023 7:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.37	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-023 **Client Sample ID** 05530700-022CF **Collection Date:** 2/20/2023 7:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-024 **Client Sample ID** 05530700-023DW **Collection Date:** 2/20/2023 7:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-025 **Client Sample ID** 05530700-024CF **Collection Date:** 2/20/2023 7:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-026 **Client Sample ID** 05530700-025DW **Collection Date:** 2/20/2023 7:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-027 **Client Sample ID** 05530700-026CF **Collection Date:** 2/20/2023 7:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-028 **Client Sample ID** 05530700-027DW **Collection Date:** 2/20/2023 7:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/10/2023

WO#: 2302878
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302878-029 **Client Sample ID:** 05530700-028CF **Collection Date:** 2/20/2023 7:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-030 **Client Sample ID:** 05530700-029DW **Collection Date:** 2/20/2023 7:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-031 **Client Sample ID:** 05530700-030CF **Collection Date:** 2/20/2023 7:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-032 **Client Sample ID:** 05530700-031DW **Collection Date:** 2/20/2023 7:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-033 **Client Sample ID:** 05530700-032CF **Collection Date:** 2/20/2023 7:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-034 **Client Sample ID:** 05530700-033DW **Collection Date:** 2/20/2023 7:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2023 6:01:00 PM	AS

Lab ID: 2302878-035 **Client Sample ID:** 05530700-034CF **Collection Date:** 2/20/2023 7:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/10/2023

WO#: 2302878
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302878-036 **Client Sample ID:** 05530700-035DW **Collection Date:** 2/20/2023 7:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-037 **Client Sample ID:** 05530700-036CF **Collection Date:** 2/20/2023 7:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-038 **Client Sample ID:** 05530700-037DW **Collection Date:** 2/20/2023 7:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-039 **Client Sample ID:** 05530700-038CF **Collection Date:** 2/20/2023 7:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-040 **Client Sample ID:** 05530700-039DW **Collection Date:** 2/20/2023 7:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-041 **Client Sample ID:** 05530700-040CF **Collection Date:** 2/20/2023 7:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-042 **Client Sample ID:** 05530700-041DW **Collection Date:** 2/20/2023 7:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.42	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/10/2023

WO#: 2302878
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302878-043 **Client Sample ID** 05530700-042BF **Collection Date:** 2/20/2023 7:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-044 **Client Sample ID** 05530700-043BF **Collection Date:** 2/20/2023 7:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.75	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-045 **Client Sample ID** 05530700-044BF **Collection Date:** 2/20/2023 7:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.57	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-046 **Client Sample ID** 05530700-045BF **Collection Date:** 2/20/2023 7:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.15	15.0	2.00		ppb	3/8/2023 9:17:00 AM	KG

Lab ID: 2302878-047 **Client Sample ID** 05530700-046BF **Collection Date:** 2/20/2023 7:31:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/9/2023 4:31:00 PM	KG

Lab ID: 2302878-048 **Client Sample ID** 05530700-047BF **Collection Date:** 2/20/2023 7:31:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/9/2023 4:31:00 PM	KG

Lab ID: 2302878-049 **Client Sample ID** 05530700-048BF **Collection Date:** 2/20/2023 7:34:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/9/2023 4:31:00 PM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/10/2023

WO#: 2302878
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302878-050	Client Sample ID 05530700-049BF	Collection Date: 2/20/2023 7:40:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/9/2023 4:31:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)
C Value is below Minimum Compound Limit.
H Holding times for preparation or analysis exceeded
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PQL Practical Quantitation Level or Reporting Limit

A Accredited by ORELAP
E Value above quantitation range
LOD Limit of Detection
NAR See note in Case Narrative
PL Permit Limit
R RPD outside accepted recovery limits

Original
Page 10 of 18



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2302878

Date: 3/10/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302878

10-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302878-001A	05530700-001DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302878-002A	05530700-002CF			Lead	A
	2302878-003A	05530700-003DW			Lead	A
	2302878-004A	05530700-004CF			Lead	A
	2302878-005A	05530700-005DW			Lead	A
	2302878-006A	05530700-006CF			Lead	A
	2302878-007A	05530700-007DW			Lead	A
	2302878-008A	05530700-008CF			Lead	A
	2302878-009A	05530700-009DW			Lead	A
	2302878-010A	05530700-010DW			Lead	A
	2302878-011A	05530700-010.5CF			Lead	A
	2302878-012A	05530700-011DW			Lead	A
	2302878-013A	05530700-012CF			Lead	A
	2302878-014A	05530700-013DW			Lead	A
	2302878-015A	05530700-014CF			Lead	A
	2302878-016A	05530700-015DW			Lead	A
	2302878-017A	05530700-016CF			Lead	A
	2302878-018A	05530700-017DW			Lead	A
	2302878-019A	05530700-018CF			Lead	A
	2302878-020A	05530700-019DW			Lead	A
	2302878-021A	05530700-020CF			Lead	A
	2302878-022A	05530700-021DW			Lead	A
	2302878-023A	05530700-022CF			Lead	A
	2302878-024A	05530700-023DW			Lead	A
	2302878-025A	05530700-024CF			Lead	A
	2302878-026A	05530700-025DW			Lead	A
	2302878-027A	05530700-026CF			Lead	A
	2302878-028A	05530700-027DW			Lead	A
	2302878-029A	05530700-028CF			Lead	A
	2302878-030A	05530700-029DW			Lead	A
	2302878-031A	05530700-030CF			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2302878# v1

Page 12 of 18



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302878

10-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302878-032A	05530700-031DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302878-033A	05530700-032CF			Lead	A
	2302878-034A	05530700-033DW			Lead	A
	2302878-035A	05530700-034CF			Lead	A
	2302878-036A	05530700-035DW			Lead	A
	2302878-037A	05530700-036CF			Lead	A
	2302878-038A	05530700-037DW			Lead	A
	2302878-039A	05530700-038CF			Lead	A
	2302878-040A	05530700-039DW			Lead	A
	2302878-041A	05530700-040CF			Lead	A
	2302878-042A	05530700-041DW			Lead	A
	2302878-043A	05530700-042BF			Lead	A
	2302878-044A	05530700-043BF			Lead	A
	2302878-045A	05530700-044BF			Lead	A
	2302878-046A	05530700-045BF			Lead	A
	2302878-047A	05530700-046BF			Lead	A
	2302878-048A	05530700-047BF			Lead	A
	2302878-049A	05530700-048BF			Lead	A
	2302878-050A	05530700-049BF			Lead	A

ORELAP A Accredited

ACCRED

Original #2302878# v1

Page 13 of 18

RES

Work Order # 2302878



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

FM

Checked:

MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-001DW	DW/Grab	2/20/2023	0629	Lead	P	1		NA	001A
05530700-002CF	DW/Grab	2/20/2023	0650	Lead	P	1			002A
05530700-003DW	DW/Grab	2/20/2023	0650	Lead	P	1			003A
05530700-004CF	DW/Grab	2/20/2023	0651	Lead	P	1			004A
05530700-005DW	DW/Grab	2/20/2023	0652	Lead	P	1			005A
05530700-006CF	DW/Grab	2/20/2023	0652	Lead	P	1			006A
05530700-007DW	DW/Grab	2/20/2023	0653	Lead	P	1			007A
05530700-008CF	DW/Grab	2/20/2023	0654	Lead	P	1			008A
05530700-009DW	DW/Grab	2/20/2023	0656	Lead	P	1			009A
05530700-010DW	DW/Grab	2/20/2023	0657	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush Incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	None: X
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23	0800				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			Jail	2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: EM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-010.5CF	DW/Grab	2/20/2023	0700	Lead	P	1		NA	011A
05530700-011DW	DW/Grab	2/20/2023	0702	Lead	P	1			012A
05530700-012CF	DW/Grab	2/20/2023	0703	Lead	P	1			013A
05530700-013DW	DW/Grab	2/20/2023	0704	Lead	P	1			014A
05530700-014CF	DW/Grab	2/20/2023	0705	Lead	P	1			015A
05530700-015DW	DW/Grab	2/20/2023	0705	Lead	P	1			016A
05530700-016CF	DW/Grab	2/20/2023	0706	Lead	P	1			017A
05530700-017DW	DW/Grab	2/20/2023	0706	Lead	P	1			018A
05530700-018CF	DW/Grab	2/20/2023	0707	Lead	P	1			019A
05530700-019DW	DW/Grab	2/20/2023	0707	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None: ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23	0800				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by/Laboratory:	Date	Time	
			Jailor	2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.comLIMS: FMChecked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-020CF	DW/Grab	2/20/2023	0707	Lead	P	1		NA	021A
05530700-021DW	DW/Grab	2/20/2023	0711	Lead	P	1			022A
05530700-022CF	DW/Grab	2/20/2023	0711	Lead	P	1			023A
05530700-023DW	DW/Grab	2/20/2023	0712	Lead	P	1			024A
05530700-024CF	DW/Grab	2/20/2023	0712	Lead	P	1			025A
05530700-025DW	DW/Grab	2/20/2023	0712	Lead	P	1			026A
05530700-026CF	DW/Grab	2/20/2023	0713	Lead	P	1			027A
05530700-027DW	DW/Grab	2/20/2023	0715	Lead	P	1			028A
05530700-028CF	DW/Grab	2/20/2023	0715	Lead	P	1			029A
05530700-029DW	DW/Grab	2/20/2023	0716	Lead	P	1			030A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23	0300				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

FM

Checked:

W

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-030CF	DW/Grab	2/20/2023	0716	Lead	P	1		NA	031A
05530700-031DW	DW/Grab	2/20/2023	0720	Lead	P	1			032A
05530700-032CF	DW/Grab	2/20/2023	0720	Lead	P	1			033A
05530700-033DW	DW/Grab	2/20/2023	0721	Lead	P	1			034A
05530700-034CF	DW/Grab	2/20/2023	0721	Lead	P	1			035A
05530700-035DW	DW/Grab	2/20/2023	0723	Lead	P	1			036A
05530700-036CF	DW/Grab	2/20/2023	0723	Lead	P	1			037A
05530700-037DW	DW/Grab	2/20/2023	0724	Lead	P	1			038A
05530700-038CF	DW/Grab	2/20/2023	0724	Lead	P	1			039A
05530700-039DW	DW/Grab	2/20/2023	0726	Lead	P	1			040A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None: ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23	0800				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.comLIMS: FMChecked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-040CF	DW/Grab	2/20/2023	0727	Lead	P	1		NA	041A
05530700-041DW	DW/Grab	2/20/2023	0728	Lead	P	1			042A
05530700-042BF	DW/Grab	2/20/2023	0727	Lead	P	1			043A
05530700-043BF	DW/Grab	2/20/2023	0728	Lead	P	1			044A
05530700-044BF	DW/Grab	2/20/2023	0729	Lead	P	1			045A
05530700-045BF	DW/Grab	2/20/2023	0730	Lead	P	1			046A
05530700-046BF	DW/Grab	2/20/2023	0731	Lead	P	1			047A
05530700-047BF	DW/Grab	2/20/2023	0731	Lead	P	1			048A
05530700-048BF	DW/Grab	2/20/2023	0734	Lead	P	1			049A
05530700-049BF	DW/Grab	2/20/2023	0740	Lead	P	1		✓	050A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None: ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			Faith	2/27/23	8:00	



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5993

Website:

March 14, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2302881

Dear Terry Rutledge:

Analytical Laboratory Group received 36 sample(s) on 2/27/2023 for the analyses presented in the following report.

Kimberly J. Reeve Morghan

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

Ridgeview



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2302881

Date: 3/14/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Date Reported: 3/14/2023

WO#: 2302881
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302881-001 **Client Sample ID:** 05530700-050BF **Collection Date:** 2/20/2023 7:40:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.36	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-002 **Client Sample ID:** 05530700-051BF **Collection Date:** 2/20/2023 7:41:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-003 **Client Sample ID:** 05530700-052BF **Collection Date:** 2/20/2023 7:41:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-004 **Client Sample ID:** 05530700-053BF **Collection Date:** 2/20/2023 7:42:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-005 **Client Sample ID:** 05530700-054BF **Collection Date:** 2/20/2023 7:42:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-006 **Client Sample ID:** 05530700-055CF **Collection Date:** 2/20/2023 7:43:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	44.3	15.0	8.00	*	ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-007 **Client Sample ID:** 05530700-056CF **Collection Date:** 2/20/2023 7:43:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	33.5	15.0	4.00	*	ppb	3/12/2023 6:07:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/14/2023

WO#: 2302881
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302881-008 **Client Sample ID** 05530700-057DW **Collection Date:** 2/20/2023 7:45:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-009 **Client Sample ID** 05530700-058WB **Collection Date:** 2/20/2023 7:46:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-010 **Client Sample ID** 05530700-059BF **Collection Date:** 2/20/2023 7:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.49	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-011 **Client Sample ID** 05530700-060BF **Collection Date:** 2/20/2023 7:37:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.20	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-012 **Client Sample ID** 05530700-061BF **Collection Date:** 2/20/2023 7:49:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.63	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-013 **Client Sample ID** 05530700-062BF **Collection Date:** 2/20/2023 7:50:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.87	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-014 **Client Sample ID** 05530700-063DW **Collection Date:** 2/20/2023 7:51:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.41	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2302881
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302881-015 **Client Sample ID** 05530700-064DW **Collection Date:** 2/20/2023 7:52:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-016 **Client Sample ID** 05530700-65CF **Collection Date:** 2/20/2023 7:53:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.17	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-017 **Client Sample ID** 05530700-066DW **Collection Date:** 2/20/2023 7:53:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-018 **Client Sample ID** 05530700-067CF **Collection Date:** 2/20/2023 7:54:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-019 **Client Sample ID** 05530700-068DW **Collection Date:** 2/20/2023 7:55:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.65	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-020 **Client Sample ID** 05530700-069BF **Collection Date:** 2/20/2023 7:56:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.24	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-021 **Client Sample ID** 05530700-070BF **Collection Date:** 2/20/2023 7:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.57	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/14/2023

WO#: 2302881
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302881-022 **Client Sample ID** 05530700-071BF **Collection Date:** 2/20/2023 7:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.06	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-023 **Client Sample ID** 05530700-072BF **Collection Date:** 2/20/2023 6:43:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.52	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-024 **Client Sample ID** 05530700-075KF **Collection Date:** 2/20/2023 6:42:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.46	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-025 **Client Sample ID** 05530700-076KF **Collection Date:** 2/20/2023 6:41:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.01	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-026 **Client Sample ID** 05530700-077SF **Collection Date:** 2/20/2023 6:41:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.32	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-027 **Client Sample ID** 05530700-078BF **Collection Date:** 2/20/2023 6:40:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.73	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-028 **Client Sample ID** 05530700-079KF **Collection Date:** 2/20/2023 6:39:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits

Date Reported: 3/14/2023

WO#: 2302881
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2302881-029 **Client Sample ID** 05530700-080KF **Collection Date:** 2/20/2023 6:39:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.38	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-030 **Client Sample ID** 05530700-081KF **Collection Date:** 2/20/2023 6:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-031 **Client Sample ID** 05530700-082SF **Collection Date:** 2/20/2023 6:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-032 **Client Sample ID** 05530700-083BF **Collection Date:** 2/20/2023 6:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	10.9	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-033 **Client Sample ID** 05530700-084BF **Collection Date:** 2/20/2023 6:35:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.76	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-034 **Client Sample ID** 05530700-085BF **Collection Date:** 2/20/2023 6:35:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	22.2	15.0	4.00	*	ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302881-035 **Client Sample ID** 05530700-086NS **Collection Date:** 2/20/2023 6:34:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	23.6	15.0	4.00	*	ppb	3/12/2023 6:07:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/14/2023

WO#: 2302881
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID:	Client Sample ID	Collection Date:
2302881-036	05530700-087BF	2/20/2023 6:32:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5993

Website:

Definition Base

WO#: 2302881

Date: 3/14/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302881

14-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302881-001A	05530700-050BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302881-002A	05530700-051BF			Lead	A
	2302881-003A	05530700-052BF			Lead	A
	2302881-004A	05530700-053BF			Lead	A
	2302881-005A	05530700-054BF			Lead	A
	2302881-006A	05530700-055CF			Lead	A
	2302881-007A	05530700-056CF			Lead	A
	2302881-008A	05530700-057DW			Lead	A
	2302881-009A	05530700-058WB			Lead	A
	2302881-010A	05530700-059BF			Lead	A
	2302881-011A	05530700-060BF			Lead	A
	2302881-012A	05530700-061BF			Lead	A
	2302881-013A	05530700-062BF			Lead	A
	2302881-014A	05530700-063DW			Lead	A
	2302881-015A	05530700-064DW			Lead	A
	2302881-016A	05530700-65CF			Lead	A
	2302881-017A	05530700-066DW			Lead	A
	2302881-018A	05530700-067CF			Lead	A
	2302881-019A	05530700-068DW			Lead	A
	2302881-020A	05530700-069BF			Lead	A
	2302881-021A	05530700-070BF			Lead	A
	2302881-022A	05530700-071BF			Lead	A
	2302881-023A	05530700-072BF			Lead	A
	2302881-024A	05530700-075KF			Lead	A
	2302881-025A	05530700-076KF			Lead	A
	2302881-026A	05530700-077SF			Lead	A
	2302881-027A	05530700-078BF			Lead	A
	2302881-028A	05530700-079KF			Lead	A
	2302881-029A	05530700-080KF			Lead	A
	2302881-030A	05530700-081KF			Lead	A
	2302881-031A	05530700-082SF			Lead	A

ORELAP A Accredited

ACCRED

Original #2302881# v1

Page 10 of 15



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302881

14-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302881-032A	05530700-083BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302881-033A	05530700-084BF			Lead	A
	2302881-034A	05530700-085BF			Lead	A
	2302881-035A	05530700-086NS			Lead	A
	2302881-036A	05530700-087BF			Lead	A

ORELAP A Accredited

ACCRED

Original #2302881# v1

Page 11 of 15

Delivering more than
just test results361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

FM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-050BF	DW/Grab	2/20/2023	0740	Lead	P	1		NA	001A
05530700-051BF	DW/Grab	2/20/2023	0741	Lead	P	1			002A
05530700-052BF	DW/Grab	2/20/2023	0741	Lead	P	1			003A
05530700-053BF	DW/Grab	2/20/2023	0742	Lead	P	1			004A
05530700-054BF	DW/Grab	2/20/2023	0742	Lead	P	1			005A
05530700-055CF	DW/Grab	2/20/2023	0743	Lead	P	1			006A
05530700-056CF	DW/Grab	2/20/2023	0743	Lead	P	1			007A
05530700-057DW	DW/Grab	2/20/2023	0745	Lead	P	1			008A
05530700-058WB	DW/Grab	2/20/2023	0746	Lead	P	1			009A
05530700-059BF	DW/Grab	2/20/2023	0736	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice: ☐ None: ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			Jail	2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.comLIMS: FMChecked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-060BF	DW/Grab	2/20/2023	0707	Lead	P	1		NA	011A 2/21/23
05530700-061BF	DW/Grab	2/20/2023	0749	Lead	P	1			012A
05530700-062BF	DW/Grab	2/20/2023	0750	Lead	P	1			013A
05530700-063DW	DW/Grab	2/20/2023	0751	Lead	P	1			014A
05530700-064DW	DW/Grab	2/20/2023	0752	Lead	P	1			015A
05530700-065CF	DW/Grab	2/20/2023	0753	Lead	P	1			016A
05530700-066DW	DW/Grab	2/20/2023	0753	Lead	P	1			017A
05530700-067CF	DW/Grab	2/20/2023	0754	Lead	P	1			018A
05530700-068DW	DW/Grab	2/20/2023	0755	Lead	P	1			019A
05530700-069BF	DW/Grab	2/20/2023	0756	Lead	P	1		V	020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	None X
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
				2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

FM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-070BF	DW/Grab	2/20/2023	0751	Lead	P	1		NK	021A
05530700-071BF	DW/Grab	2/20/2023	0751	Lead	P	1			022A
05530700-072BF	DW/Grab	2/20/2023	0643	Lead	P	1			023A
05530700-075KF	DW/Grab	2/20/2023	0642	Lead	P	1			024A
05530700-076KF	DW/Grab	2/20/2023	0641	Lead	P	1			025A
05530700-077SF	DW/Grab	2/20/2023	0641	Lead	P	1			026A
05530700-078BF	DW/Grab	2/20/2023	0640	Lead	P	1			027A
05530700-079KF	DW/Grab	2/20/2023	0639	Lead	P	1			028A
05530700-080KF	DW/Grab	2/20/2023	0639	Lead	P	1			029A
05530700-081KF	DW/Grab	2/20/2023	0636	Lead	P	1		V	030A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
REPORT	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒ X	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
				2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

FM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-082SF	DW/Grab	2/20/2023	0636	Lead	P	1		NA	031A
05530700-083BF	DW/Grab	2/20/2023	0636	Lead	P	1			032A
05530700-084BF	DW/Grab	2/20/2023	0635	Lead	P	1			033A
05530700-085BF	DW/Grab	2/20/2023	0635	Lead	P	1			034A
05530700-086NS	DW/Grab	2/20/2023	0634	Lead	P	1			035A
05530700-087BF	DW/Grab	2/20/2023	0632	Lead	P	1		✓	036A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	None : X
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
				2/27/23	8:00	



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

March 03, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE:

Order No.: 2302882

Dear Terry Rutledge:

Analytical Laboratory Group received 3 sample(s) on 2/27/2023 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2302882

Date: 3/3/2023

CLIENT: Springfield School District #19

Project:

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2302882
CLIENT: Springfield School District #19
Project:
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302882-001		Client Sample ID 05581100-051KF			Collection Date: 2/27/2023 5:22:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/1/2023 3:00:00 PM	AS

Lab ID: 2302882-002		Client Sample ID 05581100-052KF			Collection Date: 2/27/2023 5:24:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/1/2023 3:00:00 PM	AS

Lab ID: 2302882-003		Client Sample ID 05581100-053KF			Collection Date: 2/27/2023 5:22:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/1/2023 3:00:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2302882

Date: 3/3/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2302882
03-Mar-23

Client: Springfield School District #19

Project:

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302882-001A	05581100-051KF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302882-002A	05581100-052KF			Lead	A
	2302882-003A	05581100-053KF			Lead	A

ORELAP A Accredited

ACCRED



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: MT

Checked: VJ

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05581100-051KF	DW/Grab	2/27	0522	Lead	P	1		N/A	001A
05581100-052KF	DW/Grab	2/27	0524	Lead	P	1			002A
05581100-053KF	DW/Grab	2/27	0522	Lead	P	1			003A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH				Shipped Via: <u>Veronica Arciga</u>		Refrigerated	
						Ice	<u>None</u>
Relinquished by: <u>Veronica Arciga</u>	Date: <u>2/27</u>	Time: <u>0800</u>	Received by:		Date:	Time:	
Relinquished by:	Date:	Time:	Received by:		Date:	Time:	
Relinquished by:	Date:	Time:	Received by Laboratory: <u>[Signature]</u>		Date: <u>2/27/23</u>	Time: <u>08:00</u>	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

September 10, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD - Ridgeview

Order No.: 2409216

Dear Terry Rutledge:

Analytical Laboratory Group received 2 sample(s) on 9/6/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads "Kimberly J. Reeve Morghan".

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2409216

Date: 9/10/2024

CLIENT: Springfield School District #19

Project: Springfield SD - Ridgeview

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2409216
CLIENT: Springfield School District #19
Location:
Project: Springfield SD - Ridgeview
Sample Source:

Received Date: 9/6/2024 10:04:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2409216-001		Client Sample ID 05530700-085BF			Collection Date: 9/5/2024 8:35:00 PM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.13	15.0	2.00		ppb	9/9/2024 10:42:00 AM	AS

Lab ID: 2409216-002		Client Sample ID 05530700-086NS			Collection Date: 9/5/2024 8:34:00 PM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.29	15.0	2.00		ppb	9/9/2024 10:42:00 AM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5993

Website:

Definition Base

WO#: 2409216

Date: 9/10/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2409216
10-Sep-24

Client: Springfield School District #19

Project: Springfield SD - Ridgeview

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2409216-001A	05530700-085BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2409216-002A	05530700-086NS			Lead	A

ACCRED
ORELAP A Accredited

* RIDGEVIEW

Work Order #

2469216



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: MT
Checked: EM

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD - Ridgeview *	Sampler Name: <u>John Harshbarger</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-0858F	DW/Grab	9/5	20:35	Lead	P	1		N/A	021A
05530700-086NS	DW/Grab	9/5	20:34	Lead	P	1		N/A	022A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes: * Written in by lab to be included in project name. PM 9/16/21	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated <u>IR</u>	
☒ NORMAL ☐ RUSH			John		Ice ☐ None <u>NA</u>	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>John Harshbarger</u>						
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Pam Phillips</u>	9/16/21	10:04	Page 6 of 6



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

September 10, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD - Ridgeview

Order No.: 2409216

Dear Terry Rutledge:

Analytical Laboratory Group received 2 sample(s) on 9/6/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads "Kimberly J. Reeve Morghan".

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2409216

Date: 9/10/2024

CLIENT: Springfield School District #19

Project: Springfield SD - Ridgeview

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2409216
CLIENT: Springfield School District #19
Location:
Project: Springfield SD - Ridgeview
Sample Source:

Received Date: 9/6/2024 10:04:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2409216-001		Client Sample ID 05530700-085BF			Collection Date: 9/5/2024 8:35:00 PM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.13	15.0	2.00		ppb	9/9/2024 10:42:00 AM	AS

Lab ID: 2409216-002		Client Sample ID 05530700-086NS			Collection Date: 9/5/2024 8:34:00 PM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.29	15.0	2.00		ppb	9/9/2024 10:42:00 AM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5993

Website:

Definition Base

WO#: 2409216

Date: 9/10/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2409216
10-Sep-24

Client: Springfield School District #19

Project: Springfield SD - Ridgeview

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2409216-001A	05530700-085BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2409216-002A	05530700-086NS			Lead	A

ACCRED
ORELAP A Accredited

* RIDGEVIEW

Work Order #

2469216



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: MT
Checked: EM

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD - Ridgeview *	Sampler Name: <u>John Harshbarger</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05530700-0858F	DW/Grab	9/5	20:35	Lead	P	1		N/A	021A
05530700-086NS	DW/Grab	9/5	20:34	Lead	P	1		N/A	022A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes: * Written in by lab to be included in project name. PM 9/16/21	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated <u>IR</u>	
☒ NORMAL ☐ RUSH			John		Ice <u>None</u> ^{N/A}	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>John Harshbarger</u>						
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Pam Phillips</u>	9/16/21	10:04	Page 6 of 6