

Lead in Water Test Results Summary: Springfield High School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	NOTES
CDC Health center entrance bathroom faucet	5602000-001BF	2/1/24	ND	Non-Detect	[enter date]	[enter result]	[autofill]	
Nurse exam room 1	5602000-002NS	2/1/24	13.6	High				
Nurse Staff faucet	5602000-003SF	2/1/24	4.52	Low				
Nurse exam room 2	5602000-004NS	2/1/24	4.86	Low				
Nurse Bathroom Faucet	5602000-005BF	2/1/24	ND	Non-Detect				
Drinking fountain Hallway near attic stairs	5602000-006DW	2/1/24	6.15	Moderate				
Staff bathroom Single	5602000-007BF	2/1/24	2.48	Low				
Bathroom faucet (student)	5602000-008BF	2/1/24	ND	Non-Detect				
Bathroom faucet (student)	5602000-009BF	2/1/24	ND	Non-Detect				
Nursery staff faucet	5602000-010SF	2/1/24	ND	Non-Detect				
Nursery staff faucet	5602000-011SF	2/1/24	2.19	Low				
Nursery kitchen faucet 1	5602000-012KF	2/1/24	ND	Non-Detect				
Nursery kitchen faucet 2	5602000-013KF	2/1/0204	4.34	Low				
Nursery kitchen faucet 3	5602000-014KF	2/1/24	22.1	Action Req.	6/4/2025	12.8	High	
Nursery kitchen faucet 4	5602000-015SF	2/1/24	12.1	High				
bradley	5602000-017BF	2/1/24	9.42	Moderate				
mens bathroom faucet 3 Faucet Bradley (left)	5602000-018BF	2/1/24	ND	Non-Detect				
mens bathroom faucet (middle)	5602000-019BF	2/1/24	ND	Non-Detect				
mens bathroom faucet (right)	5602000-020BF	2/1/24	ND	Non-Detect				
Training room 818 staff faucet	5602000-021SF	2/1/24	ND	Non-Detect				
Boys Locker Drinking fountain	5602000-023DW	2/1/24	4.22	Low				
Coaches Rm 819 bathroom faucet	5602000-024BF	2/1/24	ND	Non-Detect				
Boys bathroom faucet	5602000-025BF	2/1/24	6.45	Moderate				
Boys bathroom faucet	5602000-026BF	2/1/24	ND	Non-Detect				
Boys bathroom faucet	5602000-027BF	2/1/24	ND	Non-Detect				
room BETWEEN 815 & 816	5602000-028BF	2/1/24	ND	Non-Detect				
Lobby drinking fountain	5602000-029DW	2/1/24	2.63	Low				
Drinking fountain	5602000-030DW	2/1/24	ND	Non-Detect				
Concessions staff faucet RM 824	5602000-031SF	2/1/24	3.39	Low				
Lobby drinking fountain	5602000-032DW	2/1/24	ND	Non-Detect				
Water bottle fill station	5602000-033WB	2/1/24	ND	Non-Detect				
Women bathroom faucet Rm 827 single bradley	5602000-034BF	2/1/24	ND	Non-Detect				
Women bathroom faucet 3 Faucet Bradley (left)	5602000-035BF	2/1/24	11.3	High				
Women bathroom faucet (middle)	5602000-036BF	2/1/24	4.59	Low				
Girls Locker room bathroom faucet	5602000-038BF	2/1/24	11.6	High				
Girls Locker room bathroom faucet	5602000-039BF	2/1/24	4.49	Low				
Girls Locker room bathroom faucet	5602000-040BF	2/1/24	4.28	Low				
Coaches Rm 829 bathroom faucet	5602000-041BF	2/2/24	33.4	Action Req.	6/4/25	ND	Non-Detect	
Girls Locker Drinking fountain	5602000-042DW	2/1/24	ND	Non-Detect				
Girls Locker Drinking fountain	5602000-043DW	2/1/24	2.11	Low				
Wood shop RM 930 Bradley	5602000-044CF	2/1/24	8.74	Moderate				
Rm 930 drinking Fountain	5602000-045DW	2/1/24	ND	Non-Detect				
Bathroom faucet RM 938	5602000-046BF	2/1/24	ND	Non-Detect				
Bathroom faucet Rm 937	5602000-047BF	2/1/24	ND	Non-Detect				
Small engine classroom faucet Bradley	5602000-048CF	2/1/24	4.55	Low				
Drinking fountain	5602000-049DW	2/1/24	4.69	Low				
Auto shop main bay drinking fountain	5602000-050DW	2/1/24	ND	Non-Detect				
Water bottle fill station	5602000-051WB	2/1/24	ND	Non-Detect				
Bathroom faucet G Rm 926	5602000-052BF	2/1/24	ND	Non-Detect				
Bathroom faucet B Rm 925	5602000-053BF	2/1/24	2.67	Low				
Classroom faucet (Hand wash)	5602000-054CF	2/1/24	ND	Non-Detect				
Industrial arts Rm 940 Classroom faucet	5602000-055CF	2/1/24	6.95	Moderate				
Rm 934 Classroom Faucet	5602000-056CF	2/1/24	26.3	Action Req.	6/4/25	8.39	Moderate	
RM 935 Drinking fountain	5602000-057DW	2/1/24	10.4	High				
Rm 935 Classroom Faucet	5602000-058CF	2/1/24	3.87	Low				
Rm 935 Classroom Faucet	5602000-059CF	2/1/24	ND	Non-Detect				
Rm 936 Classroom Faucet	5602000-061CF	2/1/24	ND	Non-Detect				
Rm 960 Bathroom Faucet	5602000-062BF	2/1/24	8.94	Moderate				
Rm 960 Classroom Faucet	5602000-063CF	2/1/24	ND	Non-Detect				
Metals Shop Drinking fountain	5602000-156DW	2/1/24	ND	Non-Detect				
Water bottle fill station	5602000-157WB	2/1/24	ND	Non-Detect				
Classroom Faucet in shop hand wash station	5602000-158CF	2/1/24	ND	Non-Detect				

Portable metals shop bathroom faucet	5602000-159BF	2/1/24	ND	Non-Detect				
Music Hall RM 761 Men's bathroom faucet	5602000-064BF	2/1/24	2.46	Low				
mens bathroom faucet	5602000-066BF	2/1/24	ND	Non-Detect				
Drinking fountain	5602000-067DW	2/1/24	ND	Non-Detect				
Drinking fountain	5602000-068DW	2/1/24	ND	Non-Detect				
RM 754 Women bathroom faucet	5602000-069BF	2/1/24	ND	Non-Detect				
Women bathroom faucet	5602000-070BF	2/1/24	ND	Non-Detect				
Women bathroom faucet	5602000-071BF	2/1/24	ND	Non-Detect				
faucet RM 745	5602000-072BF	2/1/24	8.04	Moderate				
mens bathroom faucet RM 747	5602000-073BF	2/1/24	8.9	Moderate				
Stage Classroom Faucet	5602000-074CF	2/1/24	43.4	Action Req.				NOT IN USE
Commons Mens bathroom faucet	5602000-075BF	2/1/24	3.19	Low				
Womens Bathroom faucet	5602000-076BF	2/1/24	ND	Non-Detect				
Drinking fountain	5602000-077DW	2/1/24	ND	Non-Detect				
Water bottle fill station	5602000-078WB	2/1/24	ND	Non-Detect				
Custodial room 737 Staff faucet	5602000-079SF	2/1/24	ND	Non-Detect				
Custodial room 738 bathroom faucet	5602000-080BF	2/1/24	10.8	High				
Kitchen Dishwasher area Kitchen faucet	5602000-081KF	2/2/24	9.04	Moderate				
Dishwasher area Kitchen faucet	5602000-082KF	2/2/24	8.29	Moderate				
Dishwasher area Kitchen faucet	5602000-083KF	2/2/24	14.1	High				
Kitchen faucet near ice machine	5602000-084KF	2/2/24	9.73	Moderate				
Kitchen faucet near back exit door	5602000-085KF	2/2/24	5.08	Moderate				
Kitchen faucet near office	5602000-086KF	2/2/24	2.74	Low				
Breakroom bathroom faucet rm 705	5602000-087BF	2/2/24	4.18	Low				
faucet (RM113)	5602000-088BF	2/2/24	3.21	Low				
Women bathroom faucet (RM 115)	5602000-089BF	2/2/24	3.12	Low				
Staff room 116 staff faucet	5602000-090SF	2/2/24	2.38	Low				
Student women's bathroom faucet Rm 130	5602000-091BF	2/2/24	ND	Non-Detect				
Drinking fountain	5602000-093DW	2/2/24	ND	Non-Detect				
Water bottle fill station	5602000-094WB	2/2/24	ND	Non-Detect				
Students mens bathroom faucet Rm 134	5602000-095BF	2/2/24	2.71	Low				
Nurse office sink Rm 314	5602000-096NS	2/2/24	2.82	Low				
Nurse bathroom faucet 1 Staff	5602000-097BF	2/2/24	3.2	Low				
Nurse bathroom faucet 2 Gender	5602000-098BF	2/2/24	8.27	Moderate				
Rm 319 Staff Faucet	5602000-099SF	2/2/24	8.2	Moderate				
RM 330 Classroom faucet	5602000-100CF	2/2/24	50.5	Action Req.	Science Room			Labelled no-drinking
RM 331 Classroom faucet 1	5602000-101CF	2/2/24	108	Action Req.	Science Room			Labelled no-drinking
RM 331 Classroom faucet 2	5602000-102CF	2/2/24	16.5	Action Req.	Science Room			Labelled no-drinking
RM 331 Classroom faucet 3	5602000-103CF	2/2/24	24.6	Action Req.	Science Room			Labelled no-drinking
RM 331 Classroom faucet 4	5602000-104CF	2/2/24	29.8	Action Req.	Science Room			Labelled no-drinking
RM 331 Classroom faucet 5	5602000-105CF	2/2/24	17.5	Action Req.	Science Room			Labelled no-drinking
RM 331 Classroom faucet 6	5602000-106CF	2/2/24	18.6	Action Req.	Science Room			Labelled no-drinking
Library staff faucet Rm 354 open area	5602000-107SF	2/2/24	35	Action Req.	6/4/25	4.21	Low	
Student women's bathroom faucet Rm 530 A	5602000-108BF	2/2/24	69	Action Req.	6/4/25	6.08	Moderate	
Student women's bathroom faucet B	5602000-109BF	2/2/24	63.4	Action Req.	6/4/25	ND	Non-Detect	
Student women's bathroom faucet C	5602000-110BF	2/2/24	24.5	Action Req.	6/4/25	5.05	Moderate	
Student women's bathroom faucet D	5602000-111BF	2/2/24	16.9	Action Req.	6/4/25	5.3	Moderate	
Drinking fountain 2	5602000-113DW	2/2/24	9.59	Moderate				
Students mens bathroom faucet Rm 534 A	5602000-114BF	2/2/24	22	Action Req.	6/4/25	3.21	Low	
Students mens bathroom faucet B	5602000-115BF	2/2/24	4.56	Low				
Students mens bathroom faucet C	5602000-116BF	2/2/24	5.39	Moderate				
Students mens bathroom faucet D	5602000-117BF	2/2/24	13	High				
RM 557 classroom faucet	5602000-118CF	2/2/24	15.7	Action Req.	6/4/25	8.47	Moderate	
RM 550 classroom faucet	5602000-119CF	2/2/24	5.11	Moderate				
Rm 510 Staff faucet	5602000-120SF	2/2/24	13	High				
Drinking fountain 1	5602000-122DW	2/2/24	3.41	Low				
Drinking fountain 2	5602000-123DW	2/2/24	2.01	Low				
Girls bathroom faucet Rm 234	5602000-124BF	2/2/24	2.72	Low				
Rm 213 Staff Faucet	5602000-125SF	2/2/24	11.4	High				
Science Wing Room 401 classroom faucet	5602000-126CF	2/2/24	85.5	Action Req.	Science Room			Labelled no-drinking
Room 401 classroom faucet	5602000-127CF	2/2/24	290	Action Req.	Science Room			Labelled no-drinking
Room 401 classroom faucet	5602000-128CF	2/2/24	67.6	Action Req.	Science Room			Labelled no-drinking
Room 401 classroom faucet	5602000-129CF	2/2/24	470	Action Req.	Science Room			Labelled no-drinking
Room 401 classroom faucet	5602000-130CF	2/2/24	39.4	Action Req.	Science Room			Labelled no-drinking
Room 401 classroom faucet	5602000-131CF	2/2/24	21.3	Action Req.	Science Room			Labelled no-drinking
Room 402 Classroom Faucet	5602000-131.50CF	2/2/24	177	Action Req.	Science Room			Labelled no-drinking
Room421 Classroom Faucet	5602000-132CF	2/2/24	14.8	High				
Room421 Classroom Faucet	5602000-133CF	2/2/24	16.8	Action Req.	Science Room			Labelled no-drinking
Room421 Classroom Faucet	5602000-134CF	2/2/24	139	Action Req.	Science Room			Labelled no-drinking
Room421 Classroom Faucet	5602000-135CF	2/2/24	144	Action Req.	Science Room			Labelled no-drinking
Room421 Classroom Faucet	5602000-136CF	2/2/24	178	Action Req.	Science Room			Labelled no-drinking
Room421 Classroom Faucet	5602000-137CF	2/2/24	157	Action Req.	Science Room			Labelled no-drinking
Room 403 Classroom faucet	5602000-139CF	2/2/24	7.74	Moderate				
Room 403 Classroom faucet	5602000-140CF	2/2/24	6.12	Moderate				
Room 404 Staff Faucet	5602000-141SF	2/2/24	32.8	Action Req.	Science Room			Labelled no-drinking
Room 418 Classroom Faucet	5602000-142CF	2/2/24	35.5	Action Req.	Science Room			Labelled no-drinking
Room 418 Classroom Faucet	5602000-143CF	2/2/24	103	Action Req.	Science Room			Labelled no-drinking
Room 418 Classroom Faucet	5602000-144CF	2/2/24	31.4	Action Req.	Science Room			Labelled no-drinking
Room 418 Classroom Faucet	5602000-145CF	2/2/24	108	Action Req.	Science Room			Labelled no-drinking
Room 418 Classroom Faucet	5602000-146CF	2/2/24	ND	Non-Detect				
Room 418 Classroom Faucet	5602000-147CF	2/2/24	6.2	Moderate				
Room 418 Classroom Faucet	5602000-148CF	2/2/24	8.87	Moderate				

Room 418 Classroom Faucet	5602000-149CF	2/2/24	12.6	High				
Room 415 Classroom faucet	5602000-150CF	2/2/24	35.6	Action Req.	Science Room			Labelled no-drinking
Room 414 Classroom Faucet	5602000-152CF	2/2/24	2.38	Low				
Room 414 Classroom Faucet	5602000-153CF	2/2/24	5.95	Moderate				
Room 405 Classroom faucet	5602000-154CF	2/2/24	113	Action Req.	Science Room			Labelled no-drinking
Room 405 Classroom faucet	5602000-154.5CF	2/2/24	28.5	Action Req.	Science Room			Labelled no-drinking
Room 405 Classroom faucet	5602000-155CF	2/2/24	41	Action Req.	Science Room			Labelled no-drinking
Room 406 Classroom Faucet	5602000-160CF	2/2/24	62.8	Action Req.	Science Room			Labelled no-drinking
Room 406 Staff faucet	5602000-161CF	2/2/24	10.6	High				
Room 409 Classroom Faucet	5602000-162CF	2/2/24	92.1	Action Req.	Science Room			Labelled no-drinking
Room 409 Classroom Faucet	5602000-163CF	2/2/24	59.4	Action Req.	Science Room			Labelled no-drinking
Room 409 Classroom Faucet	5602000-164CF	2/2/24	69.5	Action Req.	Science Room			Labelled no-drinking
Room 409 Classroom Faucet	5602000-165CF	2/2/24	33.6	Action Req.	Science Room			Labelled no-drinking
Room 409 Classroom Faucet	5602000-166CF	2/2/24	72.6	Action Req.	Science Room			Labelled no-drinking
Room 409 Classroom Faucet	5602000-167CF	2/2/24	38.2	Action Req.	Science Room			Labelled no-drinking
Room 410 Classroom Faucet	5602000-168CF	2/2/24	45.5	Action Req.	Science Room			Labelled no-drinking
Room 410 Classroom Faucet	5602000-169CF	2/2/24	51	Action Req.	Science Room			Labelled no-drinking
Room 411 Classroom Faucet	5602000-170CF	2/2/24	32.2	Action Req.	Science Room			Labelled no-drinking
Room 411 Classroom Faucet	5602000-171CF	2/2/24	241	Action Req.	Science Room			Labelled no-drinking
RM 630 Girls Bathroom Faucet	5602000-172BF	2/2/24	ND	Non-Detect				
Drinking fountain	5602000-173DW	2/2/24	2.43	Low				
Drinking fountain	5602000-174DW	2/2/24	2.82	Low				
Rm 634 Bathroom Faucet	5602000-175BF	2/2/24	ND	Non-Detect				
Math wing Room 456 Staff Faucet	5602000-176SF	2/2/24	26.3	Action Req.	6/4/25	20.9	Action Req.	Fixture Removed



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

February 06, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield High School CDC

Order No.: 2402009

Dear Terry Rutledge:

Analytical Laboratory Group received 15 sample(s) on 2/1/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reever Morghan'.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402009

Date: 2/6/2024

CLIENT: Springfield School District #19

Project: Springfield High School CDC

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402009
CLIENT: Springfield School District #19
Location:
Project: Springfield High School CDC
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402009-001	Client Sample ID	5602000-001BF		Collection Date: 2/1/2024 5:18:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-002	Client Sample ID	5602000-002NS		Collection Date: 2/1/2024 5:20:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	13.6	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-003	Client Sample ID	5602000-003SF		Collection Date: 2/1/2024 5:21:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.52	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-004	Client Sample ID	5602000-004NF		Collection Date: 2/1/2024 5:22:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.86	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-005	Client Sample ID	5602000-005BF	Collection Date: 2/1/2024 5:23:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-006	Client Sample ID	5602000-006DW		Collection Date: 2/1/2024 5:24:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.15	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-007	Client Sample ID	5602000-007BF		Collection Date: 2/1/2024 5:25:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.48	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402009
CLIENT: Springfield School District #19
Location:
Project: Springfield High School CDC
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402009-008	Client Sample ID	5602000-008BF		Collection Date: 2/1/2024 5:26:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-009	Client Sample ID	5602000-009BF		Collection Date: 2/1/2024 5:26:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-010	Client Sample ID	5602000-010SF			Collection Date: 2/1/2024 5:27:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-011	Client Sample ID	5602000-011SF		Collection Date: 2/1/2024 5:28:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.19	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-012	Client Sample ID	5602000-012KF		Collection Date: 2/1/2024 5:29:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-013	Client Sample ID	5602000-013KF		Collection Date: 2/1/2024 5:30:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.34	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-014	Client Sample ID	5602000-014KF		Collection Date: 2/1/2024 5:31:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	22.1	15.0	4.00	*	ppb	2/5/2024 6:24:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402009
CLIENT: Springfield School District #19
Location:
Project: Springfield High School CDC
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402009-015		Client Sample ID 5602000-015KF		Collection Date: 2/1/2024 5:32:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	12.1	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402009

Date: 2/6/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402009

06-Feb-24

Client: Springfield School District #19

Project: Springfield High School CDC

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402009-001A	5602000-001BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402009-002A	5602000-002NS			Lead	A
	2402009-003A	5602000-003SF			Lead	A
	2402009-004A	5602000-004NF			Lead	A
	2402009-005A	5602000-005BF			Lead	A
	2402009-006A	5602000-006DW			Lead	A
	2402009-007A	5602000-007BF			Lead	A
	2402009-008A	5602000-008BF			Lead	A
	2402009-009A	5602000-009BF			Lead	A
	2402009-010A	5602000-010SF			Lead	A
	2402009-011A	5602000-011SF			Lead	A
	2402009-012A	5602000-012KF			Lead	A
	2402009-013A	5602000-013KF			Lead	A
	2402009-014A	5602000-014KF			Lead	A
	2402009-015A	5602000-015KF			Lead	A

ACCREDITED
ORELAP A Accredited

Original #2402009# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

FM

Checked:

RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-001 BF	DW/Grab	2/1	0518	Lead	P	1		NA	001A
5602000-002 NS	DW/Grab	2/1	0520	Lead	P	1			002A
5602000-003 SF	DW/Grab	2/1	0521	Lead	P	1			003A
5602000-004 NS SF	DW/Grab	2/1	0522	Lead	P	1			004A
5602000-005 BF	DW/Grab	2/1	0523	Lead	P	1			005A
5602000-006 DW	DW/Grab	2/1	0524	Lead	P	1			006A
5602000-007 BF	DW/Grab	2/1	0525	Lead	P	1			007A
5602000-008 BF BF *	DW/Grab	2/1	0526	Lead	P	1			008A
5602000-009 BF	DW/Grab	2/1	0526	Lead	P	1			009A
5602000-010 SF	DW/Grab	2/1	0527	Lead	P	1		✓	010A

Notes: *Per bottle and Veronica. MT 2/1/24 / FM 2/1/24	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	Veronica Arciga	Ice ☐ None ☒
Relinquished by: Veronica Arciga	Received by:	Date: 2/1/24 Time: 1030
Relinquished by:	Received by:	Date: Time:
Relinquished by:	Received by Laboratory:	Date: 2/1/24 Time: 10:30



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School COC	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-011SF	DW/Grab	2/1	0528	Lead	P	1		NA	010A011A
5602000-012KF	DW/Grab	2/1	0529	Lead	P	1			011A012A
5602000-013KF	DW/Grab	2/1	0530	Lead	P	1			012A013A
5602000-014KF	DW/Grab	2/1	0531	Lead	P	1			013A014A
5602000-015SF*KF	DW/Grab	2/1	0532	Lead	P	1		↓	014A015A
5602000	DW/Grab	/	/	Lead	P	1			
5602000	DW/Grab	/	/	Lead	P	1			
5602000	DW/Grab	/	/	Lead	P	1			
5602000	DW/Grab	/	/	Lead	P	1			
5602000	DW/Grab	/	/	Lead	P	1			

Notes: <u>Written over/corrected by client. FM 2/1/24</u> <u>*Per bottle and Veronica. FM 2/1/24</u> <u>***Samples not relinquished; crossed off by lab. FM 2/1/24</u> <u>***FM 2/1/24</u>	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/1/24</u>	<u>1030</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Jaith</u>	<u>2/1/24</u>	<u>10:30</u>	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

June 05, 2025

John Harshberger
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 979-9667
FAX:

RE: Springfield SD 19 - Springfield High School

Order No.: 2505959

Dear John Harshberger:

Analytical Laboratory Group received 11 sample(s) on 5/30/2025 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia'.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2505959

Date: 6/5/2025

CLIENT: Springfield School District #19
Project: Springfield SD 19 - Springfield High School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2505959
CLIENT: Springfield School District #19
Location:
Project: Springfield SD 19 - Springfield High School
Sample Source:

Received Date: 5/30/2025 8:01:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2505959-001	Client Sample ID	5602000-014KF			Collection Date: 5/30/2025 6:15:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	12.8	15.0	2.00		ppb	6/4/2025 3:03:00 PM	KG

Lab ID: 2505959-002	Client Sample ID	5602000-041BF		Collection Date: 5/30/2025 6:19:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/4/2025 3:03:00 PM	KG

Lab ID: 2505959-003	Client Sample ID	5602000-056CF		Collection Date: 5/30/2025 6:22:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.39	15.0	2.00		ppb	6/4/2025 3:03:00 PM	KG

Lab ID: 2505959-004	Client Sample ID	5602000-107SF		Collection Date: 5/30/2025 6:26:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.21	15.0	2.00		ppb	6/4/2025 3:03:00 PM	KG

Lab ID: 2505959-005	Client Sample ID 5602000-108BF			Collection Date: 5/30/2025 6:29:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.08	15.0	2.00		ppb	6/4/2025 3:03:00 PM	KG

Lab ID: 2505959-006	Client Sample ID	5602000-109BF		Collection Date: 5/30/2025 6:29:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/4/2025 3:03:00 PM	KG

Lab ID: 2505959-007	Client Sample ID	5602000-110BF		Collection Date: 5/30/2025 6:30:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.05	15.0	2.00		ppb	6/4/2025 3:03:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2505959
CLIENT: Springfield School District #19
Location:
Project: Springfield SD 19 - Springfield High School
Sample Source:

Received Date: 5/30/2025 8:01:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2505959-008 **Client Sample ID** 5602000-111BF **Collection Date:** 5/30/2025 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.30	15.0	2.00		ppb	6/3/2025 9:36:00 AM	KG

Lab ID: 2505959-009 **Client Sample ID** 5602000-114BF **Collection Date:** 5/30/2025 6:32:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.21	15.0	2.00		ppb	6/3/2025 9:36:00 AM	KG

Lab ID: 2505959-010 **Client Sample ID** 5602000-118CF **Collection Date:** 5/30/2025 6:33:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.47	15.0	2.00		ppb	6/3/2025 9:36:00 AM	KG

Lab ID: 2505959-011 **Client Sample ID** 5602000-176SF **Collection Date:** 5/30/2025 6:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	20.9	15.0	2.00	*	ppb	6/3/2025 9:36:00 AM	KG



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2505959

Date: 6/5/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2505959
 05-Jun-25

Client: Springfield School District #19
Project: Springfield SD 19 - Springfield High Sc

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2505959-001A	5602000-014KF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2505959-002A	5602000-041BF			Lead	A
	2505959-003A	5602000-056CF			Lead	A
	2505959-004A	5602000-107SF			Lead	A
	2505959-005A	5602000-108BF			Lead	A
	2505959-006A	5602000-109BF			Lead	A
	2505959-007A	5602000-110BF			Lead	A
	2505959-008A	5602000-111BF			Lead	A
	2505959-009A	5602000-114BF			Lead	A
	2505959-010A	5602000-118CF			Lead	A
	2505959-011A	5602000-176SF			Lead	A



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: MT
Checked: BK

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: John Harshberger	Company: Springfield School District
Phone: (541) 979-9667	Address: 1890 North 42nd Street
Email: john.harshberger@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client: <u>SPRINGFIELD SD 19</u>	Sampler Name: <u>MARIO RODRIGUEZ</u>
Project: <u>SPRINGFIELD HIGH SCHOOL</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-014 KE	DW/Grab	5.30.25	06:15	Lead	P	1		NA	001A
5602000-041 BF	DW/Grab	5.30.25	06:19	Lead	P	1			002A
5602000-056 CF	DW/Grab	5.30.25	06:22	Lead	P	1			003A
5602000-074 CF	DW/Grab	5.30.25	06:25	Lead	P	1			
5602000-107 SF	DW/Grab	5.30.25	06:26	Lead	P	1		NA	004A
5602000-108 BF	DW/Grab	5.30.25	06:29	Lead	P	1			005A
5602000-109 BF	DW/Grab	5.30.25	06:29	Lead	P	1			006A
5602000-110 BF	DW/Grab	5.30.25	06:30	Lead	P	1			007A
5602000-111 BF	DW/Grab	5.30.25	06:30	Lead	P	1			008A

Notes: <u>6 Sample not received, lined out by client</u> <u>at Lab. MT 5/30/25</u>	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated		
☒ NORMAL ☐ RUSH			<u>Mario</u>		Ice	IR	IR NA
Relinquished by:	Date	Time	Received by:	Date	Time		
<u>Mario Rodriguez</u>	5.30.25	08:03					
Relinquished by:	Date	Time	Received by:	Date	Time		
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time		
			<u>[Signature]</u>	5/30/25	08:01		



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: MTT

Checked: BK

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: John Harshberger	Company: Springfield School District
Phone: (541) 979-9667	Address: 1890 North 42nd Street
Email: john.harshberger@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client: SPRINGFIELD SD 19	Sampler Name: MARIO RODRIGUEZ
Project: SPRINGFIELD HIGH SCHOOL	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-114BF	DW/Grab	5.30.25	06:32	Lead	P	1		NA	009A
5602000-118CF	DW/Grab	5.30.25	06:33	Lead	P	1		I	010A
5602000-176SF	DW/Grab	5.30.25	06:36	Lead	P	1		I	011A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated			
☒ NORMAL ☐ RUSH			Mario		Ice	IR	None	IR
Relinquished by:	Date	Time	Received by:	Date	Time			
<i>Handwritten Signature</i>	5.30.25	08:03						
Relinquished by:	Date	Time	Received by:	Date	Time			
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time			
			<i>Handwritten Signature</i>	5.30.25	08:01			



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

February 06, 2024

SHS

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield High School CDC

Order No.: 2402009

Dear Terry Rutledge:

Analytical Laboratory Group received 15 sample(s) on 2/1/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402009

Date: 2/6/2024

CLIENT: Springfield School District #19

Project: Springfield High School CDC

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402009
CLIENT: Springfield School District #19
Location:
Project: Springfield High School CDC
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402009-001 **Client Sample ID** 5602000-001BF **Collection Date:** 2/1/2024 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-002 **Client Sample ID** 5602000-002NS **Collection Date:** 2/1/2024 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	13.6	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-003 **Client Sample ID** 5602000-003SF **Collection Date:** 2/1/2024 5:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.52	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-004 **Client Sample ID** 5602000-004NF **Collection Date:** 2/1/2024 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.86	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-005 **Client Sample ID** 5602000-005BF **Collection Date:** 2/1/2024 5:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-006 **Client Sample ID** 5602000-006DW **Collection Date:** 2/1/2024 5:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.15	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-007 **Client Sample ID** 5602000-007BF **Collection Date:** 2/1/2024 5:25:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.48	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402009
CLIENT: Springfield School District #19
Location:
Project: Springfield High School CDC
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402009-008 **Client Sample ID** 5602000-008BF **Collection Date:** 2/1/2024 5:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-009 **Client Sample ID** 5602000-009BF **Collection Date:** 2/1/2024 5:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-010 **Client Sample ID** 5602000-010SF **Collection Date:** 2/1/2024 5:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-011 **Client Sample ID** 5602000-011SF **Collection Date:** 2/1/2024 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.19	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-012 **Client Sample ID** 5602000-012KF **Collection Date:** 2/1/2024 5:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-013 **Client Sample ID** 5602000-013KF **Collection Date:** 2/1/2024 5:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.34	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402009-014 **Client Sample ID** 5602000-014KF **Collection Date:** 2/1/2024 5:31:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	22.1	15.0	4.00	*	ppb	2/5/2024 6:24:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 2/6/2024

WO#: 2402009
CLIENT: Springfield School District #19
Location:
Project: Springfield High School CDC
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402009-015	Client Sample ID: 5602000-015KF	Collection Date: 2/1/2024 5:32:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	12.1	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402009

Date: 2/6/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2402009
06-Feb-24

Client: Springfield School District #19

Project: Springfield High School CDC

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402009-001A	5602000-001BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402009-002A	5602000-002NS			Lead	A
	2402009-003A	5602000-003SF			Lead	A
	2402009-004A	5602000-004NF			Lead	A
	2402009-005A	5602000-005BF			Lead	A
	2402009-006A	5602000-006DW			Lead	A
	2402009-007A	5602000-007BF			Lead	A
	2402009-008A	5602000-008BF			Lead	A
	2402009-009A	5602000-009BF			Lead	A
	2402009-010A	5602000-010SF			Lead	A
	2402009-011A	5602000-011SF			Lead	A
	2402009-012A	5602000-012KF			Lead	A
	2402009-013A	5602000-013KF			Lead	A
	2402009-014A	5602000-014KF			Lead	A
	2402009-015A	5602000-015KF			Lead	A

ACCRED
ORELAP A Accredited

Original #2402009# v1
Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield High School <u>COC</u>		Sampler Name: <u>Veronica Arciga</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only					
		Date	Time		Type	#	Pres	T °C	Lab ID	
5602000-001 BF	DW/Grab	2/1	0518	Lead	P	1			NR	001A
5602000-002 NS	DW/Grab	2/1	0520	Lead	P	1				002A
5602000-003 SF	DW/Grab	2/1	0521	Lead	P	1				003A
5602000-004 NS NF	DW/Grab	2/1	0522	Lead	P	1				004A
5602000-005 BF	DW/Grab	2/1	0523	Lead	P	1				005A
5602000-006 DW	DW/Grab	2/1	0524	Lead	P	1				006A
5602000-007 BF	DW/Grab	2/1	0525	Lead	P	1				007A
5602000-008 BF BF *	DW/Grab	2/1	0526	Lead	P	1				008A
5602000-009 BF	DW/Grab	2/1	0526	Lead	P	1				009A
5602000-010 SF	DW/Grab	2/1	0527	Lead	P	1			✓	010A

Notes: *Per bottle and Veronica. <u>MT 2/1/24 / FM 2/1/24</u>		PAID		Preservation Check				
		Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
		CC						
		CK						
		Cash						
		REPORT						
		Mail						
		Email						
		Fax						
		Pickup						

Turn Around Time Requested (Rush Incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/1/24</u>	<u>1030</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	<u>2/1/24</u>	<u>10:30</u>	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: <u>terry.rutledge@springfield.k12.or.us</u>	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School COC	Sampler Name: <u>Veronica Arziga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-011 SF	DW/Grab	2/1	0528	Lead	P	1		NA	011A
5602000-012 KF	DW/Grab	2/1	0529	Lead	P	1			012A
5602000-013 KF	DW/Grab	2/1	0530	Lead	P	1			013A
5602000-014 KF	DW/Grab	2/1	0531	Lead	P	1			014A
5602000-015 SF KF	DW/Grab	2/1	0532	Lead	P	1			015A
5602000	DW/Grab	/	/	Lead	P	1			
5602000	DW/Grab	/	/	Lead	P	1			
5602000	DW/Grab	/	/	Lead	P	1			
5602000	DW/Grab	/	/	Lead	P	1			
5602000	DW/Grab	/	/	Lead	P	1			

Notes: <u>Written over/corrected by client. FM 2/1/24</u> <u>*Per bottle and Veronica.</u> <u>FM 2/1/24</u> <u>***Samples not relinquished; crossed off by lab. FM 2/1/24</u> <u>***FM 2/1/24</u>	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	<u>Veronica Arziga</u>	Ice ☐ None ☒
Relinquished by: <u>Veronica Arziga</u>	Received by:	Date: <u>2/1/24</u> Time: <u>10:30</u>
Relinquished by:	Received by:	Date: Time:
Relinquished by:	Received by Laboratory:	Date: <u>2/1/24</u> Time: <u>10:30</u>



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

SHS

February 14, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield High School Metal Music Audito

Order No.: 2402022

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/1/2024 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402022

Date: 2/14/2024

CLIENT: Springfield School District #19
Project: Springfield High School Metal Music Auditoriu

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Analytical Report

Date Reported: 2/14/2024

WO#: 2402022
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Metal Music Auditoriu
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402022-001 **Client Sample ID** 5602000-156DW **Collection Date:** 2/1/2024 6:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 2:07:00 PM	AS

Lab ID: 2402022-002 **Client Sample ID** 5602000-157WB **Collection Date:** 2/1/2024 6:58:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 2:07:00 PM	AS

Lab ID: 2402022-003 **Client Sample ID** 5602000-158CF **Collection Date:** 2/1/2024 6:58:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 2:07:00 PM	AS

Lab ID: 2402022-004 **Client Sample ID** 5602000-159BF **Collection Date:** 2/1/2024 6:55:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-005 **Client Sample ID** 5602000-064BF **Collection Date:** 2/1/2024 7:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.46	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-006 **Client Sample ID** 5602000-066BF **Collection Date:** 2/1/2024 7:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-007 **Client Sample ID** 5602000-067DW **Collection Date:** 2/1/2024 7:17:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)
C Value is below Minimum Compound Limit.
H Holding times for preparation or analysis exceeded
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PQL Practical Quantitation Level or Reporting Limit

A Accredited by ORELAP
E Value above quantitation range
LOD Limit of Detection
NAR See note in Case Narrative
PL Permit Limit
R RPD outside accepted recovery limits



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/14/2024

WO#: 2402022
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Metal Music Auditoriu
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402022-008 **Client Sample ID** 5602000-068DW **Collection Date:** 2/1/2024 7:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-009 **Client Sample ID** 5602000-069BF **Collection Date:** 2/1/2024 7:19:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-010 **Client Sample ID** 5602000-070BF **Collection Date:** 2/1/2024 7:19:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-011 **Client Sample ID** 5602000-071BF **Collection Date:** 2/1/2024 7:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-012 **Client Sample ID** 5602000-072BF **Collection Date:** 2/1/2024 7:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.04	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-013 **Client Sample ID** 5602000-073BF **Collection Date:** 2/1/2024 7:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.90	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-014 **Client Sample ID** 5602000-074CF **Collection Date:** 2/1/2024 7:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	43.4	15.0	8.00	*	ppb	2/12/2024 3:58:00 PM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/14/2024

WO#: 2402022
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Metal Music Auditoriu
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402022-015 **Client Sample ID** 5602000-075BF **Collection Date:** 2/1/2024 7:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.19	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-016 **Client Sample ID** 5602000-076BF **Collection Date:** 2/1/2024 7:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/12/2024 3:58:00 PM	KG

Lab ID: 2402022-017 **Client Sample ID** 5602000-077DW **Collection Date:** 2/1/2024 7:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402022-018 **Client Sample ID** 5602000-078WB **Collection Date:** 2/1/2024 7:31:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402022-019 **Client Sample ID** 5602000-079SF **Collection Date:** 2/1/2024 7:32:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402022-020 **Client Sample ID** 5602000-080BF **Collection Date:** 2/1/2024 7:33:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	10.8	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

Original
Page 5 of 9



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2402022

Date: 2/14/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402022

14-Feb-24

Client: Springfield School District #19

Project: Springfield High School Metal Music A

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402022-001A	5602000-156DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402022-002A	5602000-157WB			Lead	A
	2402022-003A	5602000-158CF			Lead	A
	2402022-004A	5602000-159BF			Lead	A
	2402022-005A	5602000-064BF			Lead	A
	2402022-006A	5602000-066BF			Lead	A
	2402022-007A	5602000-067DW			Lead	A
	2402022-008A	5602000-068DW			Lead	A
	2402022-009A	5602000-069BF			Lead	A
	2402022-010A	5602000-070BF			Lead	A
	2402022-011A	5602000-071BF			Lead	A
	2402022-012A	5602000-072BF			Lead	A
	2402022-013A	5602000-073BF			Lead	A
	2402022-014A	5602000-074CF			Lead	A
	2402022-015A	5602000-075BF			Lead	A
	2402022-016A	5602000-076BF			Lead	A
	2402022-017A	5602000-077DW			Lead	A
	2402022-018A	5602000-078WB			Lead	A
	2402022-019A	5602000-079SF			Lead	A
	2402022-020A	5602000-080BF			Lead	A

ORELAP A Accredited

ACCRED

Original #2402022# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

FM

Checked:

RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School Metal Shop Music Hall	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000- 156 DW	DW/Grab	2/1	0657	Lead	P	1		NA	001A
5602000- 157 WB	DW/Grab	2/1	0658	Lead	P	1			002A
5602000- 158 CF	DW/Grab	2/1	0658	Lead	P	1			003A
5602000- 159 BF	DW/Grab	2/1	0655	Lead	P	1			004A
5602000- 064 BF	DW/Grab	2/1	0716	Lead	P	1			005A
5602000- 066 BF	DW/Grab	2/1	0716	Lead	P	1			006A
5602000- 067 DW	^{lower} DW/Grab	2/1	0717	Lead	P	1			007A
5602000- 068 DW	^{upper} DW/Grab	2/1	0718	Lead	P	1			008A
5602000- 069 BF	DW/Grab	2/1	0719	Lead	P	1			009A
5602000- 070 BF	DW/Grab	2/1	0719	Lead	P	1		✓	010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	Veronica Arciga	Ice ☐ None ☒
Relinquished by: Veronica Arciga	Received by:	Date Time
		2/1/24 1030
Relinquished by:	Received by:	Date Time
Relinquished by:	Received by Laboratory:	Date Time
		2/1/24 10:30



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: <u>terry.rutledge@springfield.k12.or.us</u>	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School Music Hall Auditorium Commons	Sampler Name: <u>Veronica Arciga **</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-071BF	DW/Grab	2/1	0720	Lead	P	1		NA	011A
5602000-072BF	DW/Grab	2/1	0721	Lead	P	1			012A
5602000-073BF	DW/Grab	2/1	0722	Lead	P	1			013A
5602000-074CF	DW/Grab	2/1	0723	Lead	P	1			014A
5602000-075BF	DW/Grab	2/1	0728	Lead	P	1			015A
5602000-076BF	DW/Grab	2/1	0729	Lead	P	1			016A
5602000-077DW	DW/Grab	2/1	0730	Lead	P	1			017A
5602000-078WB	DW/Grab	2/1	0731	Lead	P	1			018A
5602000-079SF	DW/Grab	2/1	0732	Lead	P	1			019A
5602000-080BF	DW/Grab	2/1	0733	Lead	P	1		✓	020A

Notes: **Per Veronica - FM 2/1/24	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH	Shipped Via: <u>Veronica Arciga</u>	Refrigerated Ice ☐ None ☒
Relinquished by: <u>Veronica Arciga</u>	Date: <u>2/1/24</u> Time: <u>1030</u>	Received by:
Relinquished by:	Date: Time:	Received by:
Relinquished by:	Date: Time:	Received by Laboratory: <u>[Signature]</u>
	Date: <u>2/1/24</u> Time: <u>10:30</u>	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

SHS

February 14, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield High School Kitchen 1st Floor

Order No.: 2402071

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/2/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia' in a cursive script.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2402071
Date: 2/14/2024

CLIENT: Springfield School District #19
Project: Springfield High School Kitchen 1st Floor

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results.

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Analytical Report

Date Reported: 2/14/2024

WO#: 2402071
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Kitchen 1st Floor
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402071-001 **Client Sample ID:** 5602000-081KF **Collection Date:** 2/2/2024 5:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.04	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-002 **Client Sample ID:** 5602000-082KF **Collection Date:** 2/2/2024 5:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.29	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-003 **Client Sample ID:** 5602000-083KF **Collection Date:** 2/2/2024 5:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	14.1	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-004 **Client Sample ID:** 5602000-084KF **Collection Date:** 2/2/2024 5:04:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.73	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-005 **Client Sample ID:** 5602000-085KF **Collection Date:** 2/2/2024 5:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.08	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-006 **Client Sample ID:** 5602000-086KF **Collection Date:** 2/2/2024 5:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.74	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-007 **Client Sample ID:** 5602000-087BF **Collection Date:** 2/2/2024 5:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.18	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

Original
Page 3 of 9



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/14/2024

WO#: 2402071
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Kitchen 1st Floor
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402071-008 **Client Sample ID:** 5602000-088BF **Collection Date:** 2/2/2024 5:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.21	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-009 **Client Sample ID:** 5602000-089BF **Collection Date:** 2/2/2024 5:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.12	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-010 **Client Sample ID:** 5602000-090SF **Collection Date:** 2/2/2024 5:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.38	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-011 **Client Sample ID:** 5602000-091BF **Collection Date:** 2/2/2024 5:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-012 **Client Sample ID:** 5602000-093DW **Collection Date:** 2/2/2024 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-013 **Client Sample ID:** 5602000-094WB **Collection Date:** 2/2/2024 5:19:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-014 **Client Sample ID:** 5602000-095BF **Collection Date:** 2/2/2024 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.71	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)
C Value is below Minimum Compound Limit.
H Holding times for preparation or analysis exceeded
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PQL Practical Quantitation Level or Reporting Limit

A Accredited by ORELAP
E Value above quantitation range
LOD Limit of Detection
NAR See note in Case Narrative
PL Permit Limit
R RPD outside accepted recovery limits



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/14/2024

WO#: 2402071
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Kitchen 1st Floor
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402071-015 **Client Sample ID:** 5602000-096NS **Collection Date:** 2/2/2024 5:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.82	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-016 **Client Sample ID:** 5602000-097BF **Collection Date:** 2/2/2024 5:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.20	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-017 **Client Sample ID:** 5602000-098BF **Collection Date:** 2/2/2024 5:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.27	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-018 **Client Sample ID:** 5602000-099SF **Collection Date:** 2/2/2024 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.20	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-019 **Client Sample ID:** 5602000-100CF **Collection Date:** 2/2/2024 5:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	50.5	15.0	8.00	*	ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402071-020 **Client Sample ID:** 5602000-101CF **Collection Date:** 2/2/2024 5:33:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	108	15.0	20.0	*	ppb	2/13/2024 5:00:00 PM	AS

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits

Original
Page 5 of 9



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2402071
Date: 2/14/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402071

14-Feb-24

Client: Springfield School District #19
Project: Springfield High School Kitchen 1st Flo

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402071-001A	5602000-081KF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402071-002A	5602000-082KF			Lead	A
	2402071-003A	5602000-083KF			Lead	A
	2402071-004A	5602000-084KF			Lead	A
	2402071-005A	5602000-085KF			Lead	A
	2402071-006A	5602000-086KF			Lead	A
	2402071-007A	5602000-087BF			Lead	A
	2402071-008A	5602000-088BF			Lead	A
	2402071-009A	5602000-089BF			Lead	A
	2402071-010A	5602000-090SF			Lead	A
	2402071-011A	5602000-091BF			Lead	A
	2402071-012A	5602000-093DW			Lead	A
	2402071-013A	5602000-094WB			Lead	A
	2402071-014A	5602000-095BF			Lead	A
	2402071-015A	5602000-096NS			Lead	A
	2402071-016A	5602000-097BF			Lead	A
	2402071-017A	5602000-098BF			Lead	A
	2402071-018A	5602000-099SF			Lead	A
	2402071-019A	5602000-100CF			Lead	A
	2402071-020A	5602000-101CF			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2402071# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: <u>terry.rutledge@springfield.k12.or.us</u>	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School <i>Kitchen 1st floor</i>	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		* Date	Time		Type	#	Pres	T °C	Lab ID
5602000-081KF	DW/Grab	<u>2/2/24</u>	<u>0502</u>	Lead	P	1		<u>NA</u>	<u>001A</u>
5602000-082KF	DW/Grab		<u>0502</u>	Lead	P	1			<u>002A</u>
5602000-083KF	DW/Grab		<u>0503</u>	Lead	P	1			<u>003A</u>
5602000-084KF	DW/Grab		<u>0504</u>	Lead	P	1			<u>004A</u>
5602000-085KF	DW/Grab		<u>0505</u>	Lead	P	1			<u>005A</u>
5602000-086KF	DW/Grab		<u>0506</u>	Lead	P	1			<u>006A</u>
5602000-087BF	DW/Grab		<u>0507</u>	Lead	P	1			<u>007A</u>
5602000-088BF	DW/Grab		<u>0511</u>	Lead	P	1			<u>008A</u>
5602000-089BF	DW/Grab		<u>0512</u>	Lead	P	1			<u>009A</u>
5602000-090SF	DW/Grab		<u>0513</u>	Lead	P	1			<u>010A</u>

Notes: <u>*Per bottles - FM 2/2/24</u>	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH	Shipped Via: <u>Veronica Arciga</u>	Refrigerated Ice ☐ None ☒
Relinquished by: <u>Veronica Arciga</u>	Date: <u>2/2</u> Time: <u>1040</u>	Received by: Date: Time:
Relinquished by:	Date: Time:	Received by:
Relinquished by:	Date: Time:	Received by Laboratory: <u>[Signature]</u>
	Date: <u>2/2/24</u> Time: <u>11:23</u>	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

FM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield High School 1st floor		Sampler Name: Veronica Arciga	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		* Date	Time		Type	#	Pres	T °C	Lab ID
5602000-091BF	DW/Grab	2/2/24	0515	Lead	P	1		NA	011A
5602000-093DW	DW/Grab		0518	Lead	P	1			012A
5602000-094WB	DW/Grab		0519	Lead	P	1			013A
5602000-095BF	DW/Grab		0520	Lead	P	1			014A
5602000-096NS	DW/Grab		0524	Lead	P	1			015A
5602000-097BF	DW/Grab		0526	Lead	P	1			016A
5602000-098BF	DW/Grab		0527	Lead	P	1			017A
5602000-099SF	DW/Grab		0528	Lead	P	1			018A
5602000-100CF	DW/Grab		0530	Lead	P	1			019A
5602000-101CF	DW/Grab		0533	Lead	P	1			020A

Notes: *Per bottles - FM 2/2/24	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
☒ NORMAL	☐ RUSH	Veronica Arciga		Ice	None
Relinquished by:	Date	Time	Received by:	Date	Time
Veronica Arciga	2/2/24	1040			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
				2/2/24	11:23



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5993
Website:

SHZ

February 19, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield High School 1st and 2nd Floor

Order No.: 2402072

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/2/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia'.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2402072
Date: 2/19/2024

CLIENT: Springfield School District #19
Project: Springfield High School 1st and 2nd Floor

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/19/2024

WO#: 2402072
CLIENT: Springfield School District #19
Location:
Project: Springfield High School 1st and 2nd Floor
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402072-001 **Client Sample ID** 5602000-113DW **Collection Date:** 2/2/2024 5:41:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.59	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-002 **Client Sample ID** 5602000-114BF **Collection Date:** 2/2/2024 5:43:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	22.0	15.0	4.00	*	ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-003 **Client Sample ID** 5602000-115BF **Collection Date:** 2/2/2024 5:44:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.56	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-004 **Client Sample ID** 5602000-116BF **Collection Date:** 2/2/2024 5:45:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.39	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-005 **Client Sample ID** 5602000-117BF **Collection Date:** 2/2/2024 5:46:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	13.0	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-006 **Client Sample ID** 5602000-118CF **Collection Date:** 2/2/2024 5:48:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	15.7	15.0	2.00	*	ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-007 **Client Sample ID** 5602000-119CF **Collection Date:** 2/2/2024 5:49:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.11	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/19/2024

WO#: 2402072
CLIENT: Springfield School District #19
Location:
Project: Springfield High School 1st and 2nd Floor
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402072-008 **Client Sample ID:** 5602000-120SF **Collection Date:** 2/2/2024 5:50:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	13.0	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-009 **Client Sample ID:** 5602000-122DW **Collection Date:** 2/2/2024 5:56:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.41	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-010 **Client Sample ID:** 5602000-123DW **Collection Date:** 2/2/2024 5:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.01	15.0	2.00		ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-011 **Client Sample ID:** 5602000-102CF **Collection Date:** 2/2/2024 5:33:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	16.5	15.0	2.00	*	ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-012 **Client Sample ID:** 5602000-103CF **Collection Date:** 2/2/2024 5:34:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	24.6	15.0	4.00	*	ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-013 **Client Sample ID:** 5602000-104CF **Collection Date:** 2/2/2024 5:35:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	29.8	15.0	4.00	*	ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-014 **Client Sample ID:** 5602000-105CF **Collection Date:** 2/2/2024 5:35:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	17.5	15.0	2.00	*	ppb	2/13/2024 5:00:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

Original
Page 4 of 9



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/19/2024

WO#: 2402072
CLIENT: Springfield School District #19
Location:
Project: Springfield High School 1st and 2nd Floor
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402072-015 **Client Sample ID:** 5602000-106CF **Collection Date:** 2/2/2024 5:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	18.6	15.0	2.00	*	ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-016 **Client Sample ID:** 5602000-107SF **Collection Date:** 2/2/2024 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	35.0	15.0	4.00	*	ppb	2/13/2024 5:00:00 PM	AS

Lab ID: 2402072-017 **Client Sample ID:** 5602000-108BF **Collection Date:** 2/2/2024 5:37:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	69.0	15.0	10.0	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402072-018 **Client Sample ID:** 5602000-109BF **Collection Date:** 2/2/2024 5:37:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	63.4	15.0	10.0	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402072-019 **Client Sample ID:** 5602000-110BF **Collection Date:** 2/2/2024 5:38:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	24.5	15.0	4.00	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402072-020 **Client Sample ID:** 5602000-111BF **Collection Date:** 2/2/2024 5:39:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	16.9	15.0	2.00	*	ppb	2/15/2024 5:37:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

Original
Page 5 of 9



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2402072
Date: 2/19/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402072

19-Feb-24

Client: Springfield School District #19
Project: Springfield High School 1st and 2nd Flo

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402072-001A	5602000-113DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402072-002A	5602000-114BF			Lead	A
	2402072-003A	5602000-115BF			Lead	A
	2402072-004A	5602000-116BF			Lead	A
	2402072-005A	5602000-117BF			Lead	A
	2402072-006A	5602000-118CF			Lead	A
	2402072-007A	5602000-119CF			Lead	A
	2402072-008A	5602000-120SF			Lead	A
	2402072-009A	5602000-122DW			Lead	A
	2402072-010A	5602000-123DW			Lead	A
	2402072-011A	5602000-102CF			Lead	A
	2402072-012A	5602000-103CF			Lead	A
	2402072-013A	5602000-104CF			Lead	A
	2402072-014A	5602000-105CF			Lead	A
	2402072-015A	5602000-106CF			Lead	A
	2402072-016A	5602000-107SF			Lead	A
	2402072-017A	5602000-108BF			Lead	A
	2402072-018A	5602000-109BF			Lead	A
	2402072-019A	5602000-110BF			Lead	A
	2402072-020A	5602000-111BF			Lead	A

ACCRED

ORELAP A Accredited

Original #2402072# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School ^{1st 2nd floor}	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		* Date	Time		Type	#	Pres	T °C	Lab ID
5602000-113 DW	DW/Grab	<u>2/2/24</u>	0541	Lead	P	1		<u>NA</u>	001A
5602000-114 BF	DW/Grab		0543	Lead	P	1			002A
5602000-115 BF	DW/Grab		0544	Lead	P	1			003A
5602000-116 BF	DW/Grab		0545	Lead	P	1			004A
5602000-117 BF	DW/Grab		0546	Lead	P	1			005A
5602000-118 CF	DW/Grab		0548	Lead	P	1			006A
5602000-119 CF	DW/Grab		0549	Lead	P	1			007A
5602000-120 SF	DW/Grab		0550	Lead	P	1			008A
5602000-122 DW	DW/Grab		0556	Lead	P	1			009A
5602000-123 DW	DW/Grab		0557	Lead	P	1			010A

Notes: <u>*Per bottles. FM 2/2/24</u>	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: <u>Veronica Arciga</u>		Refrigerated Ice ☐ (None)	
Relinquished by: <u>Veronica Arciga</u>	Date <u>2/2/24</u>	Time <u>1040</u>	Received by:		Date	Time
Relinquished by:	Date	Time	Received by:		Date	Time
Relinquished by:	Date	Time	Received by Laboratory: <u>[Signature]</u>		Date <u>2/2/24</u>	Time <u>11:23</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School ^{1st Floor}	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-102CF	DW/Grab	2/2	0533	Lead	P	1		NA	011A
5602000-103CF	DW/Grab	2/2	0534	Lead	P	1			012A
5602000-104CF	DW/Grab	2/2	0535	Lead	P	1			013A
5602000-105CF	DW/Grab	2/2	0535	Lead	P	1			014A
5602000-106CF	DW/Grab	2/2	0536	Lead	P	1			015A
5602000-107SF	DW/Grab	2/2	0522	Lead	P	1			016A
5602000-108BF	DW/Grab	2/2	0537	Lead	P	1			017A
5602000-109BF	DW/Grab	2/2	0537	Lead	P	1			018A
5602000-110BF	DW/Grab	2/2	0538	Lead	P	1			019A
5602000-111BF	DW/Grab	2/2	0539	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/2/24</u>	<u>1040</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	<u>2/2/24</u>	<u>11:23</u>	



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

SHS

February 19, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield High School

Order No.: 2402074

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/2/2024 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402074

Date: 2/19/2024

CLIENT: Springfield School District #19

Project: Springfield High School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402074
CLIENT: Springfield School District #19
Location:
Project: Springfield High School
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402074-001 **Client Sample ID** 5602000-124BF **Collection Date:** 2/2/2024 5:58:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.72	15.0	2.00		ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-002 **Client Sample ID** 5602000-125SF **Collection Date:** 2/2/2024 5:59:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.4	15.0	2.00		ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-003 **Client Sample ID** 5602000-126CF **Collection Date:** 2/2/2024 6:08:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	85.5	15.0	10.0	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-004 **Client Sample ID** 5602000-127CF **Collection Date:** 2/2/2024 6:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	290	15.0	40.0	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-005 **Client Sample ID** 5602000-128CF **Collection Date:** 2/2/2024 6:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	67.6	15.0	10.0	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-006 **Client Sample ID** 5602000-129CF **Collection Date:** 2/2/2024 6:10:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	470	15.0	80.0	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-007 **Client Sample ID** 5602000-130CF **Collection Date:** 2/2/2024 6:10:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	39.4	15.0	8.00	*	ppb	2/15/2024 5:37:00 PM	AS

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits

WO#: 2402074
CLIENT: Springfield School District #19
Location:
Project: Springfield High School
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402074-008 **Client Sample ID** 5602000-131CF **Collection Date:** 2/2/2024 6:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	21.3	15.0	4.00	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-009 **Client Sample ID** 5602000-132CF **Collection Date:** 2/2/2024 6:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	14.8	15.0	2.00		ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-010 **Client Sample ID** 5602000-133CF **Collection Date:** 2/2/2024 6:14:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	16.8	15.0	4.00	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-011 **Client Sample ID** 5602000-134CF **Collection Date:** 2/2/2024 6:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	139	15.0	20.0	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-012 **Client Sample ID** 5602000-135CF **Collection Date:** 2/2/2024 6:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	144	15.0	20.0	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-013 **Client Sample ID** 5602000-136CF **Collection Date:** 2/2/2024 6:17:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	178	15.0	40.0	*	ppb	2/16/2024 5:02:00 PM	AS

Lab ID: 2402074-014 **Client Sample ID** 5602000-137CF **Collection Date:** 2/2/2024 6:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	157	15.0	20.0	*	ppb	2/15/2024 5:37:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402074
CLIENT: Springfield School District #19
Location:
Project: Springfield High School
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402074-015 **Client Sample ID** 5602000-139CF **Collection Date:** 2/2/2024 6:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.74	15.0	2.00		ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-016 **Client Sample ID** 5602000-140CF **Collection Date:** 2/2/2024 6:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.12	15.0	2.00		ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-017 **Client Sample ID** 5602000-141SF **Collection Date:** 2/2/2024 6:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	32.8	15.0	4.00	*	ppb	2/15/2024 5:37:00 PM	AS

Lab ID: 2402074-018 **Client Sample ID** 5602000-142CF **Collection Date:** 2/2/2024 6:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	35.5	15.0	4.00	*	ppb	2/16/2024 5:02:00 PM	AS

Lab ID: 2402074-019 **Client Sample ID** 5602000-143CF **Collection Date:** 2/2/2024 6:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	103	15.0	20.0	*	ppb	2/16/2024 5:02:00 PM	AS

Lab ID: 2402074-020 **Client Sample ID** 5602000-144CF **Collection Date:** 2/2/2024 6:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	31.4	15.0	4.00	*	ppb	2/16/2024 5:02:00 PM	AS

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402074

Date: 2/19/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2402074

19-Feb-24

Client: Springfield School District #19

Project: Springfield High School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402074-001A	5602000-124BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402074-002A	5602000-125SF			Lead	A
	2402074-003A	5602000-126CF			Lead	A
	2402074-004A	5602000-127CF			Lead	A
	2402074-005A	5602000-128CF			Lead	A
	2402074-006A	5602000-129CF			Lead	A
	2402074-007A	5602000-130CF			Lead	A
	2402074-008A	5602000-131CF			Lead	A
	2402074-009A	5602000-132CF			Lead	A
	2402074-010A	5602000-133CF			Lead	A
	2402074-011A	5602000-134CF			Lead	A
	2402074-012A	5602000-135CF			Lead	A
	2402074-013A	5602000-136CF			Lead	A
	2402074-014A	5602000-137CF			Lead	A
	2402074-015A	5602000-139CF			Lead	A
	2402074-016A	5602000-140CF			Lead	A
	2402074-017A	5602000-141SF			Lead	A
	2402074-018A	5602000-142CF			Lead	A
	2402074-019A	5602000-143CF			Lead	A
	2402074-020A	5602000-144CF			Lead	A

ACCRED
ORELAP A Accredited

Original #2402074# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-124 BF	DW/Grab	<u>2/2/24</u>	<u>0558</u>	Lead	P	1		<u>NA</u>	<u>001A</u>
5602000-125 SF	DW/Grab		<u>0559</u>	Lead	P	1			<u>002A</u>
5602000-126 CF	DW/Grab		<u>0608</u>	Lead	P	1			<u>003A</u>
5602000-127 CF	DW/Grab		<u>0609</u>	Lead	P	1			<u>004A</u>
5602000-128 CF	DW/Grab		<u>0609</u>	Lead	P	1			<u>005A</u>
5602000-129 CF	DW/Grab		<u>0610</u>	Lead	P	1			<u>006A</u>
5602000-130 CF	DW/Grab		<u>0610</u>	Lead	P	1			<u>007A</u>
5602000-131 CF	DW/Grab		<u>0611</u>	Lead	P	1			<u>008A</u>
5602000-132 CF	DW/Grab		<u>0613</u>	Lead	P	1			<u>009A</u>
5602000-133 CF	DW/Grab		<u>0614</u>	Lead	P	1			<u>010A</u>

Notes: <u>*Per bottles</u>	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH		<u>Veronica Arciga</u>		Ice ☐ <u>None</u>	
Relinquished by:	Date	Time	Received by:	Date	Time
<u>Veronica Arciga</u>	<u>2/2/24</u>	<u>1040</u>			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>[Signature]</u>	<u>2/2/24</u>	<u>11:23</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		*Date	Time		Type	#	Pres	T °C	Lab ID
5602000-134CF	DW/Grab	<u>2/2/24</u>	<u>0615</u>	Lead	P	1		<u>NA</u>	<u>011A</u>
5602000-135CF	DW/Grab		<u>0616</u>	Lead	P	1			<u>012A</u>
5602000-136CF	DW/Grab		<u>0617</u>	Lead	P	1			<u>013A</u>
5602000-137CF	DW/Grab		<u>0618</u>	Lead	P	1			<u>014A</u>
5602000-139CF	DW/Grab		<u>0627</u>	Lead	P	1			<u>015A</u>
5602000-140CF	DW/Grab		<u>0628</u>	Lead	P	1			<u>016A</u>
5602000-141SF	DW/Grab		<u>0629</u>	Lead	P	1			<u>017A</u>
5602000-142CF	DW/Grab		<u>0620</u>	Lead	P	1			<u>018A</u>
5602000-143CF	DW/Grab		<u>0620</u>	Lead	P	1			<u>019A</u>
5602000-144CF	DW/Grab		<u>0621</u>	Lead	P	1			<u>020A</u>

Notes: <u>*Per bottles. FM 2/2/24</u>	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush Incurs a Surcharge): ☒ NORMAL ☐ RUSH		Shipped Via: <u>Veronica Arciga</u>		Refrigerated Ice ☐ None ☒	
Relinquished by: <u>Veronica Arciga</u>	Date <u>2/2/24</u>	Time <u>1040</u>	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory: <u>[Signature]</u>	Date <u>2/2/24</u>	Time <u>11:25</u>



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

February 12, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield High School Gym

Order No.: 2402015

Dear Terry Rutledge:

Analytical Laboratory Group received 24 sample(s) on 2/1/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia'.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402015

Date: 2/12/2024

CLIENT: Springfield School District #19

Project: Springfield High School Gym

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402015
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Gym
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402015-001	Client Sample ID	5602000-017BF		Collection Date: 2/1/2024 5:45:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.42	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402015-002	Client Sample ID	5602000-018BF		Collection Date: 2/1/2024 5:43:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402015-003	Client Sample ID	5602000-019BF		Collection Date: 2/1/2024 5:43:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402015-004	Client Sample ID	5602000-020BF		Collection Date: 2/1/2024 5:44:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402015-005	Client Sample ID	5602000-021SF		Collection Date: 2/1/2024 5:47:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402015-006	Client Sample ID	5602000-023DW		Collection Date: 2/1/2024 5:50:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.22	15.0	2.00		ppb	2/5/2024 6:24:00 PM	AS

Lab ID: 2402015-007		Client Sample ID 5602000-024BF		Collection Date: 2/1/2024 5:52:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/7/2024 5:36:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402015
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Gym
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402015-008	Client Sample ID	5602000-025BF		Collection Date: 2/1/2024 5:55:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.45	15.0	2.00		ppb	2/7/2024 5:36:00 PM	AS

Lab ID: 2402015-009	Client Sample ID	5602000-026BF		Collection Date: 2/1/2024 5:56:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/7/2024 5:36:00 PM	AS

Lab ID: 2402015-010	Client Sample ID	5602000-027BF		Collection Date: 2/1/2024 5:57:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/7/2024 5:36:00 PM	AS

Lab ID: 2402015-011	Client Sample ID	5602000-028BF		Collection Date: 2/1/2024 5:54:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/7/2024 5:36:00 PM	AS

Lab ID: 2402015-012	Client Sample ID 5602000-029DW	Collection Date: 2/1/2024 5:59:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.63	15.0	2.00		ppb	2/7/2024 5:36:00 PM	AS

Lab ID: 2402015-013	Client Sample ID	5602000-030DW		Collection Date: 2/1/2024 5:59:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/7/2024 5:36:00 PM	AS

Lab ID: 2402015-014	Client Sample ID	5602000-031SF		Collection Date: 2/1/2024 6:01:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.39	15.0	2.00		ppb	2/7/2024 5:36:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402015
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Gym
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402015-015	Client Sample ID	5602000-032DW		Collection Date: 2/1/2024 6:02:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402015-016	Client Sample ID	5602000-033WB		Collection Date: 2/1/2024 6:03:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402015-017	Client Sample ID	5602000-034BF		Collection Date: 2/1/2024 6:04:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402015-018	Client Sample ID 5602000-035BF	Collection Date: 2/1/2024 6:06:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.3	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402015-019	Client Sample ID 5602000-036BF	Collection Date: 2/1/2024 6:07:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.59	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402015-020	Client Sample ID	5602000-038BF		Collection Date: 2/1/2024 6:10:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.6	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402015-021	Client Sample ID	5602000-039BF		Collection Date: 2/1/2024 6:11:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.49	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402015
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Gym
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402015-022	Client Sample ID	5602000-040BF		Collection Date: 2/1/2024 6:12:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.28	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402015-023	Client Sample ID	5602000-042DW		Collection Date: 2/1/2024 6:14:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402015-024	Client Sample ID	5602000-043DW		Collection Date: 2/1/2024 6:15:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.11	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402015

Date: 2/12/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402015

12-Feb-24

Client: Springfield School District #19

Project: Springfield High School Gym

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402015-001A	5602000-017BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402015-002A	5602000-018BF			Lead	A
	2402015-003A	5602000-019BF			Lead	A
	2402015-004A	5602000-020BF			Lead	A
	2402015-005A	5602000-021SF			Lead	A
	2402015-006A	5602000-023DW			Lead	A
	2402015-007A	5602000-024BF			Lead	A
	2402015-008A	5602000-025BF			Lead	A
	2402015-009A	5602000-026BF			Lead	A
	2402015-010A	5602000-027BF			Lead	A
	2402015-011A	5602000-028BF			Lead	A
	2402015-012A	5602000-029DW			Lead	A
	2402015-013A	5602000-030DW			Lead	A
	2402015-014A	5602000-031SF			Lead	A
	2402015-015A	5602000-032DW			Lead	A
	2402015-016A	5602000-033WB			Lead	A
	2402015-017A	5602000-034BF			Lead	A
	2402015-018A	5602000-035BF			Lead	A
	2402015-019A	5602000-036BF			Lead	A
	2402015-020A	5602000-038BF			Lead	A
	2402015-021A	5602000-039BF			Lead	A
	2402015-022A	5602000-040BF			Lead	A
	2402015-023A	5602000-042DW			Lead	A
	2402015-024A	5602000-043DW			Lead	A

ACCRED
ORELAP A Accredited



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School GYM	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000- 017BF	DW/Grab	2/1	0545	Lead	P	1		NA	001A
5602000- 018BF	DW/Grab	2/1	0543	Lead	P	1			002A
5602000- 019BF	DW/Grab	2/1	0543	Lead	P	1			003A
5602000- 020BF	DW/Grab	2/1	0544	Lead	P	1			004A
5602000- 021SF	DW/Grab	2/1	0547	Lead	P	1			005A
5602000- 023DW	DW/Grab	2/1	0550	Lead	P	1			006A
5602000- 024BF	DW/Grab	2/1	0552	Lead	P	1			007A
5602000- 025BF	DW/Grab	2/1	0555	Lead	P	1			008A
5602000- 026BF	DW/Grab	2/1	0556	Lead	P	1			009A
5602000- 027BF	DW/Grab	2/1	0557	Lead	P	1		V	010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
REPORT	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	2/1/24	1030				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	2/1/24	10:30	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FMChecked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: <u>terry.rutledge@springfield.k12.or.us</u>	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School GYM	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-028BF	DW/Grab	2/1	0554	Lead	P	1		NA	011A
5602000-029DW	DW/Grab	2/1	0559	Lead	P	1			012A
5602000-030DW	DW/Grab	2/1	0559	Lead	P	1			013A
5602000-031SF*SF	DW/Grab	2/1	0601	Lead	P	1			014A
5602000-032DW	DW/Grab	2/1	0602	Lead	P	1			015A
5602000-033WB	DW/Grab	2/1	0603	Lead	P	1			016A
5602000-034BF	DW/Grab	2/1	0604	Lead	P	1			017A
5602000-035BF	DW/Grab	2/1	0606	Lead	P	1			018A
5602000-036BF	DW/Grab	2/1	0607	Lead	P	1			019A
5602000-038BF	DW/Grab	2/1	0610	Lead	P	1		V	020A

Notes: *Per bottle and Veronica. FM 2/1/24	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH	Shipped Via: <u>Veronica Arciga</u>	Refrigerated Ice ☐ None ☒	
Relinquished by: <u>Veronica Arciga</u>	Date <u>2/1/24</u>	Time <u>1030</u>	Received by:
Relinquished by:	Date	Time	Received by:
Relinquished by:	Date	Time	Received by Laboratory: <u>[Signature]</u>
	Date	Time	Date <u>2/1/24</u>
			Time <u>10:30</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: <u>terry.rutledge@springfield.k12.or.us</u>		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield High School GYM		Sampler Name: <u>Veronica Arciga</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-039 BF	DW/Grab	2/1	0611	Lead	P	1		NA	021A
5602000-040 BF	DW/Grab	2/1	0612	Lead	P	1			022A
5602000-042 DW	^{upper} DW/Grab	2/1	0614	Lead	P	1			023A
5602000-043 DW	^{lower} DW/Grab	2/1	0615	Lead	P	1			024A
5602000-	DW/Grab	/	/	Lead	P	1			
5602000-	DW/Grab	/	/	Lead	P	1			
5602000-	DW/Grab	/	/	Lead	P	1			
5602000-	DW/Grab	/	/	Lead	P	1			
5602000-	DW/Grab	/	/	Lead	P	1			
5602000-	DW/Grab	/	/	Lead	P	1			
5602000-	DW/Grab	/	/	Lead	P	1			

Notes: <u>Written over/corrected by client. FM 2/1/24</u> <u>*** Samples not relinquished; crossed out by lab. FM 2/1/24</u>	PAID		Preservation Check				
	Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC						
	CK						
	Cash						
REPORT							
Mail							
Email							
Fax							
Pickup							

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica</u>		Ice <u>None</u>	

Relinquished by:	Date	Time	Received by:	Date	Time
<u>Veronica Arciga</u>	<u>2/1/24</u>	<u>1030</u>			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>[Signature]</u>	<u>2/1/24</u>	<u>10:30</u>



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

February 12, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield High School Wood Autoshop

Order No.: 2402018

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/1/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia'.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402018

Date: 2/12/2024

CLIENT: Springfield School District #19
Project: Springfield High School Wood Autoshop

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402018
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Wood Autoshop
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402018-001	Client Sample ID	5602000-044CF		Collection Date: 2/1/2024 6:23:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.74	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-002	Client Sample ID	5602000-045DW		Collection Date: 2/1/2024 6:24:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-003	Client Sample ID	5602000-046BF		Collection Date: 2/1/2024 6:25:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-004	Client Sample ID	5602000-047BF		Collection Date: 2/1/2024 6:26:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-005	Client Sample ID 5602000-048CF	Collection Date: 2/1/2024 6:28:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.55	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-006	Client Sample ID 5602000-049DW	Collection Date: 2/1/2024 6:29:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.69	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-007	Client Sample ID	5602000-050DW		Collection Date: 2/1/2024 6:30:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402018
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Wood Autoshop
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402018-008	Client Sample ID	5602000-051WB		Collection Date: 2/1/2024 6:31:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-009	Client Sample ID	5602000-052BF		Collection Date: 2/1/2024 6:32:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-010	Client Sample ID	5602000-053BF		Collection Date: 2/1/2024 6:33:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.67	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-011	Client Sample ID	5602000-054CF		Collection Date: 2/1/2024 6:34:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-012	Client Sample ID	5602000-055CF		Collection Date: 2/1/2024 6:38:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.95	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-013	Client Sample ID 5602000-056CF	Collection Date: 2/1/2024 6:40:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	26.3	15.0	4.00	*	ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-014	Client Sample ID	5602000-057DW		Collection Date: 2/1/2024 6:44:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	10.4	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402018
CLIENT: Springfield School District #19
Location:
Project: Springfield High School Wood Autoshop
Sample Source:

Received Date: 2/1/2024 10:30:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402018-015	Client Sample ID	5602000-058CF		Collection Date: 2/1/2024 6:45:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.87	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-016	Client Sample ID	5602000-059CF		Collection Date: 2/1/2024 6:46:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-017	Client Sample ID	5602000-060CF		Collection Date: 2/1/2024 6:47:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.76	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-018	Client Sample ID	5602000-061CF		Collection Date: 2/1/2024 6:48:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 5:25:00 PM	AS

Lab ID: 2402018-019	Client Sample ID 5602000-062BF	Collection Date: 2/1/2024 6:49:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.94	15.0	2.00		ppb	2/9/2024 2:07:00 PM	AS

Lab ID: 2402018-020	Client Sample ID 5602000-063CF	Collection Date: 2/1/2024 6:50:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/9/2024 2:07:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402018

Date: 2/12/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2402018

12-Feb-24

Client: Springfield School District #19
Project: Springfield High School Wood Autoshop

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402018-001A	5602000-044CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402018-002A	5602000-045DW			Lead	A
	2402018-003A	5602000-046BF			Lead	A
	2402018-004A	5602000-047BF			Lead	A
	2402018-005A	5602000-048CF			Lead	A
	2402018-006A	5602000-049DW			Lead	A
	2402018-007A	5602000-050DW			Lead	A
	2402018-008A	5602000-051WB			Lead	A
	2402018-009A	5602000-052BF			Lead	A
	2402018-010A	5602000-053BF			Lead	A
	2402018-011A	5602000-054CF			Lead	A
	2402018-012A	5602000-055CF			Lead	A
	2402018-013A	5602000-056CF			Lead	A
	2402018-014A	5602000-057DW			Lead	A
	2402018-015A	5602000-058CF			Lead	A
	2402018-016A	5602000-059CF			Lead	A
	2402018-017A	5602000-060CF			Lead	A
	2402018-018A	5602000-061CF			Lead	A
	2402018-019A	5602000-062BF			Lead	A
	2402018-020A	5602000-063CF			Lead	A



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: BP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield High School	WOODSHOP Small engine Autoshop	Sampler Name: <u>Veronica Arciga</u> **	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000- 044 CF	DW/Grab	2/1	0623	Lead	P	1		NA	001A
5602000- 045 DW	DW/Grab	2/1 *	0624	Lead	P	1			002A
5602000- 046 BF	DW/Grab	2/1	0625	Lead	P	1			003A
5602000- 047 BF	DW/Grab	2/1	0626	Lead	P	1			004A
5602000- 048 CF	DW/Grab	2/1	0628	Lead	P	1			005A
5602000- 049 DW	DW/Grab	2/1	0629	Lead	P	1			006A
5602000- 050 DW	DW/Grab	2/1	0630	Lead	P	1			007A
5602000- 051 WB	DW/Grab	2/1 *	0631	Lead	P	1			008A
5602000- 052 BF	DW/Grab	2/1	0632	Lead	P	1			009A
5602000- 053 BF	DW/Grab	2/1	0633	Lead	P	1		✓	010A

Notes: * Written over/corrected by client. FM 2/1/24 ** Per Veronica. FM 2/1/24	PAID		Preservation Check				
	Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC						
	CK						
	Cash						
		REPORT					
		Mail					
		Email					
		Fax					
		Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice <u>None</u>	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	2/1/24	1030				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	2/1/24	10:30	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

FM

RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield High School <small>Auto Shop Industrial Arts</small>		Sampler Name: <u>Veronica Arciga</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-054CF	DW/Grab	2/1	0634	Lead	P	1		NA	011A
5602000-055CF	DW/Grab	2/1	0638	Lead	P	1			012A
5602000-056CF	DW/Grab	2/1	0640	Lead	P	1			013A
5602000-057DW	DW/Grab	2/1	0644	Lead	P	1			014A
5602000-058CF	DW/Grab	2/1	0645	Lead	P	1			015A
5602000-059CF	DW/Grab	2/1	0646	Lead	P	1			016A
5602000-060CF	DW/Grab	2/1	0647	Lead	P	1			017A
5602000-061CF	DW/Grab	2/1	0648	Lead	P	1			018A
5602000-062BF	DW/Grab	2/1	0649	Lead	P	1			019A
5602000-063CF	DW/Grab	2/1	0650	Lead	P	1		✓	020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
☒ NORMAL	☐ RUSH	<u>Veronica Arciga</u>		Ice	☒ None
Relinquished by:	Date	Time	Received by:	Date	Time
<u>Veronica Arciga</u>	<u>2/1/24</u>	<u>1030</u>			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>[Signature]</u>	<u>2/1/24</u>	<u>10:30</u>



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

February 20, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield High School

Order No.: 2402076

Dear Terry Rutledge:

Analytical Laboratory Group received 30 sample(s) on 2/2/2024 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402076

Date: 2/20/2024

CLIENT: Springfield School District #19

Project: Springfield High School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402076
CLIENT: Springfield School District #19
Location:
Project: Springfield High School
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402076-001	Client Sample ID 5602000-145CF	Collection Date: 2/2/2024 6:22:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	108	15.0	20.0	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-002	Client Sample ID 5602000-146CF	Collection Date: 2/2/2024 6:23:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-003	Client Sample ID 5602000-147CF	Collection Date: 2/2/2024 6:24:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.20	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-004	Client Sample ID 5602000-148CF	Collection Date: 2/2/2024 6:25:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.87	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-005	Client Sample ID 5602000-149CF	Collection Date: 2/2/2024 6:26:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	12.6	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-006	Client Sample ID 5602000-150CF	Collection Date: 2/2/2024 6:30:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	35.6	15.0	4.00	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-007	Client Sample ID 5602000-152CF	Collection Date: 2/2/2024 6:39:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.38	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits

WO#: 2402076
CLIENT: Springfield School District #19
Location:
Project: Springfield High School
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402076-008	Client Sample ID 5602000-153CF	Collection Date: 2/2/2024 6:40:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.95	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-009	Client Sample ID 5602000-154CF	Collection Date: 2/2/2024 6:32:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	113	15.0	20.0	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-010	Client Sample ID 5602000-155CF	Collection Date: 2/2/2024 6:32:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	41.0	15.0	8.00	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-011	Client Sample ID 5602000-160CF	Collection Date: 2/2/2024 6:35:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	62.8	15.0	10.0	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-012	Client Sample ID 5602000-161CF	Collection Date: 2/2/2024 6:36:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	10.6	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-013	Client Sample ID 5602000-162CF	Collection Date: 2/2/2024 6:40:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	92.1	15.0	20.0	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-014	Client Sample ID 5602000-163CF	Collection Date: 2/2/2024 6:41:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	59.4	15.0	8.00	*	ppb	2/18/2024 11:52:00 AM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits

WO#: 2402076
CLIENT: Springfield School District #19
Location:
Project: Springfield High School
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402076-015	Client Sample ID 5602000-164CF	Collection Date: 2/2/2024 6:42:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	69.5	15.0	10.0	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-016	Client Sample ID 5602000-165CF	Collection Date: 2/2/2024 6:43:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	33.6	15.0	4.00	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-017	Client Sample ID 5602000-166CF	Collection Date: 2/2/2024 6:44:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	72.6	15.0	8.00	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-018	Client Sample ID 5602000-167CF	Collection Date: 2/2/2024 6:45:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	38.2	15.0	8.00	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-019	Client Sample ID 5602000-168CF	Collection Date: 2/2/2024 6:46:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	45.5	15.0	8.00	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-020	Client Sample ID 5602000-169CF	Collection Date: 2/2/2024 6:47:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	51.0	15.0	8.00	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-021	Client Sample ID 5602000-170CF	Collection Date: 2/2/2024 6:49:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	32.2	15.0	8.00	*	ppb	2/18/2024 11:52:00 AM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2402076
CLIENT: Springfield School District #19
Location:
Project: Springfield High School
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402076-022	Client Sample ID 5602000-171CF	Collection Date: 2/2/2024 6:50:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	241	15.0	40.0	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-023	Client Sample ID 5602000-172BF	Collection Date: 2/2/2024 6:51:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-024	Client Sample ID 5602000-173DW	Collection Date: 2/2/2024 6:52:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.43	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-025	Client Sample ID 5602000-174DW	Collection Date: 2/2/2024 6:53:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.82	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-026	Client Sample ID 5602000-175BF	Collection Date: 2/2/2024 6:54:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-027	Client Sample ID 5602000-176SF	Collection Date: 2/2/2024 6:04:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	26.3	15.0	4.00	*	ppb	2/18/2024 11:52:00 AM	KG

Lab ID: 2402076-028	Client Sample ID 5602000-041BF	Collection Date: 2/2/2024 7:40:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	33.4	15.0	10.0	*	ppb	2/18/2024 11:52:00 AM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2402076
CLIENT: Springfield School District #19
Location:
Project: Springfield High School
Sample Source:

Received Date: 2/2/2024 11:23:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402076-029	Client Sample ID 5602000-154.5CF	Collection Date: 2/2/2024 6:33:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	28.5	15.0	4.00	*	ppb	2/19/2024 4:00:00 PM	AS

Lab ID: 2402076-030	Client Sample ID 5602000-131.5CF	Collection Date: 2/2/2024 6:12:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	177	15.0	32.0	*	ppb	2/18/2024 11:52:00 AM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402076

Date: 2/20/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402076

20-Feb-24

Client: Springfield School District #19

Project: Springfield High School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402076-001A	5602000-145CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402076-002A	5602000-146CF			Lead	A
	2402076-003A	5602000-147CF			Lead	A
	2402076-004A	5602000-148CF			Lead	A
	2402076-005A	5602000-149CF			Lead	A
	2402076-006A	5602000-150CF			Lead	A
	2402076-007A	5602000-152CF			Lead	A
	2402076-008A	5602000-153CF			Lead	A
	2402076-009A	5602000-154CF			Lead	A
	2402076-010A	5602000-155CF			Lead	A
	2402076-011A	5602000-160CF			Lead	A
	2402076-012A	5602000-161CF			Lead	A
	2402076-013A	5602000-162CF			Lead	A
	2402076-014A	5602000-163CF			Lead	A
	2402076-015A	5602000-164CF			Lead	A
	2402076-016A	5602000-165CF			Lead	A
	2402076-017A	5602000-166CF			Lead	A
	2402076-018A	5602000-167CF			Lead	A
	2402076-019A	5602000-168CF			Lead	A
	2402076-020A	5602000-169CF			Lead	A
	2402076-021A	5602000-170CF			Lead	A
	2402076-022A	5602000-171CF			Lead	A
	2402076-023A	5602000-172BF			Lead	A
	2402076-024A	5602000-173DW			Lead	A
	2402076-025A	5602000-174DW			Lead	A
	2402076-026A	5602000-175BF			Lead	A
	2402076-027A	5602000-176SF			Lead	A
	2402076-028A	5602000-041BF			Lead	A
	2402076-029A	5602000-154.5CF			Lead	A
	2402076-030A	5602000-131.5CF			Lead	A

ACCREDITED
ORELAP A Accredited

Original #2402076# v1

Page 9 of 12



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: MT
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		* Date	Time		Type	#	Pres	T °C	Lab ID
5602000- 145CF	DW/Grab	<u>2/2/24</u>	0622	Lead	P	1		<u>NA</u>	<u>001A</u>
5602000- 146CF	DW/Grab		0623	Lead	P	1			<u>002A</u>
5602000- 147CF	DW/Grab		0624	Lead	P	1			<u>003A</u>
5602000- 148CF	DW/Grab		0625	Lead	P	1			<u>004A</u>
5602000- 149CF	DW/Grab		0626	Lead	P	1			<u>005A</u>
5602000- 150CF	DW/Grab		0630	Lead	P	1			<u>006A</u>
5602000- 152CF	DW/Grab		0639	Lead	P	1			<u>007A</u>
5602000- 153CF	DW/Grab		0640	Lead	P	1			<u>008A</u>
5602000- 154CF	DW/Grab		0632	Lead	P	1			<u>009A</u> <u>010A</u>
5602000- 155CF	DW/Grab		0632	Lead	P	1			<u>010A</u>

Notes: <u>Per bottles. FM 2/2/24</u>	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice	<u>None</u>
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/2/24</u>	<u>1040</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	<u>2/2/24</u>	<u>11:23</u>	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: MT
RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000- 160CF	DW/Grab	2/2/24	0635	Lead	P	1		NA	011A
5602000- 161CF	DW/Grab		0636	Lead	P	1			012A
5602000- 162CF	DW/Grab		0640	Lead	P	1			013A
5602000- 163CF	DW/Grab		0641	Lead	P	1			014A
5602000- 164CF	DW/Grab		0642	Lead	P	1			015A
5602000- 165CF	DW/Grab		0643	Lead	P	1			016A
5602000- 166CF	DW/Grab		0644	Lead	P	1			017A
5602000- 167CF	DW/Grab		0645	Lead	P	1			018A
5602000- 168CF	DW/Grab		0646	Lead	P	1			019A
5602000- 169CF	DW/Grab		0647	Lead	P	1			020A

Notes: *Per bottles. FM 2/2/24

PAID

Preservation Check

Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
CC					
CK					
Cash					

REPORT

Mail
Email
Fax
Pickup

Turn Around Time Requested (Rush incurs a Surcharge):

☒ NORMAL☐ RUSH

Shipped Via:

Veronica Arciga

Refrigerated

Ice

☒ None

Relinquished by:

Veronica Arciga

Date

2/2/24

Time

1040

Received by:

Date

Time

Relinquished by:

Date

Time

Received by:

Date

Time

Relinquished by:

Date

Time

Received by Laboratory:

Date

Time

Page 1 of 12

2/2/24 11:23



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: MT
Checked: BP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield High School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5602000-170CF	DW/Grab	2/2/24	0649	Lead	P	1		NA	021A
5602000-171CF	DW/Grab		0650	Lead	P	1			022A
5602000-172BF	DW/Grab		0651	Lead	P	1			023A
5602000-173DW	DW/Grab		0652	Lead	P	1			024A
5602000-174DW	DW/Grab		0653	Lead	P	1			025A
5602000-175BF	DW/Grab		0654	Lead	P	1			026A
5602000-176SF	DW/Grab		0604	Lead	P	1			027A
5602000-041BF	DW/Grab		0740	Lead	P	1			028A
5602000-154.5CF	DW/Grab		0633	Lead	P	1			029A
5602000-131.5CF	DW/Grab		0612	Lead	P	1			030A

Notes: *Per bottles. FM 2/2/24	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	☒ None
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/2/24	1040				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/2/24	11:13	