ONTEORA
CENTRAL SCHOOL DISTRICT

Building & Grounds Department
PO Box 300, Boiceville, NY 12412
Ph. 845-657-6384 • Fax 845-657-6835
www.onteora.k12.ny.us

Facilities and Operations
Kyle Harjes
Director
kharjes@onteora.k12.ny.us
Joel Cservak
Building Maintenance Leader
jcservak@onteora.k12.ny.us
Dillon Vanleuvan
Head Custodian
dvanleuvan@onteora.k12.ny.us

A NOTICE TO PARENTS, GUARDIANS & STAFF

Onteora Middle/High School & Central Administration

2026 Lead Testing of School Drinking Water

Safe and healthy school environments can foster healthy and successful children. To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require that all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every outlet that is being used, or could potentially be used, for drinking or cooking. If lead is found at any water outlet at levels above 5 parts per billion (ppb), which is equal to 5 micrograms per liter (µg/L), the NYSDOH requires that the school to take action to reduce the exposure to lead.

What is first draw testing of school drinking water for lead?

The "on-again, off-again" nature of water use at most schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. This is why schools are required to collect a sample after the water has been sitting in the plumbing system for a certain period of time. This "first draw" sample is likely to show higher levels of lead for that outlet than what you would see if you sampled after using the water continuously. However, even if the first draw sample does not reflect what you would see with continuous usage, it is still important because it can identify outlets that have elevated lead levels.

What is being done in response to the results?

57 outlets that are used for drinking or cooking were tested in the Onteora Middle/High & Central Administration School building. Two of those outlets tested had lead levels above the (5 ppb). The two outlets have been posted with handwashing only signs, lead reduction filters have been installed and new samples where taken on June 4, 2026. Results of the retest will follow as they become available. Update: On June 29, 2026, retest lab results were received and they were below the threshold. The temporary signs were removed.

NUMBER	LOCATION	DATE SAMPLED	RESULTS	NOT APPLICABLE OUTLETS POSTED WITH HAND WASHING ONLY SIGNS
1	Room 119 Sink	5/12/2026	0.00482	
2	Girls 28 Bathroom	N/A	N/A	X
3	Girls 28 Bathroom	N/A	N/A	X
4	Girls 28 Bathroom	N/A	N/A	X
5	28 Mop Closet	N/A	N/A	X
6	Boys 28 Bathroom	N/A	N/A	X
7	Boys 28 Bathroom	N/A	N/A	X
8	28 Hall Water Fountain	5/12/2026	<0.00040	
9	28 Hall Bottle Fill	5/12/2026	<0.00040	
10	28 Single Use Bathroom	N/A	N/A	X
11	Single Use Mop Sink	N/A	N/A	X
12	Room 99 Bathroom Sink	N/A	N/A	X
13	Room 96 Sink	N/A	N/A	X
14	Room 96 Sink	N/A	N/A	X
15	Room 97 Faucet	N/A	N/A	X
16	Room 97 Faucet	N/A	N/A	X
17	Photo Lab Dev. Sink	N/A	N/A	X
18	Photo Lab Dev. Sink	N/A	N/A	X
19	Photo Lab Dev. Sink	N/A	N/A	X
20	Photo Lab Dev. Sink	N/A	N/A	X
21	Room 97 Closet	N/A	N/A	X
22	Room 97 Closet left Corner	N/A	N/A	X
23	Room 97 Sink Dark Room	N/A	N/A	X
24	Room 97 Sink Dark Room	N/A	N/A	X
25	Dark Room-Room 97 Eye Wash	N/A	N/A	X
26	Room 94 Sink	N/A	N/A	X
27	Room 94 Sink	N/A	N/A	X
28	Room 94 Sink	N/A	N/A	X
29	Room 208 Breakroom Sink	5/12/2026	0.00186	
30	Room 211 Sink	N/A	N/A	X
31	Room 211 Sink	N/A	N/A	X
32	Room 211 Sink	N/A	N/A	X
33	Room 211 Eye Wash Sink	N/A	N/A	X
34	Room 209 Office Sink	N/A	N/A	X
35	Room 206 Sink	N/A	N/A	X
36	Room 206 Sink	N/A	N/A	X
37	Room 206 Sink	N/A	N/A	X
38	Room 206 Sink	N/A	N/A	X
39	Room 206 Sink	N/A	N/A	X

40	Room 206 Sink	N/A	N/A	X
41	Room 206 Sink	N/A	N/A	X
42	Room 206 Sink	N/A	N/A	X
43	Room 206 Sink	N/A	N/A	X
44	Room 206 Sink	N/A	N/A	X
45	Room 206 Office Sink	N/A	N/A	X
46	Room 204 Office Sink	N/A	N/A	X
47	Room 204 Office Sink	N/A	N/A	X
48	Room 204 Eye Wash	N/A	N/A	X
49	Room 204 Teacher Island Sink	N/A	N/A	X
50	Room 204 Teacher Island Sink	N/A	N/A	X
51	Room 204 Island Sink	N/A	N/A	X
52	Room 204 Island Sink	N/A	N/A	X
53	Room 204 Island Sink	N/A	N/A	X
54	Room 204 Island Sink	N/A	N/A	X
55	Room 204 Island Sink	N/A	N/A	X
56	Room 204 Island Sink	N/A	N/A	X
57	Room 204 Island Sink	N/A	N/A	X
58	Room 204 Island Sink	N/A	N/A	X
59	Room 204 Island Sink	N/A	N/A	X
60	Room 204 Island Sink	N/A	N/A	X
61	Room 204 Island Sink	N/A	N/A	X
62	Room 204 Island Sink	N/A	N/A	X
63	Room 204 Island Sink	N/A	N/A	X
64	Room 204 Island Sink	N/A	N/A	X
65	Room 209 Teacher Sink	N/A	N/A	X
66	Room 209 Teacher Sink	N/A	N/A	X
67	Room 209 Eye Wash	N/A	N/A	X
68	Room 209 Island Sink	N/A	N/A	X
69	Room 209 Island Sink	N/A	N/A	X
70	Room 209 Island Sink	N/A	N/A	X
71	Room 209 Island Sink	N/A	N/A	X
72	Room 209 Island Sink	N/A	N/A	X
73	Room 209 Island Sink	N/A	N/A	X
74	Room 209 Island Sink	N/A	N/A	X
75	Room 209 Island Sink	N/A	N/A	X
76	Room 209 Island Sink	N/A	N/A	X
77	Room 209 Island Sink	N/A	N/A	X
78	Room 209 Island Sink	N/A	N/A	X
79	Science Girls Bathroom Sink	N/A	N/A	X
80	Science Girls Bathroom Sink	N/A	N/A	X
81	Science Girls Bathroom Sink	N/A	N/A	X
82	Science Water Fountain Bottle Filler	5/12/2026	<0.00040	
83	Science Water Fountain	5/12/226	<0.00040	

84	Science Boys Bathroom Closet	N/A	N/A	X
85	Science Boys Bathroom	N/A	N/A	X
86	Science Boys Bathroom	N/A	N/A	X
87	Science Boys Bathroom	N/A	N/A	X
88	Room 202 Island Sinks	N/A	N/A	X
89	Room 202 Island Sinks	N/A	N/A	X
90	Room 202 Island Sinks	N/A	N/A	X
91	Room 202 Island Sinks	N/A	N/A	X
92	Room 202 Island Sinks	N/A	N/A	X
93	Room 202 Island Sinks	N/A	N/A	X
94	Room 202 Island Sinks	N/A	N/A	X
95	Room 202 Island Sinks	N/A	N/A	X
96	Room 202 Island Sinks	N/A	N/A	X
97	Room 202 Island Sinks	N/A	N/A	X
98	Room 202 Island Sinks	N/A	N/A	X
99	Room 202 Emergency Shower	N/A	N/A	X
100	Room 202 Eye Wash	N/A	N/A	X
101	Room 202 Teacher Island	N/A	N/A	X
102	Room 202 Island Sink	N/A	N/A	X
103	Room 202 Left Hood	N/A	N/A	X
104	Room 202 Right Hood	N/A	N/A	X
105	Room 202 Office Sink	N/A	N/A	X
106	Room 200 Office Sink	N/A	N/A	X
107	Room 200 Shower Hose	N/A	N/A	X
108	Room 200 Island Sink	N/A	N/A	X
108	Room 200 Island Sink	N/A	N/A	X
110	Room 200 Island Sink	N/A	N/A	X
111	Room 200 Island Sink	N/A	N/A	X
112	Room 200 Island Sink	N/A	N/A	X
113	Room 200 Island Sink	N/A	N/A	X
114	Room 200 Island Sink	N/A	N/A	X
115	Room 200 Island Sink	N/A	N/A	X
116	Room 200 Island Sink	N/A	N/A	X
117	Room 200 Island Sink	N/A	N/A	X
118	Room 200 Island Sink	N/A	N/A	X
119	Room 200 Island Sink	N/A	N/A	X
120	Room 200 Left Hood	N/A	N/A	X
121	Room 200 Emergency Shower	N/A	N/A	X
122	Room 200 Teacher Island Sink	N/A	N/A	X
123	Room 200 Eye Wash	N/A	N/A	X
124	Room 200 Right Hood	N/A	N/A	X
125	Room 200 Wall Sink	N/A	N/A	X
126	Room 200 Corner Wall Mount	N/A	N/A	X
127	Room 203 Hood	N/A	N/A	X
128	203 Teacher Island	N/A	N/A	X

129	Room 203 Wall Sink	N/A	N/A	X
130	Room 203 Eye Wash	N/A	N/A	X
131	Room 203 Shower	N/A	N/A	X
132	Room 203 Island Sink	N/A	N/A	X
133	Room 203 Island Sink	N/A	N/A	X
134	Room 203 Island Sink	N/A	N/A	X
135	Room 203 Island Sink	N/A	N/A	X
136	Room 203 Island Sink	N/A	N/A	X
137	Room 203 Island Sink	N/A	N/A	X
138	Room 203 Island Sink	N/A	N/A	X
139	Room 203 Island Sink	N/A	N/A	X
140	Room 203 Island Sink	N/A	N/A	X
141	Room 203 Island Sink	N/A	N/A	X
142	Room 203 Island Sink	N/A	N/A	X
143	Room 203 Island Sink	N/A	N/A	X
144	Student Single Use Bathroom	N/A	N/A	X
145	Staff Single Use Bathroom	N/A	N/A	X
146	Math Hall Girls Bathroom Sink	N/A	N/A	X
147	Math Hall Girls Bathroom Sink	N/A	N/A	X
148	Math Hall Girls Bathroom Sink	N/A	N/A	X
149	Math Hall Girls Bathroom Sink	N/A	N/A	X
150	Math Hall Bottle Fill	5/12/2026	<0.00040	
151	Math Hall Water Fountain	5/12/2026	<0.00040	
152	Math Boys Bathroom Sink	N/A	N/A	X
153	Math Boys Bathroom Sink	N/A	N/A	X
154	Math Boys Bathroom Sink	N/A	N/A	X
155	Room 165 Sink	N/A	N/A	X
156	Room 163 Washing Machine	N/A	N/A	N/A
157	Room 163 Sink	5/12/2026	0.00155	
158	Room 163 Sink	5/12/2026	0.00194	
159	Room 163 Sink	5/12/2026	0.00641	Temporary signs installed
159 Retest	Room 163 Retest	6/04/2026	0.0023	Sign removed on 6/29/2026
160	Math Mop Closet Sink	N/A	N/A	X
161	Math Single Use Bathroom	N/A	N/A	X
162	Room 161 Eye Wash	N/A	N/A	X
163	Room 161 Teacher Island Sink	N/A	N/A	X
164	Room 161 Closet Sink	N/A	N/A	X
165	Room 161 Island Sink	N/A	N/A	X
166	Room 161 Island Sink	N/A	N/A	X
167	Room 161 Island Sink	N/A	N/A	X
168	Room 161 Island Sink	N/A	N/A	X
169	Room161 Island Sink	N/A	N/A	X
170	Room 161 Island Sink	N/A	N/A	X
171	Room 161 Office Sink	N/A	N/A	X
172	Room 160 Eye Wash	N/A	N/A	X

173	Room 160 Teacher Island Sink	N/A	N/A	X
174	Room 160 Sink	N/A	N/A	X
175	Room 160 Sink	N/A	N/A	X
176	Room 160 Closet Sink	N/A	N/A	X
177	Room 159 Island Sink	N/A	N/A	X
178	Upper Middle School Girls Bathroom Sink	N/A	N/A	X
179	Upper Middle School Girls Bathroom Sink	N/A	N/A	X
180	Upper Middle School Girls Bathroom Sink	N/A	N/A	X
181	Upper Middle School Mop Closet	N/A	N/A	X
182	Upper Middle School Boys Bathroom Sink	N/A	N/A	X
183	Upper Middle School Boys Bathroom Sink	N/A	N/A	X
184	Upper Middle School Breakroom	5/12/2026	0.00236	
185	Upper Middle School Bottle Fill	5/12/2026	<0.00040	
186	Upper Middle School Water Fountain	5/12/2026	<0.00040	
187	Guidance Bathroom Sink	N/A	N/A	X
188	Room 145 Sink	5/12/2026	<0.00040	
189	Room 145 Sink	5/12/2026	<0.00040	
190	Room 145 Sink	5/12/2026	0.000600	
191	Room 145 Washer	N/A	N/A	N/A
192	Room 145 Sink	5/12/2026	0.000883	
193	Lower Middle School Bottle Fill	5/12/2026	<0.00040	
194	Lower Middle School Water Fountain	5/12/2026	<0.00040	
195	Lower Middle School Mop Closet	N/A	N/A	X
196	Lower Middle School Boys Bathroom Sink	N/A	N/A	X
197	Lower Middle School Boys Bathroom Sink	N/A	N/A	X
198	Lower Middle Single Use Bathroom Sink	N/A	N/A	X
199	Room 140 Sink	N/A	N/A	X
200	Room 140 Sink	N/A	N/A	X
201	Room 140 Sink	N/A	N/A	X
202	Kitchen Custodial Closet	N/A	N/A	X

203	Kitchen Bathroom Sink	N/A	N/A	X
204	Kitchen Hand Wash Sink	5/12/2026	<0.00040	
205	Kitchen Sink Dish Washing Sink Right	5/12/2026	<0.00040	
205A	Sprayer Kitchen Dish Washing Sink Right	5/12/2026	<0.00040	
206	Kitchen Sink Dish Washing Sink Left	5/12/2026	<0.00040	
206A	Sprayer Kitchen Dish Washing Sink Left	5/12/2026	<0.0004.0	
207	Kitchen Hose Reel	5/12/2026	0.000640	
208	Kitchen Vegetable Sink	5/12/2026	0.00310	
209	Kitchen Rice Pot Left	5/12/2026	<0.0004.0	
210	Kitchen Rice Pot Right	5/12/2026	0.00102	
211	Kitchen Tray Rinse Sprayer	5/12/2026	0.00186	
212	Kitchen Head Cook Sink	5/12/2026	0.00186	
213	Kitchen Ice Machine	5/12/2026	<0.00040	
214	Kitchen Sink Left Serving Area	5/12/2026	0.00122	
215	Kitchen Sink Right Serving Area	5/12/2026	0.00168	
216	Girls Café Bathroom Sink	N/A	N/A	X
217	Girls Café Bathroom Sink	N/A	N/A	X
218	Café Water Fountain	5/12/2026	<0.00040	
219	Café Bottle Fill	5/12/2026	<0.00040	
220	Boys Café Bathroom Sink	N/A	N/A	X
221	Boys Café Bathroom Sink	N/A	N/A	X
222	Middle School Office Girls Locker Room Bathroom Sink	N/A	N/A	X
223	Middle School Office Girls Locker Room Shower	N/A	N/A	X
224	MS Girls Locker Room Sink 1	N/A	N/A	X
225	MS Girls Locker Room Sink 2	N/A	N/A	X
226	MS Girls Locker Room Shower	N/A	N/A	X
227	HS Girls Locker Room Sink 1	N/A	N/A	X
228	HS Girls Locker Room Sink 2	N/A	N/A	X
229	HS Girls Locker Room Shower Handicapped	N/A	N/A	X
230	HS Girls Locker Room Shower	N/A	N/A	X
231	HS Girls Locker Room Slop Sink	N/A	N/A	X
232	Fitness Room Ice Machine	5/12/2026	<0.00040	
233	Bottle Fill Fitness Center	5/12/2026	<0.00040	
234	Water Fountain Bubbler	5/12/0226	<0.00040	

	Fitness Center			
235	HS Gym Girls Foyer BR Sink 1	N/A	N/A	X
236	HS Gym Girls Foyer BR Sink 2	N/A	N/A	X
237	HS Gym Boys Foyer BR Sink 1	N/A	N/A	X
238	HS Gym Boys Foyer BR Sink 2	N/A	N/A	X
239	HS Gym Foyer Water Fountain Left	5/12/2026	<0.00040	
240	HS Gym Foyer Bottle Fill	5/12/2026	<0.00040	
241	HS Gym Foyer Water Fountain Right	5/12/2026	<0.00040	
242	HS Boys Locker Room Sink	N/A	N/A	X
243	HS Boys Locker Room Shower Left	N/A	N/A	X
244	HS Boys Locker Room Shower Right	N/A	N/A	X
245	HS Boys Locker Room Slop Sink	N/A	N/A	X
246	MS Boys Lock Room Sink Right	N/A	N/A	X
247	MS Boys Locker Room Sink Left	N/A	N/A	X
248	MS Boys Locker Room Shower	N/A	N/A	X
249	Main Hall Men’s Bathroom Sink Left	N/A	N/A	X
250	Main Hall Men’s Bathroom Sink Right	N/A	N/A	X
251	Main Hall Women’s BR Sink Left	N/A	N/A	X
252	Main Hall Women’s BR Sink Right	N/A	N/A	X
253	Main Hall Bottle Fill	5/12/2026	<0.00040	
254	Main Hall Water Fountain	5/12/2026	<0.00040	
255	Athletic Trainers Office Tub	N/A	N/A	X
256	Athletic Trainers Office Old Sink	N/A	N/A	X
257	Athletic Directors Bathroom Sink	N/A	N/A	X
258	Main Hall Break Room Sink	5/12/2026	0.00638	Temporary
258 Retest	Main Hall Break Room Retest	6/01/2026	0.0039	Sign removed on 6/29/26
259	Main Office Bathroom Sink	N/A	N/A	X

260	HS Principal Bathroom Sink	N/A	N/A	X
261	Conference Room Bathroom Sink	N/A	N/A	X
262	Music Room 122 Office 2 Sink	N/A	N/A	X
263	Music Room 122 Office 1 Sink	N/A	N/A	X
264	MS Nurse Bathroom Sink	N/A	N/A	X
265	MS Nurse Sink	5/12/2026	0.00167	
266	HS Nurse Bathroom Sink	N/A	N/A	X
267	HS Exam Nurse Sink	5/12/2026	<0.00040	
268	Laundry Room Washing Machine	N/A	N/A	X
269	Team Room Bradley Wash Fountain	N/A	N/A	X
270	Team Room Shower 1	N/A	N/A	X
271	Team Room Shower 2	N/A	N/A	X
272	Team Room Shower 3	N/A	N/A	X
273	Team Room Shower 4	N/A	N/A	X
274	Team Room Shower 5	N/A	N/A	X
275	Team Room Shower 6	N/A	N/A	X
276	Team Room Shower 7	N/A	N/A	X
277	Team Room Shower 8	N/A	N/A	X
278	Team Room Spigot In Shower	N/A	N/A	X
279	Team Room Coach Shower	N/A	N/A	X
280	Basement Spigot	N/A	N/A	X
281	Custodial Breakroom Sink	N/A	N/A	X
282	Wash Bay Spigot 1	N/A	N/A	X
283	Wash Bay Spigot 2	N/A	N/A	X
284	Wash Bay Spigot 3	N/A	N/A	X
285	Wash Bay Sink	N/A	N/A	X
286	Wash Bay Washing Machine	N/A	N/A	N/A
287	Central Ice Machine	5/12/2026	<0.00040	
288	Warehouse Bathroom Sink	5/12/2026	0.00215	
289	Warehouse Eyewash	N/A	N/A	X
290	Warehouse Overhead PVC 1	N/A	N/A	N/A
291	Warehouse Overhead PVC 2	N/A	N/A	N/A
292	Filtration System 1	N/A	N/A	N/A
293	Filtration System 2	N/A	N/A	N/A
294	Filtration System 3	N/A	N/A	N/A
295	Filtration System 4	N/A	N/A	N/A
296	Column Spigot	N/A	N/A	X
297	Water Holding Tank 3	N/A	N/A	N/A
298	Water Holding Tank 2	N/A	N/A	N/A
299	Water Holding Tank 1	N/A	N/A	N/A
300	Water Spigot Drain For Outside	N/A	N/A	X

301	Central (Back) Bathroom Sink	N/A	N/A	X
302	Central Breakroom Sink	5/12/2026	0.00184	
303	Victoria's Bathroom Sink	N/A	N/A	X
304	Central Water Fountain Bottle Fill	5/12/2026	<0.00040	
305	Central Water Fountain Bubbler	5/12/2026	<0.00040	
306	Spigot Central Sewer Pump Front Closet	N/A	N/A	
307	Central (Front) Bathroom Sink	N/A	N/A	X
308	Room 45 Sink Spigot 1	N/A	N/A	X
309	Room 45 Sink Spigot 2	N/A	N/A	X
310	Room 45 Sink Spigot 3	N/A	N/A	X
311	Room 44 Eye Wash	N/A	N/A	X
312	Room 44 Sink	N/A	N/A	X
313	B&G Shop Ceiling Hose	N/A	N/A	X
314	B&G Fridge Ice	5/12/2026	<0.00040	
315	B&G Fridge Water	5/12/2026	<0.00040	
316	B&G Water Fountain Bottle Fill	5/12/2026	<0.00040	
317	B&G Water Fountain	5/12/2026	<0.00040	
318	B&G Eyewash	N/A	N/A	X
319	B&G Breakroom Sink	N/A	N/A	X
320	B&G Breakroom Hose Spigot	N/A	N/A	X
321	B&G Bathroom Slop Sink	N/A	N/A	X
322	B&G Bathroom Sink	N/A	N/A	X
323	B&G Bathroom Spigot Behind Cabinet	N/A	N/A	
324	Outside 28 Wall Spigot By Room 118	N/A	N/A	X
325	Outside 28 Wall Spigot By Room 118	N/A	N/A	X
326	Outside 28 Wall Spigot By Room 104	N/A	N/A	X
327	Outside 94 Patio Spigot	N/A	N/A	X
328	Outside 94 Patio Spigot	N/A	N/A	X
329	Outside 172 Spigot	N/A	N/A	X
330	Outside 168 Spigot	N/A	N/A	X
331	Outside 154 Spigot	N/A	N/A	X
332	Kitchen Dock Spigot	5/12/2026	0.000523	
333	Outside By Track Spigot	N/A	N/A	X
334	Foyer Spigot	N/A	N/A	X
335	Shop Door Spigot	N/A	N/A	X
336	Central Spigot	N/A	N/A	X
337	Generator Spigot	N/A	N/A	X

338	Small Courtyard Spigot	N/A	N/A	X
339	Large Courtyard Spigot 1	N/A	N/A	X
340	Large Courtyard Spigot 2	N/A	N/A	X
341	Large Courtyard Spigot 3	N/A	N/A	X

What are the health effects of lead?

Lead is a metal that can harm children and adults when it gets into their bodies. Lead is a known neurotoxin, particularly harmful to the developing brain and nervous system of children under 6 years old. Lead can harm a young child's growth, behavior, and ability to learn. Lead exposure during pregnancy may contribute to low birth weight and developmental delays in infants. There are many sources of lead exposure in the environment, and it is important to reduce all lead exposures as much as possible. Water testing helps identify and correct possible sources of lead that contribute to exposure from drinking water.

What are the other sources of lead exposure?

Lead is a metal that has been used for centuries for many purposes, resulting in widespread distribution in the environment. Major sources of lead exposure include lead-based paint in older housing, and lead that built up over decades in soil and dust due to historical use of lead in gasoline, paint, and manufacturing. Lead can also be found in a number of consumer products, including certain types of pottery, pewter, brass fixtures, foods, plumbing materials, and cosmetics. Lead seldom occurs naturally in water supplies but drinking water could become a possible source of lead exposure if the building's plumbing contains lead. The primary source of lead exposure for most children with elevated blood-lead levels is lead-based paint.

Should your child be tested for lead?

The risk to an individual child from past exposure to elevated lead in drinking water depends on many factors; for example, a child's age, weight, amount of water consumed, and the amount of lead in the water. Children may also be exposed to other significant sources of lead including paint, soil and dust. Since blood lead testing is the only way to determine a child's blood lead level, parents should discuss their child's health history with their child's physician to determine if blood lead testing is appropriate. Pregnant women or women of childbearing age should also consider discussing this matter with their physician.

Additional Resources

For more information regarding the testing program or sampling results,

Contact Onteora School District Buildings and Grounds Department at 845-657-6384, or go to our school website: http://www.onteora.k12.ny.us

For information about lead in school drinking water, go to:

http://www.p12.nysed.gov/facplan/LeadTestinginSchoolDrinkingWater.html

For information about NYS Department of Health Lead Poisoning Prevention, go to: http://www.health.ny.gov/environmental/lead/

For more information on blood lead testing and ways to reduce your child's risk of exposure to lead, see "What Your Child's Blood Lead Test Means":

http://www.health.ny.gov/publications/2526/ (available in ten languages).