

Lead in Water Test Results Summary: Academy of Arts & Academics (A3)

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Nurse office sink (Main Building)	44401700-001NS	3/9/2023	ND	Non-Detect	[enter date]	[enter result]	[autofill]
Studio 4 Classroom Faucet 1	44401700-002CF	3/9/2023	ND	Non-Detect			
Studio 4 Classroom Faucet 2	44401700-003CF	3/9/2023	2.34	Low			
Studio 4 Classroom Faucet 3	44401700-004CF	3/9/2023	4.05	Low			
Studio 4 Classroom Faucet 4	44401700-005CF	3/9/2023	3.34	Low			
Studio 4 Classroom Faucet (Closet) 5	44401700-006CF	3/9/2023	10	High			
Bottle fill Station	44401700-007BF	3/9/2023	ND	Non-Detect			
Drinking Water fountain	44401700-008DW	3/9/2023	ND	Non-Detect			
Single Drinking water fountain	44401700-009DW	3/9/2023	ND	Non-Detect			
Mens restroom bathroom faucet 1	44401700-010BF	3/9/2023	ND	Non-Detect			
Mens restroom bathroom faucet 2	44401700-011BF	3/9/2023	ND	Non-Detect			
Mens restroom bathroom faucet 3	44401700-012BF	3/9/2023	3.66	Low			
Mens restroom bathroom faucet 4	44401700-013BF	3/9/2023	5.85	Moderate			
Womens restroom faucet 1	44401700-014BF	3/9/2023	ND	Non-Detect			
Womens restroom faucet 2	44401700-015BF	3/9/2023	ND	Non-Detect			
Womens restroom faucet 3	44401700-016BF	3/9/2023	ND	Non-Detect			
Womens restroom faucet 4	44401700-017BF	3/9/2023	ND	Non-Detect			
Studio B Staff faucet	44401700-018SF	3/9/2023	ND	Non-Detect			
Bathroom faucet (ANNEX3)	44401700-019BF	3/9/2023	ND	Non-Detect			
Wash out sink classroom faucet	44401700-020CF	3/9/2023	ND	Non-Detect			
Bathroom faucet (old coin shop)	44401700-021BF	3/9/2023	42	Action Req.	Fixture turned off	Not In Use	-
Bathroom Faucet (ANNEX 1)	44401700-022BF	3/9/2023	ND	Non-Detect			
Bathroom Faucet	44401700-023BF	3/9/2023	3.51	Low			
Staff room sink	44401700-024SF	3/9/2023	ND	Non-Detect			
BUILDING)1ST FLOOR	44401700-025DW	3/9/2023	ND	Non-Detect			
Classroom 108 classroom faucet	44401700-026CF	3/9/2023	2.15	Low			
Mens restroom bathroom faucet	44401700-027BF	3/9/2023	ND	Non-Detect			
Womens bathroom faucet	44401700-028BF	3/9/2023	ND	Non-Detect			
Drinking water fountain	44401700-029DW	3/9/2023	2.21	Low			
2nd Floor staff room sink	44401700-030SF	3/9/2023	2.26	Low			
Staffroom mens bathroom faucet	44401700-031BF	3/9/2023	3.96	Low			
Staffroom womens bathroom faucet	44401700-032BF	3/9/2023	14.6	High			

A3



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:



April 06, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2303346

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 3/9/2023 for the analyses presented in the following report.

A handwritten signature in black ink, reading 'Kimberly J. Reeve Morghan', is located below the main body of the letter.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2303346

Date: 4/6/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Date Reported: 4/6/2023

WO#: 2303346
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/9/2023 8:55:00 AM
Sampler Name Jeff Medina
Matrix: Drinking Water
Treatment:

Lab ID: 2303346-001		Client Sample ID 44401700-001NS			Collection Date: 3/8/2023 5:13:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-002	Client Sample ID	44401700-002CF			Collection Date: 3/8/2023 5:15:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-003		Client Sample ID 44401700-003CF			Collection Date: 3/8/2023 5:16:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.34	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-004	Client Sample ID	44401700-004CF		Collection Date: 3/8/2023 5:16:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.05	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-005	Client Sample ID	44401700-005CF			Collection Date: 3/8/2023 5:17:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.34	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-006	Client Sample ID	44401700-006CF			Collection Date: 3/8/2023 5:18:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	10.0	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-007	Client Sample ID	44401700-007BF			Collection Date: 3/8/2023 5:19:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 4/6/2023

WO#: 2303346
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/9/2023 8:55:00 AM
Sampler Name Jeff Medina
Matrix: Drinking Water
Treatment:

Lab ID: 2303346-008 **Client Sample ID** 44401700-008DW **Collection Date:** 3/8/2023 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-009 **Client Sample ID** 44401700-009DW **Collection Date:** 3/8/2023 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-010 **Client Sample ID** 44401700-010BF **Collection Date:** 3/8/2023 5:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-011 **Client Sample ID** 44401700-011BF **Collection Date:** 3/8/2023 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-012 **Client Sample ID** 44401700-012BF **Collection Date:** 3/8/2023 5:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.66	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-013 **Client Sample ID** 44401700-013BF **Collection Date:** 3/8/2023 5:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.85	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-014 **Client Sample ID** 44401700-014BF **Collection Date:** 3/8/2023 5:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 4/6/2023

WO#: 2303346
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/9/2023 8:55:00 AM
Sampler Name Jeff Medina
Matrix: Drinking Water
Treatment:

Lab ID: 2303346-015		Client Sample ID 44401700-015BF			Collection Date: 3/8/2023 5:24:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-016		Client Sample ID 44401700-016BF			Collection Date: 3/8/2023 5:25:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-017	Client Sample ID	44401700-017BF			Collection Date: 3/8/2023 5:25:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-018	Client Sample ID	44401700-018SF			Collection Date: 3/8/2023 5:27:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303346-019		Client Sample ID 44401700-019BF			Collection Date: 3/8/2023 5:14:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303346-020		Client Sample ID 44401700-020CF			Collection Date: 3/8/2023 5:15:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)
C Value is below Minimum Compound Limit.
H Holding times for preparation or analysis exceeded
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PQL Practical Quantitation Level or Reporting Limit

A Accredited by ORELAP
E Value above quantitation range
LOD Limit of Detection
NAR See note in Case Narrative
PL Permit Limit
R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2303346

Date: 4/6/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303346

06-Apr-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303346-001A	44401700-001NS	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303346-002A	44401700-002CF			Lead	A
	2303346-003A	44401700-003CF			Lead	A
	2303346-004A	44401700-004CF			Lead	A
	2303346-005A	44401700-005CF			Lead	A
	2303346-006A	44401700-006CF			Lead	A
	2303346-007A	44401700-007BF			Lead	A
	2303346-008A	44401700-008DW			Lead	A
	2303346-009A	44401700-009DW			Lead	A
	2303346-010A	44401700-010BF			Lead	A
	2303346-011A	44401700-011BF			Lead	A
	2303346-012A	44401700-012BF			Lead	A
	2303346-013A	44401700-013BF			Lead	A
	2303346-014A	44401700-014BF			Lead	A
	2303346-015A	44401700-015BF			Lead	A
	2303346-016A	44401700-016BF			Lead	A
	2303346-017A	44401700-017BF			Lead	A
	2303346-018A	44401700-018SF			Lead	A
	2303346-019A	44401700-019BF			Lead	A
	2303346-020A	44401700-020CF			Lead	A



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: BP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: JEFF MEDINA

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
44401700-001NS	DW/Grab	3/8/23	05:13	Lead	P	1		NA	001A
44401700-002CF	DW/Grab		05:15	Lead	P	1			002A
44401700-003CF	DW/Grab		05:16	Lead	P	1			003A
44401700-004CF	DW/Grab		05:16	Lead	P	1			004A
44401700-005CF	DW/Grab		05:17	Lead	P	1			005A
44401700-006CF	DW/Grab		05:18	Lead	P	1			006A
44401700-007BF	DW/Grab		05:19	Lead	P	1			007A
44401700-008DW	DW/Grab		05:20	Lead	P	1			008A
44401700-009DW	DW/Grab		05:20	Lead	P	1			009A
44401700-010BF	DW/Grab		05:21	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Test
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☒ None	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	3/8					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			Jaith	3/9/23	8:55	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: BP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>JEFF MEDINA</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
44401700-011BF	DW/Grab	3/8/23	05:22	Lead	P	1		NA	011A
44401700-012BF	DW/Grab		05:23	Lead	P	1			012A
44401700-013BF	DW/Grab		05:23	Lead	P	1			013A
44401700-014BF	DW/Grab		05:24	Lead	P	1			014A
44401700-015BF	DW/Grab		05:24	Lead	P	1			015A
44401700-016BF	DW/Grab		05:25	Lead	P	1			016A
44401700-017BF	DW/Grab		05:25	Lead	P	1			017A
44401700-018SF	DW/Grab		05:27	Lead	P	1			018A
44401700-019BF	DW/Grab		05:14	Lead	P	1			019A
44401700-020CF	DW/Grab		05:15	Lead	P	1			020A

Notes:	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
REPORT							
Mail							
Email							
Fax							
Pickup							

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	3/8					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Faith</u>	3/9/23	8:55	



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

April 04, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2303350

Dear Terry Rutledge:

Analytical Laboratory Group received 12 sample(s) on 3/9/2023 for the analyses presented in the following report.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

A3



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2303350

Date: 4/4/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Date Reported: 4/4/2023

WO#: 2303350
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/9/2023 8:55:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2303350-001 Client Sample ID 44401700-021BF Collection Date: 3/8/2023 5:17:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	42.0	15.0	8.00	*	ppb	4/1/2023 9:10:00 PM	AS

Lab ID: 2303350-002 Client Sample ID 44401700-022BF Collection Date: 3/8/2023 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2023 9:10:00 PM	AS

Lab ID: 2303350-003 Client Sample ID 44401700-023BF Collection Date: 3/8/2023 5:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.51	15.0	2.00		ppb	4/1/2023 9:10:00 PM	AS

Lab ID: 2303350-004 Client Sample ID 44401700-024SF Collection Date: 3/8/2023 5:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303350-005 Client Sample ID 44401700-025DW Collection Date: 3/8/2023 5:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303350-006 Client Sample ID 44401700-026CF Collection Date: 3/8/2023 5:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.15	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303350-007 Client Sample ID 44401700-027BF Collection Date: 3/8/2023 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 4/4/2023

WO#: 2303350
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/9/2023 8:55:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2303350-008 **Client Sample ID** 44401700-028BF **Collection Date:** 3/8/2023 5:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303350-009 **Client Sample ID** 44401700-029DW **Collection Date:** 3/8/2023 5:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.21	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303350-010 **Client Sample ID** 44401700-030SF **Collection Date:** 3/8/2023 5:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.26	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303350-011 **Client Sample ID** 44401700-031BF **Collection Date:** 3/8/2023 5:32:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.96	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303350-012 **Client Sample ID** 44401700-032BF **Collection Date:** 3/8/2023 5:32:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	14.6	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2303350
Date: 4/4/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303350

04-Apr-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303350-001A	44401700-021BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303350-002A	44401700-022BF			Lead	A
	2303350-003A	44401700-023BF			Lead	A
	2303350-004A	44401700-024SF			Lead	A
	2303350-005A	44401700-025DW			Lead	A
	2303350-006A	44401700-026CF			Lead	A
	2303350-007A	44401700-027BF			Lead	A
	2303350-008A	44401700-028BF			Lead	A
	2303350-009A	44401700-029DW			Lead	A
	2303350-010A	44401700-030SF			Lead	A
	2303350-011A	44401700-031BF			Lead	A
	2303350-012A	44401700-032BF			Lead	A

ORELAP A Accredited

ACCRED

Original #2303350# v1

Page 6 of 8



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
44401700-021BF	DW/Grab	3/8/28	0517	Lead	P	1		<u>NA</u>	001A
44401700-022BF	DW/Grab		0520	Lead	P	1			002A
44401700-023BF	DW/Grab		0521	Lead	P	1			003A
44401700-024SF	DW/Grab		0523	Lead	P	1			004A
44401700-025DW	DW/Grab		0526	Lead	P	1			005A
44401700-026CF	DW/Grab		0527	Lead	P	1			006A
44401700-027BF	DW/Grab		0528	Lead	P	1			007A
44401700-028BF	DW/Grab		0529	Lead	P	1			008A
44401700-029DW	DW/Grab		0530	Lead	P	1			009A
44401700-030SF	DW/Grab		0530	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	3/8/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Faith</u>	3/9/23	8:55	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield SD		Sampler Name: <u>Veronica Arciga</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
44401700-031BF	DW/Grab	3/8/23	0532	Lead	P	1			011A FM 3/9/23
44401700-032BF	DW/Grab	?	0532	Lead	P	1			012A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID		Preservation Check				
	Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice <u>None</u>	

Relinquished by:	Date	Time	Received by:	Date	Time
<u>Veronica Arciga</u>					
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>Faith</u>	3/9/23	8:55