

Lead in Water Test Results Summary: Administrative Building

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Room 148)	20830002-001BF	3/27/2025	2.54	Low	[enter date]	[enter result]	[autofill]
Woman's Bathroom Faucet #2	20830002-002BF	3/27/2025	ND	Non-Detect			
Men's Bathroom Faucet #1	20830002-003BF	3/27/2025	ND	Non-Detect			
Men's Bathroom Faucet #2	20830002-004BF	3/27/2025	ND	Non-Detect			
Office Faucet	20830002-005SF	3/27/2025	ND	Non-Detect			
Instant Hot Water Faucet (By Room 148)	20830002-006SF	3/27/2025	ND	Non-Detect			
Water Bottle Fill (By Room 142)	20830002-007WB	3/27/2025	ND	Non-Detect			
Bathroom Faucet (By Room 130)	20830002-008BF	3/27/2025	ND	Non-Detect			
Office Faucet	20830002-009SF	3/27/2025	ND	Non-Detect			
Instant Hot Water Faucet (By Room 130)	20830002-010SF	3/27/2025	ND	Non-Detect			
Men's Bathroom Faucet (By Room 119)	20830002-011BF	3/27/2025	ND	Non-Detect			
Woman's Bathroom Faucet	20830002-012BF	3/27/2025	ND	Non-Detect			
206)	20830002-013WB	3/27/2025	ND	Non-Detect			
Drinking Fountain (With Bottle Fill)	20830002-014DW	3/27/2025	ND	Non-Detect			
Drinking Fountain (Without Bottle Fill)	20830002-015DW	3/27/2025	ND	Non-Detect			
Men's Bathroom Faucet (By Board Room)	20830002-016BF	3/27/2025	ND	Non-Detect			
Woman's Bathroom Faucet #1	20830002-017BF	3/27/2025	ND	Non-Detect			
Woman's Bathroom Faucet #2	20830002-018BF	3/27/2025	ND	Non-Detect			
Bathroom Faucet (Next to Room 217)	20830002-019BF	3/27/2025	ND	Non-Detect			
Bathroom Faucet (By Stairs)	20830002-020BF	3/27/2025	ND	Non-Detect			
Staff Room Faucet	20830002-021SF	3/27/2025	ND	Non-Detect			
Staff Room Instant Hot Water Faucet	20830002-022SF	3/27/2025	ND	Non-Detect			
Bottle Fill (Outside Staff Room)	20830002-023WB	3/27/2025	ND	Non-Detect			



*Delivering more than
just test results*

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 03, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD

Order No.: 2503886

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 3/27/2025 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia' in a cursive script.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2503886

Date: 4/3/2025

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2503886
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/27/2025 8:00:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2503886-001 **Client Sample ID** 20830002-001BF **Collection Date:** 3/27/2025 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.54	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS

Lab ID: 2503886-002 **Client Sample ID** 20830002-002BF **Collection Date:** 3/27/2025 5:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 10:02:24 PM	KG

Lab ID: 2503886-003 **Client Sample ID** 20830002-003BF **Collection Date:** 3/27/2025 5:25:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS

Lab ID: 2503886-004 **Client Sample ID** 20830002-004BF **Collection Date:** 3/27/2025 5:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS

Lab ID: 2503886-005 **Client Sample ID** 20830002-005SF **Collection Date:** 3/27/2025 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS

Lab ID: 2503886-006 **Client Sample ID** 20830002-006SF **Collection Date:** 3/27/2025 5:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS

Lab ID: 2503886-007 **Client Sample ID** 20830002-007WB **Collection Date:** 3/27/2025 5:31:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)
C Value is below Minimum Compound Limit.
H Holding times for preparation or analysis exceeded
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PQL Practical Quantitation Level or Reporting Limit

A Accredited by ORELAP
E Value above quantitation range
LOD Limit of Detection
NAR See note in Case Narrative
PL Permit Limit
R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Analytical Report

Date Reported: 4/3/2025

WO#: 2503886
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/27/2025 8:00:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2503886-008 Client Sample ID 20830002-008BF Collection Date: 3/27/2025 5:33:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2503886-009 Client Sample ID 20830002-009SF Collection Date: 3/27/2025 5:34:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2503886-010 Client Sample ID 20830002-010SF Collection Date: 3/27/2025 5:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2503886-011 Client Sample ID 20830002-011BF Collection Date: 3/27/2025 5:38:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	4/1/2025 10:36:54 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2503886-012 Client Sample ID 20830002-012BF Collection Date: 3/27/2025 5:40:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG
------	-----------	----	------	------	--	-----	---------------------	----

Lab ID: 2503886-013 Client Sample ID 20830002-013WB Collection Date: 3/27/2025 5:43:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG
------	-----------	----	------	------	--	-----	---------------------	----

Lab ID: 2503886-014 Client Sample ID 20830002-014DW Collection Date: 3/27/2025 5:45:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG
------	-----------	----	------	------	--	-----	---------------------	----

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

Original
Page 4 of 9

Date Reported: 4/3/2025

WO#: 2503886
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/27/2025 8:00:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2503886-015 **Client Sample ID** 20830002-015DW **Collection Date:** 3/27/2025 5:46:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Lab ID: 2503886-016 **Client Sample ID** 20830002-016BF **Collection Date:** 3/27/2025 5:47:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Lab ID: 2503886-017 **Client Sample ID** 20830002-017BF **Collection Date:** 3/27/2025 5:49:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Lab ID: 2503886-018 **Client Sample ID** 20830002-018BF **Collection Date:** 3/27/2025 5:50:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Lab ID: 2503886-019 **Client Sample ID** 20830002-019BF **Collection Date:** 3/27/2025 5:52:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Lab ID: 2503886-020 **Client Sample ID** 20830002-020BF **Collection Date:** 3/27/2025 5:54:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)
C Value is below Minimum Compound Limit.
H Holding times for preparation or analysis exceeded
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PQL Practical Quantitation Level or Reporting Limit

A Accredited by ORELAP
E Value above quantitation range
LOD Limit of Detection
NAR See note in Case Narrative
PL Permit Limit
R RPD outside accepted recovery limits

Definition Base

WO#: 2503886
Date: 4/3/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2503886

03-Apr-25

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2503886-001A	20830002-001BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2503886-002A	20830002-002BF			Lead	A
	2503886-003A	20830002-003BF			Lead	A
	2503886-004A	20830002-004BF			Lead	A
	2503886-005A	20830002-005SF			Lead	A
	2503886-006A	20830002-006SF			Lead	A
	2503886-007A	20830002-007WB			Lead	A
	2503886-008A	20830002-008BF			Lead	A
	2503886-009A	20830002-009SF			Lead	A
	2503886-010A	20830002-010SF			Lead	A
	2503886-011A	20830002-011BF			Lead	A
	2503886-012A	20830002-012BF			Lead	A
	2503886-013A	20830002-013WB			Lead	A
	2503886-014A	20830002-014DW			Lead	A
	2503886-015A	20830002-015DW			Lead	A
	2503886-016A	20830002-016BF			Lead	A
	2503886-017A	20830002-017BF			Lead	A
	2503886-018A	20830002-018BF			Lead	A
	2503886-019A	20830002-019BF			Lead	A
	2503886-020A	20830002-020BF			Lead	A

ACCRED
ORELAP A Accredited

Original #2503886# v1

Page 7 of 9

Work Order # 2503886



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: MC
Checked: PK

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>MARIO RODRIGUEZ</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20830002-001 BF	DW/Grab	3-27-25	5:22 AM	Lead	P	1		NA	001A
20830002-002 RF	DW/Grab		5:23	Lead	P	1			002A
20830002-003 BF	DW/Grab		5:25	Lead	P	1			003A
20830002-004 RF	DW/Grab		5:26	Lead	P	1			004A
20830002-005 SF	DW/Grab		5:28	Lead	P	1			005A
20830002-006 SF	DW/Grab		5:29	Lead	P	1			006A
20830002-007 WR	DW/Grab		5:31	Lead	P	1			007A
20830002-008 BF	DW/Grab		5:33	Lead	P	1			008A
20830002-009 SF	DW/Grab		5:34	Lead	P	1			009A
20830002-010 SF	DW/Grab		5:36	Lead	P	1			010A

Notes:	PAID	Preservation Check			
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH
	CC				
	CK				
	Cash				
	REPORT				
	Mail				
	Email				
	Fax				
	Pickup				

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated <u>IR</u>	
☒ NORMAL	☐ RUSH	Mario		Ice	<u>None</u>
Relinquished by:	Date	Time	Received by:	Date	Time
<u>Therese Rutledge</u>	3/27/25	8:01			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>[Signature]</u>	3/27/25	08:00

Work Order # 2503886



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: MT
Checked: BH

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Mario Rodriguez</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20830002-011 BF	DW/Grab	3-27-25	5:38 AM	Lead	P	1		NA	011A
20830002-012 BF	DW/Grab		5:40	Lead	P	1			012A
20830002-013 WB	DW/Grab		5:43	Lead	P	1			013A
20830002-014 DW	DW/Grab		5:45	Lead	P	1			014A
20830002-015 DW	DW/Grab		5:46	Lead	P	1			015A
20830002-016 BF	DW/Grab		5:47	Lead	P	1			016A
20830002-017 BF	DW/Grab		5:49	Lead	P	1			017A
20830002-018 BF	DW/Grab		5:50	Lead	P	1			018A
20830002-019 BF	DW/Grab		5:52	Lead	P	1			019A
20830002-020 BF	DW/Grab		5:54	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated <u>12</u>
☒ NORMAL ☐ RUSH	<u>Mario</u>	Ice ☐ ☒ None
Relinquished by: <u>Mario Rodriguez</u>	Date: <u>3-27-25</u>	Time: <u>8:01</u>
Relinquished by:	Date:	Time:
Relinquished by:	Date:	Time:
Relinquished by:	Date:	Time:
Relinquished by:	Date:	Time:



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 03, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD

Order No.: 2503887

Dear Terry Rutledge:

Analytical Laboratory Group received 3 sample(s) on 3/27/2025 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2503887

Date: 4/3/2025

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2503887
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/27/2025 8:00:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2503887-001 **Client Sample ID** 20830002-021SF **Collection Date:** 3/27/2025 5:56:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Lab ID: 2503887-002 **Client Sample ID** 20830002-022SF **Collection Date:** 3/27/2025 5:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Lab ID: 2503887-003 **Client Sample ID** 20830002-023WB **Collection Date:** 3/27/2025 5:58:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/2/2025 6:43:22 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2503887

Date: 4/3/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2503887

03-Apr-25

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2503887-001A	20830002-021SF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2503887-002A	20830002-022SF			Lead	A
	2503887-003A	20830002-023WB			Lead	A

ACCRED ORELAP A Accredited

Original #2503887# v1

Page 5 of 6

Work Order # 2503887



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: MT
Checked: BK

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>MARCO RODRIGUEZ</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
<u>20830002-0219F</u>	DW/Grab	<u>3-27-25</u>	<u>5:56 AM</u>	Lead	P	1		<u>NA</u>	<u>001A</u>
<u>20830002-0225F</u>	DW/Grab	<u>3-27-25</u>	<u>5:57</u>	Lead	P	1			<u>002A</u>
<u>20830002-023WR</u>	DW/Grab	<u>3-27-25</u>	<u>5:58</u>	Lead	P	1			<u>003A</u>
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated <u>NR</u>	
☒ NORMAL ☐ RUSH			<u>Mario</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Mario Rodriguez</u>	<u>3-27-25</u>	<u>8:04</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	<u>3/27/25</u>	<u>8:04</u>	