

Lead in Water Test Results Summary: Agnes Stewart Middle School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Kitchen Bathroom Faucet	20831700-001BF	4/4/2025	ND	Non-Detect	[enter date]	[enter result]	[autofill]
Kitchen Faucet (Next To Restroom) #1	20831700-002KF	4/4/2025	6.18	Moderate			
Kitchen Faucet #2	20831700-003KF	4/4/2025	ND	Non-Detect			
Kitchen Faucet #3 (Next to Ice Machine)	20831700-004KF	4/4/2025	3.15	Low			
Kitchen Faucet #4 (Steam Kettle)	20831700-005KF	4/4/2025	2.41	Low			
Kitchen Faucet #5 (Left Of Dishwasher)	20831700-006KF	4/4/2025	2.45	Low			
Kitchen Faucet #6 (Right Of Dishwasher)	20831700-007KF	4/4/2025	ND	Non-Detect			
Kitchen Faucet #7 (Behind Dishwasher Left)	20831700-008KF	4/4/2025	ND	Non-Detect			
Kitchen Faucet #8 (Right)	20831700-009KF	4/4/2025	3.9	Low			
Kitchen Faucet #9 (Outside Dishwasher Area)	20831700-010KF	4/4/2025	2.15	Low			
Kitchen Faucet #10	20831700-011KF	4/4/2025	2.67	Low			
Kitchen Faucet #11	20831700-012KF	4/4/2025	3.3	Low			
Classroom 114 Band Room Faucet	20831700-013CF	4/4/2025	ND	Non-Detect			
Classroom 114 Band Room Drinking Fountain	20831700-014DW	4/4/2025	ND	Non-Detect			
Girls Bradley Bathroom Faucet #1 (Far Left)	20831700-015BF	4/4/2025	ND	Non-Detect			
Girls Bradley Bathroom Faucet #2	20831700-016BF	4/4/2025	ND	Non-Detect			
Girls Bradley Bathroom Faucet #3	20831700-017BF	4/4/2025	ND	Non-Detect			
Girls Bradley Bathroom Faucet #4 (Far Right)	20831700-018BF	NOT IN USE					
Boys Bradley Bathroom Faucet #1 (Far Left)	20831700-019BF	4/4/2025	4.9	Low			
Boys Bradley Bathroom Faucet #2	20831700-020BF	4/4/2025	3.09	Low			
Boys Bradley Bathroom Faucet #3	20831700-021BF	4/4/2025	ND	Non-Detect			
Boys Bradley Bathroom Faucet #4 (Far Right)	20831700-022BF	4/4/2025	2.15	Low			
Drinking Fountain (Next To Boys Bathroom Left)	20831700-023DW	4/4/2025	ND	Non-Detect			
Drinking Fountain (Next To Boys Bathroom Right)	20831700-024DW	4/4/2025	ND	Non-Detect			
Classroom 113 Faucet STEM Hallway	20831700-025CF	4/4/2025	ND	Non-Detect			
Classroom 117 Faucet #1	20831700-026CF	4/4/2025	ND	Non-Detect			
Classroom 117 Faucet #2	20831700-027CF	4/4/2025	ND	Non-Detect			
Classroom 117 Faucet #3	20831700-028CF	4/4/2025	ND	Non-Detect			
Staff Lounge Faucet	20831700-029SF	4/4/2025	ND	Non-Detect			
Staff Lounge Insta Hot Faucet	20831700-030SF	4/4/2025	ND	Non-Detect			
W Staff Bathroom Faucet	20831700-031BF	4/4/2025	ND	Non-Detect			
M Staff Bathroom Faucet	20831700-032BF	4/4/2025	ND	Non-Detect			
Art Classroom 111 Facuet #1 (By Entrance)	20831700-033CF	4/4/2025	ND	Non-Detect			
Art Classroom 111 Facuet #2	20831700-034CF	4/4/2025	ND	Non-Detect			
Art Classroom 111 Facuet #3 (By Window)	20831700-035CF	4/4/2025	ND	Non-Detect			
Office Faucet	20831700-036SF	4/4/2025	ND	Non-Detect			
Office Instant Hot Water Faucet	20831700-037SF	4/4/2025	ND	Non-Detect			
Staff Bathroom Faucet (Next for RM 107)	20831700-038BF	4/4/2025	ND	Non-Detect			
Nurse Office Sink (RM 106)	20831700-039NS	4/4/2025	ND	Non-Detect			
Nurse Office Drinking Fountain (RM 106)	20831700-040DW	4/4/2025	ND	Non-Detect			
Nurse Office Bathroom Faucet (RM 106)	20831700-041BF	4/4/2025	ND	Non-Detect			
Staff Bathroom Faucet (RM 105)	20831700-042BF	4/4/2025	ND	Non-Detect			
Library Staff Faucet (1)	20831700-043SF	4/4/2025	ND	Non-Detect			
Drinking Fountain (Next To Elevator Left)	20831700-044DW	4/4/2025	ND	Non-Detect			
Drinking Fountain (Next To Elevator Right)	20831700-045DW	4/4/2025	ND	Non-Detect			
Classroom A110 Faucet	20831700-046CF	4/4/2025	ND	Non-Detect			
Classroom A110 Drinking Fountain	20831700-047DW	4/4/2025	ND	Non-Detect			
Classroom A110 Bathroom Faucet	20831700-048BF	4/4/2025	3.69	Low			
Girls Bradley Bathroom Faucet #1 (Far Left)	20831700-049BF	4/4/2025	2.45	Low			
Girls Bradley Bathroom Faucet #2	20831700-050BF	NOT IN USE					

Girls Bradley Bathroom Faucet #3	20831700-051BF	4/4/2025	ND	Non-Detect
Girls Bradley Bathroom Faucet #4 (Far Right)	20831700-052BF	4/4/2025	2.12	Low
Staff Bathroom Faucet (Next To Girls RR)	20831700-053BF	4/4/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #1 (Far Left)	20831700-054BF	4/4/2025	3.16	Low
Boys Bradley Bathroom Faucet #2	20831700-055BF	4/4/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #3	20831700-056BF	4/4/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #4 (Far Right)	20831700-057BF	4/4/2025	4.63	Low
Classroom A109 Faucet #1 (Front Of Classroom)	20831700-058CF	4/4/2025	3.93	Low
Classroom A109 Faucet #2 (Far Left)	20831700-059CF	4/4/2025	ND	Non-Detect
Classroom A109 Faucet #3	20831700-060CF	4/4/2025	ND	Non-Detect
Classroom A109 Faucet #4	20831700-061CF	4/4/2025	ND	Non-Detect
Classroom A109 Faucet #5	20831700-062CF	4/4/2025	11.5	High
Classroom A109 Faucet #6 (Far Right)	20831700-063CF	4/4/2025	2.09	Low
Classroom A108 Faucet	20831700-064CF	4/4/2025	ND	Non-Detect
Classroom A108 Drinking Fountain	20831700-065DW	4/4/2025	ND	Non-Detect
Classroom A107 Faucet	20831700-066CF	4/4/2025	ND	Non-Detect
Classroom A107 Drinking Fountain	20831700-067DW	4/4/2025	ND	Non-Detect
Classroom A106 Faucet	20831700-068CF	4/4/2025	ND	Non-Detect
Classroom A106 Drinking Fountain	20831700-069DW	4/4/2025	ND	Non-Detect
Classroom A105 Faucet	20831700-070CF	4/4/2025	ND	Non-Detect
Classroom A105 Drinking Fountain	20831700-071DW	4/4/2025	ND	Non-Detect
Classroom A104 Faucet	20831700-072CF	4/4/2025	ND	Non-Detect
Classroom A104 Drinking Fountain	20831700-073DW	4/4/2025	ND	Non-Detect
Classroom A102 Faucet	20831700-074CF	4/4/2025	ND	Non-Detect
Classroom A102 Drinking Fountain	20831700-075DW	4/4/2025	ND	Non-Detect
Classroom A101 Faucet	20831700-076CF	4/4/2025	5.49	Moderate
Classroom A101 Drinking Fountain	20831700-077DW	4/4/2025	ND	Non-Detect
Left)	20831700-078DW	4/4/2025	ND	Non-Detect
Right)	20831700-079DW	4/4/2025	ND	Non-Detect
Classroom B110 Faucet	20831700-080CF	4/4/2025	ND	Non-Detect
Classroom B110 Drinking Fountain	20831700-081DW	4/4/2025	ND	Non-Detect
Girls Bradley Bathroom Faucet #1 (Far Left)	20831700-082BF	4/4/2025	ND	Non-Detect
Girls Bradley Bathroom Faucet #2	20831700-083BF	NOT IN USE		
Girls Bradley Bathroom Faucet #3	20831700-084BF	4/4/2025	ND	Non-Detect
Girls Bradley Bathroom Faucet #4 (Far Right)	20831700-085BF	4/4/2025	ND	Non-Detect
Staff Bathroom Faucet (Next To Girls RR)	20831700-086BF	4/4/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #1 (Far Left)	20831700-087BF	NOT IN USE		
Boys Bradley Bathroom Faucet #2	20831700-088BF	4/4/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #3	20831700-089BF	NOT IN USE		
Boys Bradley Bathroom Faucet #4 (Far Right)	20831700-090BF	4/4/2025	ND	Non-Detect
Classroom B109 Faucet #1 (Front Of Classroom)	20831700-091CF	4/4/2025	ND	Non-Detect
Classroom B109 Faucet #2 (Far Left)	20831700-092CF	4/4/2025	ND	Non-Detect
Classroom B109 Faucet #3	20831700-093CF	4/4/2025	ND	Non-Detect
Classroom B109 Faucet #4	20831700-094CF	4/4/2025	2.11	Low
Classroom B109 Faucet #5	20831700-095CF	4/4/2025	ND	Non-Detect
Classroom B109 Faucet #6 (Far Right)	20831700-096CF	4/4/2025	ND	Non-Detect
Classroom B108 Faucet	20831700-097CF	4/4/2025	ND	Non-Detect
Classroom B108 Drinking Fountain	20831700-098DW	4/4/2025	ND	Non-Detect
Classroom B107 Faucet	20831700-099CF	4/4/2025	ND	Non-Detect
Classroom B107 Drinking Fountain	20831700-100DW	4/4/2025	ND	Non-Detect
Classroom B106 Faucet	20831700-101CF	4/4/2025	ND	Non-Detect
Classroom B106 Drinking Fountain	20831700-102DW	4/4/2025	ND	Non-Detect
Classroom B105 Faucet	20831700-103CF	4/4/2025	ND	Non-Detect
Classroom B105 Drinking Fountain	20831700-104DW	4/7/2025	ND	Non-Detect
Classroom B104 Faucet	20831700-105CF	4/7/2025	ND	Non-Detect
Classroom B104 Drinking Fountain	20831700-106DW	4/7/2025	ND	Non-Detect
Classroom B102 Faucet	20831700-107CF	4/7/2025	ND	Non-Detect
Classroom B102 Drinking Fountain	20831700-108DW	4/7/2025	ND	Non-Detect
Classroom B101 Faucet	20831700-109CF	4/7/2025	ND	Non-Detect
Classroom B101 Drinking Fountain	20831700-110DW	4/7/2025	ND	Non-Detect
Classroom C110 Faucet - C-Wing	20831700-111CF	4/7/2025	ND	Non-Detect
Classroom C110 Drinking Fountain	20831700-112DW	4/7/2025	ND	Non-Detect
Girls Bradley Bathroom Faucet #1 (Far Left)	20831700-113BF	4/7/2025	ND	Non-Detect
Girls Bradley Bathroom Faucet #2	20831700-114BF	NOT IN USE		
Girls Bradley Bathroom Faucet #3	20831700-115BF	NOT IN USE		
Girls Bradley Bathroom Faucet #4 (Far Right)	20831700-116BF	4/7/2025	ND	Non-Detect
Staff Bathroom Faucet (Next To Girls RR)	20831700-117BF	4/7/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #1 (Far Left)	20831700-118BF	4/7/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #2	20831700-119BF	4/7/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #3	20831700-120BF	NOT IN USE		

Boys Bradley Bathroom Faucet #4 (Far Right)	20831700-121BF	4/7/2025	2.31	Low
Classroom C109 Faucet #1(Front of classroom)	20831700-122CF	4/7/2025	ND	Non-Detect
Classroom C109 Faucet #2 (Far Left)	20831700-123CF	4/7/2025	2.67	Low
Classroom C109 Faucet #3	20831700-124CF	4/7/2025	ND	Non-Detect
Classroom C109 Faucet #4	20831700-125CF	4/7/2025	2.36	Low
Classroom C109 Faucet #5	20831700-126CF	4/7/2025	5.54	Moderate
Classroom C109 Faucet #6 (Far Right)	20831700-127CF	4/7/2025	ND	Non-Detect
Classroom C108 Faucet	20831700-128CF	4/7/2025	ND	Non-Detect
Classroom C108 Drinking Fountain	20831700-129DW	4/7/2025	ND	Non-Detect
Classroom C107 Faucet	20831700-130CF	4/7/2025	ND	Non-Detect
Classroom C107 Drinking Fountain	20831700-131DW	4/7/2025	ND	Non-Detect
Classroom C106 Faucet	20831700-132CF	4/7/2025	ND	Non-Detect
Classroom C106 Drinking Fountain	20831700-133DW	4/7/2025	ND	Non-Detect
Classroom C105 Faucet	20831700-134CF	4/7/2025	3.3	Low
Classroom C105 Drinking Fountain	20831700-135DW	4/7/2025	ND	Non-Detect
Classroom C104 Faucet	20831700-136CF	4/7/2025	ND	Non-Detect
Classroom C104 Drinking Fountain	20831700-137DW	4/7/2025	ND	Non-Detect
Classroom C102 Faucet	20831700-138CF	4/7/2025	ND	Non-Detect
Classroom C102 Drinking Fountain	20831700-139DW	4/7/2025	ND	Non-Detect
Classroom C101 Faucet	20831700-140CF	4/7/2025	ND	Non-Detect
Classroom C101 Drinking Fountain	20831700-141DW	4/7/2025	ND	Non-Detect
GYM (Left)	20831700-142DW	4/7/2025	ND	Non-Detect
GYM (Right)	20831700-143DW	4/7/2025	ND	Non-Detect
Boy's Locker Room Teacher Bathrom Faucet	20831700-144BF	4/7/2025	ND	Non-Detect
(Far Left)	20831700-145BF	4/7/2025	5.71	Moderate
Boy's Locker Room Bradley Bathrom Faucet #2	20831700-146BF	4/7/2025	3.08	Low
Boy's Locker Room Bradley Bathrom Faucet #3	20831700-147BF	4/7/2025	3.22	Low
(Far Right)	20831700-148BF	4/7/2025	4.62	Low
Boys Bradley Bathroom Faucet #1 (Far Left)	20831700-149BF	4/7/2025	2.75	Low
Boys Bradley Bathroom Faucet #2	20831700-150BF	4/7/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #3	20831700-151BF	4/7/2025	ND	Non-Detect
Boys Bradley Bathroom Faucet #4 (Far Right)	20831700-152BF	4/7/2025	ND	Non-Detect
Girl's Bradley Bathroom Faucet #1 (Far Left)	20831700-153BF	4/7/2025	2.05	Low
Girl's Bradley Bathroom Faucet #2	20831700-154BF	4/7/2025	ND	Non-Detect
Girl's Bradley Bathroom Faucet #3	20831700-155BF	4/7/2025	ND	Non-Detect
Girl's Bradley Bathroom Faucet #4 (Far Right)	20831700-156BF	4/7/2025	ND	Non-Detect
Girl's Locker Room Teacher Bathroom Faucet	20831700-157BF	4/7/2025	ND	Non-Detect
Girl's Locker Room Bradlet Bathroom Faucet #1	20831700-158BF	4/7/2025	2.9	Low
Girl's Locker Room Bradlet Bathroom Faucet #2	20831700-159BF	4/7/2025	ND	Non-Detect
Girl's Locker Room Bradlet Bathroom Faucet #3	20831700-160BF	4/7/2025	ND	Non-Detect
Girl's Locker Room Bradlet Bathroom Faucet #4	20831700-161BF	4/7/2025	2.25	Low



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 15, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504213

Dear Terry Rutledge:

Analytical Laboratory Group received 17 sample(s) on 4/4/2025 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504213

Date: 4/15/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504213
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504213-001	Client Sample ID	20831700-001BF		Collection Date: 4/4/2025 5:00:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/10/2025 3:51:00 PM	AS

Lab ID: 2504213-002	Client Sample ID 20831700-002KF	Collection Date: 4/4/2025 5:01:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.18	15.0	2.00		ppb	4/10/2025 3:51:00 PM	AS

Lab ID: 2504213-003	Client Sample ID	20831700-003KF		Collection Date: 4/4/2025 5:02:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/10/2025 3:51:00 PM	AS

Lab ID: 2504213-004	Client Sample ID 20831700-004KF	Collection Date: 4/4/2025 5:03:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.15	15.0	2.00		ppb	4/10/2025 3:51:00 PM	AS

Lab ID: 2504213-005	Client Sample ID 20831700-005KF	Collection Date: 4/4/2025 5:05:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.41	15.0	2.00		ppb	4/10/2025 3:51:00 PM	AS

Lab ID: 2504213-006	Client Sample ID	20831700-006KF		Collection Date: 4/4/2025 5:07:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.45	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Lab ID: 2504213-007	Client Sample ID	20831700-007KF		Collection Date: 4/4/2025 5:08:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2504213
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504213-008	Client Sample ID	20831700-008KF		Collection Date: 4/4/2025 5:10:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Lab ID: 2504213-009	Client Sample ID 20831700-009KF	Collection Date: 4/4/2025 5:11:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.90	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Lab ID: 2504213-010	Client Sample ID	20831700-010KF		Collection Date: 4/4/2025 5:12:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.15	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Lab ID: 2504213-011	Client Sample ID	20831700-011KF		Collection Date: 4/4/2025 5:13:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.67	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Lab ID: 2504213-012	Client Sample ID 20831700-012KF	Collection Date: 4/4/2025 5:14:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.30	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Lab ID: 2504213-013	Client Sample ID 20831700-013CF	Collection Date: 4/4/2025 5:16:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Lab ID: 2504213-014	Client Sample ID	20831700-014DW		Collection Date: 4/4/2025 5:17:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2504213
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504213-015	Client Sample ID 20831700-015BF	Collection Date: 4/4/2025 5:19:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/10/2025 6:40:00 PM	AS

Lab ID: 2504213-016	Client Sample ID 20831700-016BF	Collection Date: 4/4/2025 5:20:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504213-017	Client Sample ID 20831700-017BF	Collection Date: 4/4/2025 5:20:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504213

Date: 4/15/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2504213

15-Apr-25

Client: Springfield School District #19

Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504213-001A	20831700-001BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504213-002A	20831700-002KF			Lead	A
	2504213-003A	20831700-003KF			Lead	A
	2504213-004A	20831700-004KF			Lead	A
	2504213-005A	20831700-005KF			Lead	A
	2504213-006A	20831700-006KF			Lead	A
	2504213-007A	20831700-007KF			Lead	A
	2504213-008A	20831700-008KF			Lead	A
	2504213-009A	20831700-009KF			Lead	A
	2504213-010A	20831700-010KF			Lead	A
	2504213-011A	20831700-011KF			Lead	A
	2504213-012A	20831700-012KF			Lead	A
	2504213-013A	20831700-013CF			Lead	A
	2504213-014A	20831700-014DW			Lead	A
	2504213-015A	20831700-015BF			Lead	A
	2504213-016A	20831700-016BF			Lead	A
	2504213-017A	20831700-017BF			Lead	A

ACCRED
ORELAP A Accredited



Delivering more than just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.comLIMS: FMChecked: BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>MARIO RODRIGUEZ</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-001BF	DW/Grab	4-4-25	05:00	Lead	P	1		NA	001A
20831700-002KF	DW/Grab		5:01	Lead	P	1			002A
20831700-003KF	DW/Grab		5:02	Lead	P	1			003A
20831700-004KF	DW/Grab		5:03	Lead	P	1			004A
20831700-005KF	DW/Grab		5:05	Lead	P	1			005A
20831700-006KF	DW/Grab		5:07	Lead	P	1			006A
20831700-007KF	DW/Grab		5:08	Lead	P	1			007A
20831700-008KF	DW/Grab		5:10	Lead	P	1			008A
20831700-009KF	DW/Grab		5:11	Lead	P	1			009A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	<u>Mario</u>	Ice	IR <u>None</u> IR <u>NA</u>

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Handwritten Signature</u>			<u>Handwritten Signature</u>	4/4/25	10:20



Delivering more than just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.comLIMS: FMChecked: OK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>MARIO RUDDERMAN</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-010KF	DW/Grab	<u>3/4/25</u>	<u>5:12</u>	Lead	P	1		<u>NA</u>	<u>010A</u>
20831700-011KF	DW/Grab		<u>5:13</u>	Lead	P	1			<u>011A</u>
20831700-012KF	DW/Grab		<u>5:14</u>	Lead	P	1			<u>012A</u>
20831700-013CF	DW/Grab		<u>5:16</u>	Lead	P	1			<u>013A</u>
20831700-014DW	DW/Grab		<u>5:17</u>	Lead	P	1			<u>014A</u>
20831700-015BF	DW/Grab		<u>5:19</u>	Lead	P	1			<u>015A</u>
20831700-016BF	DW/Grab		<u>5:20</u>	Lead	P	1			<u>016A</u>
20831700-017BF	DW/Grab		<u>5:20</u>	Lead	P	1			<u>017A</u>
20831700-018BF	DW/Grab			Lead	P	1			

Notes: *Sample not received; lined out by lab. <u>FM 4/4/25</u> @Corrected by client. <u>FM 4/4/25</u>	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	<u>Mario</u>	Ice	IR <u>None</u> <u>NA</u>

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Shirley Rutledge</u>			<u>FM</u>	<u>4/4/25</u>	<u>10:20</u>

Page 2 of 2



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 16, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504217

Dear Terry Rutledge:

Analytical Laboratory Group received 18 sample(s) on 4/4/2025 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504217

Date: 4/16/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504217
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504217-001	Client Sample ID	20831700-019BF		Collection Date: 4/4/2025 5:23:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.90	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-002	Client Sample ID	20831700-020BF		Collection Date: 4/4/2025 5:23:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.09	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-003	Client Sample ID	20831700-021BF		Collection Date: 4/4/2025 5:24:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-004	Client Sample ID 20831700-022BF	Collection Date: 4/4/2025 5:25:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.15	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-005	Client Sample ID	20831700-023DW		Collection Date: 4/4/2025 5:26:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-006	Client Sample ID 20831700-024DW	Collection Date: 4/4/2025 5:26:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-007		Client Sample ID 20831700-025CF		Collection Date: 4/4/2025 5:27:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2504217
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504217-008	Client Sample ID	20831700-026CF		Collection Date: 4/4/2025 5:29:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-009	Client Sample ID	20831700-027CF		Collection Date: 4/4/2025 5:30:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-010	Client Sample ID	20831700-028CF		Collection Date: 4/4/2025 5:30:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-011	Client Sample ID 20831700-029SF	Collection Date: 4/4/2025 5:32:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-012	Client Sample ID 20831700-030SF	Collection Date: 4/4/2025 5:32:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 12:36:00 AM	AS

Lab ID: 2504217-013	Client Sample ID 20831700-031BF	Collection Date: 4/4/2025 5:34:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504217-014		Client Sample ID 20831700-032BF		Collection Date: 4/4/2025 5:35:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2504217
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504217-015	Client Sample ID	20831700-033CF		Collection Date: 4/4/2025 5:36:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504217-016	Client Sample ID	20831700-034CF		Collection Date: 4/4/2025 5:36:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504217-017	Client Sample ID	20831700-035CF		Collection Date: 4/4/2025 5:37:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504217-018	Client Sample ID 20831700-036SF	Collection Date: 4/4/2025 5:40:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504217

Date: 4/16/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2504217
16-Apr-25

Client: Springfield School District #19

Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504217-001A	20831700-019BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504217-002A	20831700-020BF			Lead	A
	2504217-003A	20831700-021BF			Lead	A
	2504217-004A	20831700-022BF			Lead	A
	2504217-005A	20831700-023DW			Lead	A
	2504217-006A	20831700-024DW			Lead	A
	2504217-007A	20831700-025CF			Lead	A
	2504217-008A	20831700-026CF			Lead	A
	2504217-009A	20831700-027CF			Lead	A
	2504217-010A	20831700-028CF			Lead	A
	2504217-011A	20831700-029SF			Lead	A
	2504217-012A	20831700-030SF			Lead	A
	2504217-013A	20831700-031BF			Lead	A
	2504217-014A	20831700-032BF			Lead	A
	2504217-015A	20831700-033CF			Lead	A
	2504217-016A	20831700-034CF			Lead	A
	2504217-017A	20831700-035CF			Lead	A
	2504217-018A	20831700-036SF			Lead	A

ACCRED
ORELAP A Accredited



Delivering more than
just test results.

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

FM
BU

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge		Company: Springfield School District	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield, OR 97477	
Client Project: Springfield SD Agnes Stewart		Sampler Name: <u>MARIO RODRIGUEZ</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-019BF	DW/Grab	4-4-25	5:23	Lead	P	1		NA	001A 010A
20831700-020BF	DW/Grab		5:23	Lead	P	1			002A 011A
20831700-021BF	DW/Grab		5:24	Lead	P	1			003A 020A
20831700-022BF	DW/Grab		5:25	Lead	P	1			004A 021A
20831700-023DW	DW/Grab		5:26	Lead	P	1			005A 022A
20831700-024DW	DW/Grab		5:26	Lead	P	1			006A 023A
20831700-025CF	DW/Grab		5:27	Lead	P	1			007A 024A
20831700-026CF	DW/Grab		5:29	Lead	P	1			025A 008A
20831700-027CF	DW/Grab		5:30	Lead	P	1			026A 009A

Notes: Corrected by client. FM 4/4/25 *FM 4/4/25	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
☒ NORMAL	☐ RUSH	Mario		Ice	IR
					None NA

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Shirley Rodriguez</u>			<u>Jim</u>	4/4/25	10:20



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

FM

Checked:

BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: MARIO RODRIGUEZ

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-028CF	DW/Grab	4.4.25	5:30	Lead	P	1		NA	010A 037A
20831700-029SF	DW/Grab		5:32	Lead	P	1			011A 038A
20831700-030SF	DW/Grab		5:32	Lead	P	1			012A 039A
20831700-031BF	DW/Grab		5:34	Lead	P	1			013A 036A
20831700-032BF	DW/Grab		5:35	Lead	P	1			014A 031A
20831700-033CF	DW/Grab		5:36	Lead	P	1			015A 032A
20831700-034CF	DW/Grab		5:36	Lead	P	1			016A 033A
20831700-035CF	DW/Grab		5:37	Lead	P	1			017A 034A
20831700-036SF	DW/Grab		5:40	Lead	P	1			018A 035A

Notes: * FM 4/4/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	Mario	Ice	IR ☒ NA
Relinquished by:	Date	Time	Received by:
Relinquished by:	Date	Time	Received by:
Relinquished by:	Date	Time	Received by Laboratory:
Shirley Thompson			4/4/25 10:20



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 17, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504221

Dear Terry Rutledge:

Analytical Laboratory Group received 17 sample(s) on 4/4/2025 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504221

Date: 4/17/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504221
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504221-001	Client Sample ID	20831700-037SF		Collection Date: 4/4/2025 5:41:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Lab ID: 2504221-002	Client Sample ID	20831700-038BF		Collection Date: 4/4/2025 5:42:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Lab ID: 2504221-003	Client Sample ID	20831700-039NS		Collection Date: 4/4/2025 5:44:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Lab ID: 2504221-004	Client Sample ID	20831700-040DW			Collection Date: 4/4/2025 5:44:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Lab ID: 2504221-005	Client Sample ID 20831700-041BF	Collection Date: 4/4/2025 5:45:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Lab ID: 2504221-006	Client Sample ID 20831700-042BF	Collection Date: 4/4/2025 5:46:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Lab ID: 2504221-007	Client Sample ID	20831700-043SF		Collection Date: 4/4/2025 5:47:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2504221
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504221-008	Client Sample ID	20831700-044DW		Collection Date: 4/4/2025 5:48:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Lab ID: 2504221-009	Client Sample ID	20831700-045DW			Collection Date: 4/4/2025 5:49:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Lab ID: 2504221-010	Client Sample ID	20831700-046CF		Collection Date: 4/4/2025 5:50:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Lab ID: 2504221-011	Client Sample ID	20831700-047DW		Collection Date: 4/4/2025 5:51:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Lab ID: 2504221-012	Client Sample ID	20831700-048BF		Collection Date: 4/4/2025 5:51:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.69	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Lab ID: 2504221-013	Client Sample ID 20831700-049BF	Collection Date: 4/4/2025 5:52:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.45	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Lab ID: 2504221-014	Client Sample ID	20831700-051BF		Collection Date: 4/4/2025 5:54:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2504221
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504221-015	Client Sample ID 20831700-052BF	Collection Date: 4/4/2025 5:54:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.12	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Lab ID: 2504221-016	Client Sample ID	20831700-053BF		Collection Date: 4/4/2025 5:56:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Lab ID: 2504221-017	Client Sample ID	20831700-054BF		Collection Date: 4/4/2025 5:57:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.16	15.0	2.00		ppb	4/16/2025 5:29:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504221

Date: 4/17/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2504221

17-Apr-25

Client: Springfield School District #19

Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504221-001A	20831700-037SF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504221-002A	20831700-038BF			Lead	A
	2504221-003A	20831700-039NS			Lead	A
	2504221-004A	20831700-040DW			Lead	A
	2504221-005A	20831700-041BF			Lead	A
	2504221-006A	20831700-042BF			Lead	A
	2504221-007A	20831700-043SF			Lead	A
	2504221-008A	20831700-044DW			Lead	A
	2504221-009A	20831700-045DW			Lead	A
	2504221-010A	20831700-046CF			Lead	A
	2504221-011A	20831700-047DW			Lead	A
	2504221-012A	20831700-048BF			Lead	A
	2504221-013A	20831700-049BF			Lead	A
	2504221-014A	20831700-051BF			Lead	A
	2504221-015A	20831700-052BF			Lead	A
	2504221-016A	20831700-053BF			Lead	A
	2504221-017A	20831700-054BF			Lead	A



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

FM

Checked:

BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge				Company: Springfield School District			
Phone: (541) 744-6375				Address: 1890 North 42nd Street			
Email: terry.rutledge@springfield.k12.or.us				City, State, Zip: Springfield, OR 97477			
Client Project: Springfield SD Agnes Stewart				Sampler Name: MARIO RODRIGUEZ			

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-037SF	DW/Grab	4.4.25	5:41	Lead	P	1		NA	001A 036A
20831700-038BF	DW/Grab		5:42	Lead	P	1			002A 037A
20831700-039NS	DW/Grab		5:44	Lead	P	1			003A 038A
20831700-040DW	DW/Grab		5:44	Lead	P	1			004A 039A
20831700-041BF	DW/Grab		5:45	Lead	P	1			005A 040A
20831700-042BF	DW/Grab		5:46	Lead	P	1			006A 041A
20831700-043SF	DW/Grab		5:47	Lead	P	1			007A 042A
20831700-044DW	DW/Grab		5:48	Lead	P	1			008A 043A
20831700-045DW	DW/Grab		5:49	Lead	P	1			009A 044A

Notes: * FM 4/4/25	PAID		Preservation Check				
	Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH				Shipped Via: Mario		Refrigerated	
						Ice	IR

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <i>Mark Rutledge</i>	Date	Time	Received by Laboratory: <i>Jim</i>	Date	Time
				4/4/25	10:20



Delivering more than
just test results.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: FM
Checked: BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>MARIO RODRIGUEZ</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-046CF	DW/Grab	4-4-25	5:50	Lead	P	1		NA	010A
20831700-047DW	DW/Grab		5:51	Lead	P	1			011A
20831700-048BF	DW/Grab		5:51	Lead	P	1			012A
20831700-049BF	DW/Grab		5:52	Lead	P	1			013A
20831700-050BF	DW/Grab			Lead	P	1			
20831700-051BF	DW/Grab		5:54	Lead	P	1		NA	014A
20831700-052BF	DW/Grab		5:54	Lead	P	1			015A
20831700-053BF	DW/Grab		5:56	Lead	P	1			016A
20831700-054BF	DW/Grab		5:57	Lead	P	1			017A

Notes: *Sample not received; lined out by client and lab. FM 4/4/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH	Shipped Via: <u>Mario</u>	Refrigerated Ice IR <u>None</u> IR <u>NA</u>	
Relinquished by:	Date	Time	Received by:
Relinquished by:	Date	Time	Received by:
Relinquished by: <u>Shirley Rodriguez</u>	Date	Time	Received by Laboratory: <u>John</u>
			Date: <u>4/4/25</u> Time: <u>10:20</u>



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 16, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504220

Dear Terry Rutledge:

Analytical Laboratory Group received 16 sample(s) on 4/4/2025 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504220

Date: 4/16/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504220
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504220-001	Client Sample ID	20831700-055BF		Collection Date: 4/4/2025 5:57:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-002	Client Sample ID	20831700-056BF		Collection Date: 4/4/2025 5:59:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-003	Client Sample ID	20831700-057BF		Collection Date: 4/4/2025 5:59:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.63	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-004	Client Sample ID	20831700-058CF		Collection Date: 4/4/2025 6:00:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.93	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-005	Client Sample ID 20831700-059CF	Collection Date: 4/4/2025 6:01:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-006	Client Sample ID 20831700-060CF	Collection Date: 4/4/2025 6:02:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-007	Client Sample ID	20831700-061CF		Collection Date: 4/4/2025 6:03:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2504220
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504220-008	Client Sample ID	20831700-062CF		Collection Date: 4/4/2025 6:04:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.5	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-009	Client Sample ID	20831700-063CF		Collection Date: 4/4/2025 6:04:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.09	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-010	Client Sample ID	20831700-064CF		Collection Date: 4/4/2025 6:05:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-011	Client Sample ID	20831700-065DW		Collection Date: 4/4/2025 6:06:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-012	Client Sample ID	20831700-066CF		Collection Date: 4/4/2025 6:07:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-013	Client Sample ID 20831700-067DW	Collection Date: 4/4/2025 6:07:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 7:57:00 PM	AS

Lab ID: 2504220-014	Client Sample ID	20831700-068CF		Collection Date: 4/4/2025 6:09:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2504220
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 10:20:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2504220-015	Client Sample ID 20831700-069DW	Collection Date: 4/4/2025 6:09:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Lab ID: 2504220-016	Client Sample ID 20831700-070CF	Collection Date: 4/4/2025 6:10:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/15/2025 11:55:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504220

Date: 4/16/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2504220
 16-Apr-25

Client: Springfield School District #19
Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504220-001A	20831700-055BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504220-002A	20831700-056BF			Lead	A
	2504220-003A	20831700-057BF			Lead	A
	2504220-004A	20831700-058CF			Lead	A
	2504220-005A	20831700-059CF			Lead	A
	2504220-006A	20831700-060CF			Lead	A
	2504220-007A	20831700-061CF			Lead	A
	2504220-008A	20831700-062CF			Lead	A
	2504220-009A	20831700-063CF			Lead	A
	2504220-010A	20831700-064CF			Lead	A
	2504220-011A	20831700-065DW			Lead	A
	2504220-012A	20831700-066CF			Lead	A
	2504220-013A	20831700-067DW			Lead	A
	2504220-014A	20831700-068CF			Lead	A
	2504220-015A	20831700-069DW			Lead	A
	2504220-016A	20831700-070CF			Lead	A



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: BK

Checked: FM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge

Company: Springfield School District

Phone: (541) 744-6375

Address: 1890 North 42nd Street

Email: terry.rutledge@springfield.k12.or.us

City, State, Zip: Springfield, OR 97477

Client Project: Springfield SD Agnes Stewart

Sampler Name:

Mario Rosalez

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-055BF	DW/Grab	4-4-25	5:57	Lead	P	1		NA	001A
20831700-056BF	DW/Grab		5:59	Lead	P	1			002A
20831700-057BF	DW/Grab		5:59	Lead	P	1			003A
20831700-058CF	DW/Grab		6:00	Lead	P	1			004A
20831700-059CF	DW/Grab		6:01	Lead	P	1			005A
20831700-060CF	DW/Grab		6:02	Lead	P	1			006A
20831700-061CF	DW/Grab		6:03	Lead	P	1			007A
20831700-062CF	DW/Grab		6:04	Lead	P	1			008A
20831700-063CF	DW/Grab		6:04	Lead	P	1			009A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):

☒ NORMAL

☐ RUSH

Shipped Via:

Mario

Refrigerated

Ice IR ☒ None IR NA

Relinquished by:

Date Time

Received by:

Date Time

Relinquished by:

Date Time

Received by:

Date Time

Relinquished by:

Date Time

Received by Laboratory:

Date Time

Mark Rodriguez

Mark

4/4/25 10:26



361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: BK

Checked: FM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: MARIO RODRIGUEZ

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-064CF	DW/Grab	4.4.25	6:05	Lead	P	1		NA	010A
20831700-065DW	DW/Grab		6:06	Lead	P	1			011A
20831700-066CF	DW/Grab		6:07	Lead	P	1			012A
20831700-067DW	DW/Grab		6:07	Lead	P	1			013A
20831700-068CF	DW/Grab		6:09	Lead	P	1			014A
20831700-069DW	DW/Grab		6:09	Lead	P	1			015A
20831700-070CF	DW/Grab		6:10	Lead	P	1			016A
20831700-071DW	DW/Grab		6:10	Lead	P	1			
20831700-072CF	DW/Grab		6:12	Lead	P	1			

Notes: *Samples not received; lined out by lab. FM 4/4/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH		Shipped Via: Mario	Refrigerated Ice IR ☒ None IR NA	
Relinquished by:	Date Time	Received by:	Date	Time
Relinquished by:	Date Time	Received by:	Date	Time
Relinquished by:	Date Time	Received by Laboratory:	Date	Time
			4/4/25	6:20



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 18, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504228

Dear Terry Rutledge:

Analytical Laboratory Group received 17 sample(s) on 4/4/2025 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504228

Date: 4/18/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504228
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 11:38:00 AM
Sampler Name Mario Rodriguez and John Ha
Matrix: Drinking Water
Treatment:

Lab ID: 2504228-001	Client Sample ID	20831700-071DW			Collection Date: 4/4/2025 6:10:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Lab ID: 2504228-002	Client Sample ID	20831700-072CF		Collection Date: 4/4/2025 6:12:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Lab ID: 2504228-003	Client Sample ID	20831700-073DW		Collection Date: 4/4/2025 6:12:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Lab ID: 2504228-004	Client Sample ID	20831700-074CF		Collection Date: 4/4/2025 6:13:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Lab ID: 2504228-005	Client Sample ID	20831700-075DW		Collection Date: 4/4/2025 6:13:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Lab ID: 2504228-006	Client Sample ID	20831700-076CF		Collection Date: 4/4/2025 6:14:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.49	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Lab ID: 2504228-007	Client Sample ID	20831700-077DW		Collection Date: 4/4/2025 6:15:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2504228
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 11:38:00 AM
Sampler Name Mario Rodriguez and John Ha
Matrix: Drinking Water
Treatment:

Lab ID: 2504228-008	Client Sample ID	20831700-078DW		Collection Date: 4/4/2025 4:59:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Lab ID: 2504228-009	Client Sample ID	20831700-079DW		Collection Date: 4/4/2025 5:01:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Lab ID: 2504228-010	Client Sample ID	20831700-080CF		Collection Date: 4/4/2025 5:03:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Lab ID: 2504228-011	Client Sample ID	20831700-081DW		Collection Date: 4/4/2025 5:03:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Lab ID: 2504228-012	Client Sample ID	20831700-082BF		Collection Date: 4/4/2025 5:05:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Lab ID: 2504228-013	Client Sample ID	20831700-084BF		Collection Date: 4/4/2025 5:06:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Lab ID: 2504228-014	Client Sample ID 20831700-085BF	Collection Date: 4/4/2025 5:07:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#:	2504228	Received Date:	4/4/2025 11:38:00 AM
CLIENT:	Springfield School District #19	Sampler Name	Mario Rodriguez and John Ha
Location:		Matrix:	Drinking Water
Project:	Springfield SD Agnes Stewart	Treatment:	
Sample Source:			

Lab ID:	2504228-015	Client Sample ID	20831700-086BF	Collection Date:	4/4/2025 5:08:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Lab ID:	2504228-016	Client Sample ID	20831700-088BF	Collection Date:	4/4/2025 5:09:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG

Lab ID:	2504228-017	Client Sample ID	20831700-090BF	Collection Date:	4/4/2025 5:10:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 4:08:00 PM	KG



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504228

Date: 4/18/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2504228
 18-Apr-25

Client: Springfield School District #19
Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504228-001A	20831700-071DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504228-002A	20831700-072CF			Lead	A
	2504228-003A	20831700-073DW			Lead	A
	2504228-004A	20831700-074CF			Lead	A
	2504228-005A	20831700-075DW			Lead	A
	2504228-006A	20831700-076CF			Lead	A
	2504228-007A	20831700-077DW			Lead	A
	2504228-008A	20831700-078DW			Lead	A
	2504228-009A	20831700-079DW			Lead	A
	2504228-010A	20831700-080CF			Lead	A
	2504228-011A	20831700-081DW			Lead	A
	2504228-012A	20831700-082BF			Lead	A
	2504228-013A	20831700-084BF			Lead	A
	2504228-014A	20831700-085BF			Lead	A
	2504228-015A	20831700-086BF			Lead	A
	2504228-016A	20831700-088BF			Lead	A
	2504228-017A	20831700-090BF			Lead	A



*Delivering more than
just test results.*

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: BK
Checked: FM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>MARIO RODRIGUEZ</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-064CF	DW/Grab	4.4.25	6:05	Lead	P	1			*
20831700-065DW	DW/Grab		6:06	Lead	P	1			*
20831700-066CF	DW/Grab		6:07	Lead	P	1			*
20831700-067DW	DW/Grab		6:07	Lead	P	1			*
20831700-068CF	DW/Grab		6:09	Lead	P	1			*
20831700-069DW	DW/Grab		6:09	Lead	P	1			*
20831700-070CF	DW/Grab		6:10	Lead	P	1			*
20831700-071DW	DW/Grab		6:10	Lead	P	1		NA	001A
20831700-072CF	DW/Grab		6:12	Lead	P	1		NA	002A

Notes: * Samples not relinquished. Written over by client, lined out by lab. BK 4/4/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	<u>Mario</u>	Ice	IR <u>None</u> IR <u>NA</u>

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Umar Rodriguez</u>			<u>[Signature]</u>	4/4/25	11:38



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: BK
Checked: FM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>MARIO RODRIGUEZ</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-073DW	DW/Grab	4.4.25	6:12	Lead	P	1		NA	003A
20831700-074CF	DW/Grab		6:13	Lead	P	1			004A
20831700-075DW	DW/Grab		6:13	Lead	P	1			005A
20831700-076CF	DW/Grab		6:14	Lead	P	1			006A
20831700-077DW	DW/Grab		6:15	Lead	P	1			007A
20831700-078DW	DW/Grab			Lead	P	1			*
20831700-079DW	DW/Grab			Lead	P	1			*
20831700-080CF	DW/Grab			Lead	P	1			*
20831700-081CF	DW/Grab			Lead	P	1			*

Notes: * Samples not relinquished. Written over by client. Lined out by lab. BK 4/4/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	<u>Mario</u>	Ice	IR <u>None</u> IR <u>NA</u>

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Terry Rutledge</u>			<u>[Signature]</u>	<u>4/4/25</u>	<u>11:38</u>



*Delivering more than
just test results.*

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.comLIMS: BKChecked: EM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>John Harshberger</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
* 20831700-073DW	DW/Grab	5	4:59	Lead	P	1			*
* 20831700-074CF	DW/Grab			Lead	P	1			*
* 20831700-075DW	DW/Grab			Lead	P	1			*
* 20831700-076CF	DW/Grab			Lead	P	1			*
* 20831700-077DW	DW/Grab			Lead	P	1			*
20831700-078DW	DW/Grab	4/4	4:59	Lead	P	1		NA	008A
20831700-079DW	DW/Grab	4/4	5:01	Lead	P	1			009A
20831700-080CF	DW/Grab	4/4	5:03	Lead	P	1			010A
20831700-081DW	DW/Grab	4/4	5:03	Lead	P	1			011A

Notes: *Samples not Relinquished, written over by client, lined out by Lab. BK 4/4/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	<u>Mario</u>	Ice	IR <u>None</u> IR <u>NA</u>

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Therese Rutledge</u>			<u>[Signature]</u>	4/4/25	11:38



*Delivering more than
just test results*

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

BK

Checked:

FM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>JOHN HARSHBERGER</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-082BF	DW/Grab	4/4	5:05	Lead	P	1		NA	012A
* 20831700-083BF	DW/Grab			Lead	P	1			*
20831700-084BF	DW/Grab	4/4	5:06	Lead	P	1		NA	013A
20831700-085BF	DW/Grab	4/4	5:07	Lead	P	1		NA	014A
20831700-086BF	DW/Grab	4/4	5:08	Lead	P	1		NA	015A
* 20831700-087BF	DW/Grab			Lead	P	1			*
20831700-088BF	DW/Grab	4/4	5:09	Lead	P	1		NA	016A
* 20831700-089BF	DW/Grab			Lead	P	1			*
20831700-090BF	DW/Grab	4/4	5:10	Lead	P	1		NA	017A

Notes: *Samples not relinquished. Lined out by client and lab. BK 4/4/25	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH		Shipped Via: <u>Mario</u>		Refrigerated Ice IR None IR <u>NA</u>	
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Therese Rutledge</u>			<u>[Signature]</u>	4/4/25	11:38



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 17, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504226

Dear Terry Rutledge:

Analytical Laboratory Group received 13 sample(s) on 4/4/2025 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504226

Date: 4/17/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504226
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 11:38:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504226-001	Client Sample ID	20831700-091CF		Collection Date: 4/4/2025 5:12:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-002	Client Sample ID 20831700-092CF	Collection Date: 4/4/2025 5:13:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-003	Client Sample ID	20831700-093CF		Collection Date: 4/4/2025 5:14:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-004	Client Sample ID 20831700-094CF	Collection Date: 4/4/2025 5:14:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.11	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-005	Client Sample ID 20831700-095CF	Collection Date: 4/4/2025 5:15:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-006	Client Sample ID	20831700-096CF		Collection Date: 4/4/2025 5:15:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-007	Client Sample ID	20831700-097CF		Collection Date: 4/4/2025 5:17:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2504226
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/4/2025 11:38:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504226-008	Client Sample ID 20831700-098DW	Collection Date: 4/4/2025 5:17:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-009	Client Sample ID 20831700-099CF	Collection Date: 4/4/2025 5:19:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-010	Client Sample ID 20831700-100DW	Collection Date: 4/4/2025 5:20:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/17/2025 9:52:00 AM	KG

Lab ID: 2504226-011	Client Sample ID 20831700-101CF	Collection Date: 4/4/2025 5:21:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Lab ID: 2504226-012	Client Sample ID 20831700-102DW	Collection Date: 4/4/2025 5:21:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Lab ID: 2504226-013	Client Sample ID 20831700-103CF	Collection Date: 4/4/2025 5:22:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/16/2025 8:31:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504226

Date: 4/17/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2504226
17-Apr-25

Client: Springfield School District #19
Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504226-001A	20831700-091CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504226-002A	20831700-092CF			Lead	A
	2504226-003A	20831700-093CF			Lead	A
	2504226-004A	20831700-094CF			Lead	A
	2504226-005A	20831700-095CF			Lead	A
	2504226-006A	20831700-096CF			Lead	A
	2504226-007A	20831700-097CF			Lead	A
	2504226-008A	20831700-098DW			Lead	A
	2504226-009A	20831700-099CF			Lead	A
	2504226-010A	20831700-100DW			Lead	A
	2504226-011A	20831700-101CF			Lead	A
	2504226-012A	20831700-102DW			Lead	A
	2504226-013A	20831700-103CF			Lead	A



Delivering more than
just data/results.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: FM
Checked: BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>John HASTBERGER</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-091CF	DW/Grab	4/4	5:12	Lead	P	1		NA	001A
20831700-092CF	DW/Grab	4/4	5:13	Lead	P	1			002A
20831700-093CF	DW/Grab	4/4	5:14	Lead	P	1			003A
20831700-094CF	DW/Grab	4/4	5:14	Lead	P	1			004A
20831700-095CF	DW/Grab	4/4	5:15	Lead	P	1			005A
20831700-096CF	DW/Grab	4/4	5:15	Lead	P	1			006A
20831700-097CF	DW/Grab	4/4	5:17	Lead	P	1			007A
20831700-098DW	DW/Grab	4/4	5:17	Lead	P	1			008A
20831700-099CF	DW/Grab	4/4	5:19	Lead	P	1			009A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via: <u>Mario</u>	Refrigerated		
☒ NORMAL	☐ RUSH		Ice	IR <u>None</u> IR <u>NA</u>	
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <u>Mari Rutledge</u>	Date	Time	Received by Laboratory: <u>[Signature]</u>	Date	Time
				4/4/15	Page 7 of 8 : 38



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: FM
Checked: BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>John Harshberger</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-100DW	DW/Grab	4/4	5:20	Lead	P	1		NA	010A
20831700-101CF	DW/Grab	4/4	5:21	Lead	P	1			011A
20831700-102DW	DW/Grab	4/4	5:21	Lead	P	1			012A
20831700-103CF	DW/Grab	4/4	5:22	Lead	P	1			013A
20831700-104DW	DW/Grab	4/4	5:22	Lead	P	1			*
20831700-105CF	DW/Grab	4/4	5:24	Lead	P	1			*
20831700-106DW	DW/Grab	4/4	5:24	Lead	P	1			*
20831700-107CF	DW/Grab	4/4	5:25	Lead	P	1			*
20831700-108DW	DW/Grab	4/4	5:25	Lead	P	1			*

Notes: * Samples not relinquished. Crossed out by client, lined out by lab. BK 4/4/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	<u>Mario</u>	Ice	IR ☒ NA

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
<u>Marki Rutledge</u>			<u>[Signature]</u>	4/4/25	11:38



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

April 22, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504253

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 4/7/2025 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia'.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504253

Date: 4/22/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504253
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504253-001	Client Sample ID	20831700-104DW			Collection Date: 4/4/2025 5:22:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-002	Client Sample ID	20831700-105CF		Collection Date: 4/4/2025 5:24:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-003	Client Sample ID	20831700-106DW		Collection Date: 4/4/2025 5:24:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-004	Client Sample ID 20831700-107CF	Collection Date: 4/4/2025 5:25:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-005	Client Sample ID 20831700-108DW	Collection Date: 4/4/2025 5:25:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-006	Client Sample ID 20831700-109CF	Collection Date: 4/4/2025 5:27:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-007	Client Sample ID	20831700-110DW		Collection Date: 4/4/2025 5:28:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2504253
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504253-008	Client Sample ID	20831700-111CF		Collection Date: 4/4/2025 5:31:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-009	Client Sample ID	20831700-112DW		Collection Date: 4/4/2025 5:31:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-010	Client Sample ID	20831700-113BF		Collection Date: 4/4/2025 5:32:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-011	Client Sample ID	20831700-116BF		Collection Date: 4/4/2025 5:33:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-012	Client Sample ID 20831700-117BF	Collection Date: 4/4/2025 5:35:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-013	Client Sample ID 20831700-118BF	Collection Date: 4/4/2025 5:36:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-014	Client Sample ID	20831700-119BF		Collection Date: 4/4/2025 5:37:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2504253
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504253-015	Client Sample ID	20831700-121BF		Collection Date: 4/4/2025 5:38:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.31	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-016	Client Sample ID	20831700-122CF		Collection Date: 4/4/2025 5:39:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-017	Client Sample ID	20831700-123CF		Collection Date: 4/4/2025 5:40:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.67	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-018	Client Sample ID	20831700-124CF		Collection Date: 4/4/2025 5:40:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-019	Client Sample ID	20831700-125CF		Collection Date: 4/4/2025 5:40:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.36	15.0	2.00		ppb	4/21/2025 10:20:00 AM	AS

Lab ID: 2504253-020	Client Sample ID 20831700-126CF	Collection Date: 4/4/2025 5:41:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.54	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504253

Date: 4/22/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2504253

22-Apr-25

Client: Springfield School District #19

Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504253-001A	20831700-104DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504253-002A	20831700-105CF			Lead	A
	2504253-003A	20831700-106DW			Lead	A
	2504253-004A	20831700-107CF			Lead	A
	2504253-005A	20831700-108DW			Lead	A
	2504253-006A	20831700-109CF			Lead	A
	2504253-007A	20831700-110DW			Lead	A
	2504253-008A	20831700-111CF			Lead	A
	2504253-009A	20831700-112DW			Lead	A
	2504253-010A	20831700-113BF			Lead	A
	2504253-011A	20831700-116BF			Lead	A
	2504253-012A	20831700-117BF			Lead	A
	2504253-013A	20831700-118BF			Lead	A
	2504253-014A	20831700-119BF			Lead	A
	2504253-015A	20831700-121BF			Lead	A
	2504253-016A	20831700-122CF			Lead	A
	2504253-017A	20831700-123CF			Lead	A
	2504253-018A	20831700-124CF			Lead	A
	2504253-019A	20831700-125CF			Lead	A
	2504253-020A	20831700-126CF			Lead	A

ACCRED
ORELAP A Accredited



*Measuring more than
just test results*

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.comLIMS: FMChecked: BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>John Harshbarger</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-100DW	DW/Grab	4/4	5:20	Lead	P	1			
20831700-101CF	DW/Grab	4/4	5:21	Lead	P	1			
20831700-102DW	DW/Grab	4/4	5:21	Lead	P	1			
20831700-103CF	DW/Grab	4/4	5:22	Lead	P	1			
20831700-104DW	DW/Grab	4/4	5:22	Lead	P	1		NA	001A
20831700-105CF	DW/Grab	4/4	5:24	Lead	P	1			002A
20831700-106DW	DW/Grab	4/4	5:24	Lead	P	1			003A
20831700-107CF	DW/Grab	4/4	5:25	Lead	P	1			004A
20831700-108DW	DW/Grab	4/4	5:25	Lead	P	1			005A

Notes: * Samples not received; lined out by Lab. FM 4/3/15	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	<u>Mario</u>	Ice	IR <u>None</u> IR <u>NA</u>

Relinquished by:	Date	Time	Received by:	Date	Time
<u>Thane Rutledge</u>					
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>Smith</u>	4/4/15	9:05



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>John H. Rutledge</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-109CF	DW/Grab	4/4	5:27	Lead	P	1		NA	006A
20831700-110DW	DW/Grab	4/4	5:28	Lead	P	1		I	007A
20831700-111CF	DW/Grab			Lead	P	1			
20831700-112DW	DW/Grab			Lead	P	1			
20831700-113BT	DW/Grab			Lead	P	1			
20831700-114BT	DW/Grab			Lead	P	1			
20831700-115BT	DW/Grab			Lead	P	1			
20831700-116BT	DW/Grab			Lead	P	1			
20831700-117BT	DW/Grab			Lead	P	1			

Notes: <i>*Samples not received. Marked out by client, lined out by lab. FM 4/7/25</i>	PAID Receipt # CC CK Cash	Preservation Check				
	REPORT Mail Email Fax Pickup	Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH	Shipped Via: <u>Mario</u>	Refrigerated Ice IR <u>None</u> IR <u>NA</u>
---	------------------------------	--

Relinquished by: <u>Mark Rutledge</u>	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>John H. Rutledge</u>	<u>4/4/25</u>	<u>19:05</u>



*Delivering faster than
your test results.*

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.comLIMS: FMChecked: pol

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge

Company: Springfield School District

Phone: (541) 744-6375

Address: 1890 North 42nd Street

Email: terry.rutledge@springfield.k12.or.us

City, State, Zip: Springfield, OR 97477

Client Project: Springfield SD Agnes Stewart

Sampler Name: John Harshberger

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-108CF	DW/Grab			Lead	P	1			
20831700-110DW	DW/Grab			Lead	P	1			
20831700-111CF	DW/Grab	4/4	5:31	Lead	P	1		NA	008A
20831700-112DW	DW/Grab	4/4	5:31	Lead	P	1			009A
20831700-113BF	DW/Grab	4/4	5:32	Lead	P	1			010A
20831700-114BF	DW/Grab		5:33	Lead	P	1			
20831700-115BF	DW/Grab			Lead	P	1			
20831700-116BF	DW/Grab	4/4	5:33	Lead	P	1		NA	011A
20831700-117BF	DW/Grab	4/4	5:35	Lead	P	1			012A

Notes:

*Samples not received. Marked out by client, lined out by lab. FM 4/7/25

PAID

Receipt #

CC

CK

Cash

REPORT

Mail

Email

Fax

Pickup

Preservation Check

Lab ID

Date/Time

Pre-Preserved

pH

Tech

Turn Around Time Requested (Rush incurs a Surcharge):

☒ NORMAL☐ RUSH

Shipped Via:

Mario

Refrigerated

Ice

IR

None

NA

Relinquished by:

Date Time

Relinquished by:

Date Time

Relinquished by:

Date Time

Received by:

Date Time

Received by:

Date Time

Received by Laboratory:

Date Time

4/7/25 9:05



*Delivering more than
just test results*

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

FM

Checked:

BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge		Company: Springfield School District	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield, OR 97477	
Client Project: Springfield SD Agnes Stewart		Sampler Name: <u>John Harshberger</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-118BF	DW/Grab	4/4	5:36	Lead	P	1		NA	013A
20831700-119BF	DW/Grab	4/4	5:37	Lead	P	1		↓	014A
20831700-120BF	DW/Grab			Lead	P	1			
20831700-121BF	DW/Grab	4/4	5:38	Lead	P	1		NA	015A
20831700-122CF	DW/Grab	4/4	5:39	Lead	P	1			016A
20831700-123CF	DW/Grab	4/4	5:40	Lead	P	1			017A
20831700-124CF	DW/Grab	4/4	5:40	Lead	P	1			018A
20831700-125CF	DW/Grab	4/4	5:40	Lead	P	1			019A
20831700-126CF	DW/Grab	4/4	5:41	Lead	P	1		↓	020A

Notes: *Sample not received; lined out by client and lab. FM 4/7/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH		Shipped Via: <u>Marino</u>		Refrigerated Ice IR <u>None</u> IR NA	
--	--	--------------------------------------	--	---	--

Relinquished by: <u>Mark Holberg</u>	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory: <u>Will</u>	Date	Time

Page 11 of 19:05
 4/7/25



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 22, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504254

Dear Terry Rutledge:

Analytical Laboratory Group received 18 sample(s) on 4/7/2025 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504254

Date: 4/22/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504254
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504254-001	Client Sample ID	20831700-127CF		Collection Date: 4/4/2025 5:42:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-002	Client Sample ID 20831700-128CF	Collection Date: 4/4/2025 5:43:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-003	Client Sample ID	20831700-129DW		Collection Date: 4/4/2025 5:43:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-004	Client Sample ID 20831700-130CF	Collection Date: 4/4/2025 5:44:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-005	Client Sample ID 20831700-131DW	Collection Date: 4/4/2025 5:45:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-006	Client Sample ID	20831700-132CF		Collection Date: 4/4/2025 5:46:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-007	Client Sample ID	20831700-133DW		Collection Date: 4/4/2025 5:46:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2504254
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504254-008	Client Sample ID	20831700-134CF		Collection Date: 4/4/2025 5:47:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.30	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-009	Client Sample ID	20831700-135DW		Collection Date: 4/4/2025 5:48:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-010	Client Sample ID	20831700-136CF		Collection Date: 4/4/2025 5:49:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-011	Client Sample ID	20831700-137DW		Collection Date: 4/4/2025 5:50:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-012	Client Sample ID	20831700-138CF		Collection Date: 4/4/2025 5:51:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-013	Client Sample ID 20831700-139DW	Collection Date: 4/4/2025 5:51:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-014	Client Sample ID	20831700-140CF		Collection Date: 4/4/2025 5:52:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2504254
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504254-015	Client Sample ID 20831700-141DW	Collection Date: 4/4/2025 5:53:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-016	Client Sample ID 20831700-142DW	Collection Date: 4/4/2025 5:59:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-017	Client Sample ID 20831700-143DW	Collection Date: 4/4/2025 6:00:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Lab ID: 2504254-018	Client Sample ID 20831700-144BF	Collection Date: 4/4/2025 6:01:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/21/2025 1:56:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504254

Date: 4/22/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2504254

22-Apr-25

Client: Springfield School District #19

Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504254-001A	20831700-127CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504254-002A	20831700-128CF			Lead	A
	2504254-003A	20831700-129DW			Lead	A
	2504254-004A	20831700-130CF			Lead	A
	2504254-005A	20831700-131DW			Lead	A
	2504254-006A	20831700-132CF			Lead	A
	2504254-007A	20831700-133DW			Lead	A
	2504254-008A	20831700-134CF			Lead	A
	2504254-009A	20831700-135DW			Lead	A
	2504254-010A	20831700-136CF			Lead	A
	2504254-011A	20831700-137DW			Lead	A
	2504254-012A	20831700-138CF			Lead	A
	2504254-013A	20831700-139DW			Lead	A
	2504254-014A	20831700-140CF			Lead	A
	2504254-015A	20831700-141DW			Lead	A
	2504254-016A	20831700-142DW			Lead	A
	2504254-017A	20831700-143DW			Lead	A
	2504254-018A	20831700-144BF			Lead	A

ACCRED
ORELAP A Accredited

Original #2504254# v1

Page 7 of 10



*Delivering precise data -
just best results*

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: BK
Checked: EM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>John Harshberger</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-127CF	DW/Grab	4/4	5:42	Lead	P	1		NA	001A
20831700-128CF	DW/Grab	4/4	5:43	Lead	P	1			002A
20831700-129DW	DW/Grab	4/4	5:43	Lead	P	1			003A
20831700-130CF	DW/Grab	4/4	5:44	Lead	P	1			004A
20831700-131DW	DW/Grab	4/4	5:45	Lead	P	1			005A
20831700-132CF	DW/Grab	4/4	5:46	Lead	P	1			006A
20831700-133DW	DW/Grab	4/4	5:46	Lead	P	1			007A
20831700-134CF	DW/Grab	4/4	5:47	Lead	P	1			008A
20831700-135DW	DW/Grab	4/4	5:48	Lead	P	1			009A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
☒ NORMAL	☐ RUSH	<u>Maric</u>		Ice	IR <u>None</u> IR <u>NA</u>
Relinquished by:	Date Time	Received by:	Date	Time	
<u>Mark Rodriguez</u>					
Relinquished by:	Date Time	Received by:	Date	Time	
Relinquished by:	Date Time	Received by Laboratory:	Date	Time	
		<u>John</u>	<u>4/4/05</u>	<u>9:05</u>	



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: BK
Checked: EM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge	Company: Springfield School District
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client Project: Springfield SD Agnes Stewart	Sampler Name: <u>John Harshbarger</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-136CF	DW/Grab	4/4	5:49	Lead	P	1		NA	010A
20831700-137DW	DW/Grab	4/4	5:50	Lead	P	1			011A
20831700-138CF	DW/Grab	4/4	5:51	Lead	P	1			012A
20831700-139DW	DW/Grab	4/4	5:51	Lead	P	1			013A
20831700-140CF	DW/Grab	4/4	5:52	Lead	P	1			014A
20831700-141DW	DW/Grab	4/4	5:53	Lead	P	1			015A
* 20831700-142DW	DW/Grab			Lead	P	1			
* 20831700-143DW	DW/Grab			Lead	P	1			
* 20831700-144DW	DW/Grab			Lead	P	1			

Notes: *Samples not relinquished, lined out by Lab. BK 4/7/25	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated	
☒ NORMAL ☐ RUSH	<u>Marion</u>	Ice	IR <u>None</u> NA
Relinquished by:	Date	Time	Received by:
<u>Mark Rutledge</u>			
Relinquished by:	Date	Time	Received by:
Relinquished by:	Date	Time	Received by Laboratory:
			<u>John Harshbarger</u>
			Date/Time: <u>4/7/25 9:05</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: BK
Checked: EM

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge		Company: Springfield School District	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield, OR 97477	
Client Project: Springfield SD Agnes Stewart		Sampler Name: <u>John Harshberger</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
* 20831700-136CF	DW/Grab			Lead	P	1			*
* 20831700-137BW	DW/Grab			Lead	P	1			*
* 20831700-138CF	DW/Grab			Lead	P	1			*
* 20831700-139BW	DW/Grab			Lead	P	1			*
* 20831700-140CF	DW/Grab			Lead	P	1			*
* 20831700-141BW	DW/Grab			Lead	P	1			*
20831700-142DW	DW/Grab	4/4	5:59	Lead	P	1		NA	016A
20831700-143DW	DW/Grab	4/4	6:00	Lead	P	1			017A
20831700-144BF	DW/Grab	4/4	6:01	Lead	P	1			018A

Notes: *Samples not relinquished, turned out by lab. BK 4/2/25	PAID		Preservation Check			
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH		Shipped Via: <u>Mario</u>		Refrigerated Ice IR <u>None</u> IR	
--	--	-------------------------------------	--	---	--

Relinquished by: <u>Mark Rodriguez</u>	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory: <u>Jaill</u>	Date	Time
				4/7/25	9:05



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

April 18, 2025

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Agnes Stewart

Order No.: 2504252

Dear Terry Rutledge:

Analytical Laboratory Group received 17 sample(s) on 4/7/2025 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2504252

Date: 4/18/2025

CLIENT: Springfield School District #19

Project: Springfield SD Agnes Stewart

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2504252
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504252-001	Client Sample ID 20831700-145BF	Collection Date: 4/4/2025 6:02:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.71	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-002	Client Sample ID 20831700-146BF	Collection Date: 4/4/2025 6:03:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.08	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-003	Client Sample ID 20831700-147BF	Collection Date: 4/4/2025 6:03:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.22	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-004	Client Sample ID 20831700-148BF	Collection Date: 4/4/2025 6:04:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.62	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-005	Client Sample ID 20831700-149BF	Collection Date: 4/4/2025 6:05:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.75	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-006	Client Sample ID 20831700-150BF	Collection Date: 4/4/2025 6:06:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-007	Client Sample ID 20831700-151BF	Collection Date: 4/4/2025 6:07:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2504252
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504252-008	Client Sample ID	20831700-152BF		Collection Date: 4/4/2025 6:07:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-009	Client Sample ID	20831700-153BF		Collection Date: 4/4/2025 6:08:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.05	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-010	Client Sample ID	20831700-154BF		Collection Date: 4/4/2025 6:10:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-011	Client Sample ID	20831700-155BF		Collection Date: 4/4/2025 6:10:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-012	Client Sample ID	20831700-156BF		Collection Date: 4/4/2025 6:11:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-013	Client Sample ID 20831700-157BF	Collection Date: 4/4/2025 6:13:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-014	Client Sample ID	20831700-158BF		Collection Date: 4/4/2025 6:15:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.90	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2504252
CLIENT: Springfield School District #19
Location:
Project: Springfield SD Agnes Stewart
Sample Source:

Received Date: 4/7/2025 9:05:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2504252-015	Client Sample ID 20831700-159BF	Collection Date: 4/4/2025 6:15:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-016	Client Sample ID 20831700-160BF	Collection Date: 4/4/2025 6:16:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Lab ID: 2504252-017	Client Sample ID 20831700-161BF	Collection Date: 4/4/2025 6:17:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.25	15.0	2.00		ppb	4/18/2025 1:07:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2504252

Date: 4/18/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2504252

18-Apr-25

Client: Springfield School District #19

Project: Springfield SD Agnes Stewart

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2504252-001A	20831700-145BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2504252-002A	20831700-146BF			Lead	A
	2504252-003A	20831700-147BF			Lead	A
	2504252-004A	20831700-148BF			Lead	A
	2504252-005A	20831700-149BF			Lead	A
	2504252-006A	20831700-150BF			Lead	A
	2504252-007A	20831700-151BF			Lead	A
	2504252-008A	20831700-152BF			Lead	A
	2504252-009A	20831700-153BF			Lead	A
	2504252-010A	20831700-154BF			Lead	A
	2504252-011A	20831700-155BF			Lead	A
	2504252-012A	20831700-156BF			Lead	A
	2504252-013A	20831700-157BF			Lead	A
	2504252-014A	20831700-158BF			Lead	A
	2504252-015A	20831700-159BF			Lead	A
	2504252-016A	20831700-160BF			Lead	A
	2504252-017A	20831700-161BF			Lead	A

ACCRED
ORELAP A Accredited

Original #2504252# v1

Page 7 of 9



Environmental Testing
Soil Remediation

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: MT
Checked: BK

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge		Company: Springfield School District	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield, OR 97477	
Client Project: Springfield SD Agnes Stewart		Sampler Name: <u>John H. Hershberger</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-145BF	DW/Grab	4/4	6:02	Lead	P	1		NA	001A
20831700-146BF	DW/Grab	4/4	6:03	Lead	P	1			002A
20831700-147BF	DW/Grab	4/4	6:03	Lead	P	1			003A
20831700-148BF	DW/Grab	4/4	6:04	Lead	P	1			004A
20831700-149BF	DW/Grab	4/4	6:05	Lead	P	1			005A
20831700-150BF	DW/Grab	4/4	6:06	Lead	P	1			006A
20831700-151BF	DW/Grab	4/4	6:07	Lead	P	1			007A
20831700-152BF	DW/Grab	4/4	6:07	Lead	P	1			008A
20831700-153BF	DW/Grab	4/4	6:08	Lead	P	1			009A

Notes: 	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH		Shipped Via: <u>Mario</u>		Refrigerated Ice IR <u>None</u> IR <u>NA</u>	
---	--	---------------------------	--	--	--

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>[Signature]</u>	<u>4/4/05</u>	<u>9:05</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com

LIMS:

Checked: BR

DW GENERAL CHAIN OF CUSTODY

Report to: Terry Rutledge		Company: Springfield School District	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield, OR 97477	
Client Project: Springfield SD Agnes Stewart		Sampler Name: <u>John Harstberger</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20831700-154BF	DW/Grab	4/4	6:10	Lead	P	1		NA	010A
20831700-155BF	DW/Grab	4/4	6:10	Lead	P	1			011A
20831700-156BF	DW/Grab	4/4	6:11	Lead	P	1			012A
20831700-157BF	DW/Grab	4/4	6:13	Lead	P	1			013A
20831700-158BF	DW/Grab	4/4	6:15	Lead	P	1			014A
20831700-159BF	DW/Grab	4/4	6:15	Lead	P	1			015A
20831700-160BF	DW/Grab	4/4	6:16	Lead	P	1			016A
20831700-161BF	DW/Grab	4/4	6:17	Lead	P	1			017A
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
☒ NORMAL	☐ RUSH	Mario		Ice	IR
				None	NA

Relinquished by:	Date		Time		Received by:	Date		Time	
Relinquished by:	Date		Time		Received by:	Date		Time	
Relinquished by:	Date		Time		Received by Laboratory:	Date		Time	