

Lead in Water Test Results Summary: Brattain Campus

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes
Staff faucet breakroom	13541800-001SF	3/14/2023	2.51	Low	[enter date]	[enter result]	[autofill]	
Bathroom Faucet nurse office	13541800-002BF	3/14/2023	5.08	Moderate				
Bathroom Faucet Breakroom	13541800-003BF	3/14/2023	3.16	Low				
Nursing room staff faucet	13541800-004SF	3/14/2023	8.19	Moderate				
Boys bathroom faucet across from room 12 (north)	13541800-005BF	3/14/2023	23.9	Action Req.	5/21/2025	3.15	Low	
Boys bathroom faucet	13541800-006BF	3/14/2023	10.9	High				
Boys bathroom faucet	13541800-007BF	3/14/2023	5.75	Moderate				
Girls bathroom faucet	13541800-008BF	3/14/2023	11.6	High				
Girls bathroom faucet	13541800-009BF	3/14/2023	5.65	Moderate				
Girls bathroom faucet	13541800-010BF	3/14/2023	26.9	Action Req.	5/21/2025	3.88	Low	
Drinking Fountain between room 13 and 14	13541800-011DW	3/14/2023	ND	Non-Detect				
Water bottle filler	13541800-012WB	3/14/2023	ND	Non-Detect				
Boys bathroom faucet across from room 5 (south)	13541800-013BF	3/14/2023	ND	Non-Detect				
Boys bathroom faucet	13541800-014BF	3/14/2023	ND	Non-Detect				
Girls bathroom faucet	13541800-015BF	3/14/2023	5.3	Moderate				
Girls bathroom faucet	13541800-016BF	3/14/2023	5.36	Moderate				
Girls bathroom faucet	13541800-017BF	3/14/2023	7.33	Moderate				
Drinking Fountain between room 2 and 3	13541800-018DW	3/14/2023	ND	Non-Detect				
Water bottle filler	13541800-019WB	3/14/2023	ND	Non-Detect				
Drinking Fountain in cafeteria	13541800-020DW	3/14/2023	ND	Non-Detect				
Water bottle filler	13541800-021WB	3/14/2023	ND	Non-Detect				
Kitchen Faucet 1	13541800-022WB	3/14/2023	37.5	Action Req.	5/21/2025	3.79	Low	
Kitchen Faucet 2	13541800-023KF	3/14/2023	42.7	Action Req.	5/21/2025	7.74	Moderate	
Kitchen Faucet 3	13541800-024KF	3/14/2023	65.5	Action Req.	5/21/2025	2.88	Low	
Kitchen bathroom faucet	13541800-025BF	3/14/2023	145	Action Req.	5/21/2025	43.4	Action Req.	Faucet shut off

BC



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

April 06, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2303520

Dear Terry Rutledge:

Analytical Laboratory Group received 25 sample(s) on 3/14/2023 for the analyses presented in the following report.

A handwritten signature in black ink that reads "Kimberly J. Reever Morghan".

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2303520

Date: 4/6/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Date Reported: 4/6/2023

WO#: 2303520	Received Date: 3/14/2023 9:39:00 AM
CLIENT: Springfield School District #19	Sampler Name: Veronica Arciga and Jeff Med
Location:	Matrix: Drinking Water
Project: Springfield SD	Treatment:
Sample Source:	

Lab ID: 2303520-001	Client Sample ID: 13541800-001SF	Collection Date: 3/14/2023 5:08:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	2.51 15.0 2.00 ppb 4/3/2023 4:45:00 PM AS

Lab ID: 2303520-002	Client Sample ID: 13541800-002BF	Collection Date: 3/14/2023 5:08:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	5.08 15.0 2.00 ppb 4/3/2023 4:45:00 PM AS

Lab ID: 2303520-003	Client Sample ID: 13541800-003BF	Collection Date: 3/14/2023 5:09:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	3.16 15.0 2.00 ppb 4/3/2023 4:45:00 PM AS

Lab ID: 2303520-004	Client Sample ID: 13541800-004SF	Collection Date: 3/14/2023 5:10:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	8.19 15.0 2.00 ppb 4/3/2023 4:45:00 PM AS

Lab ID: 2303520-005	Client Sample ID: 13541800-005BF	Collection Date: 3/14/2023 5:10:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	23.9 15.0 4.00 * ppb 4/3/2023 4:45:00 PM AS

Lab ID: 2303520-006	Client Sample ID: 13541800-006BF	Collection Date: 3/14/2023 5:11:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	10.9 15.0 2.00 ppb 4/3/2023 4:45:00 PM AS

Lab ID: 2303520-007	Client Sample ID: 13541800-007BF	Collection Date: 3/14/2023 5:12:00 AM
Analyses	Method	Result MCL PQL Qual Units Date Analyzed Analyst
Lead	SM 3113 B	5.75 15.0 2.00 ppb 4/3/2023 4:45:00 PM AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 4/6/2023

WO#: 2303520
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/14/2023 9:39:00 AM
Sampler Name: Veronica Arciga and Jeff Med
Matrix: Drinking Water
Treatment:

Lab ID: 2303520-008 **Client Sample ID:** 13541800-008BF **Collection Date:** 3/14/2023 5:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.6	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303520-009 **Client Sample ID:** 13541800-009BF **Collection Date:** 3/14/2023 5:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.65	15.0	2.00		ppb	4/3/2023 4:45:00 PM	AS

Lab ID: 2303520-010 **Client Sample ID:** 13541800-010BF **Collection Date:** 3/14/2023 5:14:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	26.9	15.0	4.00	*	ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-011 **Client Sample ID:** 13541800-011DW **Collection Date:** 3/14/2023 5:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-012 **Client Sample ID:** 13541800-012WB **Collection Date:** 3/14/2023 5:17:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-013 **Client Sample ID:** 13541800-013BF **Collection Date:** 3/14/2023 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-014 **Client Sample ID:** 13541800-014BF **Collection Date:** 3/14/2023 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

Original
Page 4 of 11

Date Reported: 4/6/2023

WO#: 2303520
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/14/2023 9:39:00 AM
Sampler Name Veronica Arciga and Jeff Med
Matrix: Drinking Water
Treatment:

Lab ID: 2303520-015 **Client Sample ID** 13541800-015BF **Collection Date:** 3/14/2023 5:08:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.30	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-016 **Client Sample ID** 13541800-016BF **Collection Date:** 3/14/2023 5:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.36	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-017 **Client Sample ID** 13541800-017BF **Collection Date:** 3/14/2023 5:10:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.33	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-018 **Client Sample ID** 13541800-018DW **Collection Date:** 3/14/2023 5:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-019 **Client Sample ID** 13541800-019WB **Collection Date:** 3/14/2023 5:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-020 **Client Sample ID** 13541800-020DW **Collection Date:** 3/14/2023 5:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Lab ID: 2303520-021 **Client Sample ID** 13541800-021WB **Collection Date:** 3/14/2023 5:14:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	4/5/2023 5:17:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#:	2303520	Received Date:	3/14/2023 9:39:00 AM
CLIENT:	Springfield School District #19	Sampler Name	Veronica Arciga and Jeff Med
Location:		Matrix:	Drinking Water
Project:	Springfield SD	Treatment:	
Sample Source:			

Lab ID: 2303520-022 **Client Sample ID** 13541800-022WB **Collection Date:** 3/14/2023 5:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	37.5	15.0	4.00	*	ppb	3/30/2023 5:03:00 PM	AS

Lab ID: 2303520-023 **Client Sample ID** 13541800-023KF **Collection Date:** 3/14/2023 5:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	42.7	15.0	8.00	*	ppb	3/30/2023 5:03:00 PM	AS

Lab ID: 2303520-024 **Client Sample ID** 13541800-024KF **Collection Date:** 3/14/2023 5:17:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	65.5	15.0	8.00	*	ppb	3/30/2023 5:03:00 PM	AS

Lab ID: 2303520-025 **Client Sample ID** 13541800-025BF **Collection Date:** 3/14/2023 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	145	15.0	20.0	*	ppb	3/30/2023 5:03:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2303520

Date: 4/6/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303520

06-Apr-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303520-001A	13541800-001SF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303520-002A	13541800-002BF			Lead	A
	2303520-003A	13541800-003BF			Lead	A
	2303520-004A	13541800-004SF			Lead	A
	2303520-005A	13541800-005BF			Lead	A
	2303520-006A	13541800-006BF			Lead	A
	2303520-007A	13541800-007BF			Lead	A
	2303520-008A	13541800-008BF			Lead	A
	2303520-009A	13541800-009BF			Lead	A
	2303520-010A	13541800-010BF			Lead	A
	2303520-011A	13541800-011DW			Lead	A
	2303520-012A	13541800-012WB			Lead	A
	2303520-013A	13541800-013BF			Lead	A
	2303520-014A	13541800-014BF			Lead	A
	2303520-015A	13541800-015BF			Lead	A
	2303520-016A	13541800-016BF			Lead	A
	2303520-017A	13541800-017BF			Lead	A
	2303520-018A	13541800-018DW			Lead	A
	2303520-019A	13541800-019WB			Lead	A
	2303520-020A	13541800-020DW			Lead	A
	2303520-021A	13541800-021WB			Lead	A
	2303520-022A	13541800-022WB			Lead	A
	2303520-023A	13541800-023KF			Lead	A
	2303520-024A	13541800-024KF			Lead	A
	2303520-025A	13541800-025BF			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2303520# v1

Page 8 of 11



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge			Company: Springfield School District #19		
Phone: (541) 744-6375			Address: 1890 North 42nd Street		
Email: terry.rutledge@springfield.k12.or.us			City, State, Zip: Springfield Or, 97477		
Client Project: Springfield SD			Sampler Name: <u>Veronica Arciga</u>		

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
13541800-001SF	DW/Grab	3/14/23	0508	Lead	P	1		NA	001A
13541800-002BF	DW/Grab	}	0508	Lead	P	1			002A
13541800-003BF	DW/Grab		0509	Lead	P	1			003A
13541800-004SF	DW/Grab		0510	Lead	P	1			004A
13541800-005BF	DW/Grab		0510	Lead	P	1			005A
13541800-006BF	DW/Grab		0511	Lead	P	1			006A
13541800-007BF	DW/Grab		0512	Lead	P	1			007A
13541800-008BF	DW/Grab		0512	Lead	P	1			008A
13541800-009BF	DW/Grab		0513	Lead	P	1			009A
13541800-010BF	DW/Grab		0514	Lead	P	1			010A

Notes: <u>*Corrected by client. FM 3/14/23</u>		PAID		Preservation Check				
Receipt #		Lab ID		Date/Time	Pre-Preserved	pH	Tech	
CC								
CK								
Cash								
REPORT								
Mail								
Email								
Fax								
Pickup								

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ ☒ None	

Relinquished by:	Date	Time	Received by:	Date	Time
<u>Veronica Arciga</u>	<u>3/14/23</u>				
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>[Signature]</u>	<u>3/14/23</u>	<u>9:39</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>JEFF MEDINA</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
13541800-011DW	DW/Grab	3/14/23	0516	Lead	P	1		NA	011A
13541800-012WB	DW/Grab		0517	Lead	P	1			012A
13541800-013BF	DW/Grab		0518	Lead	P	1			013A
13541800-014BF	DW/Grab		0518	Lead	P	1			014A
13541800-015BF	DW/Grab		05:08	Lead	P	1			015A
13541800-016BF	DW/Grab		05:09	Lead	P	1			016A
13541800-017BF	DW/Grab		05:10	Lead	P	1			017A
13541800-018DW	DW/Grab		05:11	Lead	P	1			018A
13541800-019WB	DW/Grab		05:12	Lead	P	1			019A
13541800-020DW	DW/Grab		05:13	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush Incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☒ None	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	3/14					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	3/14/23	9:39	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: RP

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield, Or, 97477
Client Project: Springfield SD	Sampler Name: <u>JEFF MEDINA</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
13541800-021WB	DW/Grab	3/14/23	05:14	Lead	P	1			021A
13541800-022WB	DW/Grab		05:15	Lead	P	1			022A
13541800-023KF	DW/Grab		05:16	Lead	P	1			023A
13541800-024KF	DW/Grab		05:17	Lead	P	1			024A
13541800-025BF	DW/Grab		05:18	Lead	P	1			025A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		☐ Ice ☒ None	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	3/14					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	3/14/23	9:39	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

May 27, 2025

John Harshberger
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 979-9667
FAX:

RE: Springfield SD 19 Brattain Campus

Order No.: 2505703

Dear John Harshberger:

Analytical Laboratory Group received 6 sample(s) on 5/21/2025 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia' in a cursive script.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2505703

Date: 5/27/2025

CLIENT: Springfield School District #19
Project: Springfield SD 19 Brattain Campus

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results

ALG ORELAP ID #ORI00012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Analytical Report

Date Reported: 5/27/2025

WO#: 2505703
CLIENT: Springfield School District #19
Location:
Project: Springfield SD 19 Brattain Campus
Sample Source:

Received Date: 5/21/2025 8:10:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2505703-001 Client Sample ID 13541800-022WB Collection Date: 5/21/2025 6:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.79	15.0	2.00		ppb	5/23/2025 7:51:00 PM	AS

Lab ID: 2505703-002 Client Sample ID 13541800-023KF Collection Date: 5/21/2025 6:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.74	15.0	2.00		ppb	5/23/2025 7:51:00 PM	AS

Lab ID: 2505703-003 Client Sample ID 13541800-024KF Collection Date: 5/21/2025 6:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.88	15.0	2.00		ppb	5/23/2025 7:51:00 PM	AS

Lab ID: 2505703-004 Client Sample ID 13541800-025BF Collection Date: 5/21/2025 6:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	43.4	15.0	8.00	*	ppb	5/23/2025 7:51:00 PM	AS

Lab ID: 2505703-005 Client Sample ID 13541800-010BF Collection Date: 5/21/2025 6:25:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.88	15.0	2.00		ppb	5/23/2025 7:51:00 PM	AS

Lab ID: 2505703-006 Client Sample ID 13541800-005BF Collection Date: 5/21/2025 6:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.15	15.0	2.00		ppb	5/23/2025 7:51:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)
C Value is below Minimum Compound Limit.
H Holding times for preparation or analysis exceeded
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PQL Practical Quantitation Level or Reporting Limit

A Accredited by ORELAP
E Value above quantitation range
LOD Limit of Detection
NAR See note in Case Narrative
PL Permit Limit
R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2505703
Date: 5/27/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2505703

27-May-25

Client: Springfield School District #19
Project: Springfield SD 19 Brattain Campus

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2505703-001A	13541800-022WB	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2505703-002A	13541800-023KF			Lead	A
	2505703-003A	13541800-024KF			Lead	A
	2505703-004A	13541800-025BF			Lead	A
	2505703-005A	13541800-010BF			Lead	A
	2505703-006A	13541800-005BF			Lead	A

ORELAP A Accredited

ACCRED

Original #2505703# v1

Page 5 of 6