

Lead in Water Test Results Summary: Briggs Middle School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red** and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange** and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow** and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted** and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes
Front office Staff bathroom faucet 1	05421400-001SF	2/13/2024	ND	Non-Detect	[enter date]	[enter result]	[autofill]	
Staff bathroom faucet 1	05421400-002BF	2/13/2024	2.22	Low				
Nurse office bathroom faucet 1	05421400-003BF	2/13/2024	3.05	Low				
Nurse office sink	05421400-004NS	2/13/2024	3.75	Low				
T.A.B room bathroom faucet	05421400-005BF	2/13/2024	ND	Non-Detect				
Library staff room sink	05421400-006SF	2/13/2024	ND	Non-Detect				
Classroom 2 classroom faucet	05421400-007CF	2/13/2024	4.68	Low				
Boys bathroom faucet	05421400-008BF	2/13/2024	ND	Non-Detect				
Boys bathroom faucet	05421400-009BF	2/13/2024	ND	Non-Detect				
Drinking fountain	05421400-010DW	2/13/2024	ND	Non-Detect				
Water fill station	05421400-011WB	2/13/2024	ND	Non-Detect				
Girls bathroom faucet	05421400-012BF	2/13/2024	ND	Non-Detect				
Girls bathroom faucet	05421400-013BF	2/13/2024	ND	Non-Detect				
Staff room between class room 6 & 7 faucet	05421400-014SF	2/13/2024	ND	Non-Detect				
Classroom 3 faucet	05421400-015CF	2/13/2024	6.41	Moderate				
Classroom 4 faucet	05421400-016CF	2/13/2024	7.65	Moderate				
Classroom 4 drinking fountain	05421400-017DW	2/13/2024	6.31	Moderate				
Staff room faucet	05421400-018SF	2/13/2024	4.93	Low				
Staff room between class room 10 & 11 faucet	05421400-019SF	2/13/2024	63.9	Action Req.	5/29/2025	19.2	Action Req.	Fixture Removed
Speech language room classroom faucet	05421400-020CF	2/13/2024	ND	Non-Detect				
Drinking fountain	05421400-021DW	2/13/2024	ND	Non-Detect				
Water fill station	05421400-022WB	2/13/2024	ND	Non-Detect				
Classroom 13 faucet	05421400-023CF	2/13/2024	6.98	Moderate				
Classroom 14 faucet	05421400-024CF	2/13/2024	4.8	Low				
Staff room between class room 16 & 11 faucet	05421400-025SF	2/13/2024	13.6	High				
Girls bathroom faucet	05421400-026BF	2/13/2024	ND	Non-Detect				
Girls bathroom faucet	05421400-027BF	2/13/2024	ND	Non-Detect				
Drinking fountain	05421400-028DW	2/13/2024	ND	Non-Detect				
Boys bathroom faucet	05421400-029BF	2/13/2024	2.11	Low				
Boys bathroom faucet	05421400-030BF	2/13/2024	ND	Non-Detect				
classroom 25 classroom faucet 1	05421400-031CF	2/13/2024	4.69	Low				
classroom faucet 2	05421400-032CF	2/13/2024	22.5	Action Req.				Removed Fixture
classroom faucet 3	05421400-033CF	2/13/2024	23.3	Action Req.				Removed Fixture
classroom faucet 4	05421400-034CF	2/13/2024	34.5	Action Req.				Removed Fixture
classroom faucet 5	05421400-035CF	2/13/2024	33.8	Action Req.				Removed Fixture
classroom faucet 6	05421400-036CF	2/13/2024	25.4	Action Req.	5/29/2025	3.45	Low	
Classroom 21 classroom faucet	05421400-037CF	2/13/2024	5	Low				
classroom 26 classroom faucet 1	05421400-038CF	2/13/2024	ND	Non-Detect				
Staff room faucet	05421400-039SF	2/13/2024	7.01	Moderate				
Staff bathroom faucet 1	05421400-040SF	2/13/2024	ND	Non-Detect				
Staff bathroom faucet 2	05421400-041SF	2/13/2024	2.38	Low				
Kitchen bathroom faucet	05421400-042BF	2/13/2024	ND	Non-Detect				
Kitchen faucet 1	05421400-043KF	2/13/2024	2.85	Low				
Kitchen faucet 2	05421400-044KF	2/13/2024	5.64	Moderate				
Kitchen faucet 3	05421400-045KF	2/13/2024	11	High				
Drinking fountain near boiler rm	05421400-046DW	2/13/2024	ND	Non-Detect				
Girls bathroom faucet	05421400-047BF	2/13/2024	ND	Non-Detect				
Girls bathroom faucet	05421400-048BF	2/13/2024	ND	Non-Detect				
Boys bathroom faucet	05421400-049BF	2/13/2024	ND	Non-Detect				
Boys bathroom faucet	05421400-050BF	2/13/2024	ND	Non-Detect				
Commons Drinking fountain	05421400-051DW	2/13/2024	ND	Non-Detect				
Water Bottle fill station	05421400-052WB	2/13/2024	ND	Non-Detect				
CTE hallway bathroom faucet	05421400-053BF	2/13/2024	3.58	Low				
Classroom 28 faucet 1	05421400-054CF	2/13/2024	5.2	Moderate				
classroom faucet 2	05421400-055CF	2/13/2024	ND	Non-Detect				
classroom faucet 3	05421400-056CF	2/13/2024	26.2	Action Req.	5/29/2025	9.02	Moderate	
classroom faucet 4	05421400-057CF	2/13/2024	ND	Non-Detect				
Classroom 30 faucet 1	05421400-058CF	2/13/2024	ND	Non-Detect				
classroom faucet 2	05421400-059CF	2/13/2024	ND	Non-Detect				
classroom faucet 3	05421400-060CF	2/13/2024	2.36	Low				

Drinking fountain hallway	05421400-061DW	2/13/2024	ND	Non-Detect				
Girls locker Bathroom faucet 1	05421400-062BF	2/13/2024	ND	Non-Detect				
Bathroom faucet 2	05421400-063BF	2/13/2024	ND	Non-Detect				
Drinking fountain	05421400-064DW	2/13/2024	ND	Non-Detect				
CoAches bathroom faucet	05421400-065BF	2/13/2024	5.38	Moderate				
Boys locker Bathroom faucet 1	05421400-066BF	2/13/2024	2.25	Low				
Bathroom faucet 2	05421400-067BF	2/13/2024	ND	Non-Detect				
Drinking fountain	05421400-068DW	2/13/2024	ND	Non-Detect				
CoAches bathroom faucet	05421400-069BF	2/13/2024	3.49	Low				
Classroom 35 drinking fountain	05421400-070DW	2/13/2024	ND	Non-Detect				
Practice Room A classroom faucet 1	05421400-071CF	2/13/2024	12.6	High				
Practice Room A classroom faucet 2	05421400-072CF	2/13/2024	18.5	Action Req.	5/29/2025	26.9	Action Req.	Fixture Not In Use
Classroom 34 drinking fountain	05421400-073DW	2/13/2024	6.03	Moderate				



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

March 01, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Briggs Middle School

Order No.: 2402462

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/13/2024 for the analyses presented in the following report.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402462

Date: 3/1/2024

CLIENT: Springfield School District #19

Project: Briggs Middle School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402462
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402462-001	Client Sample ID	05421400-001SF			Collection Date: 2/13/2024 4:37:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-002		Client Sample ID 05421400-002BF		Collection Date: 2/13/2024 4:38:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.22	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-003	Client Sample ID	05421400-003BF		Collection Date: 2/13/2024 4:39:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.05	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-004	Client Sample ID 05421400-004NS	Collection Date: 2/13/2024 4:40:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.75	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-005	Client Sample ID 05421400-005BF	Collection Date: 2/13/2024 4:41:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-006	Client Sample ID	05421400-006SF			Collection Date: 2/13/2024 4:43:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-007	Client Sample ID	05421400-007CF		Collection Date: 2/13/2024 4:44:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.68	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2402462
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402462-008	Client Sample ID	05421400-008BF			Collection Date: 2/13/2024 4:45:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-009	Client Sample ID 05421400-009BF	Collection Date: 2/13/2024 4:46:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-010	Client Sample ID	05421400-010DW			Collection Date: 2/13/2024 4:47:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-011	Client Sample ID	05421400-011WB		Collection Date: 2/13/2024 4:48:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-012	Client Sample ID 05421400-012BF	Collection Date: 2/13/2024 4:49:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-013		Client Sample ID 05421400-013BF			Collection Date: 2/13/2024 4:50:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-014	Client Sample ID	05421400-014SF		Collection Date: 2/13/2024 4:51:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits

WO#: 2402462
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402462-015	Client Sample ID 05421400-015CF	Collection Date: 2/13/2024 4:53:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.41	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-016	Client Sample ID 05421400-016CF	Collection Date: 2/13/2024 4:56:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.65	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-017	Client Sample ID 05421400-017DW	Collection Date: 2/13/2024 4:57:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.31	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402462-018	Client Sample ID 05421400-018SF	Collection Date: 2/13/2024 4:58:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.93	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402462-019	Client Sample ID 05421400-019SF	Collection Date: 2/13/2024 4:59:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	63.9	15.0	8.00	*	ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402462-020	Client Sample ID 05421400-020CF	Collection Date: 2/13/2024 5:00:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402462

Date: 3/1/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402462

01-Mar-24

Client: Springfield School District #19

Project: Briggs Middle School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402462-001A	05421400-001SF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402462-002A	05421400-002BF			Lead	A
	2402462-003A	05421400-003BF			Lead	A
	2402462-004A	05421400-004NS			Lead	A
	2402462-005A	05421400-005BF			Lead	A
	2402462-006A	05421400-006SF			Lead	A
	2402462-007A	05421400-007CF			Lead	A
	2402462-008A	05421400-008BF			Lead	A
	2402462-009A	05421400-009BF			Lead	A
	2402462-010A	05421400-010DW			Lead	A
	2402462-011A	05421400-011WB			Lead	A
	2402462-012A	05421400-012BF			Lead	A
	2402462-013A	05421400-013BF			Lead	A
	2402462-014A	05421400-014SF			Lead	A
	2402462-015A	05421400-015CF			Lead	A
	2402462-016A	05421400-016CF			Lead	A
	2402462-017A	05421400-017DW			Lead	A
	2402462-018A	05421400-018SF			Lead	A
	2402462-019A	05421400-019SF			Lead	A
	2402462-020A	05421400-020CF			Lead	A

ACCRED
ORELAP A Accredited

Original #2402462# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: RP

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: <u>terry.rutledge@springfield.k12.or.us</u>	City, State, Zip: Springfield Or, 97477
Client Project: Briggs Middle School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400- 001SF	DW/Grab	2/13	437	Lead	P	1		NA	001A
05421400- 002BF	DW/Grab	2/13	438	Lead	P	1			002A
05421400- 003BF	DW/Grab	2/13	439	Lead	P	1			003A
05421400- 004NS	DW/Grab	2/13	440	Lead	P	1			004A
05421400- 005BF	DW/Grab	2/13	441	Lead	P	1			005A
05421400- 006SF	DW/Grab	2/13	443	Lead	P	1			006A
05421400- 007CF	DW/Grab	2/13	444	Lead	P	1			007A
05421400- 008BF	DW/Grab	2/13	445	Lead	P	1			008A
05421400- 009BF	DW/Grab	2/13	446	Lead	P	1			009A
05421400- 010DW	DW/Grab	2/13	447	Lead	P	1		✓	010A

Notes:	PAID	Preservation Check			
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH
	CC				
	CK				
	Cash				
	REPORT				
	Mail				
	Email				
	Fax				
	Pickup				

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: Veronica Arciga		Refrigerated Ice <u>None</u>	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/13/2024	1100				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/13/24	10:42	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: RD

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Briggs Middle School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400-011WB	DW/Grab	2/13	448	Lead	P	1		NA	011A
05421400-012BF	DW/Grab	2/13	449	Lead	P	1			012A
05421400-013BF	DW/Grab	2/13	450	Lead	P	1			013A
05421400-014SF	DW/Grab	2/13	451	Lead	P	1			014A
05421400-015 BF *CF	DW/Grab	2/13	453	Lead	P	1			015A
05421400-016CF	DW/Grab	2/13	456	Lead	P	1			016A
05421400-017DW	DW/Grab	2/13	457	Lead	P	1			017A
05421400-018SF	DW/Grab	2/13	458	Lead	P	1			018A
05421400-019SF	DW/Grab	2/13	459	Lead	P	1			019A
05421400-020CF	DW/Grab	2/13	500	Lead	P	1		✓	020A

Notes: *Per bottle, rewritten for legibility - FM 2/13/24	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/13/2024	1100				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/13/24	10:42	



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

BMS

March 05, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Briggs Middle School

Order No.: 2402463

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/13/2024 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402463

Date: 3/5/2024

CLIENT: Springfield School District #19

Project: Briggs Middle School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402463
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402463-001 **Client Sample ID:** 05421400-021DW **Collection Date:** 2/13/2024 5:01:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402463-002 **Client Sample ID:** 05421400-022WB **Collection Date:** 2/13/2024 5:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402463-003 **Client Sample ID:** 05421400-023CF **Collection Date:** 2/13/2024 5:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.98	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402463-004 **Client Sample ID:** 05421400-024CF **Collection Date:** 2/13/2024 5:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.80	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402463-005 **Client Sample ID:** 05421400-025SF **Collection Date:** 2/13/2024 5:04:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	13.6	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402463-006 **Client Sample ID:** 05421400-026BF **Collection Date:** 2/13/2024 5:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402463-007 **Client Sample ID:** 05421400-027BF **Collection Date:** 2/13/2024 5:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402463
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402463-008 **Client Sample ID** 05421400-028DW **Collection Date:** 2/13/2024 5:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402463-009 **Client Sample ID** 05421400-029BF **Collection Date:** 2/13/2024 5:08:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.11	15.0	2.00		ppb	2/29/2024 1:16:00 PM	KG

Lab ID: 2402463-010 **Client Sample ID** 05421400-030BF **Collection Date:** 2/13/2024 5:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-011 **Client Sample ID** 05421400-031CF **Collection Date:** 2/13/2024 5:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.69	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-012 **Client Sample ID** 05421400-032CF **Collection Date:** 2/13/2024 5:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	22.5	15.0	4.00	*	ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-013 **Client Sample ID** 05421400-033CF **Collection Date:** 2/13/2024 5:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	23.3	15.0	4.00	*	ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-014 **Client Sample ID** 05421400-034CF **Collection Date:** 2/13/2024 5:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	34.5	15.0	4.00	*	ppb	3/4/2024 1:00:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/5/2024

WO#: 2402463
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402463-015 **Client Sample ID** 05421400-035CF **Collection Date:** 2/13/2024 5:14:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	33.8	15.0	4.00	*	ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-016 **Client Sample ID** 05421400-036CF **Collection Date:** 2/13/2024 5:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	25.4	15.0	4.00	*	ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-017 **Client Sample ID** 05421400-037CF **Collection Date:** 2/13/2024 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.00	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-018 **Client Sample ID** 05421400-038CF **Collection Date:** 2/13/2024 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-019 **Client Sample ID** 05421400-039SF **Collection Date:** 2/13/2024 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.01	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402463-020 **Client Sample ID** 05421400-040SF **Collection Date:** 2/13/2024 5:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402463

Date: 3/5/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402463

05-Mar-24

Client: Springfield School District #19

Project: Briggs Middle School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402463-001A	05421400-021DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402463-002A	05421400-022WB			Lead	A
	2402463-003A	05421400-023CF			Lead	A
	2402463-004A	05421400-024CF			Lead	A
	2402463-005A	05421400-025SF			Lead	A
	2402463-006A	05421400-026BF			Lead	A
	2402463-007A	05421400-027BF			Lead	A
	2402463-008A	05421400-028DW			Lead	A
	2402463-009A	05421400-029BF			Lead	A
	2402463-010A	05421400-030BF			Lead	A
	2402463-011A	05421400-031CF			Lead	A
	2402463-012A	05421400-032CF			Lead	A
	2402463-013A	05421400-033CF			Lead	A
	2402463-014A	05421400-034CF			Lead	A
	2402463-015A	05421400-035CF			Lead	A
	2402463-016A	05421400-036CF			Lead	A
	2402463-017A	05421400-037CF			Lead	A
	2402463-018A	05421400-038CF			Lead	A
	2402463-019A	05421400-039SF			Lead	A
	2402463-020A	05421400-040SF			Lead	A

ACCRED
ORELAP A Accredited

Original #2402463# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: FM

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Briggs Middle School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400- 021DW	DW/Grab	2/13	501	Lead	P	1		NA	001A
05421400- 022WB	DW/Grab	2/13	502	Lead	P	1			002A
05421400- 023CF	DW/Grab	2/13	502	Lead	P	1			003A
05421400- 024CF	DW/Grab	2/13	503	Lead	P	1			004A
05421400- 025SF	DW/Grab	2/13	504	Lead	P	1			005A
05421400- 026BF	DW/Grab	2/13	505	Lead	P	1			006A
05421400- 027BF	DW/Grab	2/13	506	Lead	P	1			007A
05421400- 028DW	DW/Grab	2/13	507	Lead	P	1			008A
05421400- 029BF	DW/Grab	2/13	508	Lead	P	1			009A
05421400- 030BF	DW/Grab	2/13	509	Lead	P	1		V	010A

Notes: <i>Written over by client FM 2/13/24</i>	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	None
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/13/2024	1100				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/13/24	10:42	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: EM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Briggs Middle School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400-031 CF	DW/Grab	2/13	511	Lead	P	1		NA	011A
05421400-032 CF	DW/Grab	2/13	511	Lead	P	1			012A
05421400-033 CF	DW/Grab	2/13	512	Lead	P	1			013A
05421400-034 CF	DW/Grab	2/13	513	Lead	P	1			014A
05421400-035 CF	DW/Grab	2/13	514	Lead	P	1			015A
05421400-036 CF	DW/Grab	2/13	516	Lead	P	1			016A
05421400-037 CF	DW/Grab	2/13	518	Lead	P	1			017A
05421400-038 CF	DW/Grab	2/13	520	Lead	P	1			018A
05421400-039 SF	DW/Grab	2/13	522	Lead	P	1			019A
05421400-040 SF	DW/Grab	2/13	523	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH	Shipped Via: Veronica Arciga	Refrigerated Ice ☐ None ☒
Relinquished by: Veronica Arciga	Date: 2/13/2024	Time: 11:00
Relinquished by:	Date:	Time:
Relinquished by:	Date:	Time:
Relinquished by:	Date:	Time:
Received by:	Date:	Time:
Received by:	Date:	Time:
Received by Laboratory:	Date: 2/13/24	Time: 10:42



*Delivering more than
just test results*

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

March 06, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Briggs Middle School

Order No.: 2402465

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/13/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads "Kimberly J. Reeve Morghan".

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402465

Date: 3/6/2024

CLIENT: Springfield School District #19

Project: Briggs Middle School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402465
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402465-001 **Client Sample ID** 05421400-041SF **Collection Date:** 2/13/2024 5:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.38	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-002 **Client Sample ID** 05421400-042BF **Collection Date:** 2/13/2024 5:25:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-003 **Client Sample ID** 05421400-043KF **Collection Date:** 2/13/2024 5:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.85	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-004 **Client Sample ID** 05421400-044KF **Collection Date:** 2/13/2024 5:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.64	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-005 **Client Sample ID** 05421400-045KF **Collection Date:** 2/13/2024 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.0	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-006 **Client Sample ID** 05421400-046DW **Collection Date:** 2/13/2024 5:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-007 **Client Sample ID** 05421400-047BF **Collection Date:** 2/13/2024 5:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/6/2024

WO#: 2402465
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402465-008 **Client Sample ID:** 05421400-048BF **Collection Date:** 2/13/2024 5:31:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-009 **Client Sample ID:** 05421400-049BF **Collection Date:** 2/13/2024 5:32:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-010 **Client Sample ID:** 05421400-050BF **Collection Date:** 2/13/2024 5:33:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-011 **Client Sample ID:** 05421400-051DW **Collection Date:** 2/13/2024 5:34:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-012 **Client Sample ID:** 05421400-052WB **Collection Date:** 2/13/2024 5:34:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-013 **Client Sample ID:** 05421400-053BF **Collection Date:** 2/13/2024 5:35:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.58	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-014 **Client Sample ID:** 05421400-054CF **Collection Date:** 2/13/2024 5:35:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.20	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402465
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402465-015	Client Sample ID 05421400-055CF	Collection Date: 2/13/2024 5:36:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-016	Client Sample ID 05421400-056CF	Collection Date: 2/13/2024 5:37:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	26.2	15.0	4.00	*	ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-017	Client Sample ID 05421400-057CF	Collection Date: 2/13/2024 5:38:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/4/2024 1:00:00 PM	AS

Lab ID: 2402465-018	Client Sample ID 05421400-058CF	Collection Date: 2/13/2024 5:39:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402465-019	Client Sample ID 05421400-059CF	Collection Date: 2/13/2024 5:40:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402465-020	Client Sample ID 05421400-060CF	Collection Date: 2/13/2024 5:41:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.36	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2402465
Date: 3/6/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402465

06-Mar-24

Client: Springfield School District #19

Project: Briggs Middle School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402465-001A	05421400-041SF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402465-002A	05421400-042BF			Lead	A
	2402465-003A	05421400-043KF			Lead	A
	2402465-004A	05421400-044KF			Lead	A
	2402465-005A	05421400-045KF			Lead	A
	2402465-006A	05421400-046DW			Lead	A
	2402465-007A	05421400-047BF			Lead	A
	2402465-008A	05421400-048BF			Lead	A
	2402465-009A	05421400-049BF			Lead	A
	2402465-010A	05421400-050BF			Lead	A
	2402465-011A	05421400-051DW			Lead	A
	2402465-012A	05421400-052WB			Lead	A
	2402465-013A	05421400-053BF			Lead	A
	2402465-014A	05421400-054CF			Lead	A
	2402465-015A	05421400-055CF			Lead	A
	2402465-016A	05421400-056CF			Lead	A
	2402465-017A	05421400-057CF			Lead	A
	2402465-018A	05421400-058CF			Lead	A
	2402465-019A	05421400-059CF			Lead	A
	2402465-020A	05421400-060CF			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2402465# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

FM

Checked:

CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Briggs Middle School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400-041SF	DW/Grab	2/13	524	Lead	P	1		NA	001A
05421400-042BF	DW/Grab	2/13	525	Lead	P	1			002A
05421400-043KF	DW/Grab	2/13	526	Lead	P	1			003A
05421400-044KF	DW/Grab	2/13	527	Lead	P	1			004A
05421400-045KF	DW/Grab	2/13	528	Lead	P	1			005A
05421400-046DW	DW/Grab	2/13	529	Lead	P	1			006A
05421400-047BF	DW/Grab	2/13	530	Lead	P	1			007A
05421400-048BF	DW/Grab	2/13	531	Lead	P	1			008A
05421400-049BF	DW/Grab	2/13	532	Lead	P	1			009A
05421400-050BF	DW/Grab	2/13	533	Lead	P	1		✓	010A

Notes: <i>Written over by client.</i> FM 2/13/24	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	Veronica Arciga	Ice ☐ None ☒
Relinquished by:	Received by:	Date Time
Veronica Arciga		2/13/2024 11:00
Relinquished by:	Received by:	Date Time
Relinquished by:	Received by Laboratory:	Date Time
	<i>[Signature]</i>	2/13/24 10:42



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Briggs Middle School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400-051DW	DW/Grab	2/13	534	Lead	P	1		NA	011A
05421400-052WB	DW/Grab	2/13	534	Lead	P	1			012A
05421400-053BF	DW/Grab	2/13	535	Lead	P	1			013A
05421400-054CF	DW/Grab	2/13	535	Lead	P	1			014A
05421400-055CF	DW/Grab	2/13	536	Lead	P	1			015A
05421400-056CF	DW/Grab	2/13	537	Lead	P	1			016A
05421400-057CF	DW/Grab	2/13	538	Lead	P	1			017A
05421400-058CF	DW/Grab	2/13	539	Lead	P	1			018A
05421400-059CF	DW/Grab	2/13	540	Lead	P	1			019A
05421400-060CF	DW/Grab	2/13	541	Lead	P	1		V	020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	☒ None
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/13/2024	1100				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
				2/13/24	10:42	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

March 06, 2024

Terry Rutledge

Springfield School District #19

1890 North 42nd Street

Springfield, OR 97477

TEL: (541) 744-6375

FAX:

RE: Briggs Middle School

Order No.: 2402467

Dear Terry Rutledge:

Analytical Laboratory Group received 13 sample(s) on 2/13/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan

Quality Manager

361 West 5th Ave

Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402467

Date: 3/6/2024

CLIENT: Springfield School District #19

Project: Briggs Middle School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Date Reported: 3/6/2024

WO#: 2402467
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402467-001	Client Sample ID	05421400-061DW			Collection Date: 2/13/2024 5:41:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-002	Client Sample ID	05421400-062BF		Collection Date: 2/13/2024 5:42:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-003		Client Sample ID 05421400-063BF		Collection Date: 2/13/2024 5:43:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-004		Client Sample ID 05421400-064DW			Collection Date: 2/13/2024 5:44:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-005	Client Sample ID	05421400-065BF		Collection Date: 2/13/2024 5:45:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.38	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-006	Client Sample ID	05421400-066BF		Collection Date: 2/13/2024 5:54:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.25	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-007		Client Sample ID 05421400-067BF			Collection Date: 2/13/2024 5:55:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402467
CLIENT: Springfield School District #19
Location:
Project: Briggs Middle School
Sample Source:

Received Date: 2/13/2024 10:42:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402467-008	Client Sample ID	05421400-068DW			Collection Date: 2/13/2024 5:56:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-009		Client Sample ID 05421400-069BF			Collection Date: 2/13/2024 5:57:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.49	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-010		Client Sample ID 05421400-070DW			Collection Date: 2/13/2024 6:02:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-011	Client Sample ID 05421400-071CF			Collection Date: 2/13/2024 6:01:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	12.6	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-012	Client Sample ID	05421400-072CF				Collection Date: 2/13/2024 6:00:00 AM		
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	18.5	15.0	2.00	*	ppb	3/6/2024 9:00:00 AM	KG

Lab ID: 2402467-013	Client Sample ID	05421400-073DW			Collection Date: 2/13/2024 5:59:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.03	15.0	2.00		ppb	3/6/2024 9:00:00 AM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2402467
Date: 3/6/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402467

06-Mar-24

Client: Springfield School District #19

Project: Briggs Middle School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402467-001A	05421400-061DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402467-002A	05421400-062BF			Lead	A
	2402467-003A	05421400-063BF			Lead	A
	2402467-004A	05421400-064DW			Lead	A
	2402467-005A	05421400-065BF			Lead	A
	2402467-006A	05421400-066BF			Lead	A
	2402467-007A	05421400-067BF			Lead	A
	2402467-008A	05421400-068DW			Lead	A
	2402467-009A	05421400-069BF			Lead	A
	2402467-010A	05421400-070DW			Lead	A
	2402467-011A	05421400-071CF			Lead	A
	2402467-012A	05421400-072CF			Lead	A
	2402467-013A	05421400-073DW			Lead	A

ORELAP A Accredited

ACCRED

Original #2402467# v1

Page 6 of 8



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Briggs Middle School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400-061 DW	DW/Grab	2/13	541	Lead	P	1		NA	001A
05421400-062 BF	DW/Grab	2/13	542	Lead	P	1			002A
05421400-063 BF	DW/Grab	2/13	543	Lead	P	1			003A
05421400-064 DW	DW/Grab	2/13	544	Lead	P	1			004A
05421400-065 BF	DW/Grab	2/13	545	Lead	P	1			005A
05421400-066 BF	DW/Grab	2/13	554	Lead	P	1			006A
05421400-067 BF	DW/Grab	2/13	555	Lead	P	1			007A
05421400-068 DW	DW/Grab	2/13	556	Lead	P	1			008A
05421400-069 BF	DW/Grab	2/13	557	Lead	P	1			009A
05421400-070 DW	DW/Grab	2/13	602	Lead	P	1			010A

Notes: <u>Written over by client.</u> <u>FM 2/13/24</u>	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	<u>None</u>
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/13/2024	1100				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	2/13/24	10:42	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: <u>terry.rutledge@springfield.k12.or.us</u>	City, State, Zip: Springfield Or, 97477
Client Project: Briggs Middle School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400-071CF	DW/Grab	2/13	601	Lead	P	1		NA	011A
05421400-072CF	DW/Grab	2/13	600	Lead	P	1			012A
05421400-073DW	DW/Grab	2/13	559	Lead	P	1			013A
05421400	DW/Grab			Lead	P	1			
05421400	DW/Grab			Lead	P	1			
05421400	DW/Grab			Lead	P	1			
05421400	DW/Grab			Lead	P	1			
05421400	DW/Grab			Lead	P	1			
05421400	DW/Grab			Lead	P	1			
05421400	DW/Grab			Lead	P	1			
05421400	DW/Grab			Lead	P	1			

Notes: 1 Samples not relinquished; crossed off by client and lab. FM 2/13/24	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	<u>None</u>
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/13/2024	1100				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/13/24	10:42	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

June 02, 2025

John Harshberger
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 979-9667
FAX:

RE: Springfield SD 19 - Briggs Middle School

Order No.: 2505923

Dear John Harshberger:

Analytical Laboratory Group received 4 sample(s) on 5/29/2025 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2505923

Date: 6/2/2025

CLIENT: Springfield School District #19
Project: Springfield SD 19 - Briggs Middle School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2505923
CLIENT: Springfield School District #19
Location:
Project: Springfield SD 19 - Briggs Middle School
Sample Source:

Received Date: 5/29/2025 8:01:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2505923-001 **Client Sample ID** 05421400-019SF **Collection Date:** 5/29/2025 6:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	19.2	15.0	2.00	*	ppb	5/30/2025 4:03:00 PM	AS

Lab ID: 2505923-002 **Client Sample ID** 05421400-036CF **Collection Date:** 5/29/2025 6:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.45	15.0	2.00		ppb	5/30/2025 4:03:00 PM	AS

Lab ID: 2505923-003 **Client Sample ID** 05421400-056CF **Collection Date:** 5/29/2025 6:19:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.02	15.0	2.00		ppb	5/30/2025 4:03:00 PM	AS

Lab ID: 2505923-004 **Client Sample ID** 05421400-072CF **Collection Date:** 5/29/2025 6:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	26.9	15.0	2.00	*	ppb	5/30/2025 4:03:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2505923

Date: 6/2/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2505923
02-Jun-25

Client: Springfield School District #19
Project: Springfield SD 19 - Briggs Middle Scho

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2505923-001A	05421400-019SF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2505923-002A	05421400-036CF			Lead	A
	2505923-003A	05421400-056CF			Lead	A
	2505923-004A	05421400-072CF			Lead	A



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: BK

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: John Harshberger	Company: Springfield School District
Phone: (541) 979-9667	Address: 1890 North 42nd Street
Email: john.harshberger@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client: SPRINGFIELD SD 19 Project: BRIGGS MIDDLE SCHOOL	Sampler Name: MARIO RODRIGUEZ

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05421400-019SF	DW/Grab	5.29.25	06:13	Lead	P	1		NA	001A
05421400-036CF	DW/Grab	5.29.25	06:16	Lead	P	1		NA	002A
05421400-056CF	DW/Grab	5.29.25	06:19	Lead	P	1		NA	003A
05421400-072CF	DW/Grab	5.29.25	06:22	Lead	P	1		NA	004A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	Mario	Ice IR None IR NA

Relinquished by:	Date	Time	Received by:	Date	Time
Mario Rodriguez	5.29.25				
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
				5/29/25	8:01