MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974)
Account #: 2190
Project #: 202310677

Client: Institute for Environmental Assessment (IEA)
PO: 202310677

Emma Squires-Sperling
IEA / Brooklyn Park
9201 W Broadway Suite #600
Brooklyn Park, MN 55445

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:



Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974001 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-01 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen A123-SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 17:39	

Lab ID: 32974002 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-02 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen A123-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.97**	ug/L	15	EPA 200.8	11/20/2023 17:40	

Lab ID: 32974003 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-03 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen A123-West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.90**	ug/L	15	EPA 200.8	11/20/2023 17:41	

Lab ID: 32974004 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-07 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside Room 32/RR-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 17:42	

Lab ID: 32974005 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-08 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A122-North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.70**	ug/L	15	EPA 200.8	11/20/2023 17:43	

Lab ID: 32974006 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-09 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A122-North DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.99**	ug/L	15	EPA 200.8	11/20/2023 17:44	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974007 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-10 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A122-South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.03**	ug/L	15	EPA 200.8	11/20/2023 17:45	

Lab ID: 32974008 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-11 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A122-South DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.55**	ug/L	15	EPA 200.8	11/20/2023 17:46	

Lab ID: 32974009 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-12 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A125 North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 17:47	

Lab ID: 32974010 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-13 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A125 South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 17:48	

Lab ID: 32974011 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-14 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A130/025 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.71**	ug/L	15	EPA 200.8	11/20/2023 17:57	

Lab ID: 32974012 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-15 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A130/025 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 17:58	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974013 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-16 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A131/024 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.97**	ug/L	15	EPA 200.8	11/20/2023 17:59	

Lab ID: 32974014 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-17 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A131/024 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:00	

Lab ID: 32974015 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-18 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A141a & A142a RRs-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:01	

Lab ID: 32974016 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-19 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A141a & A142a RRs-North DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:02	

Lab ID: 32974017 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-20 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A141a & A142a RRs-South DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:03	

Lab ID: 32974018 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-21 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A133/026 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:04	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974019 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-22 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A133/026 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:05	

Lab ID: 32974020 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-23 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A134/027 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:06	

Lab ID: 32974021 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-24 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A134/027 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:15	

Lab ID: 32974022 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-25 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A134a & A135a RRs-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:16	

Lab ID: 32974023 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-26 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A134a & A135a RRs-East WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:17	

Lab ID: 32974024 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-27 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A134a & A135a RRs-West WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:18	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974025 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-28 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A135/028 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:19	

Lab ID: 32974026 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-29 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A135/028 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:20	

Lab ID: 32974027 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-30 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Nurse A182 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.46**	ug/L	15	EPA 200.8	11/20/2023 18:21	

Lab ID: 32974028 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-31 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Lounge A183i SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:22	

Lab ID: 32974029 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-32 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Lounge A183i HWD

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:23	

Lab ID: 32974030 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-33 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A177/003 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.76**	ug/L	15	EPA 200.8	11/20/2023 18:24	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974031 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-34 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A177/003 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:32	

Lab ID: 32974032 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-35 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A176/004 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.46**	ug/L	15	EPA 200.8	11/20/2023 18:33	

Lab ID: 32974033 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-36 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A176/004 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:34	

Lab ID: 32974034 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-37 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A170/005 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.97**	ug/L	15	EPA 200.8	11/20/2023 18:35	

Lab ID: 32974035 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-38 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A170/005 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:36	

Lab ID: 32974036 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-39 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A172/006 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.54**	ug/L	15	EPA 200.8	11/20/2023 18:37	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974037 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-40 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A172/006 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:39	

Lab ID: 32974038 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-41 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A171/007 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.94**	ug/L	15	EPA 200.8	11/20/2023 18:40	

Lab ID: 32974039 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-42 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A171/007 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:41	

Lab ID: 32974040 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-43 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A169/008 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.88**	ug/L	15	EPA 200.8	11/20/2023 18:42	

Lab ID: 32974041 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-44 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A169/008 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:50	

Lab ID: 32974042 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-45 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A165a & A166a RRs-North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:51	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974043 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-46 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A165a & A166a RRs-WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:52	

Lab ID: 32974044 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-47 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside A165a & A166a RRs-South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:53	

Lab ID: 32974045 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-48 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A168/009 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.50**	ug/L	15	EPA 200.8	11/20/2023 18:54	

Lab ID: 32974046 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-49 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A168/009 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:55	

Lab ID: 32974047 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-50 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A167/010 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:56	

Lab ID: 32974048 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-51 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A167/010 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:57	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974049 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-52 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A163/011 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:58	

Lab ID: 32974050 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-53 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A163/011 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 18:59	

Lab ID: 32974051 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-54 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A162/012 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.87**	ug/L	15	EPA 200.8	11/20/2023 19:12	

Lab ID: 32974052 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-55 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A162/012 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.05**	ug/L	15	EPA 200.8	11/20/2023 19:13	

Lab ID: 32974053 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-56 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A159/013 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.27**	ug/L	15	EPA 200.8	11/20/2023 19:14	

Lab ID: 32974054 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-57 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A159/013 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.77**	ug/L	15	EPA 200.8	11/20/2023 19:15	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974055 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-58 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A158/014 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.13**	ug/L	15	EPA 200.8	11/20/2023 19:16	

Lab ID: 32974056 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-59 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A158/014 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.06**	ug/L	15	EPA 200.8	11/20/2023 19:17	

Lab ID: 32974057 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-60 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A/30 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.06**	ug/L	15	EPA 200.8	11/20/2023 19:18	

Lab ID: 32974058 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-61 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A/30 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.57**	ug/L	15	EPA 200.8	11/20/2023 19:19	

Lab ID: 32974059 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-62 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room B/31 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.23**	ug/L	15	EPA 200.8	11/20/2023 19:20	

Lab ID: 32974060 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-63 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room B/31 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.50**	ug/L	15	EPA 200.8	11/20/2023 19:21	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974061 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-64 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room C/32 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.50**	ug/L	15	EPA 200.8	11/20/2023 19:30	

Lab ID: 32974062 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-65 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room C/32 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.52**	ug/L	15	EPA 200.8	11/20/2023 19:31	

Lab ID: 32974063 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-66 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside RRs/Room 32-North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 19:32	

Lab ID: 32974064 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-67 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside RRs/Room 32-South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 19:33	

Lab ID: 32974065 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-68 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room D/29 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.36**	ug/L	15	EPA 200.8	11/20/2023 19:34	

Lab ID: 32974066 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-69 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room D/29 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 19:35	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974067 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-70 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A155/015 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.66**	ug/L	15	EPA 200.8	11/20/2023 19:36	

Lab ID: 32974068 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-71 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A155/015 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.66**	ug/L	15	EPA 200.8	11/20/2023 19:37	

Lab ID: 32974069 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-72 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A154/016 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.77**	ug/L	15	EPA 200.8	11/20/2023 19:38	

Lab ID: 32974070 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-73 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A154/016 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.81**	ug/L	15	EPA 200.8	11/20/2023 19:39	

Lab ID: 32974071 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-74 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A150/017 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.65**	ug/L	15	EPA 200.8	11/20/2023 19:48	

Lab ID: 32974072 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-75 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A150/017 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.61**	ug/L	15	EPA 200.8	11/20/2023 19:49	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974073 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-76 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A152/018 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.94**	ug/L	15	EPA 200.8	11/20/2023 19:50	

Lab ID: 32974074 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-77 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A152/018 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.81**	ug/L	15	EPA 200.8	11/20/2023 19:51	

Lab ID: 32974075 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-78 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A151/019 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.54**	ug/L	15	EPA 200.8	11/20/2023 19:52	

Lab ID: 32974076 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-79 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A151/019 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 19:53	

Lab ID: 32974077 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-80 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Office A148f in Media Center SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.98**	ug/L	15	EPA 200.8	11/20/2023 19:54	

Lab ID: 32974078 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-81 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A145/021 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.77**	ug/L	15	EPA 200.8	11/20/2023 19:55	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32974079 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-82 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A145/021 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 19:56	

Lab ID: 32974080 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-83 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A144/022 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.99**	ug/L	15	EPA 200.8	11/20/2023 19:57	

Lab ID: 32974081 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-84 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A144/022 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/20/2023 20:05	

Lab ID: 32974082 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-85 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A143/023 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.24**	ug/L	15	EPA 200.8	11/20/2023 20:06	


Lab ID: 32974083 **Date Collected:** 11/01/2023 06:30 **Matrix:** Potable Water
Sample ID: 11012023SHES-86 **Date Received:** 11/02/2023 14:14
Temp @ Receipt (C):
Sample Desc: Room A143/023 DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.57**	ug/L	15	EPA 200.8	11/20/2023 20:07	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)



MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

32974

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	Wayzata Public Schools	Building Name	Sunset Hill Elementary	Analytical Lab	MVTL		
Contact Name		Project #	202310677	Project Name			
Phone #	763-315-7900	IEA Fax #	763-315-7920	Written Sample Results To			
Other Information							
Sampled By	Faith Breeden	Date	11/1/2023	Time	6:30am	Analyzed By (Company)	Analyst	Date & Time
Shipped By	Wendy Barcus	Date	11/3/2023	Time	10:00am	Turnaround Time	Notes	
Received By		Date		Time		Sample Condition	Temperature	

Lab Number	Sample Number	Sample Location	Sample Type: Water	Soil	Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
	11012023SHES-01	Kitchen A123 - SPR	X				250mL unpreserved	Lead	
	11012023SHES-02	Kitchen A123 - South SNK	X				250mL unpreserved	Lead	
	11012023SHES-03	Kitchen A123 - West SNK	X				250mL unpreserved	Lead	
	~~11012023SHES-04~~	~~Kitchen A123~~	~~X~~				~~250mL unpreserved~~	~~Lead~~	~~None found~~
	~~11012023SHES-05~~	~~Kitchen A123~~	~~X~~				~~250mL unpreserved~~	~~Lead~~	~~None found~~
	~~11012023SHES-06~~	~~Gym A113 - DF~~	~~X~~				~~250mL unpreserved~~	~~Lead~~	~~Inoperable~~
	11012023SHES-07	Outside Room 32/RR - WBF	X				250mL unpreserved	Lead	
	11012023SHES-08	Room A122 - North SNK	X				250mL unpreserved	Lead	
	11012023SHES-09	Room A122 - North DF	X				250mL unpreserved	Lead	
	11012023SHES-10	Room A122 - South SNK	X				250mL unpreserved	Lead	
	11012023SHES-11	Room A122 - South DF	X				250mL unpreserved	Lead	
	11012023SHES-12	Room A125 North SNK	X				250mL unpreserved	Lead	
	11012023SHES-13	Room A125 South SNK	X				250mL unpreserved	Lead	
	11012023SHES-14	Room A130/025 SNK	X				250mL unpreserved	Lead	
	11012023SHES-15	Room A130/025 DF	X				250mL unpreserved	Lead	
	11012023SHES-16	Room A131/024 SNK	X				250mL unpreserved	Lead	
	11012023SHES-17	Room A131/024 DF	X				250mL unpreserved	Lead	
	11012023SHES-18	Outside A141a & A142a RRs - WBF	X				250mL unpreserved	Lead	
	11012023SHES-19	Outside A141a & A142a RRs - North DF	X				250mL unpreserved	Lead	
	11012023SHES-20	Outside A141a & A142a RRs - South DF	X				250mL unpreserved	Lead	
	11012023SHES-21	Room A133/026 SNK	X				250mL unpreserved	Lead	
	11012023SHES-22	Room A133/026 DF	X				250mL unpreserved	Lead	
	11012023SHES-23	Room A134/027 SNK	X				250mL unpreserved	Lead	
	11012023SHES-24	Room A134/027 DF	X				250mL unpreserved	Lead	
	11012023SHES-25	Outside A134a & A135a RRs - WBF	X				250mL unpreserved	Lead	
	11012023SHES-26	Outside A134a & A135a RRs - East WC	X				250mL unpreserved	Lead	
	11012023SHES-27	Outside A134a & A135a RRs - West WC	X				250mL unpreserved	Lead	
	11012023SHES-28	Room A135/028 SNK	X				250mL unpreserved	Lead	
	11012023SHES-29	Room A135/028 DF	X				250mL unpreserved	Lead	
	11012023SHES-30	Nurse A182 SNK	X				250mL unpreserved	Lead	
	11012023SHES-31	Lounge A183i SNK	X				250mL unpreserved	Lead	
	11012023SHES-32	Lounge A183i HWD	X				250mL unpreserved	Lead	Not first draw

AM CM 2 NOV 23 1414 2 NOV 23 1414 17.0C TM 771 17.0 TM 771

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

	11012023SHES-33	Room A177/003 SNK	X				250mL unpreserved	Lead	
	11012023SHES-34	Room A177/003 DF	X				250mL unpreserved	Lead	
	11012023SHES-35	Room A176/004 SNK	X				250mL unpreserved	Lead	
	11012023SHES-36	Room A176/004 DF	X				250mL unpreserved	Lead	
	11012023SHES-37	Room A170/005 SNK	X				250mL unpreserved	Lead	
	11012023SHES-38	Room A170/005 DF	X				250mL unpreserved	Lead	
	11012023SHES-39	Room A172/006 SNK	X				250mL unpreserved	Lead	
	11012023SHES-40	Room A172/006 DF	X				250mL unpreserved	Lead	
	11012023SHES-41	Room A171/007 SNK	X				250mL unpreserved	Lead	
	11012023SHES-42	Room A171/007 DF	X				250mL unpreserved	Lead	
	11012023SHES-43	Room A169/008 SNK	X				250mL unpreserved	Lead	
	11012023SHES-44	Room A169/008 DF	X				250mL unpreserved	Lead	
	11012023SHES-45	Outside A165a & A166a RRs - North WC	X				250mL unpreserved	Lead	
	11012023SHES-46	Outside A165a & A166a RRs - WBF	X				250mL unpreserved	Lead	
	11012023SHES-47	Outside A165a & A166a RRs - South WC	X				250mL unpreserved	Lead	
	11012023SHES-48	Room A168/009 SNK	X				250mL unpreserved	Lead	
	11012023SHES-49	Room A168/009 DF	X				250mL unpreserved	Lead	
	11012023SHES-50	Room A167/010 SNK	X				250mL unpreserved	Lead	
	11012023SHES-51	Room A167/010 DF	X				250mL unpreserved	Lead	
	11012023SHES-52	Room A163/011 SNK	X				250mL unpreserved	Lead	
	11012023SHES-53	Room A163/011 DF	X				250mL unpreserved	Lead	
	11012023SHES-54	Room A162/012 SNK	X				250mL unpreserved	Lead	
	11012023SHES-55	Room A162/012 DF	X				250mL unpreserved	Lead	
	11012023SHES-56	Room A159/013 SNK	X				250mL unpreserved	Lead	
	11012023SHES-57	Room A159/013 DF	X				250mL unpreserved	Lead	
	11012023SHES-58	Room A158/014 SNK	X				250mL unpreserved	Lead	
	11012023SHES-59	Room A158/014 DF	X				250mL unpreserved	Lead	
	11012023SHES-60	Room A/30 SNK	X				250mL unpreserved	Lead	
	11012023SHES-61	Room A/30 DF	X				250mL unpreserved	Lead	
	11012023SHES-62	Room B/31 SNK	X				250mL unpreserved	Lead	
	11012023SHES-63	Room B/31 DF	X				250mL unpreserved	Lead	
	11012023SHES-64	Room C/32 SNK	X				250mL unpreserved	Lead	
	11012023SHES-65	Room C/32 DF	X				250mL unpreserved	Lead	
	11012023SHES-66	Outside RRs/Room 32 - North WC	X				250mL unpreserved	Lead	
	11012023SHES-67	Outside RRs/Room 32 - South WC	X				250mL unpreserved	Lead	
	11012023SHES-68	Room D/29 SNK	X				250mL unpreserved	Lead	
	11012023SHES-69	Room D/29 DF	X				250mL unpreserved	Lead	
	11012023SHES-70	Room A155/015 SNK	X				250mL unpreserved	Lead	
	11012023SHES-71	Room A155/015 DF	X				250mL unpreserved	Lead	
	11012023SHES-72	Room A154/016 SNK	X				250mL unpreserved	Lead	
	11012023SHES-73	Room A154/016 DF	X				250mL unpreserved	Lead	
	11012023SHES-74	Room A150/017 SNK	X				250mL unpreserved	Lead	
	11012023SHES-75	Room A150/017 DF	X				250mL unpreserved	Lead	
	11012023SHES-76	Room A152/018 SNK	X				250mL unpreserved	Lead	Not first draw
	11012023SHES-77	Room A152/018 DF	X				250mL unpreserved	Lead	
	11012023SHES-78	Room A151/019 SNK	X				250mL unpreserved	Lead	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

	11012023SHES-79	Room A151/019 DF	X				250mL unpreserved	Lead	
	11012023SHES-80	Office A148f in Media Center SNK	X				250mL unpreserved	Lead	
	11012023SHES-81	Room A145/021 SNK	X				250mL unpreserved	Lead	
	11012023SHES-82	Room A145/021 DF	X				250mL unpreserved	Lead	
	11012023SHES-83	Room A144/022 SNK	X				250mL unpreserved	Lead	
	11012023SHES-84	Room A144/022 DF	X				250mL unpreserved	Lead	
	11012023SHES-85	Room A143/023 SNK	X				250mL unpreserved	Lead	
	11012023SHES-86	Room A143/023 DF	X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	
			X				250mL unpreserved	Lead	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Sunset Hill Elementary (32974) **Client:** Institute for Environmental Assessment (IEA)

Sample Condition Checklist

Date: 2 NOV 23 Time: 1414 ☐ AM ☑ PM By: CM

Account Name: IEA - Shes Account #

Bill of Lading #: Cooler #:

Temp: 17.0 °C ROI ☐ Ambient ☑ Tracking #:

TM#: 771 Ice Crystals Present in Sample ☐

MVTL Courier: Dan Other:

MVTL Route: metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ SpeeDee ☐

Mail ☐ UPS Ground ☐ Fed Ex Ground ☐

Containers Supplied by MVTL: Yes ☑ No ☐ Designate customer supplied containers as "Other" in container size column

Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH
83	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	Low Level Mercury Kit	***!!DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!***		
	4 oz Jar	Clear Amber	MeOH None	n/a
	2 oz Jar	Clear Amber	MeOH None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Trip Blank Individual Set of 2 Set of 3	n/a		
	Moisture Vial	n/a		
	Manure Bottle	n/a		

*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.