MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468)
Account #: 2190
Project #: 202310677

Client: Institute for Environmental Assessment (IEA)
PO: 202310677

Emma Squires-Sperling
IEA / Brooklyn Park
9201 W Broadway Suite #600
Brooklyn Park, MN 55445

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:



Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468001 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-01 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.37**	ug/L	15	EPA 200.8	11/10/2023 13:16	

Lab ID: 32468002 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-02 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen North SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.66**	ug/L	15	EPA 200.8	11/10/2023 13:17	

Lab ID: 32468003 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-03 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen South SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.21**	ug/L	15	EPA 200.8	11/10/2023 13:18	

Lab ID: 32468004 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-04 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen North SPR

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.01**	ug/L	15	EPA 200.8	11/10/2023 13:19	

Lab ID: 32468005 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-05 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen South STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.58**	ug/L	15	EPA 200.8	11/10/2023 13:20	

Lab ID: 32468006 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-06 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Cafeteria WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/10/2023 13:21	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468007 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-08 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 221 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.92**	ug/L	15	EPA 200.8	11/10/2023 13:22	

Lab ID: 32468008 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-09 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 215 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**4.79**	ug/L	15	EPA 200.8	11/10/2023 13:23	

Lab ID: 32468009 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-12 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 213 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.31**	ug/L	15	EPA 200.8	11/10/2023 13:24	

Lab ID: 32468010 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-14 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 211 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**9.55**	ug/L	15	EPA 200.8	11/10/2023 13:25	

Lab ID: 32468011 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-16 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 209 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.24**	ug/L	15	EPA 200.8	11/10/2023 13:34	

Lab ID: 32468012 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-18 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 207 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**57.2**	ug/L	15	EPA 200.8	11/10/2023 13:35	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468013 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-19 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Lobby Across 206 WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.93**	ug/L	15	EPA 200.8	11/10/2023 13:36	

Lab ID: 32468014 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-21 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Lobby Across 206 South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.13**	ug/L	15	EPA 200.8	11/10/2023 13:37	

Lab ID: 32468015 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-22 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Media Center A223D SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.21**	ug/L	15	EPA 200.8	11/10/2023 13:38	

Lab ID: 32468016 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-23 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: A236A Work Room SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.97**	ug/L	15	EPA 200.8	11/10/2023 13:39	

Lab ID: 32468017 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-24 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Conf Room A239 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**10.0**	ug/L	15	EPA 200.8	11/10/2023 13:40	

Lab ID: 32468018 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-25 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Health Office A238C West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.54**	ug/L	15	EPA 200.8	11/10/2023 13:41	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468019 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-26 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Health Office A238C East SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.30**	ug/L	15	EPA 200.8	11/10/2023 13:42	

Lab ID: 32468020 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-27 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: A242 Staff Lounge SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.94**	ug/L	15	EPA 200.8	11/08/2023 19:40	

Lab ID: 32468021 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-29 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 108 FACS SNK 2

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.68**	ug/L	15	EPA 200.8	11/08/2023 19:41	

Lab ID: 32468022 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-30 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 108 FACS SNK 3

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.93**	ug/L	15	EPA 200.8	11/08/2023 19:42	

Lab ID: 32468023 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-31 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 108 FACS SNK 4

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**5.26**	ug/L	15	EPA 200.8	11/08/2023 19:43	

Lab ID: 32468024 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-32 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 108 FACS SNK 5

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.98**	ug/L	15	EPA 200.8	11/08/2023 19:44	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468025 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-33 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 108 FACS SNK 6

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**6.30**	ug/L	15	EPA 200.8	11/08/2023 19:53	

Lab ID: 32468026 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-34 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 108 FACS SNK 7

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.03**	ug/L	15	EPA 200.8	11/08/2023 19:54	

Lab ID: 32468027 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-35 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 108 FACS SNK 8

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.58**	ug/L	15	EPA 200.8	11/08/2023 19:55	

Lab ID: 32468028 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-36 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 109 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.69**	ug/L	15	EPA 200.8	11/08/2023 19:56	

Lab ID: 32468029 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-37 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Corridor Across 110 WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/08/2023 19:57	

Lab ID: 32468030 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-38 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Band Storage A142C SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.13**	ug/L	15	EPA 200.8	11/08/2023 19:58	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468031 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-39 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 110 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**16.1**	ug/L	15	EPA 200.8	11/08/2023 19:59	

Lab ID: 32468032 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-40 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: A128 Gym #2 WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.22**	ug/L	15	EPA 200.8	11/08/2023 20:00	

Lab ID: 32468033 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-41 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: A128 Gym #2 WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.32**	ug/L	15	EPA 200.8	11/08/2023 20:01	

Lab ID: 32468034 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-42 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside Fitness Center WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.10**	ug/L	15	EPA 200.8	11/08/2023 20:02	

Lab ID: 32468035 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-43 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside Fitness Center North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.11**	ug/L	15	EPA 200.8	11/08/2023 20:11	

Lab ID: 32468036 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-44 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Outside Fitness Center South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.12**	ug/L	15	EPA 200.8	11/08/2023 20:12	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468037 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-45 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Pool Area WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/08/2023 20:13	

Lab ID: 32468038 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-46 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Pool Area WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/08/2023 20:14	

Lab ID: 32468039 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-47 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Lobby Near Stairs A117 WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.05**	ug/L	15	EPA 200.8	11/08/2023 20:15	

Lab ID: 32468040 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-48 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Lobby Near stairs A117 North WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.04**	ug/L	15	EPA 200.8	11/08/2023 20:16	

Lab ID: 32468041 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-49 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Lobby Near Stairs A117 South WC

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.95**	ug/L	15	EPA 200.8	11/08/2023 20:17	

Lab ID: 32468042 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-50 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 125 SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**14.0**	ug/L	15	EPA 200.8	11/08/2023 20:18	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468043 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-51 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: 127B SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**7.80**	ug/L	15	EPA 200.8	11/08/2023 20:19	

Lab ID: 32468044 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-52 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: A104 Lobby WBF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/08/2023 20:20	

Lab ID: 32468045 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-53 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen Southeast SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**1.64**	ug/L	15	EPA 200.8	11/08/2023 20:28	

Lab ID: 32468046 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-54 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen Northwest SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.56**	ug/L	15	EPA 200.8	11/08/2023 20:29	

Lab ID: 32468047 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-55 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen West SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**2.87**	ug/L	15	EPA 200.8	11/08/2023 20:31	

Lab ID: 32468048 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-56 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Kitchen North STK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**0.54**	ug/L	15	EPA 200.8	11/08/2023 20:32	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Analytical Results

Lab ID: 32468049 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-57 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: Cafeteria SNK

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	**3.59**	ug/L	15	EPA 200.8	11/08/2023 20:33	

Lab ID: 32468050 **Date Collected:** 10/26/2023 09:00 **Matrix:** Potable Water
Sample ID: 10262023WEMS-58 **Date Received:** 10/27/2023 14:14
Temp @ Receipt (C):
Sample Desc: A242 Staff Lounge HWD

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	11/08/2023 20:34	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)



MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

324108

50 ~~90~~ Samples

Chain of Custody

9201 West Broadway North, Suite 600
Brooklyn Park, MN 55445
763.315.7900 1.800.233.9513

Client Name	Wayzata Public Schools	Building Name	Wayzata East MS	Analytical Lab	MVTL
Contact Name		Project #	202310677	Project Name	
Phone #	763-315-7900	IEA Fax #	763-315-7920	Written Sample Results To	
Other Information					
Sampled By	Emma Hillis	Date	10/26/2023	Time	9:00 AM
Analyzed By (Company)		Analyst		Date & Time	
Shipped By		Date		Time	
Turnaround Time		Notes			
Received By		Date		Time	
Sample Condition		Temperature			

Lab Numbe	Sample Number	Sample Location	Sample Type: Water	Sample Type: Soil	Sample Type: Other	Date Sampled	Volume/ Bottle Type	Analysis Required	Comments & Observations
1	10262023WEMS-01	Kitchen SPR	X			10/26/2023	250 mL inpreserved	Lead	south end of kitchen
2	10262023WEMS-02	Kitchen - North SNK	X			10/26/2023	250 mL inpreserved	Lead	NFD
3	10262023WEMS-03	Kitchen - South SNK	X			10/26/2023	251 mL inpreserved	Lead	
4	10262023WEMS-04	Kitchen - North SPR	X			10/26/2023	252 mL inpreserved	Lead	dishwashing sprayer
5	10262023WEMS-05	Kitchen - South STK	X			10/26/2023	253 mL inpreserved	Lead	bottom steam oven
6	10262023WEMS-06	Cafeteria WBF	X			10/26/2023	250 mL inpreserved	Lead	
	~~10262023WEMS-07~~	~~221 DF~~	~~X~~			~~10/26/2023~~	~~250 mL inpreserved~~	~~Lead~~	not working
7	10262023WEMS-08	221 SNK	X			10/26/2023	250 mL inpreserved	Lead	NFD
8	10262023WEMS-09	215 SNK	X			10/26/2023	250 mL inpreserved	Lead	
	~~10262023WEMS-10~~	~~215 DF~~	~~X~~			~~10/26/2023~~	~~250 mL inpreserved~~	~~Lead~~	not working
	~~10262023WEMS-11~~	~~213 DF~~	~~X~~			~~10/26/2023~~	~~250 mL inpreserved~~	~~Lead~~	not working
9	10262023WEMS-12	213 SNK	X			10/26/2023	250 mL inpreserved	Lead	
	~~10262023WEMS-13~~	~~211 DF~~	~~X~~			~~10/26/2023~~	~~250 mL inpreserved~~	~~Lead~~	not working
10	10262023WEMS-14	211 SNK	X			10/26/2023	250 mL inpreserved	Lead	
	~~10262023WEMS-15~~	~~209 DF~~	~~X~~			~~10/26/2023~~	~~250 mL inpreserved~~	~~Lead~~	not working
11	10262023WEMS-16	209 SNK	X			10/26/2023	250 mL inpreserved	Lead	
	~~10262023WEMS-17~~	~~207 DF~~	~~X~~			~~10/26/2023~~	~~250 mL inpreserved~~	~~Lead~~	not working
12	10262023WEMS-18	207 SNK	X			10/26/2023	250 mL inpreserved	Lead	
13	10262023WEMS-19	Lobby Across 206 WBF	X			10/26/2023	250 mL inpreserved	Lead	NFD
	~~10262023WEMS-20~~	~~Lobby Across 206 North WC~~	~~X~~			~~10/26/2023~~	~~250 mL inpreserved~~	~~Lead~~	not working
14	10262023WEMS-21	Lobby Across 206 South WC	X			10/26/2023	250 mL inpreserved	Lead	
15	10262023WEMS-22	Media Center A223D SNK	X			10/26/2023	250 mL inpreserved	Lead	NFD
16	10262023WEMS-23	A236A Work Room SNK	X			10/26/2023	250 mL inpreserved	Lead	
17	10262023WEMS-24	Conf Room A239 SNK	X			10/26/2023	250 mL inpreserved	Lead	
18	10262023WEMS-25	Health Office A238C West SNK	X			10/26/2023	250 mL inpreserved	Lead	NFD
19	10262023WEMS-26	Health Office A238C East SNK	X			10/26/2023	250 mL inpreserved	Lead	NFD
20	10262023WEMS-27	A242 Staff Lounge SNK	X			10/26/2023	250 mL inpreserved	Lead	
	~~10262023WEMS-28~~	~~108 FACS SNK 1~~	~~X~~			~~10/26/2023~~	~~250 mL inpreserved~~	~~Lead~~	only 7 sinks in FACS room
21	10262023WEMS-29	108 FACS SNK 2	X			10/26/2023	250 mL inpreserved	Lead	
22	10262023WEMS-30	108 FACS SNK 3	X			10/26/2023	250 mL inpreserved	Lead	
23	10262023WEMS-31	108 FACS SNK 4	X			10/26/2023	250 mL inpreserved	Lead	
24	10262023WEMS-32	108 FACS SNK 5	X			10/26/2023	250 mL inpreserved	Lead	

HFC 27 oct 23 1414 AMB SP 27 oct 23 1414

18.2 938

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

25	10262023WEMS-33	108 FACS SNK 6	X			10/26/2023	250 mL inpreserved	Lead	
26	10262023WEMS-34	108 FACS SNK 7	X			10/26/2023	250 mL inpreserved	Lead	
27	10262023WEMS-35	108 FACS SNK 8	X			10/26/2023	250 mL inpreserved	Lead	
28	10262023WEMS-36	109 SNK	X			10/26/2023	250 mL inpreserved	Lead	
29	10262023WEMS-37	Corridor Across 110 WBF	X			10/26/2023	250 mL inpreserved	Lead	
30	10262023WEMS-38	Band Storage A142C SNK	X			10/26/2023	250 mL inpreserved	Lead	
31	10262023WEMS-39	110 SNK	X			10/26/2023	250 mL inpreserved	Lead	
32	10262023WEMS-40	A128 Gym #2 WBF	X			10/26/2023	250 mL inpreserved	Lead	
33	10262023WEMS-41	A128 Gym #2 WC	X			10/26/2023	250 mL inpreserved	Lead	
34	10262023WEMS-42	Outside Fitness Center WBF	X			10/26/2023	250 mL inpreserved	Lead	
35	10262023WEMS-43	Outside Fitness Center North WC	X			10/26/2023	250 mL inpreserved	Lead	
36	10262023WEMS-44	Outside Fitness Center South WC	X			10/26/2023	250 mL inpreserved	Lead	
37	10262023WEMS-45	Pool Area WBF	X			10/26/2023	250 mL inpreserved	Lead	
38	10262023WEMS-46	Pool Area WC	X			10/26/2023	250 mL inpreserved	Lead	
39	10262023WEMS-47	Lobby Near Stairs A117 WBF	X			10/26/2023	250 mL inpreserved	Lead	NFD
40	10262023WEMS-48	Lobby Near Stairs A117 North WC	X			10/26/2023	250 mL inpreserved	Lead	NFD
41	10262023WEMS-49	Lobby Near Stairs A117 South WC	X			10/26/2023	250 mL inpreserved	Lead	NFD
42	10262023WEMS-50	125 SNK	X			10/26/2023	250 mL inpreserved	Lead	
43	10262023WEMS-51	127B SNK	X			10/26/2023	250 mL inpreserved	Lead	
44	10262023WEMS-52	A104 Lobby WBF	X			10/26/2023	250 mL inpreserved	Lead	NFD
45	10262023WEMS-53	Kitchen - Southeast SNK	X			10/26/2023	250 mL inpreserved	Lead	
46	10262023WEMS-54	Kitchen - Northwest SNK	X			10/26/2023	250 mL inpreserved	Lead	dishwashing sink
47	10262023WEMS-55	Kitchen - West SNK	X			10/26/2023	250 mL inpreserved	Lead	
48	10262023WEMS-56	Kitchen - North STK	X			10/26/2023	250 mL inpreserved	Lead	top steam oven
49	10262023WEMS-57	Cafeteria SNK	X			10/26/2023	250 mL inpreserved	Lead	
50	10262023WEMS-58	A242 Staff Lounge HWD	X			10/26/2023	250 mL inpreserved	Lead	water wasn't hot

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

MINNESOTA VALLEY TESTING LABORATORIES, INC.
1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Workorder: Wayzata East MS (32468) **Client:** Institute for Environmental Assessment (IEA)

Sample Condition Checklist

Date: 27 Oct 23 Time: 1414 ☐ AM ☒ PM By: SP

Account Name: IEA / WEMS Account # —

Bill of Lading #: — Cooler #: —

Temp: 18.2 °C ROI ☐ Ambient ☐ Tracking #: —

TM#: 938 Ice Crystals Present in Sample ☐ —

MVTL Courier: Dan Other:

MVTL Route: Metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ SpeeDee ☐

Mail ☐ UPS Ground ☐ Fed Ex Ground ☐

Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column

Comments:

Number	Containers Size (mL)	Container Type	Preservation	pH
50	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	$NaHSO_4$ $Na_2O_3S_2$ NONE HNO_3 H_2SO_4 NaOH HCl SUB*	<2 >9 >12 N/A Add
	Low Level Mercury Kit	***!!DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!!***		
	4 oz Jar	Clear Amber	MeOH None	n/a
	2 oz Jar	Clear Amber	MeOH None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Vials Individual Set of 2 Set of 3	Clear Amber	HCl H_3PO_4 H_2SO_4 None	n/a
	Trip Blank Individual Set of 2 Set of 3	n/a		
	Moisture Vial	n/a		
	Manure Bottle	n/a		

*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.