

Lead in Water Test Results Summary: Maple Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.


- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Nurse office (A115) Sink	20830700-001NS	5/20/2025	4.2	Low	[enter date]	[enter result]	[autofill]
Nurse office Drinking fountain	20830700-002DW	5/20/2025	3.1	Low			
Nurse office Bathroom faucet	20830700-003BF	5/20/2025	1.5	Low			
Staff bathroom faucet office area	20830700-004BF	5/20/2025	ND	Non-Detect			
Classroom A100 Faucet	20830700-005CF	5/20/2025	ND	Non-Detect			
Classroom A100 Drinking Fountain	20830700-006DW	5/20/2025	2.3	Low			
Classroom A101 Faucet	20830700-007CF	5/20/2025	ND	Non-Detect			
Classroom A101 Drinking Fountain	20830700-008DW	5/20/2025	ND	Non-Detect			
Classroom A102 Faucet	20830700-009CF	5/20/2025	ND	Non-Detect			
Classroom A102 Drinking Fountain	20830700-010DW	5/20/2025	1.8	Low			
Classroom A103 Faucet	20830700-011CF	5/20/2025	ND	Non-Detect			
Classroom A103 Drinking Fountain	20830700-012DW	5/20/2025	ND	Non-Detect			
Classroom A104 Faucet	20830700-013CF	5/20/2025	ND	Non-Detect			
Classroom A104 Drinking Fountain	20830700-014DW	5/20/2025	ND	Non-Detect			
A-Wing Bathroom Faucet #1(Far Left)	20830700-015BF	5/20/2025	ND	Non-Detect			
A-Wing Bathroom Faucet #2	20830700-016BF	5/20/2025	ND	Non-Detect			
A-Wing Bathroom Faucet #3	20830700-017BF	5/20/2025	ND	Non-Detect			
A-Wing Bathroom Faucet #4	20830700-018BF	5/20/2025	ND	Non-Detect			
A-Wing Bathroom Faucet #5	20830700-019BF	5/20/2025	ND	Non-Detect			
A-Wing Bathroom Faucet #6 (Far Right)	20830700-020BF	5/20/2025	ND	Non-Detect			
Room A106 Faucet	20830700-021SF	5/20/2025	ND	Non-Detect			
Room A106 Drinking Fountain	20830700-022DW	5/20/2025	6.2	Moderate			
Library Office Faucet	20830700-023SF	5/20/2025	4.6	Low			
Library Office Drinking Fountain	20830700-024DW	5/20/2025	7.8	Moderate			
Gym Drinking fountain #1	20830700-025DW	5/20/2025	ND	Non-Detect			
Gym Drinking fountain #2	20830700-026DW	5/20/2025	ND	Non-Detect			
Classroom B100 Faucet (B-Wing First Floor)	20830700-027CF	5/20/2025	6.4	Moderate			
Classroom B100 Drinking Fountain	20830700-028DW	5/20/2025	7.5	Moderate			
Classroom B102 Faucet	20830700-031CF	5/20/2025	7.5	Moderate			
Classroom B102 Drinking Fountain	20830700-032DW	5/20/2025	11.6	High			
Classroom B103 Faucet	20830700-033CF	5/20/2025	6.3	Moderate			
Classroom B104 Faucet	20830700-035CF	5/20/2025	4.4	Low			
Classroom B104 Drinking Fountain	20830700-036DW	5/20/2025	2.7	Low			
B-Wing Staff Bathroom Faucet	20830700-037BF	5/20/2025	ND	Non-Detect			
Drinking Fountain #1	20830700-038DW	5/20/2025	ND	Non-Detect			
Drinking Fountain #2	20830700-039DW	5/20/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #1 (Far Left)	20830700-040BF	5/20/2025	2.6	Low			
B-Wing Bathroom Faucet #2	20830700-041BF	5/20/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #3	20830700-042BF	5/20/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #4 (Far Right)	20830700-043BF	5/20/2025	1.1	Low			
Commons Faucet	20830700-044SF	5/20/2025	1.3	Low			
Commons Drinking Fountain	20830700-045DW	5/20/2025	3	Low			
C-Wing Bathroom Faucet #1 (Far Left)	20830700-046BF	5/20/2025	ND	Non-Detect			
Bathroom Faucet #2	20830700-047BF	5/20/2025	ND	Non-Detect			
Bathroom Faucet #3	20830700-048BF	5/20/2025	ND	Non-Detect			
Bathroom Faucet #4 (Far Right)	20830700-049BF	5/20/2025	ND	Non-Detect			
Drinking Fountain #1	20830700-050DW	5/20/2025	ND	Non-Detect			
Drinking Fountain #2	20830700-051DW	5/20/2025	ND	Non-Detect			
C-WING Staff bathroom faucet	20830700-052BF	5/20/2025	ND	Non-Detect			
Classroom C101 Faucet	20830700-053CF	5/20/2025	3.5	Low			

Classroom C101 Drinking Fountain	20830700-054DW	5/20/2025	2.4	Low			
Classroom C102 Faucet	20830700-055CF	5/20/2025	2.1	Low			
Classroom C102 Drinking Fountain	20830700-056DW	5/20/2025	1.5	Low			
Classroom C103 Faucet	20830700-057CF	5/20/2025	2.3	Low			
Classroom C103 Drinking Fountain	20830700-058DW	5/20/2025	1.7	Low			
Classroom C104 Faucet	20830700-059CF	5/20/2025	2.1	Low			
Classroom C104 Bathroom Faucet	20830700-061BF	5/20/2025	1.2	Low			
C106 Staff Lounge Faucet	20830700-062SF	5/20/2025	1	Low			
C106 Staff Lounge Insta-Hot	20830700-063SF	5/20/2025	ND	Non-Detect			
Classroom C107 Faucet	20830700-064CF	5/20/2025	8.6	Moderate	5/23/2025	ND	Non-Detect
Classroom C107 Drinking Fountain	20830700-065CF	5/20/2025	3.8	Low			
Kitchen Bathroom Faucet	20830700-066BF	5/20/2025	2.2	Low			
Kitchen Faucet #1 (By Freezer, Left)	20830700-067KF	5/20/2025	1.3	Low			
Kitchen Faucet #2 (By Freezer, Right)	20830700-068KF	5/20/2025	ND	Non-Detect			
Kitchen Faucet #3 (Steam Kettle)	20830700-069KF	5/20/2025	ND	Non-Detect			
Dishwasher area	20830700-070KF	5/20/2025	ND	Non-Detect			
Dishwasher area	20830700-071KF	5/20/2025	ND	Non-Detect			
Kitchen Faucet #6 (Faucet next to dishwasher)	20830700-072KF	5/20/2025	ND	Non-Detect			
Classroom C200 Faucet Second Floor C-wing)	20830700-073CF	5/20/2025	6.1	Moderate			
Classroom C200 Drinking Fountain	20830700-074DW	5/20/2025	3	Low			
C-Wing Staff bathroom faucet	20830700-075BF	5/20/2025	1.5	Low			
Classroom C201 Faucet	20830700-076CF	5/20/2025	4.8	Low			
Classroom C201 Drinking Fountain	20830700-077DW	5/20/2025	1.7	Low			
Classroom C202 Faucet	20830700-078CF	5/20/2025	3.6	Low			
Classroom C202 Drinking Fountain	20830700-079DW	5/20/2025	2.5	Low			
Classroom C203 Faucet	20830700-080CF	5/20/2025	2.6	Low			
Classroom C203 Drinking Fountain	20830700-081DW	5/20/2025	1.1	Low			
Classroom C204 Faucet	20830700-082CF	5/20/2025	ND	Non-Detect			
Classroom C204 Drinking Fountain	20830700-083DW	5/20/2025	ND	Non-Detect			
Drinking Fountain #1	20830700-084DW	5/20/2025	ND	Non-Detect			
Drinking Fountain #2	20830700-085DW	5/20/2025	ND	Non-Detect			
C-Wing Bathroom Faucet #1 (Far Left)	20830700-086BF	5/20/2025	ND	Non-Detect			
Bathroom Faucet #2	20830700-087BF	5/20/2025	ND	Non-Detect			
Bathroom Faucet #3	20830700-088BF	5/20/2025	1.3	Low			
Bathroom Faucet #4 (Far Right)	20830700-089BF	5/20/2025	3.5	Low			
B-Wing Bathroom Faucet #1 (Far Left)	20830700-090BF	5/20/2025	1.6	Low			
B-Wing Bathroom Faucet #2	20830700-091BF	5/20/2025	2	Low			
B-Wing Bathroom Faucet #3	20830700-092BF	5/20/2025	1.3	Low			
B-Wing Bathroom Faucet #4 (Far Right)	20830700-093BF	5/20/2025	ND	Non-Detect			
Drinking Fountain #1	20830700-094DW	5/20/2025	ND	Non-Detect			
Drinking Fountain #2	20830700-095DW	5/20/2025	ND	Non-Detect			
B-Wing Staff bathroom faucet	20830700-096BF	5/20/2025	1.4	Low			
Classroom B200 Faucet (B-Wing Second Floor)	20830700-097CF	5/20/2025	8	Moderate			
Classroom B200 Drinking Fountain	20830700-098DW	5/20/2025	1.6	Low			
Classroom B201 Faucet	20830700-099CF	5/20/2025	6.2	Moderate			
Classroom B201 Drinking Fountain	20830700-100DW	5/20/2025	8.2	Moderate			
Classroom B202 Faucet	20830700-101CF	5/20/2025	2.6	Low			
Classroom B202 Drinking Fountain	20830700-102DW	5/20/2025	1.2	Low			
Classroom B203 Faucet	20830700-103CF	5/20/2025	2.7	Low			
Classroom B203 Drinking Fountain	20830700-104DW	5/20/2025	1.3	Low			
Classroom B204 Faucet	20830700-105CF	5/20/2025	6.6	Moderate			
Classroom B204 Drinking Fountain	20830700-106DW	5/20/2025	2.4	Low			
Outside Bathroom Faucet (By Gym)	20830700-107BF	5/20/2025	5.4	Moderate			



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052709

Springfield Public Schools	Project: Lead Testing	Date Reported: 06/04/25
1890 42nd Street	Project #: Springfield School District 19 Maple	Date Received: 05/27/25 11:30
Springfield, OR 97477	Elementary	Sampled By: Mario Rodriguez
	Client Contact: John Harshberger	

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052709-01	Sample Location: 20830700-001NS									
Lead (±)		1030	4.2	ppb	1.0	15	05/20/25 04:55	06/03/25	DST	
5052709-02	Sample Location: 20830700-002DW									
Lead (±)		1030	3.1	ppb	1.0	15	05/20/25 04:55	06/03/25	DST	
5052709-03	Sample Location: 20830700-003BF									
Lead (±)		1030	1.5	ppb	1.0	15	05/20/25 04:55	06/03/25	DST	
5052709-04	Sample Location: 20830700-004BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 04:56	06/03/25	DST	
5052709-05	Sample Location: 20830700-005CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 04:58	06/03/25	DST	
5052709-06	Sample Location: 20830700-006DW									
Lead (±)		1030	2.3	ppb	1.0	15	05/20/25 04:58	06/03/25	DST	
5052709-07	Sample Location: 20830700-007CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:00	06/03/25	DST	
5052709-08	Sample Location: 20830700-008DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:00	06/03/25	DST	
5052709-09	Sample Location: 20830700-009CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:01	06/03/25	DST	
5052709-10	Sample Location: 20830700-010DW									
Lead (±)		1030	1.8	ppb	1.0	15	05/20/25 05:01	06/03/25	DST	
5052709-11	Sample Location: 20830700-011CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:03	06/03/25	DST	
5052709-12	Sample Location: 20830700-012DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:03	06/03/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052709

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052709-13	Sample Location: 20830700-013CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:04	06/03/25	DST	
5052709-14	Sample Location: 20830700-014DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:04	06/03/25	DST	
5052709-15	Sample Location: 20830700-015BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:05	06/03/25	DST	
5052709-16	Sample Location: 20830700-016BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:06	06/03/25	DST	
5052709-17	Sample Location: 20830700-017BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:06	06/03/25	DST	
5052709-18	Sample Location: 20830700-018BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:07	06/03/25	DST	
5052709-19	Sample Location: 20830700-019BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:07	06/03/25	DST	
5052709-20	Sample Location: 20830700-020BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:08	06/03/25	DST	
5052709-21	Sample Location: 20830700-021SF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:09	06/03/25	DST	
5052709-22	Sample Location: 20830700-022DW									
Lead (±)		1030	6.2	ppb	1.0	15	05/20/25 05:09	06/03/25	DST	
5052709-23	Sample Location: 20830700-023SF									
Lead (±)		1030	4.6	ppb	1.0	15	05/20/25 05:11	06/03/25	DST	
5052709-24	Sample Location: 20830700-024DW									
Lead (±)		1030	7.8	ppb	1.0	15	05/20/25 05:11	06/03/25	DST	
5052709-25	Sample Location: 20830700-025DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:12	06/03/25	DST	
5052709-26	Sample Location: 20830700-026DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:12	06/03/25	DST	
5052709-27	Sample Location: 20830700-027CF									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052709

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	6.4	ppb	1.0	15	05/20/25 05:14	06/03/25	DST	
5052709-28	Sample Location: 20830700-028DW									
Lead (±)		1030	7.5	ppb	1.0	15	05/20/25 05:14	06/03/25	DST	
5052709-29	Sample Location: 20830700-031CF									
Lead (±)		1030	7.5	ppb	1.0	15	05/20/25 05:17	06/03/25	DST	
5052709-30	Sample Location: 20830700-032DW									
Lead (±)		1030	11.6	ppb	1.0	15	05/20/25 05:17	06/03/25	DST	
5052709-31	Sample Location: 20830700-033CF									
Lead (±)		1030	6.3	ppb	1.0	15	05/20/25 05:19	06/03/25	DST	
5052709-32	Sample Location: 20830700-035CF									
Lead (±)		1030	4.4	ppb	1.0	15	05/20/25 05:21	06/03/25	DST	
5052709-33	Sample Location: 20830700-036DW									
Lead (±)		1030	2.7	ppb	1.0	15	05/20/25 05:21	06/03/25	DST	
5052709-34	Sample Location: 20830700-037BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:22	06/03/25	DST	
5052709-35	Sample Location: 20830700-038DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:23	06/03/25	DST	
5052709-36	Sample Location: 20830700-039DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:23	06/03/25	DST	
5052709-37	Sample Location: 20830700-040BF									
Lead (±)		1030	2.6	ppb	1.0	15	05/20/25 05:24	06/03/25	DST	
5052709-38	Sample Location: 20830700-041BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:25	06/03/25	DST	
5052709-39	Sample Location: 20830700-042BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:25	06/03/25	DST	
5052709-40	Sample Location: 20830700-043BF									
Lead (±)		1030	1.1	ppb	1.0	15	05/20/25 05:26	06/03/25	DST	
5052709-41	Sample Location: 20830700-044SF									
Lead (±)		1030	1.3	ppb	1.0	15	05/20/25 05:27	06/03/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052709

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052709-42	Sample Location: 20830700-045DW									
Lead (±)		1030	3.0	ppb	1.0	15	05/20/25 05:27	06/03/25	DST	
5052709-43	Sample Location: 20830700-046BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:28	06/03/25	DST	
5052709-44	Sample Location: 20830700-047BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:28	06/03/25	DST	
5052709-45	Sample Location: 20830700-048BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:29	06/03/25	DST	
5052709-46	Sample Location: 20830700-049BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:29	06/03/25	DST	
5052709-47	Sample Location: 20830700-050DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:30	06/03/25	DST	
5052709-48	Sample Location: 20830700-051DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:30	06/03/25	DST	
5052709-49	Sample Location: 20830700-052BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:31	06/03/25	DST	
5052709-50	Sample Location: 20830700-053CF									
Lead (±)		1030	3.5	ppb	1.0	15	05/20/25 05:31	06/03/25	DST	
5052709-51	Sample Location: 20830700-054DW									
Lead (±)		1030	2.4	ppb	1.0	15	05/20/25 05:32	06/03/25	DST	
5052709-52	Sample Location: 20830700-055CF									
Lead (±)		1030	2.1	ppb	1.0	15	05/20/25 05:34	06/03/25	DST	
5052709-53	Sample Location: 20830700-056DW									
Lead (±)		1030	1.5	ppb	1.0	15	05/20/25 05:34	06/03/25	DST	
5052709-54	Sample Location: 20830700-057CF									
Lead (±)		1030	2.3	ppb	1.0	15	05/20/25 05:35	06/03/25	DST	
5052709-55	Sample Location: 20830700-058DW									
Lead (±)		1030	1.7	ppb	1.0	15	05/20/25 05:36	06/03/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052709

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052709-56	Sample Location: 20830700-059CF									
Lead (Pb)		1030	2.1	ppb	1.0	15	05/20/25 05:37	06/03/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052709

Qualifiers and Definitions


DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052708

Springfield Public Schools	Project: Lead Testing	Date Reported: 06/04/25
1890 42nd Street	Project #: Springfield School District 19 Maple	Date Received: 05/27/25 11:30
Springfield, OR 97477	Elementary	Sampled By: Mario Rodriguez
	Client Contact: John Harshberger	

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052708-01	Sample Location: 20830700-061BF									
Lead (±)		1030	1.2	ppb	1.0	15	05/20/25 05:37	06/03/25	DST	
5052708-02	Sample Location: 20830700-062SF									
Lead (±)		1030	1.0	ppb	1.0	15	05/20/25 05:39	06/03/25	DST	
5052708-03	Sample Location: 20830700-063SF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:39	06/03/25	DST	
5052708-04	Sample Location: 20830700-064CF									
Lead (±)		1030	8.6	ppb	1.0	15	05/20/25 05:41	06/03/25	DST	
5052708-05	Sample Location: 20830700-065DW									
Lead (±)		1030	3.8	ppb	1.0	15	05/20/25 05:41	06/03/25	DST	
5052708-06	Sample Location: 20830700-066BF									
Lead (±)		1030	2.2	ppb	1.0	15	05/20/25 05:43	06/03/25	DST	
5052708-07	Sample Location: 20830700-067KF									
Lead (±)		1030	1.3	ppb	1.0	15	05/20/25 05:44	06/03/25	DST	
5052708-08	Sample Location: 20830700-068KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:45	06/03/25	DST	
5052708-09	Sample Location: 20830700-069KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:46	06/03/25	DST	
5052708-10	Sample Location: 20830700-070KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:46	06/03/25	DST	
5052708-11	Sample Location: 20830700-071KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:47	06/03/25	DST	
5052708-12	Sample Location: 20830700-072KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:47	06/03/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052708

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052708-13	Sample Location: 20830700-073CF									
Lead (±)		1030	6.1	ppb	1.0	15	05/20/25 05:51	06/03/25	DST	
5052708-14	Sample Location: 20830700-074DW									
Lead (±)		1030	3.0	ppb	1.0	15	05/20/25 05:52	06/03/25	DST	
5052708-15	Sample Location: 20830700-075BF									
Lead (±)		1030	1.5	ppb	1.0	15	05/20/25 05:53	06/03/25	DST	
5052708-16	Sample Location: 20830700-076CF									
Lead (±)		1030	4.8	ppb	1.0	15	05/20/25 05:54	06/03/25	DST	
5052708-17	Sample Location: 20830700-077DW									
Lead (±)		1030	1.7	ppb	1.0	15	05/20/25 05:54	06/03/25	DST	
5052708-18	Sample Location: 20830700-078CF									
Lead (±)		1030	3.6	ppb	1.0	15	05/20/25 05:55	06/03/25	DST	
5052708-19	Sample Location: 20830700-079DW									
Lead (±)		1030	2.5	ppb	1.0	15	05/20/25 05:56	06/03/25	DST	
5052708-20	Sample Location: 20830700-080CF									
Lead (±)		1030	2.6	ppb	1.0	15	05/20/25 05:57	06/03/25	DST	
5052708-21	Sample Location: 20830700-081DW									
Lead (±)		1030	1.1	ppb	1.0	15	05/20/25 05:57	06/03/25	DST	
5052708-22	Sample Location: 20830700-082CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:58	06/03/25	DST	
5052708-23	Sample Location: 20830700-083DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 05:58	06/03/25	DST	
5052708-24	Sample Location: 20830700-084DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 06:00	06/03/25	DST	
5052708-25	Sample Location: 20830700-085DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 06:00	06/03/25	DST	
5052708-26	Sample Location: 20830700-086BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 06:01	06/03/25	DST	
5052708-27	Sample Location: 20830700-087BF									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052708

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 06:01	06/03/25	DST	
5052708-28	Sample Location: 20830700-088BF									
Lead (±)		1030	1.3	ppb	1.0	15	05/20/25 06:02	06/03/25	DST	
5052708-29	Sample Location: 20830700-089BF									
Lead (±)		1030	3.5	ppb	1.0	15	05/20/25 06:02	06/03/25	DST	
5052708-30	Sample Location: 20830700-090BF									
Lead (±)		1030	1.6	ppb	1.0	15	05/20/25 06:03	06/03/25	DST	
5052708-31	Sample Location: 20830700-091BF									
Lead (±)		1030	2.0	ppb	1.0	15	05/20/25 06:03	06/03/25	DST	
5052708-32	Sample Location: 20830700-092BF									
Lead (±)		1030	1.3	ppb	1.0	15	05/20/25 06:03	06/03/25	DST	
5052708-33	Sample Location: 20830700-093BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 06:04	06/03/25	DST	
5052708-34	Sample Location: 20830700-094DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 06:05	06/03/25	DST	
5052708-35	Sample Location: 20830700-095DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/25 06:05	06/03/25	DST	
5052708-36	Sample Location: 20830700-096BF									
Lead (±)		1030	1.4	ppb	1.0	15	05/20/25 06:06	06/03/25	DST	
5052708-37	Sample Location: 20830700-097CF									
Lead (±)		1030	8.0	ppb	1.0	15	05/20/25 06:07	06/03/25	DST	
5052708-38	Sample Location: 20830700-098DW									
Lead (±)		1030	1.6	ppb	1.0	15	05/20/25 06:07	06/03/25	DST	
5052708-39	Sample Location: 20830700-099CF									
Lead (±)		1030	6.2	ppb	1.0	15	05/20/25 06:09	06/03/25	DST	
5052708-40	Sample Location: 20830700-100DW									
Lead (±)		1030	8.2	ppb	1.0	15	05/20/25 06:09	06/03/25	DST	
5052708-41	Sample Location: 20830700-101CF									
Lead (±)		1030	2.6	ppb	1.0	15	05/20/25 06:11	06/03/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052708

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052708-42	Sample Location: 20830700-102DW									
Lead (±)		1030	1.2	ppb	1.0	15	05/20/25 06:11	06/03/25	DST	
5052708-43	Sample Location: 20830700-103CF									
Lead (±)		1030	2.7	ppb	1.0	15	05/20/25 06:12	06/03/25	DST	
5052708-44	Sample Location: 20830700-104DW									
Lead (±)		1030	1.3	ppb	1.0	15	05/20/25 06:12	06/03/25	DST	
5052708-45	Sample Location: 20830700-105CF									
Lead (±)		1030	6.6	ppb	1.0	15	05/20/25 06:13	06/03/25	DST	
5052708-46	Sample Location: 20830700-106DW									
Lead (±)		1030	2.4	ppb	1.0	15	05/20/25 06:13	06/03/25	DST	
5052708-47	Sample Location: 20830700-107BF									
Lead (±)		1030	5.4	ppb	1.0	15	05/20/25 06:17	06/03/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052708

Qualifiers and Definitions


DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # **5052718**

Springfield Public Schools
1890 42nd Street
Springfield, OR 97477

Project: Lead Testing
Project #: Springfield SD 19 Elizabeth Page
Elementary
Client Contact: Jody Olson

Date Reported: 06/26/25
Date Received: 05/27/25 11:30
Sampled By:

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052718-01	Sample Location: 20830400-064BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 06:31	05/29/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052718

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager