

Lead in Water Test Results Summary: Thurston Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.


- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Nurse office (A115) Sink	20831000-001NS	5/23/2025	3	Low	[enter date]	[enter result]	[autofill]
Nurse office Drinking fountain	20831000-002DW	5/23/2025	3.3	Low			
Nurse office Bathroom faucet	20831000-003BF	5/23/2025	1.7	Low			
Staff Bathroom Faucet (Office Area)	20831000-004BF	5/23/2025	ND	Non-Detect			
A-Wing Classroom A101 Faucet	20831000-005CF	5/23/2025	1.4	Low			
Classroom A101 Drinking Fountain	20831000-006DW	5/23/2025	ND	Non-Detect			
Classroom A102 Faucet	20831000-007CF	5/23/2025	1.6	Low			
Classroom A102 Drinking Fountain	20831000-008DW	5/23/2025	4	Low			
Classroom A103 Faucet	20831000-009CF	5/23/2025	3.7	Low			
Classroom A103 Drinking Fountain	20831000-010DW	5/23/2025	ND	Non-Detect			
Classroom A104 Faucet	20831000-011CF	5/23/2025	3.3	Low			
Classroom A104 Drinking Fountain	20831000-012DW	5/23/2025	1.6	Low			
A-Wing Bathroom Faucet #1(Far Left)	20831000-013BF	5/23/2025	ND	Non-Detect			
A-Wing Bathroom Faucet #2	20831000-014BF	5/23/2025	1.9	Low			
A-Wing Bathroom Faucet #3	20831000-015BF	5/23/2025	ND	Non-Detect			
A-Wing Bathroom Faucet #4(Far Right)	20831000-016BF	5/23/2025	1.8	Low			
Classroom A100 Faucet	20831000-017CF	5/23/2025	8.6	Moderate			
Classroom A100 Drinking Fountain	20831000-018DW	5/23/2025	5.1	Moderate			
Gym Drinking fountain #1	20831000-019DW	5/23/2025	ND	Non-Detect			
Gym Drinking fountain #2	20831000-020DW	5/23/2025	ND	Non-Detect			
Speech Classroom Faucet (Next To Gym Entrance)	20831000-021CF	5/23/2025	7.2	Moderate			
Speech Classroom Drinking Fountain	20831000-022DW	5/23/2025	3.2	Low			
B-Wing Classroom B101 Faucet	20831000-023CF	5/23/2025	1.6	Low			
Classroom B101 Drinking Fountain	20831000-024DW	5/23/2025	2.7	Low			
Classroom B102 Faucet	20831000-025CF	5/23/2025	3.5	Low			
Classroom B102 Drinking Fountain	20831000-026DW	5/23/2025	1.5	Low			
Classroom B103 Faucet	20831000-027CF	5/23/2025	2.2	Low			
Classroom B103 Drinking Fountain	20831000-028DW	5/23/2025	1.8	Low			
Classroom B104 Faucet	20831000-029CF	5/23/2025	5.4	Moderate			
Classroom B104 Drinking Fountain	20831000-030DW	5/23/2025	4.4	Low			
B-Wing Staff Bathroom Faucet	20831000-031BF	5/23/2025	ND	Non-Detect			
Drinking fountain #1	20831000-032DW	5/23/2025	ND	Non-Detect			
Drinking fountain #2	20831000-033DW	5/23/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #1 (Far Left)	20831000-034BF	5/23/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #2	20831000-035BF	5/23/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #3	20831000-036BF	5/23/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #4 (Far Right)	20831000-037BF	5/23/2025	ND	Non-Detect			
C-Wing Bathroom Faucet #1 (Far Left)	20831000-038BF	5/23/2025	ND	Non-Detect			
Bathroom Faucet #2	20831000-039BF	5/23/2025	ND	Non-Detect			
Bathroom Faucet #3	20831000-040BF	5/23/2025	ND	Non-Detect			
Bathroom Faucet #4 (Far Right)	20831000-041BF	5/23/2025	ND	Non-Detect			
Drinking fountain #1	20831000-042DW	5/23/2025	ND	Non-Detect			
Drinking fountain #2	20831000-043DW	5/23/2025	ND	Non-Detect			
Staff Faucet (Across From Drinnking Fountains)	20831000-044SF	5/23/2025	1.5	Low			
Drinking Fountain (Across From Drinnking Fountains)	20831000-045DW	5/23/2025	3.4	Low			

C-WING Staff Bathroom Faucet	20831000-046BF	5/23/2025	ND	Non-Detect			
Classroom C101 Faucet	20831000-047CF	5/23/2025	3	Low			
Classroom C101 Drinking Fountain	20831000-048DW	5/23/2025	1.9	Low			
Classroom C102 Faucet	20831000-049CF	5/23/2025	1.5	Low			
Classroom C102 Drinking Fountain	20831000-050DW	5/23/2025	1.3	Low			
Classroom C103 Faucet	20831000-051CF	5/23/2025	3.1	Low			
Classroom C103 Drinking Fountain	20831000-052DW	5/23/2025	2	Low			
Classroom C104 Faucet	20831000-053CF	5/23/2025	2.1	Low			
Classroom C104 Bathroom Faucet	20831000-055BF	5/23/2025	ND	Non-Detect			
C106 Staff Lounge Faucet	20831000-056SF	5/23/2025	ND	Non-Detect			
C106 Staff Lounge Insta-Hot	20831000-057SF	5/23/2025	ND	Non-Detect			
Classroom C107 Faucet	20831000-058CF	5/23/2025	5.7	Moderate			
Classroom C107 Drinking Fountain	20831000-059DW	5/23/2025	3.6	Low			
Kitchen Bathroom Faucet	20831000-060BF	5/23/2025	2.2	Low			
Kitchen Faucet #1 (By Freezer, Left)	20831000-061KF	5/23/2025	ND	Non-Detect			
Kitchen Faucet #2 (By Freezer, Right)	20831000-062KF	5/23/2025	ND	Non-Detect			
Kitchen Faucet #3 (Steam Kettle Next To Stove)	20831000-063KF	5/23/2025	ND	Non-Detect			
Kitchen Faucet #4 (West Wall Left Faucet)				Non-Detect			
Dishwasher area	20831000-064KF	5/23/2025	ND				
Kitchen Faucet #5 (West Wall Right Faucet)				Non-Detect			
Dishwasher area	20831000-065KF	5/23/2025	ND				
Kitchen Faucet #6 (Faucet next to dishwasher)	20831000-066KF	5/23/2025	4.9	Low			
Classroom C200 Faucet Second Floor C-wing)	20831000-067CF	5/23/2025	3	Low			
Classroom C200 Drinking Fountain	20831000-068DW	5/23/2025	2.2	Low			
C-Wing Staff bathroom faucet	20831000-069BF	5/23/2025	ND	Non-Detect			
Classroom C201 Faucet	20831000-070CF	5/23/2025	6.1	Moderate			
Classroom C201 Drinking Fountain	20831000-071DW	5/23/2025	2.6	Low			
Classroom C202 Faucet	20831000-072CF	5/23/2025	2.9	Low			
Classroom C202 Drinking Fountain	20831000-073DW	5/23/2025	1.6	Low			
Classroom C203 Faucet	20831000-074CF	5/23/2025	2	Low			
Classroom C203 Drinking Fountain	20831000-075DW	5/23/2025	2.4	Low			
Classroom C204 Faucet	20831000-076CF	5/23/2025	5.2	Moderate			
Classroom C204 Drinking Fountain	20831000-077DW	5/23/2025	1.6	Low			
Drinking Fountain #1	20831000-078DW	5/23/2025	ND	Non-Detect			
Drinking Fountain #2	20831000-079DW	5/23/2025	ND	Non-Detect			
C-Wing Bathroom Faucet #1 (Far Left)	20831000-080BF	5/23/2025	ND	Non-Detect			
Bathroom Faucet #2	20831000-081BF	5/23/2025	1	Low			
Bathroom Faucet #3	20831000-082BF	5/23/2025	ND	Non-Detect			
Bathroom Faucet #4 (Far Right)	20831000-083BF	5/23/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #1 (Far Left)	20831000-084BF	5/23/2025	ND	Non-Detect			
B-Wing Bathroom Faucet #2	20831000-085BF	5/23/2025	1.2	Low			
B-Wing Bathroom Faucet #3	20831000-086BF	5/23/2025	1.2	Low			
B-Wing Bathroom Faucet #4 (Far Right)	20831000-087BF	5/23/2025	1.3	Low			
Drinking Fountain #1	20831000-088DW	5/23/2025	ND	Non-Detect			
Drinking Fountain #2	20831000-089DW	5/23/2025	ND	Non-Detect			
B-Wing Staff bathroom faucet	20831000-090BF	5/23/2025	ND	Non-Detect			
Classroom B200 Faucet (B-Wing Second Floor)	20831000-091CF	5/23/2025	3	Low			
Classroom B200 Drinking Fountain	20831000-092DW	5/23/2025	2.6	Low			
Classroom B201 Faucet	20831000-093CF	5/23/2025	1.9	Low			
Classroom B201 Drinking Fountain	20831000-094DW	5/23/2025	1.7	Low			
Classroom B202 Faucet	20831000-095CF	5/23/2025	1.5	Low			
Classroom B202 Drinking Fountain	20831000-096DW	5/23/2025	2.2	Low			
Classroom B203 Faucet	20831000-097CF	5/23/2025	3.7	Low			
Classroom B203 Drinking Fountain	20831000-098DW	5/23/2025	1.4	Low			
Classroom B204 Faucet	20831000-099CF	5/23/2025	3.5	Low			
Classroom B204 Drinking Fountain	20831000-100DW	5/23/2025	1.5	Low			



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052710

Springfield Public Schools	Project: Lead Testing	Date Reported: 06/13/25
1890 42nd Street	Project #: Springfield School District 19	Date Received: 05/27/25 11:30
Springfield, OR 97477	Thurston Elementary	Sampled By: Mario Rodriguez
	Client Contact: Jody Olson	

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052710-01	Sample Location: 20831000-001NS									
Lead (±)		1030	3.0	ppb	1.0	15	05/23/25 04:56	06/06/25	DST	
5052710-02	Sample Location: 20831000-002DW									
Lead (±)		1030	3.3	ppb	1.0	15	05/23/25 04:56	06/06/25	DST	
5052710-03	Sample Location: 20831000-003BF									
Lead (±)		1030	1.7	ppb	1.0	15	05/23/25 04:57	06/06/25	DST	
5052710-04	Sample Location: 20831000-004BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 04:57	06/06/25	DST	
5052710-05	Sample Location: 20831000-005CF									
Lead (±)		1030	1.4	ppb	1.0	15	05/23/25 04:59	06/06/25	DST	
5052710-06	Sample Location: 20831000-006DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 04:59	06/06/25	DST	
5052710-07	Sample Location: 20831000-007CF									
Lead (±)		1030	1.6	ppb	1.0	15	05/23/25 05:00	06/06/25	DST	
5052710-08	Sample Location: 20831000-008DW									
Lead (±)		1030	4.0	ppb	1.0	15	05/23/25 05:00	06/06/25	DST	
5052710-09	Sample Location: 20831000-009CF									
Lead (±)		1030	3.7	ppb	1.0	15	05/23/25 05:02	06/06/25	DST	
5052710-10	Sample Location: 20831000-010DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:02	06/06/25	DST	
5052710-11	Sample Location: 20831000-011CF									
Lead (±)		1030	3.3	ppb	1.0	15	05/23/25 05:03	06/06/25	DST	
5052710-12	Sample Location: 20831000-012DW									
Lead (±)		1030	1.6	ppb	1.0	15	05/23/25 05:03	06/06/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052710

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052710-13	Sample Location: 20831000-013BF									
Lead (¢)		1030	ND	ppb	1.0	15	05/23/25 05:05	06/06/25	DST	
5052710-14	Sample Location: 20831000-014BF									
Lead (¢)		1030	1.9	ppb	1.0	15	05/23/25 05:05	06/06/25	DST	
5052710-15	Sample Location: 20831000-015BF									
Lead (¢)		1030	ND	ppb	1.0	15	05/23/25 05:05	06/06/25	DST	
5052710-16	Sample Location: 20831000-016BF									
Lead (¢)		1030	1.8	ppb	1.0	15	05/23/25 05:06	06/06/25	DST	
5052710-17	Sample Location: 20831000-017CF									
Lead (¢)		1030	8.6	ppb	1.0	15	05/23/25 05:08	06/06/25	DST	
5052710-18	Sample Location: 20831000-018DW									
Lead (¢)		1030	5.1	ppb	1.0	15	05/23/25 05:08	06/06/25	DST	
5052710-19	Sample Location: 20831000-019DW									
Lead (¢)		1030	ND	ppb	1.0	15	05/23/25 05:11	06/06/25	DST	
5052710-20	Sample Location: 20831000-020DW									
Lead (¢)		1030	ND	ppb	1.0	15	05/23/25 05:11	06/06/25	DST	
5052710-21	Sample Location: 20831000-021CF									
Lead (¢)		1030	7.2	ppb	1.0	15	05/23/25 05:12	06/06/25	DST	
5052710-22	Sample Location: 20831000-022DW									
Lead (¢)		1030	3.2	ppb	1.0	15	05/23/25 05:13	06/06/25	DST	
5052710-23	Sample Location: 20831000-023CF									
Lead (¢)		1030	1.6	ppb	1.0	15	05/23/25 05:15	06/12/25	DST	
5052710-24	Sample Location: 20831000-024DW									
Lead (¢)		1030	2.7	ppb	1.0	15	05/23/25 05:15	06/12/25	DST	
5052710-25	Sample Location: 20831000-025CF									
Lead (¢)		1030	3.5	ppb	1.0	15	05/23/25 05:16	06/12/25	DST	
5052710-26	Sample Location: 20831000-026DW									
Lead (¢)		1030	1.5	ppb	1.0	15	05/23/25 05:16	06/12/25	DST	
5052710-27	Sample Location: 20831000-027CF									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052710

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	2.2	ppb	1.0	15	05/23/25 05:18	06/12/25	DST	
5052710-28	Sample Location: 20831000-028DW									
Lead (±)		1030	1.8	ppb	1.0	15	05/23/25 05:18	06/12/25	DST	
5052710-29	Sample Location: 20831000-029CF									
Lead (±)		1030	5.4	ppb	1.0	15	05/23/25 05:19	06/12/25	DST	
5052710-30	Sample Location: 20831000-030DW									
Lead (±)		1030	4.4	ppb	1.0	15	05/23/25 05:19	06/12/25	DST	
5052710-31	Sample Location: 20831000-031BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:20	06/12/25	DST	
5052710-32	Sample Location: 20831000-032DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:21	06/12/25	DST	
5052710-33	Sample Location: 20831000-033DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:21	06/12/25	DST	
5052710-34	Sample Location: 20831000-034BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:22	06/12/25	DST	
5052710-35	Sample Location: 20831000-035BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:22	06/12/25	DST	
5052710-36	Sample Location: 20831000-036BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:23	06/12/25	DST	
5052710-37	Sample Location: 20831000-037BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:23	06/12/25	DST	
5052710-38	Sample Location: 20831000-038BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:24	06/12/25	DST	
5052710-39	Sample Location: 20831000-039BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:25	06/12/25	DST	
5052710-40	Sample Location: 20831000-040BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:25	06/12/25	DST	
5052710-41	Sample Location: 20831000-041BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:25	06/12/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052710

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052710-42	Sample Location: 20831000-042DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:26	06/12/25	DST	
5052710-43	Sample Location: 20831000-043DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:27	06/12/25	DST	
5052710-44	Sample Location: 20831000-044SF									
Lead (±)		1030	1.5	ppb	1.0	15	05/23/25 05:28	06/12/25	DST	
5052710-45	Sample Location: 20831000-045DW									
Lead (±)		1030	3.4	ppb	1.0	15	05/23/25 05:28	06/12/25	DST	
5052710-46	Sample Location: 20831000-046BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:29	06/12/25	DST	
5052710-47	Sample Location: 20831000-047CF									
Lead (±)		1030	3.0	ppb	1.0	15	05/23/25 05:30	06/12/25	DST	
5052710-48	Sample Location: 20831000-048DW									
Lead (±)		1030	1.9	ppb	1.0	15	05/23/25 05:30	06/12/25	DST	
5052710-49	Sample Location: 20831000-049CF									
Lead (±)		1030	1.5	ppb	1.0	15	05/23/25 05:31	06/12/25	DST	
5052710-50	Sample Location: 20831000-050DW									
Lead (±)		1030	1.3	ppb	1.0	15	05/23/25 05:31	06/12/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052710

Qualifiers and Definitions


DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052711

Springfield Public Schools 1890 42nd Street Springfield, OR 97477	Project: Lead Testing Project #: Springfield School District 19 Thurston Elementary Client Contact: Jody Olson	Date Reported: 06/20/25 Date Received: 05/27/25 11:30 Sampled By: Mario Rodriguez
---	---	---

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052711-01	Sample Location: 20831000-051CF									
Lead (±)		1030	3.1	ppb	1.0	15	05/23/25 05:33	06/12/25	DST	
5052711-02	Sample Location: 20831000-052DW									
Lead (±)		1030	2.0	ppb	1.0	15	05/23/25 05:33	06/12/25	DST	
5052711-03	Sample Location: 20831000-053CF									
Lead (±)		1030	2.1	ppb	1.0	15	05/23/25 05:35	06/12/25	DST	
5052711-04	Sample Location: 20831000-055BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:35	06/12/25	DST	
5052711-05	Sample Location: 20831000-056SF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:37	06/12/25	DST	
5052711-06	Sample Location: 20831000-057SF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:37	06/12/25	DST	
5052711-07	Sample Location: 20831000-058CF									
Lead (±)		1030	5.7	ppb	1.0	15	05/23/25 05:38	06/12/25	DST	
5052711-08	Sample Location: 20831000-059DW									
Lead (±)		1030	3.6	ppb	1.0	15	05/23/25 05:38	06/12/25	DST	
5052711-09	Sample Location: 20831000-060BF									
Lead (±)		1030	2.2	ppb	1.0	15	05/23/25 05:40	06/12/25	DST	
5052711-10	Sample Location: 20831000-061KF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:41	06/12/25	DST	
5052711-11	Sample Location: 20831000-062KF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:41	06/12/25	DST	
5052711-12	Sample Location: 20831000-063KF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:42	06/12/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052711

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052711-13	Sample Location: 20831000-064KF									
Lead (¢)		1030	ND	ppb	1.0	15	05/23/25 05:43	06/12/25	DST	
5052711-14	Sample Location: 20831000-065KF									
Lead (¢)		1030	ND	ppb	1.0	15	05/23/25 05:43	06/12/25	DST	
5052711-15	Sample Location: 20831000-066KF									
Lead (¢)		1030	4.9	ppb	1.0	15	05/23/25 05:43	06/12/25	DST	
5052711-16	Sample Location: 20831000-067CF									
Lead (¢)		1030	3.0	ppb	1.0	15	05/23/25 05:47	06/12/25	DST	
5052711-17	Sample Location: 20831000-068DW									
Lead (¢)		1030	2.2	ppb	1.0	15	05/23/25 05:47	06/12/25	DST	
5052711-18	Sample Location: 20831000-069BF									
Lead (¢)		1030	ND	ppb	1.0	15	05/23/25 05:48	06/12/25	DST	
5052711-19	Sample Location: 20831000-070CF									
Lead (¢)		1030	6.1	ppb	1.0	15	05/23/25 05:50	06/12/25	DST	
5052711-20	Sample Location: 20831000-071DW									
Lead (¢)		1030	2.6	ppb	1.0	15	05/23/25 05:50	06/12/25	DST	
5052711-21	Sample Location: 20831000-072CF									
Lead (¢)		1030	2.9	ppb	1.0	15	05/23/25 05:51	06/13/25	DST	
5052711-22	Sample Location: 20831000-073DW									
Lead (¢)		1030	1.6	ppb	1.0	15	05/23/25 05:51	06/13/25	DST	
5052711-23	Sample Location: 20831000-074CF									
Lead (¢)		1030	2.0	ppb	1.0	15	05/23/25 05:52	06/13/25	DST	
5052711-24	Sample Location: 20831000-075DW									
Lead (¢)		1030	2.4	ppb	1.0	15	05/23/25 05:52	06/13/25	DST	
5052711-25	Sample Location: 20831000-076CF									
Lead (¢)		1030	5.2	ppb	1.0	15	05/23/25 05:53	06/13/25	DST	
5052711-26	Sample Location: 20831000-077DW									
Lead (¢)		1030	1.6	ppb	1.0	15	05/23/25 05:53	06/13/25	DST	
5052711-27	Sample Location: 20831000-078DW									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052711

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:55	06/13/25	DST	
5052711-28	Sample Location: 20831000-079DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:55	06/13/25	DST	
5052711-29	Sample Location: 20831000-080BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:56	06/13/25	DST	
5052711-30	Sample Location: 20831000-081BF									
Lead (±)		1030	1.0	ppb	1.0	15	05/23/25 05:56	06/13/25	DST	
5052711-31	Sample Location: 20831000-082BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:56	06/13/25	DST	
5052711-32	Sample Location: 20831000-083BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:57	06/13/25	DST	
5052711-33	Sample Location: 20831000-084BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:59	06/13/25	DST	
5052711-34	Sample Location: 20831000-085BF									
Lead (±)		1030	1.2	ppb	1.0	15	05/23/25 05:59	06/13/25	DST	
5052711-35	Sample Location: 20831000-086BF									
Lead (±)		1030	1.2	ppb	1.0	15	05/23/25 05:59	06/13/25	DST	
5052711-36	Sample Location: 20831000-087BF									
Lead (±)		1030	1.3	ppb	1.0	15	05/23/25 05:59	06/17/25	DST	
5052711-37	Sample Location: 20831000-088DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 06:00	06/17/25	DST	
5052711-38	Sample Location: 20831000-089DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 06:00	06/17/25	DST	
5052711-39	Sample Location: 20831000-090BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 06:01	06/17/25	DST	
5052711-40	Sample Location: 20831000-091CF									
Lead (±)		1030	3.0	ppb	1.0	15	05/23/25 06:02	06/17/25	DST	
5052711-41	Sample Location: 20831000-092DW									
Lead (±)		1030	2.6	ppb	1.0	15	05/23/25 06:02	06/17/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052711

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052711-42	Sample Location: 20831000-093CF									
Lead (±)		1030	1.9	ppb	1.0	15	05/23/25 06:04	06/17/25	DST	
5052711-43	Sample Location: 20831000-094DW									
Lead (±)		1030	1.7	ppb	1.0	15	05/23/25 06:05	06/17/25	DST	
5052711-44	Sample Location: 20831000-095CF									
Lead (±)		1030	1.5	ppb	1.0	15	05/23/25 06:06	06/17/25	DST	
5052711-45	Sample Location: 20831000-096DW									
Lead (±)		1030	2.2	ppb	1.0	15	05/23/25 06:06	06/17/25	DST	
5052711-46	Sample Location: 20831000-097CF									
Lead (±)		1030	3.7	ppb	1.0	15	05/23/25 06:07	06/17/25	DST	
5052711-47	Sample Location: 20831000-098DW									
Lead (±)		1030	1.4	ppb	1.0	15	05/23/25 06:07	06/17/25	DST	
5052711-48	Sample Location: 20831000-099CF									
Lead (±)		1030	3.5	ppb	1.0	15	05/23/25 06:08	06/17/25	DST	
5052711-49	Sample Location: 20831000-100DW									
Lead (±)		1030	1.5	ppb	1.0	15	05/23/25 06:08	06/17/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 5052711

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager