

Lead in Water Test Results Summary: Thurston High School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Column1
Main office Nurse sink faucet	5612100-001NS	2/7/2024	ND	Non-Detect	[enter date]	[enter result]	[autofill]	
Nurses bathroom faucet	5612100-002BF	2/7/2024	ND	Non-Detect				
Mens restroom faucet (Student services)	5612100-003BF	2/7/2024	ND	Non-Detect				
Mens restroom faucet (Student services)	5612100-004BF	2/7/2024	2.1	Low				
Drinking Fountain	5612100-005DW	2/7/2024	ND	Non-Detect				
Drinking Fountain	5612100-006DW	2/7/2024	ND	Non-Detect				
Womens bathroom faucet (student services)	5612100-007BF	2/7/2024	ND	Non-Detect				
Womens bathroom faucet (student services)	5612100-008BF	2/7/2024	2.08	Low				
Staffroom faucet	5612100-009SF	2/7/2024	ND	Non-Detect				
Drinking Fountain	5612100-010DW	2/7/2024	ND	Non-Detect				
Water bottle fill station	5612100-011WB	2/7/2024	ND	Non-Detect				
Rm 74 classroom faucet	5612100-012CF	2/7/2024	3.59	Low				
Rm 76 classroom faucet	5612100-013CF	2/7/2024	2.33	Low				
Rm 77 classroom faucet	5612100-014CF	2/7/2024	ND	Non-Detect				
Drinking water fountain end of 82-87 wing	5612100-015DW	2/7/2024	ND	Non-Detect				
Drinking water fountain end of 92-96 wing	5612100-016DW	2/7/2024	ND	Non-Detect				
Rm 93 classroom faucet	5612100-017CF	2/7/2024	ND	Non-Detect				
ADA bathroom faucet behind room 49 (1)	5612100-018BF	2/7/2024	ND	Non-Detect				
Rm 50 classroom faucet	5612100-019CF	2/7/2024	2.1	Low				
Rm 50 classroom faucet (hand wash)	5612100-020CF	2/7/2024	2.05	Low				
Mens restroom faucet (2) back of 44-47 wing	5612100-021BF	2/7/2024	ND	Non-Detect				
Womens bathroom faucet (2)	5612100-022BF	2/7/2024	2.5	Low				
Mens restroom faucet (3) back of 42-43 wing	5612100-023BF	2/7/2024	2.42	Low				
Womens bathroom faucet (3)	5612100-024BF	2/7/2024	3	Low				
Library drinking water fountain	5612100-025DW	2/7/2024	ND	Non-Detect				
Rm 141 classroom faucet	5612100-026CF	2/7/2024	ND	Non-Detect				
Rm 142 classroom faucet	5612100-027CF	2/7/2024	ND	Non-Detect				
Rm 142 classroom faucet	5612100-028CF	2/7/2024	ND	Non-Detect				
Rm 142 classroom faucet	5612100-029CF	2/7/2024	ND	Non-Detect				
Rm 142 classroom faucet	5612100-030CF	2/7/2024	ND	Non-Detect				
Rm 142 classroom faucet	5612100-031CF	2/7/2024	ND	Non-Detect				
Rm 142 classroom faucet	5612100-032CF	2/7/2024	2.4	Low				
Rm 130 classroom faucet	5612100-033CF	2/7/2024	9.81	Moderate				
Rm 130 classroom faucet	5612100-034CF	2/7/2024	3.99	Low				
Rm 130 classroom faucet	5612100-036CF	2/7/2024	3.65	Low				
Rm 130 classroom faucet	5612100-037CF	2/7/2024	4.23	Low				
Rm 130 classroom faucet	5612100-038CF	2/7/2024	ND	Non-Detect				
Rm 130 classroom faucet	5612100-040CF	2/7/2024	9.8	Moderate				
Rm 130 classroom faucet	5612100-041CF	2/7/2024	6.29	Moderate				
Rm 130 classroom faucet	5612100-042CF	2/7/2024	8.46	Moderate				
Rm 130 classroom faucet	5612100-043CF	2/7/2024	19.2	Action Req.	Labelled no-drinking			
Rm 130 classroom faucet	5612100-044CF	2/7/2024	5.22	Moderate				
Rm 130 classroom faucet	5612100-045CF	2/7/2024	5.05	Moderate				
Rm 130 classroom faucet	5612100-046CF	2/7/2024	3.18	Low				
Rm 130 classroom faucet	5612100-047CF	2/7/2024	32.3	Action Req.	Labelled no-drinking			
Rm 130 classroom faucet	5612100-048CF	2/7/2024	17.4	Action Req.	Labelled no-drinking			
Rm 130 drinking water fountain	5612100-049DW	2/7/2024	67.2	Action Req.	Fixture Removed			
Back of Rm 130 & 131 staff faucet	5612100-050SF	2/7/2024	7.66	Moderate				
Rm 131 classroom faucet	5612100-051CF	2/7/2024	4.25	Low				
Rm 131 classroom faucet	5612100-052CF	2/7/2024	22.8	Action Req.	Labelled no-drinking			
Rm 131 classroom faucet	5612100-054CF	2/7/2024	26.7	Action Req.	Labelled no-drinking			
Rm 131 classroom faucet	5612100-055CF	2/7/2024	3.03	Low				
Rm 131 classroom faucet	5612100-056CF	2/7/2024	21.2	Action Req.	Labelled no-drinking			
Rm 131 classroom faucet	5612100-058CF	2/7/2024	2.43	Low				
Rm 131 classroom faucet	5612100-059CF	2/7/2024	4.48	Low				
Rm 131 classroom faucet	5612100-062CF	2/7/2024	7.05	Moderate				
Rm 132 classroom faucet	5612100-063CF	2/7/2024	3.39	Low				
Rm 132 classroom faucet	5612100-064CF	2/7/2024	2.74	Low				
Rm 132 classroom faucet	5612100-065CF	2/7/2024	4.23	Low				
Rm 132 classroom faucet	5612100-066CF	2/7/2024	3.68	Low				
Rm 132 classroom faucet	5612100-067CF	2/7/2024	ND	Non-Detect				
Rm 132 classroom faucet	5612100-068CF	2/7/2024	ND	Non-Detect				
Rm 120 classroom faucet	5612100-069CF	2/7/2024	8.49	Moderate				
Rm 120 classroom faucet	5612100-070CF	2/7/2024	5.28	Moderate				
Rm 120 Drinking Water Facuet	5612100-071DW	2/7/2024	11.5	High				

Rm 120 classroom faucet	5612100-072CF	2/7/2024	6.29	Moderate		
Rm 121 Classroom Faucet	5612100-073CF	2/7/2024	2.6	Low		
Rm 122 classroom faucet	5612100-074CF	2/7/2024	6.09	Moderate		
Rm 122 classroom faucet	5612100-075CF	2/7/2024	6.92	Moderate		
Rm 122 classroom faucet	5612100-076CF	2/7/2024	ND	Non-Detect		
Rm 122 Drinking water fountain	5612100-077DW	2/7/2024	5.74	Moderate		
Rm 135 classroom faucet	5612100-078CF	2/7/2024	ND	Non-Detect		
Rm 135 classroom faucet	5612100-079CF	2/7/2024	4.85	Low		
Rm 135 classroom faucet	5612100-080CF	2/7/2024	8.32	Moderate		
Rm 135 classroom faucet	5612100-081CF	2/7/2024	7.39	Moderate		
Rm 135 classroom faucet	5612100-082CF	2/7/2024	3.03	Low		
Rm 135 classroom faucet	5612100-083CF	2/7/2024	3.39	Low		
Rm 135 classroom faucet	5612100-084CF	2/7/2024	2.64	Low		
RM134 classroom faucet	5612100-085CF	2/7/2024	5.93	Moderate		
RM134 classroom faucet	5612100-086CF	2/7/2024	33.9	Action Req.	Science Room	Labelled No-Drinking
RM134 classroom faucet	5612100-087CF	2/7/2024	106	Action Req.	Science Room	Labelled No-Drinking
RM134 classroom faucet	5612100-088CF	2/7/2024	46.2	Action Req.	Science Room	Labelled No-Drinking
RM134 classroom faucet	5612100-089CF	2/7/2024	42.9	Action Req.	Science Room	Labelled No-Drinking
RM134 classroom faucet	5612100-090CF	2/7/2024	43.9	Action Req.	Science Room	Labelled No-Drinking
Staffroom faucet between 134 & 133	5612100-091SF	2/7/2024	2.87	Low		
RM133 classroom faucet	5612100-092CF	2/7/2024	ND	Non-Detect		
RM133 classroom faucet	5612100-093CF	2/7/2024	2.37	Low		
Main Gym Mens bathroom faucet	5612100-094BF	2/7/2024	ND	Non-Detect		
Drinking water fountain	5612100-095DW	2/7/2024	4.96	Low		
Boys locker room bathroom faucet	5612100-096BF	2/7/2024	ND	Non-Detect		
Boys locker room bathroom faucet	5612100-097BF	2/7/2024	ND	Non-Detect		
Boys locker room bathroom faucet (coaches)	5612100-098BF	2/7/2024	2.82	Low		
Drinking water fountain	5612100-099DW	2/7/2024	ND	Non-Detect		
Student store (concessions) Staff faucet	5612100-101SF	2/7/2024	2.69	Low		
Water bottle fill station	5612100-102WB	2/7/2024	ND	Non-Detect		
Drinking water fountain	5612100-103DW	2/7/2024	ND	Non-Detect		
Womens bathroom faucet	5612100-104BF	2/7/2024	ND	Non-Detect		
Aux Gym Girls locker bathroom faucet	5612100-105BF	2/9/2024	ND	Non-Detect		
Girls locker bathroom faucet	5612100-106BF	2/9/2024	ND	Non-Detect		
Girls locker bathroom faucet	5612100-107BF	2/9/2024	ND	Non-Detect		
Girls locker bathroom faucet	5612100-108BF	2/9/2024	ND	Non-Detect		
Girls locker bathroom faucet	5612100-109BF	2/9/2024	ND	Non-Detect		
Girls locker bathroom faucet	5612100-110BF	2/9/2024	ND	Non-Detect		
Girls locker bathroom faucet	5612100-111BF	2/9/2024	ND	Non-Detect		
Drinking water fountain	5612100-112DW	2/9/2024	5	Low		
Coaches bathroom faucet	5612100-113BF	2/9/2024	ND	Non-Detect		
Girls training room drinking water fountain	5612100-115DW	2/9/2024	ND	Non-Detect		
Athletic trainer room staff faucet	5612100-116SF	2/9/2024	ND	Non-Detect		
Athletic trainer room Drinking water fountain	5612100-117DW	2/9/2024	ND	Non-Detect		
AUX GYM bottle water fill station	5612100-118WB	2/9/2024	ND	Non-Detect		
Drinking water fountain	5612100-119DW	2/9/2024	ND	Non-Detect		
Weight room Drinking water fountain	5612100-120DW	2/9/2024	ND	Non-Detect		
Rm 151 music drinking water fountain	5612100-121DW	2/9/2024	ND	Non-Detect		
Bathroom between 150 & 151 mens	5612100-122BF	2/9/2024	ND	Non-Detect		
Bathroom between 150 & 151 womens	5612100-123BF	2/9/2024	ND	Non-Detect		
Cafeteria Drinking water fountain	5612100-124DW	2/9/2024	ND	Non-Detect		
Water bottle fill station	5612100-125WB	2/9/2024	ND	Non-Detect		
Kitchen Faucet	5612100-126KF	2/9/2024	6.86	Moderate		
Kitchen faucet serving area	5612100-127KF	2/9/2024	ND	Non-Detect		
Kitchen faucet neat walk in cooler	5612100-128KF	2/9/2024	4.54	Low		
Kitchen faucet	5612100-129KF	2/9/2024	6.96	Moderate		
Kitchen faucet near office	5612100-130KF	2/9/2024	9.09	Moderate		
Kitchen faucet dishwahr area	5612100-131KF	2/9/2024	7.13	Moderate		
Kitchen faucet dishwahr area	5612100-132KF	2/9/2024	5.16	Moderate		
Kitchen faucet dishwahr area	5612100-133KF	2/9/2024	ND	Non-Detect		
Kitchen faucet	5612100-134KF	2/9/2024	3.59	Low		
Kitchen faucet	5612100-135KF	2/9/2024	3.5	Low		
Kitchen saff bathroom faucet	5612100-136KF	2/9/2024	ND	Non-Detect		
Auditorium Drinking water fountain	5612100-137DW	2/9/2024	ND	Non-Detect		
Mens bathroom faucet	5612100-138BF	2/9/2024	6.01	Moderate		
Womens bathroom faucet	5612100-139BF	2/9/2024	ND	Non-Detect		
Drinking fountain main entrance	5612100-140DW	2/9/2024	ND	Non-Detect		
Drinking fountain ticket booth area	5612100-141DW	2/9/2024	5.05	Moderate		
Womens make up room classroom faucet	5612100-142CF	2/9/2024	11.3	High		
Mens make up room classroom faucet	5612100-143CF	2/9/2024	ND	Non-Detect		
Bathroom faucet	5612100-144BF	2/9/2024	ND	Non-Detect		
Bathroom faucet	5612100-145BF	2/9/2024	ND	Non-Detect		
(160)	5612100-146SF	2/9/2024	ND	Non-Detect		
Wood shop class room faucet	5612100-147CF	2/9/2024	ND	Non-Detect		
Wood shop class room faucet	5612100-148CF	2/9/2024	ND	Non-Detect		
Metal 162 classroom faucet at entrance	5612100-149CF	2/9/2024	9.11	Moderate		
Classroom faucet passed lockers	5612100-150CF	2/9/2024	ND	Non-Detect		
Classroom faucet passed lockers	5612100-151CF	2/9/2024	ND	Non-Detect		
Drinking water fountain	5612100-152DW	2/9/2024	ND	Non-Detect		
Hallway Water bottle fill station	5612100-153WB	2/9/2024	ND	Non-Detect		
Drinking water fountain	5612100-154DW	2/9/2024	ND	Non-Detect		
Rm 164 Classroom faucet	5612100-155CF	2/9/2024	ND	Non-Detect		
Drinking water fountain	5612100-156DW	2/9/2024	ND	Non-Detect		
Rm 165 Classroom faucet	5612100-157CF	2/9/2024	ND	Non-Detect		

Rm 168 Classroom faucet	5612100-158CF	2/9/2024	ND	Non-Detect	
Drinking water fountain	5612100-159DW	2/9/2024	ND	Non-Detect	
Boys bathroom faucet	5612100-160BF	2/9/2024	ND	Non-Detect	
Womens bathroom faucet	5612100-161BF	2/9/2024	ND	Non-Detect	
Rm 167 Classroom faucet	5612100-162CF	2/9/2024	2.73	Low	
Classroom faucet	5612100-163CF	2/9/2024	ND	Non-Detect	
Classroom faucet	5612100-164CF	2/9/2024	ND	Non-Detect	
Classroom faucet	5612100-165CF	2/9/2024	ND	Non-Detect	
Classroom faucet	5612100-166CF	2/9/2024	ND	Non-Detect	
Rm 169 Drinking Water	5612100-167DW	2/9/2024	12.9	High	
Classroom faucet	5612100-168CF	2/9/2024	ND	Non-Detect	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

February 21, 2024

THS

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Property: THS

Order No.: 2402212

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/7/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia'.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402212

Date: 2/21/2024

CLIENT: Springfield School District #19

Project: Springfield SD Property: THS

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#:	2402212	Received Date:	2/7/2024 9:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD Property: THS	Matrix:	Drinking Water

Lab ID: 2402212-001	Client Sample ID 5612100-001NS	Collection Date: 2/6/2024 4:56:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/18/24 11:52	KG

Lab ID: 2402212-002	Client Sample ID 5612100-002BF	Collection Date: 2/6/2024 4:57:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/18/24 11:52	KG

Lab ID: 2402212-003	Client Sample ID 5612100-003BF	Collection Date: 2/6/2024 4:58:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/18/24 11:52	KG

Lab ID: 2402212-004	Client Sample ID 5612100-004BF	Collection Date: 2/6/2024 4:59:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.10		2.00	1.00	ppb	02/19/24 16:00	AS

Lab ID: 2402212-005	Client Sample ID 5612100-005DW	Collection Date: 2/6/2024 5:03:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/19/24 16:00	AS

Lab ID: 2402212-006	Client Sample ID 5612100-006DW	Collection Date: 2/6/2024 5:02:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/19/24 16:00	AS

Lab ID: 2402212-007	Client Sample ID 5612100-007BF	Collection Date: 2/6/2024 5:02:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Definitions:

A	Accredited by ORELAP
LOD	Limit of Detection
MCL	Maximum Contaminant Level
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit

Qualifiers:

WO#:	2402212	Received Date:	2/7/2024 9:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD Property: THS	Matrix:	Drinking Water

Lab ID: 2402212-008	Client Sample ID 5612100-008BF	Collection Date: 2/6/2024 5:00:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.08		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402212-009	Client Sample ID 5612100-009SF	Collection Date: 2/6/2024 5:01:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402212-010	Client Sample ID 5612100-010DW	Collection Date: 2/6/2024 5:01:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402212-011	Client Sample ID 5612100-011WB	Collection Date: 2/6/2024 5:07:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402212-012	Client Sample ID 5612100-012CF	Collection Date: 2/6/2024 5:09:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.59		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402212-013	Client Sample ID 5612100-013CF	Collection Date: 2/6/2024 5:10:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.33		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402212-014	Client Sample ID 5612100-014CF	Collection Date: 2/6/2024 5:10:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Definitions:	A	Accredited by ORELAP
	LOD	Limit of Detection
	MCL	Maximum Contaminant Level
	ND	Not Detected at the Reporting Limit
	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit

Qualifiers:

WO#:	2402212	Received Date:	2/7/2024 9:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD Property: THS	Matrix:	Drinking Water

Lab ID:	2402212-015	Client Sample ID	5612100-015DW	Collection Date:	2/6/2024 5:12:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID:	2402212-016	Client Sample ID	5612100-016DW	Collection Date:	2/6/2024 5:13:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID:	2402212-017	Client Sample ID	5612100-017CF	Collection Date:	2/6/2024 5:16:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID:	2402212-018	Client Sample ID	5612100-018BF	Collection Date:	2/6/2024 5:17:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID:	2402212-019	Client Sample ID	5612100-019CF	Collection Date:	2/6/2024 5:19:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.10		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID:	2402212-020	Client Sample ID	5612100-020CF	Collection Date:	2/6/2024 5:20:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.05		2.00	1.00	ppb	02/20/24 14:50	AS

Definitions:

A	Accredited by ORELAP
LOD	Limit of Detection
MCL	Maximum Contaminant Level
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit

Qualifiers:



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402212

Date: 2/21/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2402212
21-Feb-24

Client: Springfield School District #19

Project: Springfield SD Property: THS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402212-001A	5612100-001NS	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402212-002A	5612100-002BF			Lead	A
	2402212-003A	5612100-003BF			Lead	A
	2402212-004A	5612100-004BF			Lead	A
	2402212-005A	5612100-005DW			Lead	A
	2402212-006A	5612100-006DW			Lead	A
	2402212-007A	5612100-007BF			Lead	A
	2402212-008A	5612100-008BF			Lead	A
	2402212-009A	5612100-009SF			Lead	A
	2402212-010A	5612100-010DW			Lead	A
	2402212-011A	5612100-011WB			Lead	A
	2402212-012A	5612100-012CF			Lead	A
	2402212-013A	5612100-013CF			Lead	A
	2402212-014A	5612100-014CF			Lead	A
	2402212-015A	5612100-015DW			Lead	A
	2402212-016A	5612100-016DW			Lead	A
	2402212-017A	5612100-017CF			Lead	A
	2402212-018A	5612100-018BF			Lead	A
	2402212-019A	5612100-019CF			Lead	A
	2402212-020A	5612100-020CF			Lead	A

ACCRED
ORELAP A Accredited

Original #2402212# v1
Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100- 001 NS	DW/Grab	2/6	456	Lead	P	1		NA	001A
5612100- 002 BF	DW/Grab	2/6	457	Lead	P	1			002A
5612100- 003 BF	DW/Grab	2/6	458	Lead	P	1			003A
5612100- 004 BF	DW/Grab	2/6	459	Lead	P	1			004A
5612100- 005 DW	DW/Grab	2/6	503	Lead	P	1			005A
5612100- 006 DW*	DW/Grab	2/6	502	Lead	P	1			006A
5612100- 007 BF	DW/Grab	2/6	502	Lead	P	1			007A
5612100- 008 BF	DW/Grab	2/6	500	Lead	P	1			008A
5612100- 009 SF	DW/Grab	2/6	501	Lead	P	1			009A
5612100- 010 PW	DW/Grab	2/6	501	Lead	P	1			010A

Notes: *Corrected by client - FM 2/7/24	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH	Shipped Via: <u>Veronica Arciga</u>	Refrigerated Ice ☐ None ☒	
Relinquished by: <u>Veronica Arciga</u>	Date: <u>2/7/24</u>	Time: <u>9:00</u>	Received by:
Relinquished by:	Date:	Time:	Received by:
Relinquished by:	Date:	Time:	Received by Laboratory:
			Date: <u>2/7/24</u> Time: <u>9:00</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com
 LIMS: FM
 Checked: my

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: <u>Veronica Arciga</u> [Ⓢ]

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100- 011 WB	DW/Grab	2/6	507	Lead	P	1		NA	011A
5612100- 012 CF	DW/Grab	2/6	509	Lead	P	1			012A
5612100- 013 CF	DW/Grab	2/6	510	Lead	P	1			013A
5612100- 014 CF	DW/Grab	2/6	510	Lead	P	1			014A
5612100- 015 DW	DW/Grab	2/6	512	Lead	P	1			015A
5612100- 016 DW	DW/Grab	2/6	513	Lead	P	1			016A
5612100- 017 CF	DW/Grab	2/6	516	Lead	P	1			017A
5612100- 018 BF	DW/Grab	2/6	517	Lead	P	1			018A
5612100- 019 CF	DW/Grab	2/6	519	Lead	P	1			019A
5612100- 020 CF	DW/Grab	2/6	520	Lead	P	1			020A

Notes: <u>Per Veronica - FM 2/7/24</u>	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
REPORT							
Mail							
Email							
Fax							
Pickup							

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice <u>None</u>	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/7/24</u>	<u>9:00</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Jaith</u>	<u>2/7/24</u>	<u>9:00</u>	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

February 22, 2024

THS

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD Property: THS

Order No.: 2402224

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/7/2024 for the analyses presented in the following report.

Katrina Garcia

Katrina Garcia
Technical Director Chemistry
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402224

Date: 2/22/2024

CLIENT: Springfield School District #19

Project: Springfield SD Property: THS

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

WO#: 2402224
CLIENT: Springfield School District #19
Project: Springfield SD Property: THS

Received Date: 2/7/2024 9:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402224-001 Client Sample ID 5612100-021BF Collection Date: 2/6/2024 5:24:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402224-002 Client Sample ID 5612100-022BF Collection Date: 2/6/2024 5:22:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.50		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402224-003 Client Sample ID 5612100-023BF Collection Date: 2/6/2024 5:27:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.42		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402224-004 Client Sample ID 5612100-024BF Collection Date: 2/6/2024 5:28:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.00		2.00	1.00	ppb	02/20/24 14:50	AS

Lab ID: 2402224-005 Client Sample ID 5612100-025DW Collection Date: 2/6/2024 5:30:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-006 Client Sample ID 5612100-026CF Collection Date: 2/6/2024 5:36:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-007 Client Sample ID 5612100-027CF Collection Date: 2/6/2024 5:38:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 12:40	AS

Definitions:

- A Accredited by ORELAP
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- PQL Practical Quantitation Level or Reporting Limit

Qualifiers:

Analytical Report

Date Reported: 2/22/2024

WO#: 2402224
CLIENT: Springfield School District #19
Project: Springfield SD Property: THS

Received Date: 2/7/2024 9:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402224-008 Client Sample ID 5612100-028CF Collection Date: 2/6/2024 5:38:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-009 Client Sample ID 5612100-029CF Collection Date: 2/6/2024 5:39:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-010 Client Sample ID 5612100-030CF Collection Date: 2/6/2024 5:40:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-011 Client Sample ID 5612100-031CF Collection Date: 2/6/2024 5:40:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-012 Client Sample ID 5612100-032CF Collection Date: 2/6/2024 5:41:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.40		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-013 Client Sample ID 5612100-033CF Collection Date: 2/6/2024 5:48:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.81		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-014 Client Sample ID 5612100-034CF Collection Date: 2/6/2024 5:48:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.99		2.00	1.00	ppb	02/21/24 12:40	AS

Definitions:

- A Accredited by ORELAP
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- PQL Practical Quantitation Level or Reporting Limit

Qualifiers:

WO#:	2402224	Received Date:	2/7/2024 9:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD Property: THS	Matrix:	Drinking Water

Lab ID: 2402224-015	Client Sample ID 5612100-036CF	Collection Date: 2/6/2024 5:49:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.65		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-016	Client Sample ID 5612100-037CF	Collection Date: 2/6/2024 5:49:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.23		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-017	Client Sample ID 5612100-038CF	Collection Date: 2/6/2024 5:50:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-018	Client Sample ID 5612100-040CF	Collection Date: 2/6/2024 5:50:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.80		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-019	Client Sample ID 5612100-041CF	Collection Date: 2/6/2024 5:52:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.29		2.00	1.00	ppb	02/21/24 12:40	AS

Lab ID: 2402224-020	Client Sample ID 5612100-042CF	Collection Date: 2/6/2024 5:52:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.46		2.00	1.00	ppb	02/21/24 12:40	AS

Definitions:

A	Accredited by ORELAP
LOD	Limit of Detection
MCL	Maximum Contaminant Level
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit

Qualifiers:



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402224

Date: 2/22/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2402224
22-Feb-24

Client: Springfield School District #19

Project: Springfield SD Property: THS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402224-001A	5612100-021BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402224-002A	5612100-022BF			Lead	A
	2402224-003A	5612100-023BF			Lead	A
	2402224-004A	5612100-024BF			Lead	A
	2402224-005A	5612100-025DW			Lead	A
	2402224-006A	5612100-026CF			Lead	A
	2402224-007A	5612100-027CF			Lead	A
	2402224-008A	5612100-028CF			Lead	A
	2402224-009A	5612100-029CF			Lead	A
	2402224-010A	5612100-030CF			Lead	A
	2402224-011A	5612100-031CF			Lead	A
	2402224-012A	5612100-032CF			Lead	A
	2402224-013A	5612100-033CF			Lead	A
	2402224-014A	5612100-034CF			Lead	A
	2402224-015A	5612100-036CF			Lead	A
	2402224-016A	5612100-037CF			Lead	A
	2402224-017A	5612100-038CF			Lead	A
	2402224-018A	5612100-040CF			Lead	A
	2402224-019A	5612100-041CF			Lead	A
	2402224-020A	5612100-042CF			Lead	A

ACCRED
ORELAP A Accredited



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-021BF	DW/Grab	2/6	524	Lead	P	1		NA	001A
5612100-022BF	DW/Grab	2/6	522	Lead	P	1			002A
5612100-023BF	DW/Grab	2/6	527	Lead	P	1			003A
5612100-024BF	DW/Grab	2/6	528	Lead	P	1			004A
5612100-025DW	DW/Grab	2/6	530	Lead	P	1			005A
5612100-026CF	DW/Grab	2/6	536	Lead	P	1			006A
5612100-027CF	DW/Grab	2/6	538	Lead	P	1			007A
5612100-028CF	DW/Grab	2/6	538	Lead	P	1			008A
5612100-029CF	DW/Grab	2/6	539	Lead	P	1			009A
5612100-030CF	DW/Grab	2/6	540	Lead	P	1			010A

Notes: *Per Veronica - FM 2/7/24	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/7/11	900				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date of 9	Time	
				2/7/24	9:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100- 0310CF **	DW/Grab	2/6	540	Lead	P	1		ND	011A
5612100- 032CF	DW/Grab	2/6	541	Lead	P	1			012A
5612100- 033CF	DW/Grab	2/6	548	Lead	P	1			013A
5612100- 034CF	DW/Grab	2/6	548	Lead	P	1			014A
5612100- 036CF	DW/Grab	2/6	549	Lead	P	1			015A
5612100- 037CF	DW/Grab	2/6	549	Lead	P	1			016A
5612100- 038CF	DW/Grab	2/6	550	Lead	P	1			017A
5612100- 040CF	DW/Grab	2/6	550	Lead	P	1			018A
5612100- 041CF	DW/Grab	2/6	552	Lead	P	1			019A
5612100- 042CF	DW/Grab	2/6	552	Lead	P	1			020A

Notes: **Whiteout used by client. FM 2/7/24	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/7/24</u>	<u>900</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	<u>2/7/24</u>	<u>9:00</u>	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

February 22, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

THS

RE: Springfield SD Property: THS

Order No.: 2402226

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/7/2024 for the analyses presented in the following report.

Katrina Garcia

Katrina Garcia
Technical Director Chemistry
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402226

Date: 2/22/2024

CLIENT: Springfield School District #19

Project: Springfield SD Property: THS

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Analytical Report

Date Reported: 2/22/2024

WO#: 2402226
CLIENT: Springfield School District #19
Project: Springfield SD Property: THS

Received Date: 2/7/2024 9:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402226-001 Client Sample ID 5612100-043CF Collection Date: 2/6/2024 5:52:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	19.2	*	4.00	2.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-002 Client Sample ID 5612100-044CF Collection Date: 2/6/2024 5:53:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.22		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-003 Client Sample ID 5612100-045CF Collection Date: 2/6/2024 5:53:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.05		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-004 Client Sample ID 5612100-046CF Collection Date: 2/6/2024 5:54:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.18		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-005 Client Sample ID 5612100-047CF Collection Date: 2/6/2024 5:54:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	32.3	*	4.00	2.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-006 Client Sample ID 5612100-048CF Collection Date: 2/6/2024 5:55:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	17.4	*	2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-007 Client Sample ID 5612100-049DW Collection Date: 2/6/2024 5:56:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	67.2	*	8.00	4.00	ppb	02/21/24 17:23	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level		*	Value exceeds Maximum Contaminant Level (MCL)
	ND	Not Detected at the Reporting Limit		*	Value exceeds Maximum Contaminant Level (MCL)
	PL	Permit Limit		*	Value exceeds Maximum Contaminant Level (MCL)
	PQL	Practical Quantitation Level or Reporting Limit		*	Value exceeds Maximum Contaminant Level (MCL)
				*	Value exceeds Maximum Contaminant Level (MCL)

WO#: 2402226
CLIENT: Springfield School District #19
Project: Springfield SD Property: THS

Received Date: 2/7/2024 9:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402226-008 Client Sample ID 5612100-050SF Collection Date: 2/6/2024 5:59:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.66		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-009 Client Sample ID 5612100-051CF Collection Date: 2/6/2024 5:59:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.25		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-010 Client Sample ID 5612100-052CF Collection Date: 2/6/2024 6:00:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	22.8	*	4.00	2.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-011 Client Sample ID 5612100-054CF Collection Date: 2/6/2024 6:01:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	26.7	*	4.00	2.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-012 Client Sample ID 5612100-055CF Collection Date: 2/6/2024 6:01:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.03		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-013 Client Sample ID 5612100-056CF Collection Date: 2/6/2024 6:02:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	21.2	*	4.00	2.00	ppb	02/21/24 17:23	AS

Lab ID: 2402226-014 Client Sample ID 5612100-058CF Collection Date: 2/6/2024 6:03:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.43		2.00	1.00	ppb	02/21/24 17:23	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level		*	Value exceeds Maximum Contaminant Level (MCL)
	ND	Not Detected at the Reporting Limit		*	Value exceeds Maximum Contaminant Level (MCL)
	PL	Permit Limit		*	Value exceeds Maximum Contaminant Level (MCL)
	PQL	Practical Quantitation Level or Reporting Limit		*	Value exceeds Maximum Contaminant Level (MCL)
				*	Value exceeds Maximum Contaminant Level (MCL)

WO#: 2402226
CLIENT: Springfield School District #19
Project: Springfield SD Property: THS

Received Date: 2/7/2024 9:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402226-015	Client Sample ID 5612100-059CF	Collection Date: 2/6/2024 6:03:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	4.48 2.00 1.00 ppb 02/21/24 17:23 AS

Lab ID: 2402226-016	Client Sample ID 5612100-062CF	Collection Date: 2/6/2024 6:05:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	7.05 2.00 1.00 ppb 02/21/24 17:23 AS

Lab ID: 2402226-017	Client Sample ID 5612100-063CF	Collection Date: 2/6/2024 6:10:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	3.39 2.00 1.00 ppb 02/21/24 17:23 AS

Lab ID: 2402226-018	Client Sample ID 5612100-064CF	Collection Date: 2/6/2024 6:10:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	2.74 2.00 1.00 ppb 02/21/24 17:23 AS

Lab ID: 2402226-019	Client Sample ID 5612100-065CF	Collection Date: 2/6/2024 6:11:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	4.23 2.00 1.00 ppb 02/21/24 17:23 AS

Lab ID: 2402226-020	Client Sample ID 5612100-066CF	Collection Date: 2/6/2024 6:11:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	3.68 2.00 1.00 ppb 02/21/24 17:23 AS

Definitions:

A	Accredited by ORELAP
LOD	Limit of Detection
MCL	Maximum Contaminant Level
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
*	Value exceeds Maximum Contaminant Level (MCL)
*	Value exceeds Maximum Contaminant Level (MCL)
*	Value exceeds Maximum Contaminant Level (MCL)
*	Value exceeds Maximum Contaminant Level (MCL)
*	Value exceeds Maximum Contaminant Level (MCL)
*	Value exceeds Maximum Contaminant Level (MCL)



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402226

Date: 2/22/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2402226
22-Feb-24

Client: Springfield School District #19

Project: Springfield SD Property: THS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402226-001A	5612100-043CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402226-002A	5612100-044CF			Lead	A
	2402226-003A	5612100-045CF			Lead	A
	2402226-004A	5612100-046CF			Lead	A
	2402226-005A	5612100-047CF			Lead	A
	2402226-006A	5612100-048CF			Lead	A
	2402226-007A	5612100-049DW			Lead	A
	2402226-008A	5612100-050SF			Lead	A
	2402226-009A	5612100-051CF			Lead	A
	2402226-010A	5612100-052CF			Lead	A
	2402226-011A	5612100-054CF			Lead	A
	2402226-012A	5612100-055CF			Lead	A
	2402226-013A	5612100-056CF			Lead	A
	2402226-014A	5612100-058CF			Lead	A
	2402226-015A	5612100-059CF			Lead	A
	2402226-016A	5612100-062CF			Lead	A
	2402226-017A	5612100-063CF			Lead	A
	2402226-018A	5612100-064CF			Lead	A
	2402226-019A	5612100-065CF			Lead	A
	2402226-020A	5612100-066CF			Lead	A

ACCRED

ORELAP A Accredited

Original #2402226# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-043CF	DW/Grab	2/6	552	Lead	P	1		NA	001A
5612100-044CF	DW/Grab	2/6	553	Lead	P	1			002A
5612100-045CF	DW/Grab	2/6	553	Lead	P	1			003A
5612100-046CF	DW/Grab	2/6	554	Lead	P	1			004A
5612100-047CF	DW/Grab	2/6	554	Lead	P	1			005A
5612100-048CF	DW/Grab	2/6	555	Lead	P	1			006A
5612100-049DW	DW/Grab	2/6	556	Lead	P	1			007A
5612100-050SF	DW/Grab	2/6	559	Lead	P	1			008A
5612100-051CF	DW/Grab	2/6	559	Lead	P	1			009A
5612100-052CF	DW/Grab	2/6	600	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	<u>Veronica Arciga</u>	Ice ☐ None ☒
Relinquished by:	Received by:	Date
<u>Veronica Arciga</u>		
Relinquished by:	Received by:	Date
Relinquished by:	Received by Laboratory:	Date of 9
	<u>Smith</u>	<u>2/7/24 9:00</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-054CF	DW/Grab	2/6	601	Lead	P	1		NA	011A
5612100-055CF	DW/Grab	2/6	601	Lead	P	1			012A
5612100-056CF	DW/Grab	2/6	602	Lead	P	1			013A
5612100-058CF	DW/Grab	2/6	603	Lead	P	1			014A
5612100-059CF	DW/Grab	2/6	603	Lead	P	1			015A
5612100-062CF	DW/Grab	2/6	605	Lead	P	1			016A
5612100-063CF	DW/Grab	2/6	610	Lead	P	1			017A
5612100-064CF	DW/Grab	2/6	610	Lead	P	1			018A
5612100-065CF	DW/Grab	2/6	611	Lead	P	1			019A
5612100-066CF	DW/Grab	2/6	611	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/7/24</u>					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Faith</u>	<u>2/7/24</u>	<u>9:00</u>	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

THS

February 26, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Property: THS

Order No.: 2402231

Dear Terry Rutledge:

Analytical Laboratory Group received 22 sample(s) on 2/7/2024 for the analyses presented in the following report.

Teresa Garcia

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2402231

Date: 2/26/2024

CLIENT: Springfield School District #19

Project: Springfield SD Property: THS

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/26/2024

WO#: 2402231
CLIENT: Springfield School District #19
Project: Springfield SD Property: THS

Received Date: 2/7/2024 9:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402231-001 Client Sample ID 5612100-067CF Collection Date: 2/6/2024 6:12:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402231-002 Client Sample ID 5612100-068CF Collection Date: 2/6/2024 6:13:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402231-003 Client Sample ID 5612100-069CF Collection Date: 2/7/2024 6:11:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.49		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402231-004 Client Sample ID 5612100-070CF Collection Date: 2/7/2024 6:12:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.28		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402231-005 Client Sample ID 5612100-071DW Collection Date: 2/7/2024 6:22:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.5		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402231-006 Client Sample ID 5612100-072CF Collection Date: 2/7/2024 6:21:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.29		2.00	1.00	ppb	02/21/24 17:23	AS

Lab ID: 2402231-007 Client Sample ID 5612100-073CF Collection Date: 2/7/2024 6:20:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.60		2.00	1.00	ppb	02/21/24 17:23	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level		*	Value exceeds Maximum Contaminant Level (MCL)
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/26/2024

WO#:	2402231			Received Date: 2/7/2024 9:00:00 AM				
CLIENT:	Springfield School District #19			Sampler Name: Veronica Arciga				
Project:	Springfield SD Property: THS			Matrix: Drinking Water				
Lab ID: 2402231-008	Client Sample ID	5612100-074CF		Collection Date: 2/7/2024 6:17:00 AM				
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.09		2.00	1.00	ppb	02/21/24 17:23	AS
Lab ID: 2402231-009	Client Sample ID	5612100-075CF		Collection Date: 2/7/2024 6:16:00 AM				
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.92		2.00	1.00	ppb	02/21/24 17:23	AS
Lab ID: 2402231-010	Client Sample ID	5612100-076CF		Collection Date: 2/7/2024 6:15:00 AM				
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/21/24 17:23	AS
Lab ID: 2402231-011	Client Sample ID	5612100-077DW		Collection Date: 2/7/2024 6:14:00 AM				
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.74		2.00	1.00	ppb	02/23/24 17:30	KG
Lab ID: 2402231-012	Client Sample ID	5612100-078CF		Collection Date: 2/7/2024 6:04:00 AM				
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/22/24 18:18	AS
Lab ID: 2402231-013	Client Sample ID	5612100-079CF		Collection Date: 2/7/2024 6:06:00 AM				
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.85		2.00	1.00	ppb	02/22/24 18:18	AS
Lab ID: 2402231-014	Client Sample ID	5612100-080CF		Collection Date: 2/7/2024 6:06:00 AM				
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.32		2.00	1.00	ppb	02/22/24 18:18	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level		*	Value exceeds Maximum Contaminant Level (MCL)
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/26/2024

WO#: 2402231
CLIENT: Springfield School District #19
Project: Springfield SD Property: THS

Received Date: 2/7/2024 9:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402231-015	Client Sample ID 5612100-081CF	Collection Date: 2/7/2024 6:07:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	7.39 2.00 1.00 ppb 02/22/24 18:18 AS

Lab ID: 2402231-016	Client Sample ID 5612100-082CF	Collection Date: 2/7/2024 6:07:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	3.03 2.00 1.00 ppb 02/22/24 18:18 AS

Lab ID: 2402231-017	Client Sample ID 5612100-083CF	Collection Date: 2/7/2024 6:08:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	3.39 2.00 1.00 ppb 02/22/24 18:18 AS

Lab ID: 2402231-018	Client Sample ID 5612100-084CF	Collection Date: 2/7/2024 6:08:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	2.64 2.00 1.00 ppb 02/22/24 18:18 AS

Lab ID: 2402231-019	Client Sample ID 5612100-085CF	Collection Date: 2/7/2024 6:00:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	5.93 2.00 1.00 ppb 02/23/24 17:30 KG

Lab ID: 2402231-020	Client Sample ID 5612100-086CF	Collection Date: 2/7/2024 6:00:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	33.9 * 8.00 4.00 ppb 02/18/24 11:52 KG

Lab ID: 2402231-021	Client Sample ID 5612100-087CF	Collection Date: 2/7/2024 6:01:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	106 * 20.0 10.0 ppb 02/18/24 11:52 KG

Definitions:	A Accredited by ORELAP	Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)
	LOD Limit of Detection		* Value exceeds Maximum Contaminant Level (MCL)
	MCL Maximum Contaminant Level		* Value exceeds Maximum Contaminant Level (MCL)
	ND Not Detected at the Reporting Limit		
	PL Permit Limit		
	PQL Practical Quantitation Level or Reporting Limit		



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Analytical Report

Date Reported: 2/26/2024

WO#: 2402231 **Received Date:** 2/7/2024 9:00:00 AM
CLIENT: Springfield School District #19 **Sampler Name:** Veronica Arciga
Project: Springfield SD Property: THS **Matrix:** Drinking Water

Lab ID: 2402231-022 **Client Sample ID** 5612100-088CF **Collection Date:** 2/7/2024 6:01:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	46.2	*	8.00	4.00	ppb	02/23/24 17:30	KG

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level		*	Value exceeds Maximum Contaminant Level (MCL)
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2402231

Date: 2/26/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402231

26-Feb-24

Client: Springfield School District #19

Project: Springfield SD Property: THS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402231-001A	5612100-067CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402231-002A	5612100-068CF			Lead	A
	2402231-003A	5612100-069CF			Lead	A
	2402231-004A	5612100-070CF			Lead	A
	2402231-005A	5612100-071DW			Lead	A
	2402231-006A	5612100-072CF			Lead	A
	2402231-007A	5612100-073CF			Lead	A
	2402231-008A	5612100-074CF			Lead	A
	2402231-009A	5612100-075CF			Lead	A
	2402231-010A	5612100-076CF			Lead	A
	2402231-011A	5612100-077DW			Lead	A
	2402231-012A	5612100-078CF			Lead	A
	2402231-013A	5612100-079CF			Lead	A
	2402231-014A	5612100-080CF			Lead	A
	2402231-015A	5612100-081CF			Lead	A
	2402231-016A	5612100-082CF			Lead	A
	2402231-017A	5612100-083CF			Lead	A
	2402231-018A	5612100-084CF			Lead	A
	2402231-019A	5612100-085CF			Lead	A
	2402231-020A	5612100-086CF			Lead	A
	2402231-021A	5612100-087CF			Lead	A
	2402231-022A	5612100-088CF			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2402231# v1

Page 8 of 11



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: EM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100- 067CF	DW/Grab	2/6	6/2	Lead	P	1		NA	001A
5612100- 068CF	DW/Grab	2/6	6/3	Lead	P	1		NA	002A
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			

Notes: ^ Samples not relinquished; crossed out by lab. EM 2/7/24	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: <u>Veronica Arciga</u>		Refrigerated Ice <u>None</u>	
Relinquished by: <u>Veronica Arciga</u>	Date <u>2/7/24</u>	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by laboratory: <u>[Signature]</u>	Date <u>2/7/24</u>	Time <u>9:00</u>	



*Delivering more than
just test results*

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100- 069CF	DW/Grab	2/7	611	Lead	P	1		NA	003A
5612100- 070CF	DW/Grab	2/7	612	Lead	P	1			004A
5612100- 071DW	DW/Grab	2/7	622	Lead	P	1			005A
5612100- 072CF *	DW/Grab	2/7	621	Lead	P	1			006A
5612100- 073CF	DW/Grab	2/7	620	Lead	P	1			007A
5612100- 074CF	DW/Grab	2/7	617	Lead	P	1			008A
5612100- 075CF	DW/Grab	2/7	616	Lead	P	1			009A
5612100- 076CF	DW/Grab	2/7	615	Lead	P	1			010A
5612100- 077DW	DW/Grab	2/7	614	Lead	P	1			011A
5612100- 078CF	DW/Grab	2/7	604	Lead	P	1			012A

Notes: *Corrected by client. FM 2/7/24	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH					Ice	none
Relinquished by:	Date	Time	Received by:		Date	Time
Veronica Arciga	2/7/2024					
Relinquished by:	Date	Time	Received by:		Date	Time
Relinquished by:	Date	Time	Received by Laboratory:		Page Date of 11	Time
						2/7/24 9:00



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: BT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100- 079CF	DW/Grab	2/7	606	Lead	P	1		NA	013A
5612100- 080CF	DW/Grab	2/7	606	Lead	P	1			014A
5612100- 081CF	DW/Grab	2/7	607	Lead	P	1			015A
5612100- 082CF	DW/Grab	2/7	607	Lead	P	1			016A
5612100- 083CF	DW/Grab	2/7	608	Lead	P	1			017A
5612100- 084CF	DW/Grab	2/7	608	Lead	P	1			018A
5612100- 085CF	DW/Grab	2/7	600	Lead	P	1			019A
5612100- 086CF	DW/Grab	2/7	600	Lead	P	1			020A
5612100- 087CF	DW/Grab	2/7	601	Lead	P	1			021A
5612100- 088CF	DW/Grab	2/7	601	Lead	P	1			022A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ none ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/7/2024					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Page 1 of 1	Date	Time
			<i>[Signature]</i>		2/7/24	9:00



*Delivering more than
just test results*

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5993
Website:

THS.

February 26, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD Property: THS

Order No.: 2402237

Dear Terry Rutledge:

Analytical Laboratory Group received 15 sample(s) on 2/7/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads "Teresa Garcia". The signature is written in a cursive, flowing style.

Teresa Garcia
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2402237

Date: 2/26/2024

CLIENT: Springfield School District #19

Project: Springfield SD Property: THS

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/26/2024

WO#:	2402237				Received Date: 2/7/2024 9:00:00 AM				
CLIENT:	Springfield School District #19				Sampler Name: Veronica Arciga				
Project:	Springfield SD Property: THS				Matrix: Drinking Water				
Lab ID: 2402237-001	Client Sample ID	5612100-089CF	Collection Date: 2/7/2024 6:02:00 AM						
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst	
Lead	SM 3113 B	42.9	*	8.00	4.00	ppb	02/23/24 17:30	KG	
Lab ID: 2402237-002	Client Sample ID	5612100-090CF	Collection Date: 2/7/2024 6:03:00 AM						
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst	
Lead	SM 3113 B	43.9	*	8.00	4.00	ppb	02/18/24 11:52	KG	
Lab ID: 2402237-003	Client Sample ID	5612100-091SF	Collection Date: 2/7/2024 5:57:00 AM						
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst	
Lead	SM 3113 B	2.87		2.00	1.00	ppb	02/23/24 17:30	KG	
Lab ID: 2402237-004	Client Sample ID	5612100-092CF	Collection Date: 2/7/2024 5:55:00 AM						
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst	
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/23/24 17:30	KG	
Lab ID: 2402237-005	Client Sample ID	5612100-093CF	Collection Date: 2/7/2024 5:55:00 AM						
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst	
Lead	SM 3113 B	2.37		2.00	1.00	ppb	02/23/24 17:30	KG	
Lab ID: 2402237-006	Client Sample ID	5612100-094BF	Collection Date: 2/7/2024 5:33:00 AM						
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst	
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/23/24 17:30	KG	
Lab ID: 2402237-007	Client Sample ID	5612100-095DW	Collection Date: 2/7/2024 5:34:00 AM						
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst	
Lead	SM 3113 B	4.96		2.00	1.00	ppb	02/23/24 17:30	KG	

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/26/2024

WO#: 2402237
CLIENT: Springfield School District #19
Project: Springfield SD Property: THS

Received Date: 2/7/2024 9:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402237-008 **Client Sample ID** 5612100-096BF **Collection Date:** 2/7/2024 5:30:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/23/24 17:30	KG

Lab ID: 2402237-009 **Client Sample ID** 5612100-097BF **Collection Date:** 2/7/2024 5:39:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/23/24 17:30	KG

Lab ID: 2402237-010 **Client Sample ID** 5612100-098BF **Collection Date:** 2/7/2024 5:41:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.82		2.00	1.00	ppb	02/23/24 17:30	KG

Lab ID: 2402237-011 **Client Sample ID** 5612100-099DW **Collection Date:** 2/7/2024 5:37:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/23/24 17:30	KG

Lab ID: 2402237-012 **Client Sample ID** 5612100-101SF **Collection Date:** 2/7/2024 5:35:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.69		2.00	1.00	ppb	02/23/24 17:30	KG

Lab ID: 2402237-013 **Client Sample ID** 5612100-102WB **Collection Date:** 2/7/2024 5:44:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/23/24 17:30	KG

Lab ID: 2402237-014 **Client Sample ID** 5612100-103DW **Collection Date:** 2/7/2024 5:45:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/23/24 17:30	KG

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/26/2024

WO#:	2402237					Received Date:	2/7/2024 9:00:00 AM			
CLIENT:	Springfield School District #19					Sampler Name:	Veronica Arciga			
Project:	Springfield SD Property: THS					Matrix:	Drinking Water			
Lab ID:	2402237-015	Client Sample ID	5612100-104BF			Collection Date: 2/7/2024 5:52:00 AM				
Analyses		Method		Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead		SM 3113 B		ND		2.00	1.00	ppb	02/23/24 17:30	KG

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



*Delivering more than
just test results*

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2402237
Date: 2/26/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2402237

26-Feb-24

Client: Springfield School District #19

Project: Springfield SD Property: THS

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402237-001A	5612100-089CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402237-002A	5612100-090CF			Lead	A
	2402237-003A	5612100-091SF			Lead	A
	2402237-004A	5612100-092CF			Lead	A
	2402237-005A	5612100-093CF			Lead	A
	2402237-006A	5612100-094BF			Lead	A
	2402237-007A	5612100-095DW			Lead	A
	2402237-008A	5612100-096BF			Lead	A
	2402237-009A	5612100-097BF			Lead	A
	2402237-010A	5612100-098BF			Lead	A
	2402237-011A	5612100-099DW			Lead	A
	2402237-012A	5612100-101SF			Lead	A
	2402237-013A	5612100-102WB			Lead	A
	2402237-014A	5612100-103DW			Lead	A
	2402237-015A	5612100-104BF			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2402237# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: EM
Checked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100- 089CF	DW/Grab	2/7	602	Lead	P	1		NA	001A
5612100- 090CF	DW/Grab	2/7	603	Lead	P	1			002A
5612100- 091SF	DW/Grab	2/7	557	Lead	P	1			003A
5612100- 092CF	DW/Grab	2/7	555	Lead	P	1			004A
5612100- 093CF	DW/Grab	2/7	555	Lead	P	1			005A
5612100- 094BF	DW/Grab	2/7	533	Lead	P	1			006A
5612100- 095DW	DW/Grab	2/7	534	Lead	P	1			007A
5612100- 096BF	DW/Grab	2/7	530	Lead	P	1			008A
5612100- 097BF	DW/Grab	2/7	539	Lead	P	1			009A
5612100- 098BF	DW/Grab	2/7	541	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice <u>none</u>	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/7/2024					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/7/24	9:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.comLIMS: FMChecked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD Property: THS	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-099DW	DW/Grab	2/7	0537	Lead	P	1		NA	011A
5612100-101SF	DW/Grab	2/7	535	Lead	P	1			012A
5612100-102WB	DW/Grab	2/7	544	Lead	P	1			013A
5612100-103DW	DW/Grab	2/7	545	Lead	P	1			014A
5612100-104BF	DW/Grab	2/7	552	Lead	P	1			015A
5612100	DW/Grab			Lead	P	1			
5612100	DW/Grab			Lead	P	1			
5612100	DW/Grab			Lead	P	1			
5612100	DW/Grab			Lead	P	1			
5612100	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
1 Samples not relinquished; crossed out by client and lab. FM 2/7/24	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ none ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/7/2024					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/7/24	9:00	



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

THK

February 27, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Thurston High School

Order No.: 2402368

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/9/2024 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402368

Date: 2/27/2024

CLIENT: Springfield School District #19

Project: Thurston High School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402368
CLIENT: Springfield School District #19
Location:
Project: Thurston High School
Sample Source:

Received Date: 2/9/2024 10:18:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402368-001 **Client Sample ID** 5612100-105BF **Collection Date:** 2/9/2024 6:04:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/23/2024 5:30:00 PM	KG

Lab ID: 2402368-002 **Client Sample ID** 5612100-106BF **Collection Date:** 2/9/2024 6:04:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/24/2024 6:22:00 PM	KG

Lab ID: 2402368-003 **Client Sample ID** 5612100-107BF **Collection Date:** 2/9/2024 6:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/24/2024 6:22:00 PM	KG

Lab ID: 2402368-004 **Client Sample ID** 5612100-108BF **Collection Date:** 2/9/2024 6:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/24/2024 6:22:00 PM	KG

Lab ID: 2402368-005 **Client Sample ID** 5612100-109BF **Collection Date:** 2/9/2024 6:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/24/2024 6:22:00 PM	KG

Lab ID: 2402368-006 **Client Sample ID** 5612100-110BF **Collection Date:** 2/9/2024 6:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/24/2024 6:22:00 PM	KG

Lab ID: 2402368-007 **Client Sample ID** 5612100-111BF **Collection Date:** 2/9/2024 6:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/24/2024 6:22:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results.

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 2/27/2024

WO#: 2402368
CLIENT: Springfield School District #19
Location:
Project: Thurston High School
Sample Source:

Received Date: 2/9/2024 10:18:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402368-008 **Client Sample ID** 5612100-112DW **Collection Date:** 2/9/2024 6:01:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.00	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-009 **Client Sample ID** 5612100-113BF **Collection Date:** 2/9/2024 6:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-010 **Client Sample ID** 5612100-115DW **Collection Date:** 2/9/2024 5:56:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-011 **Client Sample ID** 5612100-116SF **Collection Date:** 2/9/2024 5:52:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-012 **Client Sample ID** 5612100-117DW **Collection Date:** 2/9/2024 5:53:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-013 **Client Sample ID** 5612100-118WB **Collection Date:** 2/9/2024 5:58:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-014 **Client Sample ID** 5612100-119DW **Collection Date:** 2/9/2024 5:59:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)
C Value is below Minimum Compound Limit.
H Holding times for preparation or analysis exceeded
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PQL Practical Quantitation Level or Reporting Limit

A Accredited by ORELAP
E Value above quantitation range
LOD Limit of Detection
NAR See note in Case Narrative
PL Permit Limit
R RPD outside accepted recovery limits

Original
Page 4 of 9

Date Reported: 2/27/2024

WO#: 2402368
CLIENT: Springfield School District #19
Location:
Project: Thurston High School
Sample Source:

Received Date: 2/9/2024 10:18:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402368-015 **Client Sample ID** 5612100-120DW **Collection Date:** 2/9/2024 5:49:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-016 **Client Sample ID** 5612100-121DW **Collection Date:** 2/9/2024 5:45:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-017 **Client Sample ID** 5612100-122BF **Collection Date:** 2/9/2024 5:46:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-018 **Client Sample ID** 5612100-123BF **Collection Date:** 2/9/2024 5:47:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-019 **Client Sample ID** 5612100-124DW **Collection Date:** 2/9/2024 4:47:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402368-020 **Client Sample ID** 5612100-125WB **Collection Date:** 2/9/2024 4:46:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402368

Date: 2/27/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2402368
27-Feb-24

Client: Springfield School District #19

Project: Thurston High School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402368-001A	5612100-105BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402368-002A	5612100-106BF			Lead	A
	2402368-003A	5612100-107BF			Lead	A
	2402368-004A	5612100-108BF			Lead	A
	2402368-005A	5612100-109BF			Lead	A
	2402368-006A	5612100-110BF			Lead	A
	2402368-007A	5612100-111BF			Lead	A
	2402368-008A	5612100-112DW			Lead	A
	2402368-009A	5612100-113BF			Lead	A
	2402368-010A	5612100-115DW			Lead	A
	2402368-011A	5612100-116SF			Lead	A
	2402368-012A	5612100-117DW			Lead	A
	2402368-013A	5612100-118WB			Lead	A
	2402368-014A	5612100-119DW			Lead	A
	2402368-015A	5612100-120DW			Lead	A
	2402368-016A	5612100-121DW			Lead	A
	2402368-017A	5612100-122BF			Lead	A
	2402368-018A	5612100-123BF			Lead	A
	2402368-019A	5612100-124DW			Lead	A
	2402368-020A	5612100-125WB			Lead	A

ACCRED

ORELAP A Accredited

Original #2402368# v1

Page 7 of 9

Work Order # 2402368

Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM
Checked: MI

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Thurston High School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
* 5612100-105BF	DW/Grab	2/9	604	Lead	P	1		NA	001A
* 5612100-106BF	DW/Grab	2/9	604	Lead	P	1			002A
5612100-107BF	DW/Grab	2/9	605	Lead	P	1			003A
5612100-108BF	DW/Grab	2/9	605	Lead	P	1			004A
* 5612100-109BF	DW/Grab	2/9	606	Lead	P	1			005A
5612100-110BF	DW/Grab	2/9	606	Lead	P	1			006A
5612100-111BF	DW/Grab	2/9	607	Lead	P	1			007A
5612100-112DW	DW/Grab	2/9	601	Lead	P	1			008A
5612100-113BF	DW/Grab	2/9	602	Lead	P	1			009A
5612100-115DW	DW/Grab	2/9	556	Lead	P	1		✓	010A

Notes: <u>Aluminum used by client.</u> <u>FM 2/9/24</u>	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH	Shipped Via: Veronica Arciga	Refrigerated Ice ☐ None ☒
Relinquished by: Veronica Arciga	Date: 2/9 Time: 1020	Received by:
Relinquished by:	Date: Time:	Received by:
Relinquished by:	Date: Time:	Received by Laboratory:
		2/9/24 10:18

Work Order # 2402368

Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: FM

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Thurston High School		Sampler Name: Veronica Arciga	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-116SF	DW/Grab	2/9	552	Lead	P	1		NA	011A
5612100-117DW	DW/Grab	2/9	553	Lead	P	1			012A
5612100-118WB	DW/Grab	2/9	558	Lead	P	1			013A
5612100-119DW	DW/Grab	2/9	559	Lead	P	1			014A
5612100-120DW	DW/Grab	2/9	549	Lead	P	1			015A
5612100-121DW	DW/Grab	2/9	545	Lead	P	1			016A
5612100-122BF	DW/Grab	2/9	546	Lead	P	1			017A
5612100-123BF	DW/Grab	2/9	547	Lead	P	1			018A
5612100-124DW	DW/Grab	2/9	547	Lead	P	1			019A
5612100-125WB	DW/Grab	2/9	446	Lead	P	1		✓	020A

Notes: <u>Written over by client - FM 2/9/24</u>	PAID		Preservation Check				
	Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
Pickup							

Turn Around Time Requested (Rush incurs a Surcharge):		Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH		Veronica Arciga		Ice	☒ None
Relinquished by:	Date Time	Received by:	Date Time		
Veronica Arciga	2/9 1020				
Relinquished by:	Date Time	Received by:	Date Time		
Relinquished by:	Date Time	Received by Laboratory:	Date Time		
		<i>[Signature]</i>	2/9/24 10:18		



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5993

Website:

February 27, 2024

THS

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Thurston High School

Order No.: 2402370

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 2/9/2024 for the analyses presented in the following report.

Kimberly J. Reeve Morghan

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402370

Date: 2/27/2024

CLIENT: Springfield School District #19

Project: Thurston High School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#:	2402370	Received Date:	2/9/2024 10:18:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Thurston High School	Matrix:	Drinking Water

Lab ID:	2402370-001	Client Sample ID	5612100-136BF	Collection Date:	2/9/2024 4:49:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID:	2402370-002	Client Sample ID	5612100-137DW	Collection Date:	2/9/2024 4:39:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID:	2402370-003	Client Sample ID	5612100-138BF	Collection Date:	2/9/2024 4:40:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.01		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID:	2402370-004	Client Sample ID	5612100-139BF	Collection Date:	2/9/2024 4:41:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID:	2402370-005	Client Sample ID	5612100-140DW	Collection Date:	2/9/2024 4:42:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID:	2402370-006	Client Sample ID	5612100-141DW	Collection Date:	2/9/2024 4:43:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.05		2.00	1.00	ppb	02/26/24 15:42	KG

Lab ID:	2402370-007	Client Sample ID	5612100-142CF	Collection Date:	2/9/2024 5:40:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.3		2.00	1.00	ppb	02/25/24 18:55	AS

Definitions:

A	Accredited by ORELAP
LOD	Limit of Detection
MCL	Maximum Contaminant Level
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit

Qualifiers:

WO#: 2402370
CLIENT: Springfield School District #19
Project: Thurston High School

Received Date: 2/9/2024 10:18:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2402370-008 **Client Sample ID** 5612100-143CF **Collection Date:** 2/9/2024 5:41:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/26/24 15:42	KG

Lab ID: 2402370-009 **Client Sample ID** 5612100-144BF **Collection Date:** 2/9/2024 5:38:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-010 **Client Sample ID** 5612100-145BF **Collection Date:** 2/9/2024 5:37:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-011 **Client Sample ID** 5612100-126KF **Collection Date:** 2/9/2024 4:55:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.86		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-012 **Client Sample ID** 5612100-127KF **Collection Date:** 2/9/2024 4:54:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-013 **Client Sample ID** 5612100-128KF **Collection Date:** 2/9/2024 4:55:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.54		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-014 **Client Sample ID** 5612100-129KF **Collection Date:** 2/9/2024 4:56:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.96		2.00	1.00	ppb	02/25/24 18:55	AS

Definitions: A Accredited by ORELAP
LOD Limit of Detection
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit

Qualifiers:

WO#:	2402370	Received Date:	2/9/2024 10:18:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Thurston High School	Matrix:	Drinking Water

Lab ID: 2402370-015	Client Sample ID 5612100-130KF	Collection Date: 2/9/2024 4:53:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.09		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-016	Client Sample ID 5612100-131KF	Collection Date: 2/9/2024 4:51:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.13		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-017	Client Sample ID 5612100-132KF	Collection Date: 2/9/2024 4:50:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.16		2.00	1.00	ppb	02/26/24 15:42	KG

Lab ID: 2402370-018	Client Sample ID 5612100-133KF	Collection Date: 2/9/2024 4:50:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-019	Client Sample ID 5612100-134KF	Collection Date: 2/9/2024 4:57:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.59		2.00	1.00	ppb	02/25/24 18:55	AS

Lab ID: 2402370-020	Client Sample ID 5612100-135KF	Collection Date: 2/9/2024 4:58:00 AM
----------------------------	---------------------------------------	---

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.50		2.00	1.00	ppb	02/25/24 18:55	AS

Definitions:

A	Accredited by ORELAP
LOD	Limit of Detection
MCL	Maximum Contaminant Level
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit

Qualifiers:



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402370

Date: 2/27/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2402370
27-Feb-24

Client: Springfield School District #19

Project: Thurston High School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402370-001A	5612100-136BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402370-002A	5612100-137DW			Lead	A
	2402370-003A	5612100-138BF			Lead	A
	2402370-004A	5612100-139BF			Lead	A
	2402370-005A	5612100-140DW			Lead	A
	2402370-006A	5612100-141DW			Lead	A
	2402370-007A	5612100-142CF			Lead	A
	2402370-008A	5612100-143CF			Lead	A
	2402370-009A	5612100-144BF			Lead	A
	2402370-010A	5612100-145BF			Lead	A
	2402370-011A	5612100-126KF			Lead	A
	2402370-012A	5612100-127KF			Lead	A
	2402370-013A	5612100-128KF			Lead	A
	2402370-014A	5612100-129KF			Lead	A
	2402370-015A	5612100-130KF			Lead	A
	2402370-016A	5612100-131KF			Lead	A
	2402370-017A	5612100-132KF			Lead	A
	2402370-018A	5612100-133KF			Lead	A
	2402370-019A	5612100-134KF			Lead	A
	2402370-020A	5612100-135KF			Lead	A

ACCRED
ORELAP A Accredited

Original #2402370# v1
Page 7 of 9

Work Order # 2402370

*Delivering more than
just test results*

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FMChecked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Thurston High School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-136BF	DW/Grab	2/9	449	Lead	P	1		N/A	001A
5612100-137DW	DW/Grab	2/9	439	Lead	P	1			002A
5612100-138BF	DW/Grab	2/9	440	Lead	P	1			003A
5612100-139BF	DW/Grab	2/9	441	Lead	P	1			004A
5612100-140DW	DW/Grab	2/9	442	Lead	P	1			005A
5612100-141DW	DW/Grab	2/9	443	Lead	P	1			006A
5612100-142CF	DW/Grab	2/9	540	Lead	P	1			007A
5612100-143CF	DW/Grab	2/9	541	Lead	P	1			008A
5612100-144BF	DW/Grab	2/9	538	Lead	P	1			009A
5612100-145BF	DW/Grab	2/9	537	Lead	P	1		✓	010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/9	10:10				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/9/24	10:18	

Chain of Custody LEAD THS

Page 1 of 2

FM 2/9/24 10:18
2/9/24 10:18

Work Order # 2402370Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: FM
MD**CHAIN OF CUSTODY - FIRST DRAW LEAD**

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Thurston High School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-126KF	DW/Grab	2/9	455	Lead	P	1		NA	011A
5612100-127KF	DW/Grab	2/9	454	Lead	P	1			012A
5612100-128KF	DW/Grab	2/9	455	Lead	P	1			013A
5612100-129KF	DW/Grab	2/9	456	Lead	P	1			014A
5612100-130KF	DW/Grab	2/9	453	Lead	P	1			015A
5612100-131KF	DW/Grab	2/9	451	Lead	P	1			016A
5612100-132KF	DW/Grab	2/9	450	Lead	P	1			017A
5612100-133KF	DW/Grab	2/9	450	Lead	P	1			018A
5612100-134KF	DW/Grab	2/9	457	Lead	P	1			019A
5612100-135KF	DW/Grab	2/9	458	Lead	P	1		V	020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/9	10:20				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/9/24	10:18	



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

February 27, 2024

THS

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Thurston High School

Order No.: 2402373

Dear Terry Rutledge:

Analytical Laboratory Group received 23 sample(s) on 2/9/2024 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2402373

Date: 2/27/2024

CLIENT: Springfield School District #19

Project: Thurston High School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2402373
CLIENT: Springfield School District #19
Location:
Project: Thurston High School
Sample Source:

Received Date: 2/9/2024 10:18:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402373-001 **Client Sample ID** 5612100-146SF **Collection Date:** 2/9/2024 5:04:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402373-002 **Client Sample ID** 5612100-147CF **Collection Date:** 2/9/2024 5:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402373-003 **Client Sample ID** 5612100-148CF **Collection Date:** 2/9/2024 5:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/25/2024 6:55:00 PM	AS

Lab ID: 2402373-004 **Client Sample ID** 5612100-149CF **Collection Date:** 2/9/2024 5:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	9.11	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-005 **Client Sample ID** 5612100-150CF **Collection Date:** 2/9/2024 5:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-006 **Client Sample ID** 5612100-151CF **Collection Date:** 2/9/2024 5:10:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-007 **Client Sample ID** 5612100-152DW **Collection Date:** 2/9/2024 5:10:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402373
CLIENT: Springfield School District #19
Location:
Project: Thurston High School
Sample Source:

Received Date: 2/9/2024 10:18:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402373-008 **Client Sample ID** 5612100-153WB **Collection Date:** 2/9/2024 5:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-009 **Client Sample ID** 5612100-1154DW **Collection Date:** 2/9/2024 5:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-010 **Client Sample ID** 5612100-155CF **Collection Date:** 2/9/2024 5:14:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-011 **Client Sample ID** 5612100-156DW **Collection Date:** 2/9/2024 5:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-012 **Client Sample ID** 5612100-157CF **Collection Date:** 2/9/2024 5:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-013 **Client Sample ID** 5612100-158CF **Collection Date:** 2/9/2024 5:19:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-014 **Client Sample ID** 5612100-159DW **Collection Date:** 2/9/2024 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2402373
CLIENT: Springfield School District #19
Location:
Project: Thurston High School
Sample Source:

Received Date: 2/9/2024 10:18:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402373-015 **Client Sample ID** 5612100-160BF **Collection Date:** 2/9/2024 5:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-016 **Client Sample ID** 5612100-161BF **Collection Date:** 2/9/2024 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-017 **Client Sample ID** 5612100-162CF **Collection Date:** 2/9/2024 5:25:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.73	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-018 **Client Sample ID** 5612100-163CF **Collection Date:** 2/9/2024 5:25:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-019 **Client Sample ID** 5612100-164CF **Collection Date:** 2/9/2024 5:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-020 **Client Sample ID** 5612100-165CF **Collection Date:** 2/9/2024 5:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-021 **Client Sample ID** 5612100-166CF **Collection Date:** 2/9/2024 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- PQL Practical Quantitation Level or Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit
- R RPD outside accepted recovery limits

Date Reported: 2/27/2024

WO#: 2402373
CLIENT: Springfield School District #19
Location:
Project: Thurston High School
Sample Source:

Received Date: 2/9/2024 10:18:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2402373-022 **Client Sample ID** 5612100-167DW **Collection Date:** 2/9/2024 5:32:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	12.9	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Lab ID: 2402373-023 **Client Sample ID** 5612100-168CF **Collection Date:** 2/9/2024 5:33:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	2/26/2024 3:42:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2402373

Date: 2/27/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Accreditation Program Analytes Report

WO#: 2402373
27-Feb-24

Client: Springfield School District #19

Project: Thurston High School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2402373-001A	5612100-146SF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2402373-002A	5612100-147CF			Lead	A
	2402373-003A	5612100-148CF			Lead	A
	2402373-004A	5612100-149CF			Lead	A
	2402373-005A	5612100-150CF			Lead	A
	2402373-006A	5612100-151CF			Lead	A
	2402373-007A	5612100-152DW			Lead	A
	2402373-008A	5612100-153WB			Lead	A
	2402373-009A	5612100-1154DW			Lead	A
	2402373-010A	5612100-155CF			Lead	A
	2402373-011A	5612100-156DW			Lead	A
	2402373-012A	5612100-157CF			Lead	A
	2402373-013A	5612100-158CF			Lead	A
	2402373-014A	5612100-159DW			Lead	A
	2402373-015A	5612100-160BF			Lead	A
	2402373-016A	5612100-161BF			Lead	A
	2402373-017A	5612100-162CF			Lead	A
	2402373-018A	5612100-163CF			Lead	A
	2402373-019A	5612100-164CF			Lead	A
	2402373-020A	5612100-165CF			Lead	A
	2402373-021A	5612100-166CF			Lead	A
	2402373-022A	5612100-167DW			Lead	A
	2402373-023A	5612100-168CF			Lead	A

ACCRED
ORELAP A Accredited

Original #2402373# v1
Page 8 of 11

Work Order # 2402373Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: FM
MT**CHAIN OF CUSTODY - FIRST DRAW LEAD**

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Thurston High School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-146SF	DW/Grab	2/9	504	Lead	P	1		NA	001A
5612100-147CF	DW/Grab	2/9	506	Lead	P	1			002A
5612100-148CF	DW/Grab	2/9	506	Lead	P	1			003A
5612100-149CF	DW/Grab	2/9	507	Lead	P	1			004A
5612100-150CF	DW/Grab	2/9	509	Lead	P	1			005A
5612100-151CF	DW/Grab	2/9	510	Lead	P	1			006A
5612100-152DW	DW/Grab	2/9	510	Lead	P	1			007A
5612100-153WB	DW/Grab	2/9	512	Lead	P	1			008A
5612100-154DW	DW/Grab	2/9	513	Lead	P	1			009A
5612100-155CF	DW/Grab	2/9	514	Lead	P	1		V	010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice <u>None</u>	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/9	1020				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/9/24	10:18	

Work Order # 2402373



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: FM
Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Thurston High School		Sampler Name: Veronica Arciga	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-156DW	DW/Grab	2/9	515	Lead	P	1		NA	011A
5612100-157CF	DW/Grab	2/9	516	Lead	P	1			012A
5612100-158CF	DW/Grab	2/9	519	Lead	P	1			013A
5612100-159DW	DW/Grab	2/9	520	Lead	P	1			014A
5612100-160BF	DW/Grab	2/9	521	Lead	P	1			015A
5612100-161BF	DW/Grab	2/9	522	Lead	P	1			016A
5612100-162CF	DW/Grab	2/9	525	Lead	P	1			017A
5612100-163CF	DW/Grab	2/9	525	Lead	P	1			018A
5612100-164CF	DW/Grab	2/9	526	Lead	P	1			019A
5612100-165CF	DW/Grab	2/9	527	Lead	P	1		✓	020A

Notes:	PAID		Preservation Check				
	Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice <u>None</u>	
Relinquished by:	Date	Time	Received by:		Date	Time
Veronica Arciga	2/9	1020				
Relinquished by:	Date	Time	Received by:		Date	Time
Relinquished by:	Date	Time	Received by Laboratory:		Date	Time
					Page 10 of 11 2/9/24 10:18	

Work Order # 2402373

*Delivering more than
just test results*

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: EM
Checked: MC

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Thurston High School	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
5612100-166CF	DW/Grab	2/9	528	Lead	P	1		NA	021A
5612100-167DW	DW/Grab	2/9	532	Lead	P	1			022A
5612100-168CF	DW/Grab	2/9	533	Lead	P	1			023A
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			
^ 5612100	DW/Grab			Lead	P	1			

Notes: 1 Samples not relinquished; crossed off by client and lab. EM 2/9/24	PAID		Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/9	1020				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	2/9/24	10:18	