

Lead in Water Test Results Summary: Thurston Middle School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Upstairs Staff faucet (front office area)	05571600-001SF	2/27/2023	2.07	Low	[enter date]	[enter result]	[autofill]
Upstairs staff mens restroom bathroom faucet	05571600-002BF	2/27/2023	3.15	Low			
Upstairs staff women's restroom bathroom faucet	05571600-003BF	2/27/2023	4.97	Low			
Downstairs back of front office outside nurses office	05571600-004DW	2/27/2023	ND	Non-Detect			
Nurses office sink	05571600-005NS	2/27/2023	ND	Non-Detect			
Outside front office drinking fountain	05571600-006DW	2/27/2023	ND	Non-Detect			
Outside front office bottle fill station	05571600-007WB	2/27/2023	ND	Non-Detect			
South hall in custodial room bathroom faucet	05571600-008BF	2/27/2023	2.35	Low			
Staff restroom across from classroom 5 bathroom faucet	05571600-009BF	2/27/2023	ND	Non-Detect			
Drinking fountain between room 7 and 8	05571600-010DW	2/27/2023	ND	Non-Detect			
Classroom# 8 Class room faucet	05571600-011CF	2/27/2023	5.54	Moderate			
Classroom # Classroom faucet	05571600-012CF	2/27/2023	2.71	Low			
Kitchen faucet # 1 at back entrance	05571600-013KF	2/27/2023	5.8	Moderate			
Staff faucet (hand wash station)	05571600-014SF	2/27/2023	2.66	Low			
Kitchen faucet # 2 north west wall	05571600-015KF	2/27/2023	2.8	Low			
Kitchen faucet # 3 north wall near staff restroom	05571600-016KF	2/27/2023	3.01	Low			
Staff restroom bathroom faucet in kitchen	05571600-017BF	2/27/2023	3.49	Low			
Kitchen faucet # 4 south wall near dishwasher	05571600-018KF	2/27/2023	2.59	Low			
Drinking water fountain across from classroom 12	05571600-019DW	2/27/2023	6.4	Moderate			
Room 11 bathroom faucet	05571600-020BF	2/27/2023	6.31	Moderate			
Boys restroom Bradley Bathroom Faucet # 1 (next to room 14)	05571600-021BF	2/27/2023	2.38	Low			
Boys restroom Bradley Bathroom Faucet # 2	05571600-022BF	2/27/2023	ND	Non-Detect			
Boys restroom Bradley Bathroom Faucet # 3	05571600-023BF	2/27/2023	ND	Non-Detect			
Girls restroom Bradley Bathroom Faucet # 1	05571600-024BF	2/27/2023	ND	Non-Detect			
Girls restroom Bradley Bathroom Faucet # 2	05571600-025BF	2/27/2023	ND	Non-Detect			
Girls restroom Bradley Bathroom Faucet # 3	05571600-026BF	2/27/2023	ND	Non-Detect			
Classroom 18 between room 16 and library Classroom faucet	05571600-027CF	2/27/2023	4	Low			
Classroom # 23 classroom faucet (south)	05571600-029CF	2/27/2023	ND	Non-Detect			
Classroom # 23 classroom faucet (north)	05571600-030CF	2/27/2023	50.4	Action Req.	3/3/2025	5.29	Moderate
Classroom # 24 classroom faucet	05571600-031CF	2/27/2023	8.78	Moderate			
Classroom # 25 classroom faucet	05571600-032CF	2/27/2023	77.6	Action Req.	3/3/2025	3.92	Low
Boys locker room (south) Bathroom faucet	05571600-033BF	2/27/2023	ND	Non-Detect			
Boys locker room (middle) Bathroom faucet coaches room	05571600-035BF	2/27/2023	4.78	Low			
Drinking Fountain (north)	05571600-036DW	2/27/2023	ND	Non-Detect			
Boys locker room (north) Bathroom faucet	05571600-037BF	2/27/2023	4.29	Low			
Outside Gym wall drinking Fountain	05571600-038DW	2/27/2023	ND	Non-Detect			
Outside Gym wall Water bottle fill	05571600-039WB	2/27/2023	ND	Non-Detect			
Girls restroom Bradley Bathroom Faucet # 1	05571600-040BF	2/27/2023	ND	Non-Detect			
Girls restroom Bradley Bathroom Faucet # 2	05571600-041BF	2/27/2023	ND	Non-Detect			
Girls restroom Bradley Bathroom Faucet # 3	05571600-042BF	2/27/2023	ND	Non-Detect			
Boys restroom Bradley Bathroom Faucet # 1	05571600-043BF	2/27/2023	ND	Non-Detect			
Boys restroom Bradley Bathroom Faucet # 2	05571600-044BF	2/27/2023	ND	Non-Detect			

Boys restroom Bradley Bathroom Faucet # 3	05571600-045BF	2/27/2023	ND	Non-Detect			
Girls Locker room (south) Bathroom Faucet	05571600-046BF	2/27/2023	4.73	Low			
Girls Locker room Drinking Fountain	05571600-047DW	2/27/2023	2.57	Low			
Girls Locker room (north) Bathroom Faucet	05571600-048BF	2/27/2023	5.96	Moderate			
Classroom # 28 Classroom faucet (South)	05571600-049CF	2/27/2023	ND	Non-Detect			
Classroom # 28 Classroom faucet (Middle)	05571600-050CF	2/27/2023	2.19	Low			
Classroom # 28 Classroom faucet (Middle)	05571600-051CF	2/27/2023	3.04	Low			
Classroom # 28 Classroom faucet (North)	05571600-052CF	2/27/2023	8.89	Moderate			
Woodshop Bathroom Faucet	05571600-053BF	2/27/2023	ND	Non-Detect			
Gym Drinking Fountain	05571600-054DW	2/27/2023	ND	Non-Detect			



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

March 06, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2302877

Dear Terry Rutledge:

Analytical Laboratory Group received 50 sample(s) on 2/27/2023 for the analyses presented in the following report.

Teresa Garcia-Lande
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2302877

Date: 3/6/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Analytical Report

Date Reported: 3/6/2023

WO#:	2302877	Received Date:	2/27/2023 8:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD	Matrix:	Drinking Water

Lab ID: 2302877-001	Client Sample ID 05571600-001SF	Collection Date: 2/20/2023 5:07:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.07		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-002	Client Sample ID 05571600-002BF	Collection Date: 2/20/2023 5:07:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.15		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-003	Client Sample ID 05571600-003BF	Collection Date: 2/20/2023 5:07:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.97		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-004	Client Sample ID 05571600-004DW	Collection Date: 2/20/2023 5:08:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-005	Client Sample ID 05571600-005NS	Collection Date: 2/20/2023 5:08:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-006	Client Sample ID 05571600-006DW	Collection Date: 2/20/2023 5:08:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-007	Client Sample ID 05571600-007WB	Collection Date: 2/20/2023 5:09:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			

Analytical Report

Date Reported: 3/6/2023

WO#:	2302877	Received Date:	2/27/2023 8:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD	Matrix:	Drinking Water

Lab ID: 2302877-008	Client Sample ID 05571600-008BF	Collection Date: 2/20/2023 5:14:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.35		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-009	Client Sample ID 05571600-009BF	Collection Date: 2/20/2023 5:14:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-010	Client Sample ID 05571600-010DW	Collection Date: 2/20/2023 5:15:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-011	Client Sample ID 05571600-011CF	Collection Date: 2/20/2023 5:16:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.54		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-012	Client Sample ID 05571600-012CF	Collection Date: 2/20/2023 5:17:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.71		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-013	Client Sample ID 05571600-013KF	Collection Date: 2/20/2023 5:21:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.80		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-014	Client Sample ID 05571600-014SF	Collection Date: 2/20/2023 5:21:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.66		2.00	1.00	ppb	03/01/23 15:00	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			

Analytical Report

Date Reported: 3/6/2023

WO#:	2302877	Received Date:	2/27/2023 8:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD	Matrix:	Drinking Water

Lab ID: 2302877-015	Client Sample ID 05571600-015KF	Collection Date: 2/20/2023 5:21:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.80		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-016	Client Sample ID 05571600-016KF	Collection Date: 2/20/2023 5:22:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.01		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-017	Client Sample ID 05571600-017BF	Collection Date: 2/20/2023 5:22:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.49		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-018	Client Sample ID 05571600-018KF	Collection Date: 2/20/2023 5:23:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.59		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-019	Client Sample ID 05571600-019DW	Collection Date: 2/20/2023 5:25:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.40		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-020	Client Sample ID 05571600-020BF	Collection Date: 2/20/2023 5:28:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.31		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-021	Client Sample ID 05571600-021BF	Collection Date: 2/20/2023 5:28:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.38		2.00	1.00	ppb	03/01/23 15:00	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			

Analytical Report

Date Reported: 3/6/2023

WO#: 2302877
CLIENT: Springfield School District #19
Project: Springfield SD

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2302877-022 **Client Sample ID** 05571600-022BF **Collection Date:** 2/20/2023 5:28:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-023 **Client Sample ID** 05571600-023BF **Collection Date:** 2/20/2023 5:28:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-024 **Client Sample ID** 05571600-024BF **Collection Date:** 2/20/2023 5:31:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-025 **Client Sample ID** 05571600-025BF **Collection Date:** 2/20/2023 5:31:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-026 **Client Sample ID** 05571600-026BF **Collection Date:** 2/20/2023 5:31:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-027 **Client Sample ID** 05571600-027CF **Collection Date:** 2/20/2023 5:33:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.00		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-028 **Client Sample ID** 05571600-029CF **Collection Date:** 2/20/2023 5:34:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/02/23 18:11	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/6/2023

WO#: 2302877 **Received Date:** 2/27/2023 8:00:00 AM
CLIENT: Springfield School District #19 **Sampler Name:** Veronica Arciga
Project: Springfield SD **Matrix:** Drinking Water

Lab ID: 2302877-029 **Client Sample ID** 05571600-030CF **Collection Date:** 2/20/2023 5:36:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	50.4	*	8.00	4.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-030 **Client Sample ID** 05571600-031CF **Collection Date:** 2/20/2023 5:47:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.78		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-031 **Client Sample ID** 05571600-032CF **Collection Date:** 2/20/2023 5:47:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	77.6	*	20.0	10.0	ppb	03/01/23 15:00	AS

Lab ID: 2302877-032 **Client Sample ID** 05571600-033BF **Collection Date:** 2/20/2023 5:50:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-033 **Client Sample ID** 05571600-035BF **Collection Date:** 2/20/2023 5:50:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.78		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-034 **Client Sample ID** 05571600-036DW **Collection Date:** 2/20/2023 5:52:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-035 **Client Sample ID** 05571600-037BF **Collection Date:** 2/20/2023 5:54:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.29		2.00	1.00	ppb	03/01/23 15:00	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/6/2023

WO#:	2302877	Received Date:	2/27/2023 8:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD	Matrix:	Drinking Water

Lab ID: 2302877-036	Client Sample ID	05571600-038DW	Collection Date: 2/20/2023 5:58:00 AM
----------------------------	-------------------------	----------------	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-037	Client Sample ID	05571600-039WB	Collection Date: 2/20/2023 5:58:00 AM
----------------------------	-------------------------	----------------	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-038	Client Sample ID	05571600-040BF	Collection Date: 2/20/2023 6:00:00 AM
----------------------------	-------------------------	----------------	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-039	Client Sample ID	05571600-041BF	Collection Date: 2/20/2023 6:00:00 AM
----------------------------	-------------------------	----------------	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/01/23 15:00	AS

Lab ID: 2302877-040	Client Sample ID	05571600-042BF	Collection Date: 2/20/2023 6:00:00 AM
----------------------------	-------------------------	----------------	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/02/23 18:11	AS

Lab ID: 2302877-041	Client Sample ID	05571600-043BF	Collection Date: 2/20/2023 6:02:00 AM
----------------------------	-------------------------	----------------	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/02/23 18:11	AS

Lab ID: 2302877-042	Client Sample ID	05571600-044BF	Collection Date: 2/20/2023 6:03:00 AM
----------------------------	-------------------------	----------------	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/02/23 18:11	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/6/2023

WO#:	2302877	Received Date:	2/27/2023 8:00:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Veronica Arciga
Project:	Springfield SD	Matrix:	Drinking Water

Lab ID: 2302877-043	Client Sample ID 05571600-045BF	Collection Date: 2/20/2023 6:03:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/02/23 18:11	AS

Lab ID: 2302877-044	Client Sample ID 05571600-046BF	Collection Date: 2/20/2023 6:09:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.73		2.00	1.00	ppb	03/02/23 18:11	AS

Lab ID: 2302877-045	Client Sample ID 05571600-047DW	Collection Date: 2/20/2023 6:10:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.57		2.00	1.00	ppb	03/02/23 18:11	AS

Lab ID: 2302877-046	Client Sample ID 05571600-048BF	Collection Date: 2/20/2023 6:11:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.96		2.00	1.00	ppb	03/02/23 18:11	AS

Lab ID: 2302877-047	Client Sample ID 05571600-049CF	Collection Date: 2/20/2023 6:04:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	03/02/23 18:11	AS

Lab ID: 2302877-048	Client Sample ID 05571600-050CF	Collection Date: 2/20/2023 6:05:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.19		2.00	1.00	ppb	03/02/23 18:11	AS

Lab ID: 2302877-049	Client Sample ID 05571600-051CF	Collection Date: 2/20/2023 6:06:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.04		2.00	1.00	ppb	03/02/23 18:11	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/6/2023

WO#: 2302877
CLIENT: Springfield School District #19
Project: Springfield SD

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2302877-050 **Client Sample ID** 05571600-052CF **Collection Date:** 2/20/2023 6:07:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.89		2.00	1.00	ppb	03/02/23 18:11	AS

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection		*	Value exceeds Maximum Contaminant Level (MCL)
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2302877

Date: 3/6/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302877

06-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302877-001A	05571600-001SF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302877-002A	05571600-002BF			Lead	A
	2302877-003A	05571600-003BF			Lead	A
	2302877-004A	05571600-004DW			Lead	A
	2302877-005A	05571600-005NS			Lead	A
	2302877-006A	05571600-006DW			Lead	A
	2302877-007A	05571600-007WB			Lead	A
	2302877-008A	05571600-008BF			Lead	A
	2302877-009A	05571600-009BF			Lead	A
	2302877-010A	05571600-010DW			Lead	A
	2302877-011A	05571600-011CF			Lead	A
	2302877-012A	05571600-012CF			Lead	A
	2302877-013A	05571600-013KF			Lead	A
	2302877-014A	05571600-014SF			Lead	A
	2302877-015A	05571600-015KF			Lead	A
	2302877-016A	05571600-016KF			Lead	A
	2302877-017A	05571600-017BF			Lead	A
	2302877-018A	05571600-018KF			Lead	A
	2302877-019A	05571600-019DW			Lead	A
	2302877-020A	05571600-020BF			Lead	A
	2302877-021A	05571600-021BF			Lead	A
	2302877-022A	05571600-022BF			Lead	A
	2302877-023A	05571600-023BF			Lead	A
	2302877-024A	05571600-024BF			Lead	A
	2302877-025A	05571600-025BF			Lead	A
	2302877-026A	05571600-026BF			Lead	A
	2302877-027A	05571600-027CF			Lead	A
	2302877-028A	05571600-029CF			Lead	A
	2302877-029A	05571600-030CF			Lead	A
	2302877-030A	05571600-031CF			Lead	A
	2302877-031A	05571600-032CF			Lead	A

ORELAP A Accredited

ACCRED

Original #2302877# v1

Page 12 of 18



Delivering more than
just test results

ALG ORELAP ID #ORI00012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302877

06-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302877-032A	05571600-033BF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302877-033A	05571600-035BF			Lead	A
	2302877-034A	05571600-036DW			Lead	A
	2302877-035A	05571600-037BF			Lead	A
	2302877-036A	05571600-038DW			Lead	A
	2302877-037A	05571600-039WB			Lead	A
	2302877-038A	05571600-040BF			Lead	A
	2302877-039A	05571600-041BF			Lead	A
	2302877-040A	05571600-042BF			Lead	A
	2302877-041A	05571600-043BF			Lead	A
	2302877-042A	05571600-044BF			Lead	A
	2302877-043A	05571600-045BF			Lead	A
	2302877-044A	05571600-046BF			Lead	A
	2302877-045A	05571600-047DW			Lead	A
	2302877-046A	05571600-048BF			Lead	A
	2302877-047A	05571600-049CF			Lead	A
	2302877-048A	05571600-050CF			Lead	A
	2302877-049A	05571600-051CF			Lead	A
	2302877-050A	05571600-052CF			Lead	A

ACCRED

ORELAP A Accredited

Original #2302877# v1

Page 13 of 18

TMS

Work Order # 2302877



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: CB

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05571600-001SF	DW/Grab	2/20/2023	0507	Lead	P	1		NA	001A
05571600-002BF	DW/Grab	2/20/2023	0507	Lead	P	1			002A
05571600-003BF	DW/Grab	2/20/2023	0507	Lead	P	1			003A
05571600-004DW	DW/Grab	2/20/2023	0508	Lead	P	1			004A
05571600-005NS	DW/Grab	2/20/2023	0508	Lead	P	1			005A
05571600-006DW	DW/Grab	2/20/2023	0508	Lead	P	1			006A
05571600-007WB	DW/Grab	2/20/2023	0509	Lead	P	1			007A
05571600-008BF	DW/Grab	2/20/2023	0514	Lead	P	1			008A
05571600-009BF	DW/Grab	2/20/2023	0514	Lead	P	1			009A
05571600-010DW	DW/Grab	2/20/2023	0515	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/21/23	0800				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
				2/21/23	08:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: CB

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05571600-011CF	DW/Grab	2/20/2023	0516	Lead	P	1		NA	011A
05571600-012CF	DW/Grab	2/20/2023	0517	Lead	P	1			012A
05571600-013KF	DW/Grab	2/20/2023	0521	Lead	P	1			013A
05571600-014SF	DW/Grab	2/20/2023	0521	Lead	P	1			014A
05571600-015KF	DW/Grab	2/20/2023	0521	Lead	P	1			015A
05571600-016KF	DW/Grab	2/20/2023	0522	Lead	P	1			016A
05571600-017BF	DW/Grab	2/20/2023	0522	Lead	P	1			017A
05571600-018KF	DW/Grab	2/20/2023	0523	Lead	P	1			018A
05571600-019DW	DW/Grab	2/20/2023	0525	Lead	P	1			019A
05571600-020BF	DW/Grab	2/20/2023	0528	Lead	P	1		✓	020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None : ☒ X	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
				2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: CB

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05571600-021BF	DW/Grab	2/20/2023	0508	Lead	P	1		NA	021A
05571600-022BF	DW/Grab	2/20/2023	0528	Lead	P	1			022A
05571600-023BF	DW/Grab	2/20/2023	0528	Lead	P	1			023A
05571600-024BF	DW/Grab	2/20/2023	0531	Lead	P	1			024A
05571600-025BF	DW/Grab	2/20/2023	0531	Lead	P	1			025A
05571600-026BF	DW/Grab	2/20/2023	0531	Lead	P	1			026A
05571600-027CF	DW/Grab	2/20/2023	0533	Lead	P	1			027A
05571600-029CF	DW/Grab	2/20/2023	0534	Lead	P	1			028A
05571600-030CF	DW/Grab	2/20/2023	0536	Lead	P	1			029A
05571600-031CF	DW/Grab	2/20/2023	0547	Lead	P	1			030A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None: X ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga						
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
				2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: CB

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05571600-032CF	DW/Grab	2/20/2023	0547	Lead	P	1		NA	031A
05571600-033BF	DW/Grab	2/20/2023	0550	Lead	P	1			032A
05571600-035BF	DW/Grab	2/20/2023	0550	Lead	P	1			033A
05571600-036DW	DW/Grab	2/20/2023	0552	Lead	P	1			034A
05571600-037BF	DW/Grab	2/20/2023	0554	Lead	P	1			035A
05571600-038DW	DW/Grab	2/20/2023	0558	Lead	P	1			036A
05571600-039WB	DW/Grab	2/20/2023	0558	Lead	P	1			037A
05571600-040BF	DW/Grab	2/20/2023	0600	Lead	P	1			038A
05571600-041BF	DW/Grab	2/20/2023	0600	Lead	P	1			039A
05571600-042BF	DW/Grab	2/20/2023	0600	Lead	P	1		V	040A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
				2/27/23	8:00	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: CB

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05571600-043BF	DW/Grab	2/20/2023	0602	Lead	P	1		NA	041A
05571600-044BF	DW/Grab	2/20/2023	0603	Lead	P	1			042A
05571600-045BF	DW/Grab	2/20/2023	0603	Lead	P	1			043A
05571600-046BF	DW/Grab	2/20/2023	0609	Lead	P	1			044A
05571600-047DW	DW/Grab	2/20/2023	0610	Lead	P	1			045A
05571600-048BF	DW/Grab	2/20/2023	0611	Lead	P	1			046A
05571600-049CF	DW/Grab	2/20/2023	0604	Lead	P	1			047A
05571600-050CF	DW/Grab	2/20/2023	0605	Lead	P	1			048A
05571600-051CF	DW/Grab	2/20/2023	0606	Lead	P	1			049A
05571600-052CF	DW/Grab	2/20/2023	0607	Lead	P	1			050A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
		REPORT				
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: <u>Veronica Arciga</u>		Refrigerated	
					Ice	☒ None : X
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/27/23</u>					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	<u>2/27/23</u>	<u>8:00</u>	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

March 03, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2302880

Dear Terry Rutledge:

Analytical Laboratory Group received 2 sample(s) on 2/27/2023 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2302880

Date: 3/3/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2302880
CLIENT: Springfield School District #19
Project: Springfield SD
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302880-001 **Client Sample ID** 05571600-053BF **Collection Date:** 2/20/2023 6:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/1/2023 3:00:00 PM	AS

Lab ID: 2302880-002 **Client Sample ID** 05571600-053DW **Collection Date:** 2/20/2023 5:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/1/2023 3:00:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2302880

Date: 3/3/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302880

03-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302880-001A	05571600-053BF	Drinking Water	AA Metals by SM 3113	Lead	A
	2302880-002A	05571600-053DW		Schools 250mL	Lead	A

ACCRED ORELAP A Accredited

Version #2302880# v2

Page 5 of 6



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: CB

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciga

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05571600-053BF	DW/Grab	2/20/2023	0615	Lead	P	1		NA	001A
05571600-053DW	DW/Grab	2/20/2023	0530	Lead	P	1			002A
* 05571600-540W	DW/Grab	2/20/2023	0535	Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes: *Sample not relinquished. FM 2/27/23	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice	None: X
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	2/27/23					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			Jath	2/27/23	8:00	