

Lead in Water Test Results Summary: Two Rivers Dos Rios Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Main office nurse room faucet	50591000-001NS	3/16/2023	ND	Non-Detect	[enter date]	[enter result]	[autofill]
2nd floor staffroom faucet	50591000-002SF	3/16/2023	ND	Non-Detect			
Staff bathroom faucet (1)	50591000-003BF	3/16/2023	2.12	Low			
Staff bathroom faucet (2)	50591000-004BF	3/16/2023	2.11	Low			
Outside office drinking fountain	50591000-005DW	3/16/2023	ND	Non-Detect			
water bottle fill station	50591000-006WB	3/16/2023	ND	Non-Detect			
Classroom 1 drinking water fountain	50591000-007DW	3/16/2023	2.13	Low			
Classroom 1 classroom faucet	50591000-008CF	3/16/2023	ND	Non-Detect			
Classroom 2 drinking water fountain	50591000-009DW	3/16/2023	ND	Non-Detect			
Classroom 2 classroom faucet	50591000-010CF	3/16/2023	3.16	Low			
Classroom 3 drinking water fountain	50591000-011DW	3/16/2023	ND	Non-Detect			
Classroom 3 classroom faucet	50591000-012CF	3/16/2023	3.28	Low			
Classroom 16 drinking water fountain	50591000-013DW	3/16/2023	2.52	Low			
Classroom 16 classroom faucet	50591000-014CF	3/16/2023	2.28	Low			
Room 15 staff back area staffroom faucet	50591000-015SF	3/16/2023	3.9	Low			
Classroom 4 drinking water fountain	50591000-016DW	3/16/2023	2.55	Low			
Classroom 4 classroom faucet	50591000-017CF	3/16/2023	2.25	Low			
Classroom 13 drinking water fountain	50591000-018DW	3/16/2023	ND	Non-Detect			
Classroom 13 classroom faucet	50591000-019CF	3/16/2023	3.88	Low			
Classroom 5 drinking water fountain	50591000-020DW	3/16/2023	6.07	Moderate			
Classroom 5 classroom faucet	50591000-021CF	3/16/2023	5.39	Moderate			
Classroom 12 drinking water fountain	50591000-022DW	3/16/2023	2.01	Low			
Classroom 12 classroom faucet	50591000-023CF	3/16/2023	ND	Non-Detect			
Classroom 6 drinking water fountain	50591000-024DW	3/16/2023	3.52	Low			
Classroom 6 classroom faucet	50591000-025CF	3/16/2023	4.69	Low			
Restroom Faucet	50591000-026BF	3/16/2023	ND	Non-Detect			
outside library drinking fountain	50591000-027DW	3/16/2023	ND	Non-Detect			
Restroom Faucet	50591000-028BF	3/16/2023	ND	Non-Detect			
Drinking fountain	50591000-029DW	3/16/2023	ND	Non-Detect			
Water bottle fill station	50591000-030WB	3/16/2023	ND	Non-Detect			
Girls bathroom faucet	50591000-031BF	3/16/2023	ND	Non-Detect			
Girls bathroom faucet	50591000-032BF	3/16/2023	ND	Non-Detect			
Boys bathroom faucet	50591000-033BF	3/16/2023	ND	Non-Detect			
Boys bathroom faucet	50591000-034BF	3/16/2023	ND	Non-Detect			
Classroom 11 drinking water fountain	50591000-035DW	3/16/2023	ND	Non-Detect			
Classroom 11 classroom faucet	50591000-036CF	3/16/2023	3.36	Low			
Classroom 10 drinking water fountain	50591000-037DW	3/16/2023	22.7	Action Req.	9/6/2024	ND	Non-Detect
Classroom 10 classroom faucet	50591000-038CF	3/16/2023	4.97	Low			
Classroom 32 classroom faucet	50591000-039CF	3/16/2023	ND	Non-Detect			
Classroom 20 drinking water fountain	50591000-040DW	3/16/2023	ND	Non-Detect			
Classroom 20 classroom faucet	50591000-041CF	3/16/2023	3.31	Low			
Drinking water fountain outside room 20	50591000-042DW	3/16/2023	15.5	Action Req.	5/21/2025	4.63	Low
Classroom 17 drinking water fountain	50591000-043DW	3/16/2023	3.24	Low			
Classroom 17 classroom faucet	50591000-044CF	3/16/2023	2.42	Low			
Boys bathroom faucet	50591000-045BF	3/16/2023	2.08	Low			
Boys bathroom faucet	50591000-046BF	3/16/2023	ND	Non-Detect			
Boys bathroom faucet	50591000-047BF	3/16/2023	ND	Non-Detect			
Girls bathroom faucet	50591000-048BF	3/16/2023	ND	Non-Detect			
Girls bathroom faucet	50591000-049BF	3/16/2023	ND	Non-Detect			
Girls bathroom faucet	50591000-050BF	3/16/2023	ND	Non-Detect			

Bathroom faucet across from room 25	50591000-051BF	3/16/2023	ND	Non-Detect
Classroom 22 classroom faucet	50591000-052CF	3/16/2023	2.1	Low
Classroom 22 classroom faucet	50591000-053CF	3/16/2023	10	High
Kitchen faucet back entrance	50591000-054KF	3/16/2023	3.85	Low
Kitchen staff faucet(hand wash)	50591000-055SF	3/16/2023	2.55	Low
Kitchen faucet dishwasher area	50591000-056KF	3/16/2023	2.52	Low
Bathroom faucet kitchen	50591000-057BF	3/16/2023	ND	Non-Detect
Kitchen faucet	50591000-058KF	3/16/2023	2.86	Low
Kitchen Faucet back window	50591000-059KF	3/16/2023	4.1	Low
water is off)	50591000-060DW			Not In Use

TRDR



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

April 10, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX

RE: Springfield SD

Order No.: 2303682

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 3/17/2023 for the analyses presented in the following report.

Teresa Garcia-Lande

Teresa Garcia-Lande
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2303682

Date: 4/10/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 4/10/2023

WO#: 2303682
CLIENT: Springfield School District #19
Project: Springfield SD

Received Date: 3/17/2023 8:30:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID:	Client Sample ID	Collection Date:
2303682-001	50591000-001NS	3/16/2023 5:09:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID:	Client Sample ID	Collection Date:
2303682-002	50591000-002SF	3/16/2023 5:10:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID:	Client Sample ID	Collection Date:
2303682-003	50591000-003BF	3/16/2023 5:11:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.12		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID:	Client Sample ID	Collection Date:
2303682-004	50591000-004BF	3/16/2023 5:12:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.11		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID:	Client Sample ID	Collection Date:
2303682-005	50591000-005DW	3/16/2023 5:13:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID:	Client Sample ID	Collection Date:
2303682-006	50591000-006WB	3/16/2023 5:14:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID:	Client Sample ID	Collection Date:
2303682-007	50591000-007DW	3/16/2023 5:16:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.13		2.00	1.00	ppb	04/07/23 18:29	AS

Definitions:

A	Accredited by ORELAP
LOD	Limit of Detection
MCL	Maximum Contaminant Level
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit

Qualifiers:

WO#: 2303682
CLIENT: Springfield School District #19
Project: Springfield SD

Received Date: 3/17/2023 8:30:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2303682-008	Client Sample ID 50591000-008CF	Collection Date: 3/16/2023 5:17:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	ND 2.00 1.00 ppb 04/07/23 18:29 AS

Lab ID: 2303682-009	Client Sample ID 50591000-009DW	Collection Date: 3/16/2023 5:18:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	ND 2.00 1.00 ppb 04/07/23 18:29 AS

Lab ID: 2303682-010	Client Sample ID 50591000-010CF	Collection Date: 3/16/2023 5:19:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	3.16 2.00 1.00 ppb 04/07/23 18:29 AS

Lab ID: 2303682-011	Client Sample ID 50591000-011DW	Collection Date: 3/16/2023 5:19:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	ND 2.00 1.00 ppb 04/07/23 18:29 AS

Lab ID: 2303682-012	Client Sample ID 50591000-012CF	Collection Date: 3/16/2023 5:19:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	3.28 2.00 1.00 ppb 04/07/23 18:29 AS

Lab ID: 2303682-013	Client Sample ID 50591000-013DW	Collection Date: 3/16/2023 5:20:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	2.52 2.00 1.00 ppb 04/07/23 18:29 AS

Lab ID: 2303682-014	Client Sample ID 50591000-014CF	Collection Date: 3/16/2023 5:20:00 AM
Analyses	Method	Result Qual PQL LOD Units Date Analyzed Analyst
Lead	SM 3113 B	2.28 2.00 1.00 ppb 04/07/23 18:29 AS

Definitions:	A Accredited by ORELAP	Qualifiers:
	LOD Limit of Detection	
	MCL Maximum Contaminant Level	
	ND Not Detected at the Reporting Limit	
	PL Permit Limit	
	PQL Practical Quantitation Level or Reporting Limit	



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 4/10/2023

WO#: 2303682
CLIENT: Springfield School District #19
Project: Springfield SD

Received Date: 3/17/2023 8:30:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water

Lab ID: 2303682-015 Client Sample ID 50591000-015SF Collection Date: 3/16/2023 5:23:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.90		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303682-016 Client Sample ID 50591000-016DW Collection Date: 3/16/2023 5:24:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.55		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303682-017 Client Sample ID 50591000-017CF Collection Date: 3/16/2023 5:25:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.25		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303682-018 Client Sample ID 50591000-018DW Collection Date: 3/16/2023 5:26:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303682-019 Client Sample ID 50591000-019CF Collection Date: 3/16/2023 5:27:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.88		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303682-020 Client Sample ID 50591000-020DW Collection Date: 3/16/2023 5:27:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.07		2.00	1.00	ppb	04/07/23 18:29	AS

Definitions: A Accredited by ORELAP
LOD Limit of Detection
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit

Qualifiers:



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2303682

Date: 4/10/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303682

10-Apr-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303682-001A	50591000-001NS	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303682-002A	50591000-002SF			Lead	A
	2303682-003A	50591000-003BF			Lead	A
	2303682-004A	50591000-004BF			Lead	A
	2303682-005A	50591000-005DW			Lead	A
	2303682-006A	50591000-006WB			Lead	A
	2303682-007A	50591000-007DW			Lead	A
	2303682-008A	50591000-008CF			Lead	A
	2303682-009A	50591000-009DW			Lead	A
	2303682-010A	50591000-010CF			Lead	A
	2303682-011A	50591000-011DW			Lead	A
	2303682-012A	50591000-012CF			Lead	A
	2303682-013A	50591000-013DW			Lead	A
	2303682-014A	50591000-014CF			Lead	A
	2303682-015A	50591000-015SF			Lead	A
	2303682-016A	50591000-016DW			Lead	A
	2303682-017A	50591000-017CF			Lead	A
	2303682-018A	50591000-018DW			Lead	A
	2303682-019A	50591000-019CF			Lead	A
	2303682-020A	50591000-020DW			Lead	A

ACCRED

ORELAP A Accredited

Original #2303682# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: FM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
50591000-001NS	DW/Grab	03/16	0509	Lead	P	1		NK	001A
50591000-002SF	DW/Grab		0510	Lead	P	1			002A
50591000-003BF	DW/Grab		0511	Lead	P	1			003A
50591000-004BF	DW/Grab		0512	Lead	P	1			004A
50591000-005DW	DW/Grab		0513	Lead	P	1			005A
50591000-006WB	DW/Grab		0514	Lead	P	1			006A
50591000-007DW	DW/Grab		0516	Lead	P	1			007A
50591000-008CF	DW/Grab		0517	Lead	P	1			008A
50591000-009DW	DW/Grab		0518	Lead	P	1			009A
50591000-010CF	DW/Grab		0519	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush Incurs a Surcharge):			Shipped Via:			Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>			Ice	<u>None</u>
Relinquished by:	Date	Time	Received by:	Date	Time		
<u>Veronica Arciga</u>	<u>3/17</u>	<u>830</u>					
Relinquished by:	Date	Time	Received by:	Date	Time		
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time		
			<u>[Signature]</u>	<u>3/17/23</u>	<u>8:30</u>		



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: NI

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield SD		Sampler Name: <u>Veronica Arciga</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
50591000-011DW	DW/Grab	03/16	0519	Lead	P	1		NA	011A
50591000-012CF	DW/Grab	}	0519	Lead	P	1			012A
50591000-013DW	DW/Grab		0520	Lead	P	1			013A
50591000-014CF	DW/Grab		0520	Lead	P	1			014A
50591000-015SF	DW/Grab		0523	Lead	P	1			015A
50591000-016DW	DW/Grab		0524	Lead	P	1			016A
50591000-017CF	DW/Grab		0525	Lead	P	1			017A
50591000-018DW	DW/Grab		0526	Lead	P	1			018A
50591000-019CF	DW/Grab		0527	Lead	P	1			019A
50591000-020DW	DW/Grab		0527	Lead	P	1			020A

Notes:	PAID		Preservation Check				
	Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
	Fax						
	Pickup						

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: <u>Veronica Arciga</u>		Refrigerated Ice <u>None</u>	
Relinquished by: <u>Veronica Arciga</u>			Received by:		Date Time	
Relinquished by:			Received by:		Date Time	
Relinquished by:			Received by Laboratory:		Date Time	

Page 9 of 9
3/17/23 8:30

TRDR



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

April 10, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX

COPY

RE: Springfield SD

Order No.: 2303683

Dear Terry Rutledge:

Analytical Laboratory Group received 20 sample(s) on 3/17/2023 for the analyses presented in the following report.

Teresa Garcia-Lande

Teresa Garcia-Lande
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2303683

Date: 4/10/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 4/10/2023

WO#: 2303683 **Received Date:** 3/17/2023 8:30:00 AM
CLIENT: Springfield School District #19 **Sampler Name:** Jeff Medina and Veronica Arc
Project: Springfield SD **Matrix:** Drinking Water

Lab ID: 2303683-001 **Client Sample ID** 50591000-021CF **Collection Date:** 3/16/2023 5:28:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.39		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-002 **Client Sample ID** 50591000-022DW **Collection Date:** 3/16/2023 5:29:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.01		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-003 **Client Sample ID** 50591000-023CF **Collection Date:** 3/16/2023 5:30:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-004 **Client Sample ID** 50591000-024DW **Collection Date:** 3/16/2023 5:30:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.52		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-005 **Client Sample ID** 50591000-025CF **Collection Date:** 3/16/2023 5:31:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.69		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-006 **Client Sample ID** 50591000-026BF **Collection Date:** 3/16/2023 5:32:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-007 **Client Sample ID** 50591000-027DW **Collection Date:** 3/16/2023 5:33:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Definitions: A Accredited by ORELAP **Qualifiers:** * Value exceeds Maximum Contaminant Level (MCL)
 LOD Limit of Detection
 MCL Maximum Contaminant Level
 ND Not Detected at the Reporting Limit
 PL Permit Limit
 PQL Practical Quantitation Level or Reporting Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 4/10/2023

WO#: 2303683 **Received Date:** 3/17/2023 8:30:00 AM
CLIENT: Springfield School District #19 **Sampler Name:** Jeff Medina and Veronica Arc
Project: Springfield SD **Matrix:** Drinking Water

Lab ID: 2303683-008 **Client Sample ID** 50591000-028BF **Collection Date:** 3/16/2023 5:34:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-009 **Client Sample ID** 50591000-029DW **Collection Date:** 3/16/2023 5:35:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-010 **Client Sample ID** 50591000-030WB **Collection Date:** 3/16/2023 5:35:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-011 **Client Sample ID** 50591000-031BF **Collection Date:** 3/16/2023 5:36:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-012 **Client Sample ID** 50591000-032BF **Collection Date:** 3/16/2023 5:37:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-013 **Client Sample ID** 50591000-033BF **Collection Date:** 3/16/2023 5:38:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-014 **Client Sample ID** 50591000-034BF **Collection Date:** 3/16/2023 5:38:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Definitions: A Accredited by ORELAP **Qualifiers:** * Value exceeds Maximum Contaminant Level (MCL)
 LOD Limit of Detection
 MCL Maximum Contaminant Level
 ND Not Detected at the Reporting Limit
 PL Permit Limit
 PQL Practical Quantitation Level or Reporting Limit

WO#:	2303683	Received Date:	3/17/2023 8:30:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Jeff Medina and Veronica Arc
Project:	Springfield SD	Matrix:	Drinking Water

Lab ID: 2303683-015	Client Sample ID 50591000-035DW	Collection Date: 3/16/2023 5:39:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-016	Client Sample ID 50591000-036CF	Collection Date: 3/16/2023 5:10:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.36		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-017	Client Sample ID 50591000-037DW	Collection Date: 3/16/2023 5:12:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	22.7	*	4.00	2.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-018	Client Sample ID 50591000-038CF	Collection Date: 3/16/2023 5:13:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.97		2.00	1.00	ppb	04/07/23 18:29	AS

Lab ID: 2303683-019	Client Sample ID 50591000-039CF	Collection Date: 3/16/2023 5:18:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/08/23 09:41	KG

Lab ID: 2303683-020	Client Sample ID 50591000-040DW	Collection Date: 3/16/2023 5:20:00 AM
----------------------------	--	--

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/08/23 09:41	KG

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection			
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2303683

Date: 4/10/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303683

10-Apr-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303683-001A	50591000-021CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303683-002A	50591000-022DW			Lead	A
	2303683-003A	50591000-023CF			Lead	A
	2303683-004A	50591000-024DW			Lead	A
	2303683-005A	50591000-025CF			Lead	A
	2303683-006A	50591000-026BF			Lead	A
	2303683-007A	50591000-027DW			Lead	A
	2303683-008A	50591000-028BF			Lead	A
	2303683-009A	50591000-029DW			Lead	A
	2303683-010A	50591000-030WB			Lead	A
	2303683-011A	50591000-031BF			Lead	A
	2303683-012A	50591000-032BF			Lead	A
	2303683-013A	50591000-033BF			Lead	A
	2303683-014A	50591000-034BF			Lead	A
	2303683-015A	50591000-035DW			Lead	A
	2303683-016A	50591000-036CF			Lead	A
	2303683-017A	50591000-037DW			Lead	A
	2303683-018A	50591000-038CF			Lead	A
	2303683-019A	50591000-039CF			Lead	A
	2303683-020A	50591000-040DW			Lead	A

ACCRED

ORELAP A Accredited

Original #2303683# v1

Page 7 of 9



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
50591000-021CF	DW/Grab	03/16	0528	Lead	P	1		NA	001A
50591000-022DW	DW/Grab		0529	Lead	P	1			002A
50591000-023CF	DW/Grab		0530	Lead	P	1			003A
50591000-024DW	DW/Grab		0530	Lead	P	1			004A
50591000-025CF	DW/Grab		0531	Lead	P	1			005A
50591000-026BF	DW/Grab		0532	Lead	P	1			006A
50591000-027DW	DW/Grab		0533	Lead	P	1			007A
50591000-028BF	DW/Grab		0534	Lead	P	1			008A
50591000-029DW	DW/Grab		0535	Lead	P	1			009A
50591000-030WB	DW/Grab		0535	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush Incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	3/17	8:30				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Smith</u>	3/17/13	8:30	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FMChecked: MI

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: JEFF MEDINA & VERONICA ARCEGA

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
50591000-031BF	DW/Grab	3/16/23	0536	Lead	P	1		NA	011A
50591000-032BF	DW/Grab		0537	Lead	P	1			012A
50591000-033BF	DW/Grab		0538	Lead	P	1			013A
50591000-034BF	DW/Grab		0538	Lead	P	1			014A
50591000-035DW	DW/Grab		0539	Lead	P	1			015A
50591000-036CF	DW/Grab		05:10	Lead	P	1			016A
50591000-037DW	DW/Grab		05:12	Lead	P	1			017A
50591000-038CF	DW/Grab		05:13	Lead	P	1			018A
50591000-039CF	DW/Grab		05:18	Lead	P	1			019A
50591000-040DW	DW/Grab		05:20	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arcega		Ice	None
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arcega	3/17	8:30				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			Jaith	3/17/23	8:30	



*Delivering more than
just test results.*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

April 10, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX

RE: Springfield SD

Order No.: 2303684

Dear Terry Rutledge:

Analytical Laboratory Group received 19 sample(s) on 3/17/2023 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Teresa Garcia-Lande'.

Teresa Garcia-Lande
Quality Manager Assistant
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2303684

Date: 4/10/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#:	2303684	Received Date:	3/17/2023 8:30:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Jeff Medina
Project:	Springfield SD	Matrix:	Drinking Water

Lab ID:	2303684-001	Client Sample ID	50591000-041CF	Collection Date:	3/16/2023 5:21:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.31		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-002	Client Sample ID	50591000-042DW	Collection Date:	3/16/2023 5:22:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	15.5	*	2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-003	Client Sample ID	50591000-043DW	Collection Date:	3/16/2023 5:23:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.24		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-004	Client Sample ID	50591000-044CF	Collection Date:	3/16/2023 5:23:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.42		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-005	Client Sample ID	50591000-045BF	Collection Date:	3/16/2023 5:25:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.08		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-006	Client Sample ID	50591000-046BF	Collection Date:	3/16/2023 5:26:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-007	Client Sample ID	50591000-047BF	Collection Date:	3/16/2023 5:26:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/09/23 14:38	KG

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection			
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			

WO#:	2303684	Received Date:	3/17/2023 8:30:00 AM
CLIENT:	Springfield School District #19	Sampler Name:	Jeff Medina
Project:	Springfield SD	Matrix:	Drinking Water

Lab ID:	2303684-008	Client Sample ID	50591000-048BF	Collection Date:	3/16/2023 5:27:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-009	Client Sample ID	50591000-049BF	Collection Date:	3/16/2023 5:28:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-010	Client Sample ID	50591000-050BF	Collection Date:	3/16/2023 5:28:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-011	Client Sample ID	50591000-051BF	Collection Date:	3/16/2023 5:31:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-012	Client Sample ID	50591000-052CF	Collection Date:	3/16/2023 5:32:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.10		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-013	Client Sample ID	50591000-053CF	Collection Date:	3/16/2023 5:33:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	10.0		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID:	2303684-014	Client Sample ID	50591000-054KF	Collection Date:	3/16/2023 5:35:00 AM			
Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.85		2.00	1.00	ppb	04/09/23 14:38	KG

Definitions:	A	Accredited by ORELAP	Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)
	LOD	Limit of Detection			
	MCL	Maximum Contaminant Level			
	ND	Not Detected at the Reporting Limit			
	PL	Permit Limit			
	PQL	Practical Quantitation Level or Reporting Limit			

Analytical Report

Date Reported: 4/10/2023

WO#: 2303684
CLIENT: Springfield School District #19
Project: Springfield SD

Received Date: 3/17/2023 8:30:00 AM
Sampler Name: Jeff Medina
Matrix: Drinking Water

Lab ID: 2303684-015 **Client Sample ID** 50591000-055SF **Collection Date:** 3/16/2023 5:36:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.55		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID: 2303684-016 **Client Sample ID** 50591000-056KF **Collection Date:** 3/16/2023 5:37:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.52		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID: 2303684-017 **Client Sample ID** 50591000-057BF **Collection Date:** 3/16/2023 5:38:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID: 2303684-018 **Client Sample ID** 50591000-058KF **Collection Date:** 3/16/2023 5:39:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.86		2.00	1.00	ppb	04/09/23 14:38	KG

Lab ID: 2303684-019 **Client Sample ID** 50591000-059KF **Collection Date:** 3/16/2023 5:39:00 AM

Analyses	Method	Result	Qual	PQL	LOD	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.10		2.00	1.00	ppb	04/09/23 14:38	KG

Definitions: A Accredited by ORELAP
LOD Limit of Detection
MCL Maximum Contaminant Level
ND Not Detected at the Reporting Limit
PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit

Qualifiers: * Value exceeds Maximum Contaminant Level (MCL)



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2303684

Date: 4/10/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303684

10-Apr-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303684-001A	50591000-041CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303684-002A	50591000-042DW			Lead	A
	2303684-003A	50591000-043DW			Lead	A
	2303684-004A	50591000-044CF			Lead	A
	2303684-005A	50591000-045BF			Lead	A
	2303684-006A	50591000-046BF			Lead	A
	2303684-007A	50591000-047BF			Lead	A
	2303684-008A	50591000-048BF			Lead	A
	2303684-009A	50591000-049BF			Lead	A
	2303684-010A	50591000-050BF			Lead	A
	2303684-011A	50591000-051BF			Lead	A
	2303684-012A	50591000-052CF			Lead	A
	2303684-013A	50591000-053CF			Lead	A
	2303684-014A	50591000-054KF			Lead	A
	2303684-015A	50591000-055SF			Lead	A
	2303684-016A	50591000-056KF			Lead	A
	2303684-017A	50591000-057BF			Lead	A
	2303684-018A	50591000-058KF			Lead	A
	2303684-019A	50591000-059KF			Lead	A

ORELAP A Accredited

ACCRED

Original #2303684# v1

Page 7 of 9



Delivering more than
just test results.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

BP
FM

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>JEFF MEDINA</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
50591000-041CF	DW/Grab	3/16/23	05:21	Lead	P	1		NA	001A
50591000-042DW	DW/Grab		05:22	Lead	P	1			002A
50591000-043DW	DW/Grab		05:23	Lead	P	1			003A
50591000-044CF	DW/Grab		05:23	Lead	P	1			004A
50591000-045BF	DW/Grab		05:25	Lead	P	1			005A
50591000-046BF	DW/Grab		05:26	Lead	P	1			006A
50591000-047BF	DW/Grab		05:26	Lead	P	1			007A
50591000-048BF	DW/Grab		05:27	Lead	P	1			008A
50591000-049BF	DW/Grab		05:28	Lead	P	1			009A
50591000-050BF	DW/Grab		05:28	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	Veronica Arciga	Ice ☐ None ☒
Relinquished by:	Received by:	Date Time
Veronica Arciga		3/17 8:30
Relinquished by:	Received by:	Date Time
Relinquished by:	Received by Laboratory:	Date Time
		3/17/23 8:30



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: RP
Checked: FM

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>JEFF MEDINA</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
50591000-051BF	DW/Grab	3/16/23	05:31	Lead	P	1		NA	011A
50591000-052CF	DW/Grab		05:32	Lead	P	1			012A
50591000-053CF	DW/Grab		05:33	Lead	P	1			013A
50591000-054KF	DW/Grab		05:35	Lead	P	1			014A
50591000-055SF	DW/Grab		05:36	Lead	P	1			015A
50591000-056KF	DW/Grab		05:37	Lead	P	1			016A
50591000-057BF	DW/Grab		05:38	Lead	P	1			017A
50591000-058KF	DW/Grab		05:39	Lead	P	1			018A
50591000-059KF	DW/Grab		05:39	Lead	P	1			019A
	DW/Grab			Lead	P	1			

Notes: * Sample not relinquished & crossed out by lab. For 3/17/23	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: <u>Veronica Arciga</u>		Refrigerated Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	3/17	830				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>Jaith</u>	3/17/23	8:30	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

September 10, 2024

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 744-6375
FAX:

RE: Springfield SD - TRDR

Order No.: 2409220

Dear Terry Rutledge:

Analytical Laboratory Group received 1 sample(s) on 9/6/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads "Kimberly J. Reeve Morghan".

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2409220

Date: 9/10/2024

CLIENT: Springfield School District #19

Project: Springfield SD - TRDR

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

Date Reported: 9/10/2024

WO#: 2409220
CLIENT: Springfield School District #19
Location:
Project: Springfield SD - TRDR
Sample Source:

Received Date: 9/6/2024 10:04:00 AM
Sampler Name John Harshberger
Matrix: Drinking Water
Treatment:

Lab ID: 2409220-001	Client Sample ID 50591000-037DW	Collection Date: 9/5/2024 7:48:00 PM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	9/9/2024 10:42:00 AM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2409220

Date: 9/10/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2409220

10-Sep-24

Client: Springfield School District #19

Project: Springfield SD - TRDR

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2409220-001A	50591000-037DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A

ACCRED

ORELAP A Accredited

Original #2409220# v1

Page 5 of 6

*TRDR

Work Order # 2409220



361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
Phone: 541-485-8404 Fax: 541-484-5995
Email: alglabs@alglabsinc.com

LIMS: BV
Checked: SW

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield SD - TRDR *		Sampler Name: <u>John Harsberger</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
50591000-0370w	DW/Grab	9/5	19:48	Lead	P	1		NA	001A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes: * per client note, moved to project name by lab. BV 9/6/24	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH		Shipped Via: <u>John</u>		Refrigerated <u>IR</u> Ice ☐ <u>None</u>	
Relinquished by:	Date	Time	Received by:	Date	Time
<u>John Harsberger</u>					
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<u>Pam Phillips</u>	9/6/24	10:04