

Lead in Water Test Results Summary: Yolanda Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Nurse office sink	05591200-001NS	3/2/2023	4.23	Low	[enter date]	[enter result]	[autofill]
Nurse office bathroom faucet	05591200-002BF	3/2/2023	ND	Non-Detect			
Staff bathroom faucet	05591200-003BF	3/2/2023	2.58	Low			
Staff bathroom faucet	05591200-004BF	3/2/2023	2.63	Low			
Staff Faucet	05591200-005SF	3/2/2023	ND	Non-Detect			
Staff Faucet	05591200-006SF	3/2/2023	ND	Non-Detect			
Cafeteria drinking water fountain	05591200-007DW	3/2/2023	ND	Non-Detect			
Cafeteria Bottle Fill Station	05591200-008BF	3/2/2023	ND	Non-Detect			
Kitchen Faucet near dishwasher	05591200-009KF	3/2/2023	3.52	Low			
Kitchen Faucet Middle	05591200-010KF	3/2/2023	3.15	Low			
Kitchen Faucet single on east	05591200-011KF	3/2/2023	4.6	Low			
Bathroom Faucet in kitchen staff restroom	05591200-012BF	3/2/2023	11.7	High			
Gym girls restroom Bathroom Faucet	05591200-013BF	3/2/2023	2.21	Low			
Gym girls restroom Drinking water faucet	05591200-014DW	3/2/2023	ND	Non-Detect			
Gym Staff restroom Bathroom Faucet	05591200-015BF	3/2/2023	7.3	Moderate			
Gym Boys restroom bathroom faucet	05591200-016BF	3/2/2023	4.08	Low			
Gym Boys restroom Drinking Water fountain	05591200-017DW	3/2/2023	ND	Non-Detect			
Gym main entrance Drinking Water fountain	05591200-018DW	3/2/2023	ND	Non-Detect			
				Low			
Building C Classroom 18 Drinking Water Fountain	05591200-019DW	3/2/2023	4.14				
Classroom 18 Classroom Faucet	05591200-020CF	3/2/2023	2.61	Low			
Classroom 17 Drinking Water Fountain	05591200-021DW	3/2/2023	5.54	Moderate			
Classroom 17 Classroom Faucet	05591200-022CF	3/2/2023	ND	Non-Detect			
Classroom 16 Drinking Water Fountain	05591200-023DW	3/2/2023	ND	Non-Detect			
Classroom 16 Classroom Faucet	05591200-024CF	3/2/2023	3.67	Low			
Classroom 15 Drinking Water Fountain	05591200-025DW	3/2/2023	3.06	Low			
Classroom 15 Classroom Faucet	05591200-026CF	3/2/2023	2.11	Low			
Classroom 14 Drinking Water Fountain	05591200-027DW	3/2/2023	ND	Non-Detect			
Classroom 14 Classroom Faucet	05591200-028CF	3/2/2023	3.65	Low			
Classroom 13 Drinking Water Fountain	05591200-029DW	3/2/2023	7.82	Moderate			
Classroom 13 Classroom Faucet	05591200-030CF	3/2/2023	2.67	Low			
				Non-Detect			
Building B Classroom 12 Drinking Water Fountain	05591200-031DW	3/2/2023	ND				
Classroom 12 Classroom Faucet	05591200-032CF	3/2/2023	4.34	Low			
Classroom 11 Drinking Water Fountain	05591200-033DW	3/2/2023	2.24	Low			
Classroom 11 Classroom Faucet	05591200-034CF	3/2/2023	ND	Non-Detect			
Classroom 10 Drinking Water Fountain	05591200-035DW	3/2/2023	ND	Non-Detect			
Classroom 10 Classroom Faucet	05591200-036CF	3/2/2023	ND	Non-Detect			
Classroom 09 Drinking Water Fountain	05591200-037DW	3/2/2023	ND	Non-Detect			
Classroom 09 Classroom Faucet	05591200-038CF	3/2/2023	ND	Non-Detect			
Classroom 08 Drinking Water Fountain	05591200-039DW	3/2/2023	ND	Non-Detect			
Classroom 08 Classroom Faucet	05591200-040CF	3/2/2023	ND	Non-Detect			
Classroom 07 Drinking Water Fountain	05591200-041DW	3/2/2023	4.26	Low			
Classroom 07 Classroom Faucet	05591200-042CF	3/2/2023	ND	Non-Detect			
				Non-Detect			
Building D classroom 19 Drinking Water Fountain	05591200-043DW	3/2/2023	ND				
Classroom 19 Classroom Faucet	05591200-044CF	3/2/2023	ND	Non-Detect			
Classroom 20 Drinking water Fountain	05591200-045DW	3/2/2023	ND	Non-Detect			

Classroom 20 Classroom Faucet	05591200-046CF	3/2/2023	ND	Non-Detect			
Student restroom Bathroom Faucet	05591200-047BF	3/2/2023	ND	Non-Detect			
Staff restroom Bathroom Faucet	05591200-048BF	3/2/2023	ND	Non-Detect			
				Non-Detect			
Building A Classroom 6 Drinking Water Fountain	05591200-049DW	3/2/2023	ND				
Classroom 6 Classroom Faucet	05591200-050CF	3/2/2023	ND	Non-Detect			
Classroom 5 Drinking Water Fountain	05591200-051DW	3/2/2023	ND	Non-Detect			
Classroom 5 Classroom Faucet	05591200-052CF	3/2/2023	ND	Non-Detect			
Classroom 4 Drinking Water Fountain	05591200-053DW	3/2/2023	2.07	Low			
Classroom 4 Classroom Faucet	05591200-054CF	3/2/2023	ND	Non-Detect			
Bathroom Faucet east	05591200-055BF	3/2/2023	ND	Non-Detect			
Bathroom Faucet mid	05591200-056BF	3/2/2023	ND	Non-Detect			
Bathroom Faucet mid	05591200-057BF	3/2/2023	ND	Non-Detect			
Bathroom Faucet west	05591200-058BF	3/2/2023	ND	Non-Detect			
Classroom 3 Drinking Water Faucet	05591200-059DW	3/2/2023	ND	Non-Detect			
Classroom 3 Classroom Faucet	05591200-060CF	3/2/2023	ND	Non-Detect			
Classroom 2 Drinking Water Faucet	05591200-061DW	3/2/2023	ND	Non-Detect			
Classroom 2 Classroom Faucet	05591200-062CF	3/2/2023	ND	Non-Detect			
Classroom 1 Drinking Water Faucet	05591200-063DW	3/2/2023	ND	Non-Detect			
Classroom 1 Classroom Faucet	05591200-064CF	3/2/2023	ND	Non-Detect			



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

March 28, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2303093

Dear Terry Rutledge:

Analytical Laboratory Group received 50 sample(s) on 3/2/2023 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2303093

Date: 3/28/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#:	2303093	Received Date:	3/2/2023 9:05:00 AM
CLIENT:	Springfield School District #19	Sampler Name	Jeff Medina and Veronica Arc
Location:		Matrix:	Drinking Water
Project:	Springfield SD	Treatment:	
Sample Source:			

Lab ID: 2303093-001	Client Sample ID 05591200-001NS	Collection Date: 3/2/2023 5:02:00 AM
----------------------------	--	---

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.23	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-002	Client Sample ID 05591200-002BF	Collection Date: 3/2/2023 5:03:00 AM
----------------------------	--	---

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-003	Client Sample ID 05591200-003BF	Collection Date: 3/2/2023 5:04:00 AM
----------------------------	--	---

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.58	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-004	Client Sample ID 05591200-004BF	Collection Date: 3/2/2023 5:05:00 AM
----------------------------	--	---

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.63	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-005	Client Sample ID 05591200-005SF	Collection Date: 3/2/2023 5:06:00 AM
----------------------------	--	---

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-006	Client Sample ID 05591200-006SF	Collection Date: 3/2/2023 5:07:00 AM
----------------------------	--	---

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-007	Client Sample ID 05591200-007DW	Collection Date: 3/2/2023 5:09:00 AM
----------------------------	--	---

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/28/2023

WO#: 2303093
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/2/2023 9:05:00 AM
Sampler Name: Jeff Medina and Veronica Arc
Matrix: Drinking Water
Treatment:

Lab ID: 2303093-008 **Client Sample ID:** 05591200-008BF **Collection Date:** 3/2/2023 5:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-009 **Client Sample ID:** 05591200-009KF **Collection Date:** 3/2/2023 5:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.52	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-010 **Client Sample ID:** 05591200-010KF **Collection Date:** 3/2/2023 5:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.15	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-011 **Client Sample ID:** 05591200-011KF **Collection Date:** 3/2/2023 5:14:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.60	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-012 **Client Sample ID:** 05591200-012BF **Collection Date:** 3/2/2023 5:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	11.7	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-013 **Client Sample ID:** 05591200-013BF **Collection Date:** 3/2/2023 5:17:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.21	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-014 **Client Sample ID:** 05591200-014DW **Collection Date:** 3/2/2023 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/28/2023

WO#: 2303093
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/2/2023 9:05:00 AM
Sampler Name: Jeff Medina and Veronica Arc
Matrix: Drinking Water
Treatment:

Lab ID: 2303093-015 **Client Sample ID:** 05591200-015BF **Collection Date:** 3/2/2023 5:19:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.30	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-016 **Client Sample ID:** 05591200-016BF **Collection Date:** 3/2/2023 5:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.08	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-017 **Client Sample ID:** 05591200-017DW **Collection Date:** 3/2/2023 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-018 **Client Sample ID:** 05591200-018DW **Collection Date:** 3/2/2023 5:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-019 **Client Sample ID:** 05591200-019DW **Collection Date:** 3/2/2023 5:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.14	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-020 **Client Sample ID:** 05591200-020CF **Collection Date:** 3/2/2023 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.61	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-021 **Client Sample ID:** 05591200-021DW **Collection Date:** 3/2/2023 5:29:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.54	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2303093
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/2/2023 9:05:00 AM
Sampler Name: Jeff Medina and Veronica Arc
Matrix: Drinking Water
Treatment:

Lab ID: 2303093-022 **Client Sample ID:** 05591200-022CF **Collection Date:** 3/2/2023 5:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-023 **Client Sample ID:** 05591200-023DW **Collection Date:** 3/2/2023 5:31:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-024 **Client Sample ID:** 05591200-024CF **Collection Date:** 3/2/2023 5:32:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.67	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-025 **Client Sample ID:** 05591200-025DW **Collection Date:** 3/2/2023 5:33:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.06	15.0	2.00		ppb	3/24/2023 9:00:00 AM	AS

Lab ID: 2303093-026 **Client Sample ID:** 05591200-026CF **Collection Date:** 3/2/2023 5:34:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.11	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-027 **Client Sample ID:** 05591200-027DW **Collection Date:** 3/2/2023 5:35:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-028 **Client Sample ID:** 05591200-028CF **Collection Date:** 3/2/2023 5:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.65	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2303093
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/2/2023 9:05:00 AM
Sampler Name: Jeff Medina and Veronica Arc
Matrix: Drinking Water
Treatment:

Lab ID: 2303093-029 **Client Sample ID:** 05591200-029DW **Collection Date:** 3/2/2023 5:37:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.82	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-030 **Client Sample ID:** 05591200-030CF **Collection Date:** 3/2/2023 5:38:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.67	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-031 **Client Sample ID:** 05591200-031DW **Collection Date:** 3/2/2023 5:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-032 **Client Sample ID:** 05591200-032CF **Collection Date:** 3/2/2023 5:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.34	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-033 **Client Sample ID:** 05591200-033DW **Collection Date:** 3/2/2023 5:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.24	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-034 **Client Sample ID:** 05591200-034CF **Collection Date:** 3/2/2023 5:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-035 **Client Sample ID:** 05591200-035DW **Collection Date:** 3/2/2023 5:04:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/28/2023

WO#: 2303093
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/2/2023 9:05:00 AM
Sampler Name: Jeff Medina and Veronica Arc
Matrix: Drinking Water
Treatment:

Lab ID: 2303093-036 **Client Sample ID:** 05591200-036CF **Collection Date:** 3/2/2023 5:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-037 **Client Sample ID:** 05591200-037DW **Collection Date:** 3/2/2023 5:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-038 **Client Sample ID:** 05591200-038CF **Collection Date:** 3/2/2023 5:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-039 **Client Sample ID:** 05591200-039DW **Collection Date:** 3/2/2023 5:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-040 **Client Sample ID:** 05591200-040CF **Collection Date:** 3/2/2023 5:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-041 **Client Sample ID:** 05591200-041DW **Collection Date:** 3/2/2023 5:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.26	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-042 **Client Sample ID:** 05591200-042CF **Collection Date:** 3/2/2023 5:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

Date Reported: 3/28/2023

WO#: 2303093
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/2/2023 9:05:00 AM
Sampler Name: Jeff Medina and Veronica Arc
Matrix: Drinking Water
Treatment:

Lab ID: 2303093-043 **Client Sample ID:** 05591200-043DW **Collection Date:** 3/2/2023 5:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-044 **Client Sample ID:** 05591200-044CF **Collection Date:** 3/2/2023 5:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-045 **Client Sample ID:** 05591200-045DW **Collection Date:** 3/2/2023 5:12:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-046 **Client Sample ID:** 05591200-046CF **Collection Date:** 3/2/2023 5:13:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-047 **Client Sample ID:** 05591200-047BF **Collection Date:** 3/2/2023 5:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-048 **Client Sample ID:** 05591200-048BF **Collection Date:** 3/2/2023 5:16:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Lab ID: 2303093-049 **Client Sample ID:** 05591200-049DW **Collection Date:** 3/2/2023 5:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2303093

CLIENT: Springfield School District #19

Location:

Project: Springfield SD

Sample Source:

Received Date: 3/2/2023 9:05:00 AM

Sampler Name Jeff Medina and Veronica Arc

Matrix: Drinking Water

Treatment:

Lab ID: 2303093-050

Client Sample ID 05591200-050CF

Collection Date: 3/2/2023 5:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/27/2023 5:00:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2303093

Date: 3/28/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303093

28-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303093-001A	05591200-001NS	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303093-002A	05591200-002BF			Lead	A
	2303093-003A	05591200-003BF			Lead	A
	2303093-004A	05591200-004BF			Lead	A
	2303093-005A	05591200-005SF			Lead	A
	2303093-006A	05591200-006SF			Lead	A
	2303093-007A	05591200-007DW			Lead	A
	2303093-008A	05591200-008BF			Lead	A
	2303093-009A	05591200-009KF			Lead	A
	2303093-010A	05591200-010KF			Lead	A
	2303093-011A	05591200-011KF			Lead	A
	2303093-012A	05591200-012BF			Lead	A
	2303093-013A	05591200-013BF			Lead	A
	2303093-014A	05591200-014DW			Lead	A
	2303093-015A	05591200-015BF			Lead	A
	2303093-016A	05591200-016BF			Lead	A
	2303093-017A	05591200-017DW			Lead	A
	2303093-018A	05591200-018DW			Lead	A
	2303093-019A	05591200-019DW			Lead	A
	2303093-020A	05591200-020CF			Lead	A
	2303093-021A	05591200-021DW			Lead	A
	2303093-022A	05591200-022CF			Lead	A
	2303093-023A	05591200-023DW			Lead	A
	2303093-024A	05591200-024CF			Lead	A
	2303093-025A	05591200-025DW			Lead	A
	2303093-026A	05591200-026CF			Lead	A
	2303093-027A	05591200-027DW			Lead	A
	2303093-028A	05591200-028CF			Lead	A
	2303093-029A	05591200-029DW			Lead	A
	2303093-030A	05591200-030CF			Lead	A
	2303093-031A	05591200-031DW			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2303093# v1

Page 12 of 18



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303093

28-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303093-032A	05591200-032CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303093-033A	05591200-033DW			Lead	A
	2303093-034A	05591200-034CF			Lead	A
	2303093-035A	05591200-035DW			Lead	A
	2303093-036A	05591200-036CF			Lead	A
	2303093-037A	05591200-037DW			Lead	A
	2303093-038A	05591200-038CF			Lead	A
	2303093-039A	05591200-039DW			Lead	A
	2303093-040A	05591200-040CF			Lead	A
	2303093-041A	05591200-041DW			Lead	A
	2303093-042A	05591200-042CF			Lead	A
	2303093-043A	05591200-043DW			Lead	A
	2303093-044A	05591200-044CF			Lead	A
	2303093-045A	05591200-045DW			Lead	A
	2303093-046A	05591200-046CF			Lead	A
	2303093-047A	05591200-047BF			Lead	A
	2303093-048A	05591200-048BF			Lead	A
	2303093-049A	05591200-049DW			Lead	A
	2303093-050A	05591200-050CF			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2303093# v1

Page 13 of 18



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

FM

MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: JEFF MEDINA

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05591200-001NS	DW/Grab	3/2/23	05:02	Lead	P	1		NA	001A
05591200-002BF	DW/Grab		05:03	Lead	P	1			002A
05591200-003BF	DW/Grab		05:04	Lead	P	1			003A
05591200-004BF	DW/Grab		05:05	Lead	P	1			004A
05591200-005SF	DW/Grab		05:06	Lead	P	1			005A
05591200-006SF	DW/Grab		05:07	Lead	P	1			006A
05591200-007DW	DW/Grab		05:09	Lead	P	1			007A
05591200-008BF	DW/Grab		05:09	Lead	P	1			008A
05591200-009KF	DW/Grab		05:12	Lead	P	1			009A
05591200-010KF	DW/Grab		05:13	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☒ None	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	3/2	9:05				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			Jail	3/2/23	9:05	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

FM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: JEFF MEDINA

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05591200-011KF	DW/Grab	3/2/23	05:14	Lead	P	1		NA	011A
05591200-012BF	DW/Grab		05:15	Lead	P	1			012A
05591200-013BF	DW/Grab		05:17	Lead	P	1			013A
05591200-014DW	DW/Grab		05:18	Lead	P	1			014A
05591200-015BF	DW/Grab		05:19	Lead	P	1			015A
05591200-016BF	DW/Grab		05:21	Lead	P	1			016A
05591200-017DW	DW/Grab		05:22	Lead	P	1			017A
05591200-018DW	DW/Grab		05:23	Lead	P	1			018A
05591200-019DW	DW/Grab		05:27	Lead	P	1			019A
05591200-020CF	DW/Grab		05:28	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush Incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Veronica Arciga		Ice ☒ None	
Relinquished by:	Date	Time	Received by:	Date	Time	
Veronica Arciga	3/2/23	9:05				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			Jail	3/2/23	9:05	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: FM
MI

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05591200-021DW	DW/Grab	3/2/23	05:29	Lead	P	1		NA	021A
05591200-022CF	DW/Grab		05:30	Lead	P	1			022A
05591200-023DW	DW/Grab		05:31	Lead	P	1			023A
05591200-024CF	DW/Grab		05:32	Lead	P	1			024A
05591200-025DW	DW/Grab		05:33	Lead	P	1			025A
05591200-026CF	DW/Grab		05:34	Lead	P	1			026A
05591200-027DW	DW/Grab		05:35	Lead	P	1			027A
05591200-028CF	DW/Grab		05:36	Lead	P	1			028A
05591200-029DW	DW/Grab		05:37	Lead	P	1			029A
05591200-030CF	DW/Grab		05:38	Lead	P	1			030A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	<u>Veronica Arciga</u>	Ice ☐ ☒ None
Relinquished by:	Received by:	Date
<u>Veronica Arciga</u>		
Relinquished by:	Received by:	Date
Relinquished by:	Received by Laboratory:	Date
	<u>Jaith</u>	<u>3/2/23</u>
		Time
		<u>9:05</u>



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: EM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05591200-031DW	DW/Grab	3/2	0502	Lead	P	1		NA	031A
05591200-032CF	DW/Grab		0502	Lead	P	1			032A
05591200-033DW	DW/Grab		0503	Lead	P	1			033A
05591200-034CF	DW/Grab		0503	Lead	P	1			034A
05591200-035DW	DW/Grab		0504	Lead	P	1			035A
05591200-036CF	DW/Grab		0506	Lead	P	1			036A
05591200-037DW	DW/Grab		0506	Lead	P	1			037A
05591200-038CF	DW/Grab		0507	Lead	P	1			038A
05591200-039DW	DW/Grab		0507	Lead	P	1			039A
05591200-040CF	DW/Grab		0509	Lead	P	1			040A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	3/2	9:05				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	3/2/23	9:05	



Delivering more than
just test results

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked: FM
MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05591200-041DW	DW/Grab	3/2	0509	Lead	P	1		NA	041A
05591200-042CF	DW/Grab		0511	Lead	P	1			042A
05591200-043DW	DW/Grab		0511	Lead	P	1			043A
05591200-044CF	DW/Grab		0512	Lead	P	1			044A
05591200-045DW	DW/Grab		0512	Lead	P	1			045A
05591200-046CF	DW/Grab		0513	Lead	P	1			046A
05591200-047BF	DW/Grab		0515	Lead	P	1			047A
05591200-048BF	DW/Grab		0516	Lead	P	1			048A
05591200-049DW	DW/Grab		0527	Lead	P	1			049A
05591200-050CF	DW/Grab		0527	Lead	P	1			050A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice ☐ None ☒	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	3/2	9:05				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>John</u>	3/2/23	9:05	



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

March 23, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2303097

Dear Terry Rutledge:

Analytical Laboratory Group received 14 sample(s) on 3/2/2023 for the analyses presented in the following report.

Kimberly J. Reeve Morghan

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

Yolanda



Delivering more than
just test results

ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5993
Website:

Case Narrative

WO#: 2303097
Date: 3/23/2023

CLIENT: Springfield School District #19
Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2303097
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/2/2023 9:05:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2303097-001 **Client Sample ID** 05591200-051DW **Collection Date:** 3/2/2023 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-002 **Client Sample ID** 05591200-052CF **Collection Date:** 3/2/2023 5:28:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-003 **Client Sample ID** 05591200-053DW **Collection Date:** 3/2/2023 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.07	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-004 **Client Sample ID** 05591200-054CF **Collection Date:** 3/2/2023 5:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-005 **Client Sample ID** 05591200-055BF **Collection Date:** 3/2/2023 5:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-006 **Client Sample ID** 05591200-056BF **Collection Date:** 3/2/2023 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-007 **Client Sample ID** 05591200-057BF **Collection Date:** 3/2/2023 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit
	PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits

WO#: 2303097
CLIENT: Springfield School District #19
Location:
Project: Springfield SD
Sample Source:

Received Date: 3/2/2023 9:05:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Treatment:

Lab ID: 2303097-008 **Client Sample ID:** 05591200-058BF **Collection Date:** 3/2/2023 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-009 **Client Sample ID:** 05591200-059DW **Collection Date:** 3/2/2023 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-010 **Client Sample ID:** 05591200-060CF **Collection Date:** 3/2/2023 5:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-011 **Client Sample ID:** 05591200-061DW **Collection Date:** 3/2/2023 5:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-012 **Client Sample ID:** 05591200-062CF **Collection Date:** 3/2/2023 5:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-013 **Client Sample ID:** 05591200-063DW **Collection Date:** 3/2/2023 5:25:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Lab ID: 2303097-014 **Client Sample ID:** 05591200-064CF **Collection Date:** 3/2/2023 5:25:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/23/2023 10:27:00 AM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit
PQL Practical Quantitation Level or Reporting Limit	R RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2303097

Date: 3/23/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2303097

23-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2303097-001A	05591200-051DW	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2303097-002A	05591200-052CF			Lead	A
	2303097-003A	05591200-053DW			Lead	A
	2303097-004A	05591200-054CF			Lead	A
	2303097-005A	05591200-055BF			Lead	A
	2303097-006A	05591200-056BF			Lead	A
	2303097-007A	05591200-057BF			Lead	A
	2303097-008A	05591200-058BF			Lead	A
	2303097-009A	05591200-059DW			Lead	A
	2303097-010A	05591200-060CF			Lead	A
	2303097-011A	05591200-061DW			Lead	A
	2303097-012A	05591200-062CF			Lead	A
	2303097-013A	05591200-063DW			Lead	A
	2303097-014A	05591200-064CF			Lead	A

ORELAP A Accredited

ACCREDITED

Original #2303097# v1

Page 6 of 8



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05591200-051DW	DW/Grab	3/2	0528	Lead	P	1		NA	001A
05591200-052CF	DW/Grab		0528	Lead	P	1			002A
05591200-053DW	DW/Grab		0520	Lead	P	1			003A
05591200-054CF	DW/Grab		0521	Lead	P	1			004A
05591200-055BF	DW/Grab		0521	Lead	P	1			005A
05591200-056BF	DW/Grab		0522	Lead	P	1			006A
05591200-057BF	DW/Grab		0522	Lead	P	1			007A
05591200-058BF	DW/Grab		0522	Lead	P	1			008A
05591200-059DW	DW/Grab		0520	Lead	P	1			009A
05591200-060CF	DW/Grab		0520	Lead	P	1			010A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush Incurs a Surcharge):			Shipped Via:			Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>			Ice	<u>None</u>
Relinquished by:	Date	Time	Received by:	Date	Time		
<u>Veronica Arciga</u>	3/2	9:05					
Relinquished by:	Date	Time	Received by:	Date	Time		
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time		
			<u>Faith</u>	3/2/23	9:05		



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: FM

Checked: MT

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05591200-061DW	DW/Grab	3/2/23	0524	Lead	P	1		NA	011A
05591200-062CF	DW/Grab		0524	Lead	P	1			012A
05591200-063DW	DW/Grab		0525	Lead	P	1			013A
05591200-064CF	DW/Grab		0525	Lead	P	1			014A
	DW/Grab			Lead	P	1		*	
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check:				
* FM 3/2/23	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
** Per bottles - FM 3/2/23	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush Incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	<u>Veronica Arciga</u>	Ice ☐ None ☒
Relinquished by:	Received by:	Date
<u>Veronica Arciga</u>		3/2
Relinquished by:	Received by:	Time
		9:05
Relinquished by:	Received by Laboratory:	Date
	<u>[Signature]</u>	3/2/23
		Time
		9:05