

Lead in Water Test Results Summary: Waltherville Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of [#] ppb.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Health room Faucet	05581100-001NS	1/19/2023	ND	Non-Detect	[enter date]	[enter result]	[autofill]
Health room drinking fountain	05581100-002DW	1/19/2023	ND	Non-Detect			
Office bathroom (north)	05581100-003BF	1/19/2023	ND	Non-Detect			
Office bathroom (south)	05581100-004BF	1/19/2023	ND	Non-Detect			
Office breakroom faucet	05581100-005SF	1/19/2023	ND	Non-Detect			
East Boys bathroom faucet (north)	05581100-006BF	1/19/2023	ND	Non-Detect			
East Boys bathroom faucet (middle)	05581100-007BF	1/19/2023	ND	Non-Detect			
East Boys bathroom faucet (south)	05581100-008BF	1/19/2023	ND	Non-Detect			
East Girls bathroom faucet (north)	05581100-009BF	1/19/2023	ND	Non-Detect			
East Girls bathroom faucet (middle)	05581100-010BF	1/19/2023	ND	Non-Detect			
East Girls bathroom faucet (south)	05581100-011BF	1/19/2023	ND	Non-Detect			
Room #9 faucet	05581100-012CF	1/19/2023	ND	Non-Detect			
Room #9 drinking fountain	05581100-013DW	1/19/2023	ND	Non-Detect			
Room #10 faucet	05581100-014CF	1/19/2023	ND	Non-Detect			
Room #10 drinking fountain	05581100-015DW	1/19/2023	ND	Non-Detect			
Room #11 faucet	05581100-016CF	1/19/2023	ND	Non-Detect			
Room #11 drinking fountain	05581100-017DW	1/19/2023	ND	Non-Detect			
Room #12 faucet	05581100-018CF	1/19/2023	3.32	Low			
Room #12 drinking fountain	05581100-019DW	1/19/2023	3.09	Low			
Center Boys bathroom faucet (north)	05581100-020BF	1/19/2023	ND	Non-Detect			
Center Boys bathroom faucet (middle)	05581100-021BF	1/19/2023	ND	Non-Detect			
Center Boys bathroom faucet (south)	05581100-022BF	1/19/2023	2.26	Low			
Center Girls bathroom faucet (north)	05581100-023BF	1/19/2023	2.04	Low			
Center Girls bathroom faucet (middle)	05581100-024BF	1/19/2023	ND	Non-Detect			
Center Girls bathroom faucet (south)	05581100-025BF	1/19/2023	ND	Non-Detect			
Room #5 faucet	05581100-026CF	1/19/2023	ND	Non-Detect			
Room #5 drinking fountain	05581100-027DW	1/19/2023	ND	Non-Detect			
Room #6 faucet	05581100-028CF	1/21/2023	ND	Non-Detect			
Room #6 drinking fountain	05581100-029DW	1/21/2023	ND	Non-Detect			
Room #7 faucet	05581100-030CF	1/19/2023	7.2	Moderate			
Room #7 drinking fountain	05581100-031DW	1/19/2023	ND	Non-Detect			
Room #8 faucet	05581100-032CF	1/19/2023	18.4	Action Req.	5/29/2025	Fixture Removed	
Room #8 drinking fountain	05581100-033DW	1/19/2023	ND	Non-Detect			
West Boys bathroom faucet (west)	05581100-034BF	1/19/2023	ND	Non-Detect			
West Boys bathroom faucet (middle)	05581100-035BF	1/19/2023	2.19	Low			
West Boys bathroom faucet (east)	05581100-036BF	1/19/2023	ND	Non-Detect			
West Girls bathroom faucet (west)	05581100-037BF	1/19/2023	ND	Non-Detect			
West Girls bathroom faucet (middle)	05581100-038BF	1/19/2023	ND	Non-Detect			
West Girls bathroom faucet (east)	05581100-039BF	1/19/2023	ND	Non-Detect			
Room #1 faucet	05581100-040CF	1/19/2023	ND	Non-Detect			
Room #1 drinking fountain	05581100-041DW	1/19/2023	2.15	Low			
Room #2 faucet	05581100-042CF	1/19/2023	ND	Non-Detect			
Room #2 drinking fountain	05581100-043DW	1/19/2023	ND	Non-Detect			
Room #3 faucet	05581100-044CF	1/19/2023	ND	Non-Detect			
Room #3 drinking fountain	05581100-045DW	1/19/2023	ND	Non-Detect			
Room #4 faucet	05581100-046CF	1/19/2023	19.3	Action Req.	5/29/2025	2.02	Low
Room #4 drinking fountain	05581100-047DW	1/19/2023	ND	Non-Detect			
Gym bathroom faucet	05581100-048BF	1/19/2023	3.41	Low			
Gym drinking fountain	05581100-049DW	1/19/2023	ND	Non-Detect			
Gym bottle filler	05581100-050WB	1/19/2023	ND	Non-Detect			
Kitchen (west)	05581100-051KF	2/27/2023	ND	Non-Detect			
Kitchen (middle)	05581100-052KF	2/27/2023	ND	Non-Detect			
Kitchen (east)	05581100-053KF	2/27/2023	ND	Non-Detect			



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

March 14, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE: Springfield SD

Order No.: 2302879

Dear Terry Rutledge:

Analytical Laboratory Group received 50 sample(s) on 2/27/2023 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2302879

Date: 3/14/2023

CLIENT: Springfield School District #19

Project: Springfield SD

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Note: Samples for Lead analysis should be received by the laboratory and preserved with acid within fourteen days of collection. Most of these samples were collected on January 19, 2023 and received at the laboratory on February 27, 2023. The bottles were preserved with acid when they were received at the laboratory.

Original

WO#: 2302879
CLIENT: Springfield School District #19
Project: Springfield SD
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302879-001	Client Sample ID 05581100-001NS			Collection Date: 1/19/2023 5:42:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG

Lab ID: 2302879-002		Client Sample ID 05581100-002DW			Collection Date: 1/19/2023 5:43:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG

Lab ID: 2302879-003	Client Sample ID 05581100-003BF			Collection Date: 1/19/2023 5:50:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG

Lab ID: 2302879-004	Client Sample ID 05581100-004BF			Collection Date: 1/19/2023 5:50:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG

Lab ID: 2302879-005	Client Sample ID 05581100-005SF			Collection Date: 1/19/2023 5:51:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG

Lab ID: 2302879-006	Client Sample ID 05581100-006BF			Collection Date: 1/19/2023 5:56:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG

Lab ID: 2302879-007	Client Sample ID	05581100-007BF		Collection Date: 1/19/2023 5:56:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG

Lab ID: 2302879-008	Client Sample ID	05581100-008BF		Collection Date: 1/19/2023 5:57:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 2302879
CLIENT: Springfield School District #19
Project: Springfield SD
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302879-009 **Client Sample ID** 05581100-009BF **Collection Date:** 1/19/2023 5:59:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-010 **Client Sample ID** 05581100-010BF **Collection Date:** 1/19/2023 5:59:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-011 **Client Sample ID** 05581100-011BF **Collection Date:** 1/19/2023 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-012 **Client Sample ID** 05581100-012CF **Collection Date:** 1/19/2023 6:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-013 **Client Sample ID** 05581100-013DW **Collection Date:** 1/19/2023 6:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-014 **Client Sample ID** 05581100-014CF **Collection Date:** 1/19/2023 6:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-015 **Client Sample ID** 05581100-015DW **Collection Date:** 1/19/2023 6:07:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/10/2023 8:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2302879
CLIENT: Springfield School District #19
Project: Springfield SD
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302879-016	Client Sample ID	05581100-016CF			Collection Date: 1/19/2023 6:09:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-017	Client Sample ID 05581100-017DW			Collection Date: 1/19/2023 6:09:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-018	Client Sample ID 05581100-018CF			Collection Date: 1/19/2023 6:13:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.32	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-019	Client Sample ID 05581100-019DW			Collection Date: 1/19/2023 6:13:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.09	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-020	Client Sample ID 05581100-020BF			Collection Date: 1/19/2023 6:18:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-021	Client Sample ID 05581100-021BF			Collection Date: 1/19/2023 6:20:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-022	Client Sample ID 05581100-022BF			Collection Date: 1/19/2023 6:21:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.26	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-023	Client Sample ID	05581100-023BF			Collection Date: 1/19/2023 6:22:00 AM			
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.04	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 2302879
CLIENT: Springfield School District #19
Project: Springfield SD
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302879-024 **Client Sample ID** 05581100-024BF **Collection Date:** 1/19/2023 6:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-025 **Client Sample ID** 05581100-025BF **Collection Date:** 1/19/2023 6:23:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-026 **Client Sample ID** 05581100-026CF **Collection Date:** 1/19/2023 6:26:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-027 **Client Sample ID** 05581100-027DW **Collection Date:** 1/19/2023 6:27:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-028 **Client Sample ID** 05581100-028CF **Collection Date:** 2/27/2023 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-029 **Client Sample ID** 05581100-029DW **Collection Date:** 2/27/2023 5:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-030 **Client Sample ID** 05581100-030CF **Collection Date:** 1/19/2023 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	7.20	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS
------	-----------	------	------	------	--	-----	----------------------	----

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 2302879
CLIENT: Springfield School District #19
Project: Springfield SD
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302879-031	Client Sample ID 05581100-031DW	Collection Date: 1/19/2023 6:30:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-032	Client Sample ID 05581100-032CF	Collection Date: 1/19/2023 6:33:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	18.4	15.0	2.00	*	ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-033	Client Sample ID 05581100-033DW	Collection Date: 1/19/2023 6:34:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-034	Client Sample ID 05581100-034BF	Collection Date: 1/19/2023 6:38:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-035	Client Sample ID 05581100-035BF	Collection Date: 1/19/2023 6:38:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.19	15.0	2.00		ppb	3/11/2023 8:00:00 PM	AS

Lab ID: 2302879-036	Client Sample ID 05581100-036BF	Collection Date: 1/19/2023 6:38:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302879-037	Client Sample ID 05581100-037BF	Collection Date: 1/19/2023 6:45:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302879-038	Client Sample ID 05581100-038BF	Collection Date: 1/19/2023 6:45:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 2302879
CLIENT: Springfield School District #19
Project: Springfield SD
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302879-039 **Client Sample ID** 05581100-039BF **Collection Date:** 1/19/2023 6:46:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-040 **Client Sample ID** 05581100-040CF **Collection Date:** 1/19/2023 6:48:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-041 **Client Sample ID** 05581100-041DW **Collection Date:** 1/19/2023 6:48:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	2.15	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG
------	-----------	------	------	------	--	-----	----------------------	----

Lab ID: 2302879-042 **Client Sample ID** 05581100-042CF **Collection Date:** 1/19/2023 6:48:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-043 **Client Sample ID** 05581100-043DW **Collection Date:** 1/19/2023 6:52:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-044 **Client Sample ID** 05581100-044CF **Collection Date:** 1/19/2023 6:52:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Lab ID: 2302879-045 **Client Sample ID** 05581100-045DW **Collection Date:** 1/19/2023 6:55:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
----------	--------	--------	-----	-----	------	-------	---------------	---------

Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG
------	-----------	----	------	------	--	-----	----------------------	----

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2302879
CLIENT: Springfield School District #19
Project: Springfield SD
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302879-046	Client Sample ID 05581100-046CF	Collection Date: 1/19/2023 6:57:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	193	15.0	40.0	*	ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302879-047	Client Sample ID 05581100-047DW	Collection Date: 1/19/2023 6:57:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302879-048	Client Sample ID 05581100-048BF	Collection Date: 1/19/2023 7:00:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.41	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302879-049	Client Sample ID 05581100-049DW	Collection Date: 1/19/2023 7:02:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Lab ID: 2302879-050	Client Sample ID 05581100-050WB	Collection Date: 1/19/2023 7:02:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/12/2023 6:07:00 PM	KG

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2302879

Date: 3/14/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302879

14-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302879-001A	05581100-001NS	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302879-002A	05581100-002DW			Lead	A
	2302879-003A	05581100-003BF			Lead	A
	2302879-004A	05581100-004BF			Lead	A
	2302879-005A	05581100-005SF			Lead	A
	2302879-006A	05581100-006BF			Lead	A
	2302879-007A	05581100-007BF			Lead	A
	2302879-008A	05581100-008BF			Lead	A
	2302879-009A	05581100-009BF			Lead	A
	2302879-010A	05581100-010BF			Lead	A
	2302879-011A	05581100-011BF			Lead	A
	2302879-012A	05581100-012CF			Lead	A
	2302879-013A	05581100-013DW			Lead	A
	2302879-014A	05581100-014CF			Lead	A
	2302879-015A	05581100-015DW			Lead	A
	2302879-016A	05581100-016CF			Lead	A
	2302879-017A	05581100-017DW			Lead	A
	2302879-018A	05581100-018CF			Lead	A
	2302879-019A	05581100-019DW			Lead	A
	2302879-020A	05581100-020BF			Lead	A
	2302879-021A	05581100-021BF			Lead	A
	2302879-022A	05581100-022BF			Lead	A
	2302879-023A	05581100-023BF			Lead	A
	2302879-024A	05581100-024BF			Lead	A
	2302879-025A	05581100-025BF			Lead	A
	2302879-026A	05581100-026CF			Lead	A
	2302879-027A	05581100-027DW			Lead	A
	2302879-028A	05581100-028CF			Lead	A
	2302879-029A	05581100-029DW			Lead	A
	2302879-030A	05581100-030CF			Lead	A
	2302879-031A	05581100-031DW			Lead	A

ORELAP A Accredited

ACCRED

Original #2302879# v1

Page 11 of 17



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302879

14-Mar-23

Client: Springfield School District #19

Project: Springfield SD

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302879-032A	05581100-032CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302879-033A	05581100-033DW			Lead	A
	2302879-034A	05581100-034BF			Lead	A
	2302879-035A	05581100-035BF			Lead	A
	2302879-036A	05581100-036BF			Lead	A
	2302879-037A	05581100-037BF			Lead	A
	2302879-038A	05581100-038BF			Lead	A
	2302879-039A	05581100-039BF			Lead	A
	2302879-040A	05581100-040CF			Lead	A
	2302879-041A	05581100-041DW			Lead	A
	2302879-042A	05581100-042CF			Lead	A
	2302879-043A	05581100-043DW			Lead	A
	2302879-044A	05581100-044CF			Lead	A
	2302879-045A	05581100-045DW			Lead	A
	2302879-046A	05581100-046CF			Lead	A
	2302879-047A	05581100-047DW			Lead	A
	2302879-048A	05581100-048BF			Lead	A
	2302879-049A	05581100-049DW			Lead	A
	2302879-050A	05581100-050WB			Lead	A

ACCRED
ORELAP A Accredited

Original #2302879# v1

Page 12 of 17



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: MT

Checked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield SD		Sampler Name: Veronica Arciga	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05581100-001NS	DW/Grab	1/19/23	542	Lead	P	1		N/A	001A
05581100-002DW	DW/Grab	1/19	543	Lead	P	1			002A
05581100-003BF	DW/Grab	1/19	550	Lead	P	1			003A
05581100-004BF	DW/Grab	1/19	550	Lead	P	1			004A
05581100-005SF	DW/Grab	1/19	551	Lead	P	1			005A
05581100-006BF	DW/Grab	1/19	556	Lead	P	1			006A
05581100-007BF	DW/Grab	1/19	556	Lead	P	1			007A
05581100-008BF	DW/Grab	1/19	557	Lead	P	1			008A
05581100-009BF	DW/Grab	1/19	559	Lead	P	1			009A
05581100-010BF	DW/Grab	1/19	559	Lead	P	1			010A

Notes:	PAID	Preservation Check			
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH
	CC				
	CK				
	Cash				
	REPORT				
	Mail				
	Email				
	Fax				
	Pickup				

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: Veronica Arciga		Refrigerated	
					Ice	None
Relinquished by: Veronica Arciga	Date 2/27	Time 0800	Received by:		Date	Time
Relinquished by:	Date	Time			Date	Time
Relinquished by:	Date	Time	Received by Laboratory:		Date	Time
					2/27/23	08:00



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: M1

Checked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05581100-011BF	DW/Grab	1/19	0600	Lead	P	1		WA	011A
05581100-012CF	DW/Grab	1/19	0603	Lead	P	1			012A
05581100-013DW	DW/Grab	1/19	0603	Lead	P	1			013A
05581100-014CF	DW/Grab	1/19	0606	Lead	P	1			014A
05581100-015DW	DW/Grab	1/19	0607	Lead	P	1			015A
05581100-016CF	DW/Grab	1/19	609	Lead	P	1			016A
05581100-017DW	DW/Grab	1/19	609	Lead	P	1			017A
05581100-018CF	DW/Grab	1/19	613	Lead	P	1			018A
05581100-019DW	DW/Grab	1/19	613	Lead	P	1			019A
05581100-020BF	DW/Grab	1/19	618	Lead	P	1			020A

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: <u>Veronica Arciga</u>		Refrigerated	
					Ice	<u>None</u>
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/27</u>	<u>0800</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	<u>2/27/23</u>	<u>08:00</u>	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: MTChecked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge		Company: Springfield School District #19	
Phone: (541) 744-6375		Address: 1890 North 42nd Street	
Email: terry.rutledge@springfield.k12.or.us		City, State, Zip: Springfield Or, 97477	
Client Project: Springfield SD		Sampler Name: <u>Veronica Arciga</u>	

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05581100-021BF	DW/Grab	1-19	620	Lead	P	1		N/A	021A
05581100-022BF	DW/Grab	1-19	621	Lead	P	1		↓	022A
05581100-023BF	DW/Grab	1-19	622	Lead	P	1			023A
05581100-024BF	DW/Grab	1-19	622	Lead	P	1			024A
05581100-025BF	DW/Grab	1-19	623	Lead	P	1			025A
05581100-026CF	DW/Grab	1-19	626	Lead	P	1			026A
05581100-027DW	DW/Grab	1-19	627	Lead	P	1			027A
05581100-028CF	DW/Grab	2/27	0518	Lead	P	1			028A
05581100-029DW	DW/Grab	2/27	0518	Lead	P	1			029A
05581100-030CF	DW/Grab	1-19	0630	Lead	P	1		030A	

Notes: <u>1 bottle at used by client. MT 2/27/23</u>	PAID		Preservation Check				
	Receipt #		Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC						
	CK						
	Cash						
	REPORT						
	Mail						
	Email						
Fax							
Pickup							

Turn Around Time Requested (Rush incurs a Surcharge): ☒ NORMAL ☐ RUSH			Shipped Via: <u>Veronica Arciga</u>		Refrigerated Ice ☒ None	
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	<u>2/27</u>	<u>0800</u>				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	<u>2/27/23</u>	<u>08:00</u>	



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: MT

Checked: CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05581100-031DW	DW/Grab	1/19	630	Lead	P	1		W/A	031A
05581100-032CF	DW/Grab	1/19	633*	Lead	P	1			032A
05581100-033DW	DW/Grab	1/19	634*	Lead	P	1			033A
05581100-034BF	DW/Grab	1/19	638*	Lead	P	1			034A
05581100-035BF	DW/Grab	1/19	638*	Lead	P	1			035A
05581100-036BF	DW/Grab	1/19	638*	Lead	P	1			036A
05581100-037BF	DW/Grab	1/19	645*	Lead	P	1			037A
05581100-038BF	DW/Grab	1/19	645*	Lead	P	1			038A
05581100-039BF	DW/Grab	1/19	646*	Lead	P	1			039A
05581100-040CF	DW/Grab	1/19	648*	Lead	P	1			040A

Notes: <u>Unk. not used by client. MT 2/27/23</u>	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	<u>Veronica Arciga</u>	Ice ☐ None ☒
Relinquished by:	Received by:	Date Time
<u>Veronica Arciga</u>		2/27 0800
Relinquished by:	Received by:	Date Time
Relinquished by:	Received by Laboratory:	Date Time
	<u>[Signature]</u>	2/27/23 08:00



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

MT

CB

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: Veronica Arciza

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05581100-041DW	DW/Grab	1/19	6:48*	Lead	P	1		NA	041A
05581100-042CF	DW/Grab	1/19	6:48*	Lead	P	1			042A
05581100-043DW	DW/Grab	1/19	6:52*	Lead	P	1			043A
05581100-044CF	DW/Grab	1/19	6:52*	Lead	P	1			044A
05581100-045DW	DW/Grab	1/19	6:55*	Lead	P	1			045A
05581100-046CF	DW/Grab	1/19	6:57*	Lead	P	1			046A
05581100-047DW	DW/Grab	1/19	6:57*	Lead	P	1			047A
05581100-048BF	DW/Grab	1/19	7:00	Lead	P	1			048A
05581100-049DW	DW/Grab	1/19	7:02	Lead	P	1			049A
05581100-050WB	DW/Grab	1/19	7:02	Lead	P	1		V	050A

Notes: * White oak used by client. mt 2/27/13	PAID	Preservation Check				
Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech	
CC						
CK						
Cash						
REPORT						
Mail						
Email						
Fax						
Pickup						

Turn Around Time Requested (Rush incurs a Surcharge):	Shipped Via:	Refrigerated
☒ NORMAL ☐ RUSH	Veronica Arciza	Ice ☐ None ☒
Relinquished by: Veronica Arciza	Received by:	Date: 2/27/13 Time: 08:00
Relinquished by:	Received by:	Date: Time:
Relinquished by:	Received by Laboratory:	Date: 2/27/13 Time: 08:00



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

March 03, 2023

Terry Rutledge
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 915-8278
FAX:

RE:

Order No.: 2302882

Dear Terry Rutledge:

Analytical Laboratory Group received 3 sample(s) on 2/27/2023 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401

K. A. Herveville



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2302882

Date: 3/3/2023

CLIENT: Springfield School District #19

Project:

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported: 3/3/2023

WO#: 2302882
CLIENT: Springfield School District #19
Project:
PWS Number:
Sample Source:

Received Date: 2/27/2023 8:00:00 AM
Sampler Name: Veronica Arciga
Matrix: Drinking Water
Sample Type:

Lab ID: 2302882-001 Client Sample ID 05581100-051KF Collection Date: 2/27/2023 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/1/2023 3:00:00 PM	AS

Lab ID: 2302882-002 Client Sample ID 05581100-052KF Collection Date: 2/27/2023 5:24:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/1/2023 3:00:00 PM	AS

Lab ID: 2302882-003 Client Sample ID 05581100-053KF Collection Date: 2/27/2023 5:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	3/1/2023 3:00:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2302882

Date: 3/3/2023

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave
Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2302882

03-Mar-23

Client: Springfield School District #19

Project:

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2302882-001A	05581100-051KF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2302882-002A	05581100-052KF			Lead	A
	2302882-003A	05581100-053KF			Lead	A

ACCRED

ORELAP A Accredited

Original #2302882# v1

Page 5 of 6



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS: MS

Checked: MS

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: Terry Rutledge	Company: Springfield School District #19
Phone: (541) 744-6375	Address: 1890 North 42nd Street
Email: terry.rutledge@springfield.k12.or.us	City, State, Zip: Springfield Or, 97477
Client Project: Springfield SD	Sampler Name: <u>Veronica Arciga</u>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05581100-051KF	DW/Grab	2/27	0522	Lead	P	1		N/A	001A
05581100-052KF	DW/Grab	2/27	0524	Lead	P	1			002A
05581100-053KF	DW/Grab	2/27	0522	Lead	P	1			003A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			<u>Veronica Arciga</u>		Ice	☒ None
Relinquished by:	Date	Time	Received by:	Date	Time	
<u>Veronica Arciga</u>	2/27	0800				
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<u>[Signature]</u>	2/27/23	08:00	



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

June 02, 2025

John Harshberger
Springfield School District #19
1890 North 42nd Street
Springfield, OR 97477
TEL: (541) 979-9667
FAX:

RE: Springfield SD 19 - Walterville Elementary S

Order No.: 2505927

Dear John Harshberger:

Analytical Laboratory Group received 1 sample(s) on 5/29/2025 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: 2505927

Date: 6/2/2025

CLIENT: Springfield School District #19
Project: Springfield SD 19 - Walterville Elementary Sch

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

Original

WO#: 2505927
CLIENT: Springfield School District #19
Location:
Project: Springfield SD 19 - Walterville Elementary Sch
Sample Source:

Received Date: 5/29/2025 8:01:00 AM
Sampler Name Mario Rodriguez
Matrix: Drinking Water
Treatment:

Lab ID: 2505927-001	Client Sample ID	05581100-046CF		Collection Date: 5/29/2025 7:03:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.02	15.0	2.00		ppb	5/30/2025 4:03:00 PM	AS

Qualifiers:	*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
	C	Value is below Minimum Compound Limit.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
	MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Level or Reporting Limit	R	RPD outside accepted recovery limits



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2505927

Date: 6/2/2025

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2505927

02-Jun-25

Client: Springfield School District #19

Project: Springfield SD 19 - Walterville Element

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2505927-001A	05581100-046CF	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A

ACCRED

ORELAP A Accredited

Original #2505927# v1

Page 5 of 6



Delivering more than
just test results

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401

Phone: 541-485-8404 Fax: 541-484-5995

Email: alglabs@alglabsinc.com

LIMS:

Checked:

MTT
BN

CHAIN OF CUSTODY - FIRST DRAW LEAD

Report to: John Harshberger	Company: Springfield School District
Phone: (541) 979-9667	Address: 1890 North 42nd Street
Email: john.harshberger@springfield.k12.or.us	City, State, Zip: Springfield, OR 97477
Client: <i>SPRINGFIELD SD 19</i> Project: <i>WATERVILLE ELEMENTARY SCHOOL</i>	Sampler Name: <i>MARIO RODRIGUEZ</i>

Sample Point	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
05581100-046CF	DW/Grab	5.29.25	07:03	Lead	P	1		NA	001A
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			
	DW/Grab			Lead	P	1			

Notes:	PAID	Preservation Check				
	Receipt #	Lab ID	Date/Time	Pre-Preserved	pH	Tech
	CC					
	CK					
	Cash					
	REPORT					
	Mail					
	Email					
	Fax					
	Pickup					

Turn Around Time Requested (Rush incurs a Surcharge):			Shipped Via:		Refrigerated	
☒ NORMAL ☐ RUSH			Mario		Ice	IR
					None	IR NA
Relinquished by:	Date	Time	Received by:	Date	Time	
<i>Mario Rodriguez</i>	5.29.25					
Relinquished by:	Date	Time	Received by:	Date	Time	
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time	
			<i>[Signature]</i>	5/29/25	8:01	