# Lead in Water Test Results Summary: Mt.Vernon Elementary School

**Notes:**

• **The lead in water Action Level is 15 parts per billion (ppb).**

***Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.***

• A "**ND**" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

**Legend:**

• Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.

• Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.

• Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.

• Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

| Fixture Location Description | Fixture ID # | Initial Test Date | Initial Test Result (ppb) | Initial Level | Final Retest Date | Final Test Result (ppb) | Final Level |
|---|---|---|---|---|---|---|---|
| Kitchen Sink Food Prep | 20830900-001KF | 5/21/2026 | ND | Non-Detect | *[enter date]* | *[enter result]* | *[autofill]* |
| Kitchen Sink Sprayer | 20830900-002KF | 5/21/2026 | ND | Non-Detect | | | |
| Kitchen Handwash Station | 20830900-003KF | 5/21/2026 | 1.3 | Low | | | |
| Kitchen Bathroom Faucet | 20830900-004BF | 5/21/2026 | 2.9 | Low | | | |
| Kitchen Faucet (Dishwasher) | 20830900-005KF | 5/21/2026 | ND | Non-Detect | | | |
| Kitchen Faucet sprayer Dishwasher | 20830900-006KF | 5/21/2026 | ND | Non-Detect | | | |
| Water Bottle Fill | 20830900-007WB | 5/21/2026 | ND | Non-Detect | | | |
| Drinking Fountain (With Bottle Fill) | 20830900-008DW | 5/21/2026 | ND | Non-Detect | | | |
| Drinking Fountain (Without Bottle Fill) | 20830900-009DW | 5/21/2026 | ND | Non-Detect | | | |
| Boys Bradley Bathroom Faucet #1 (Far Left) | 20830900-010BF | 5/21/2026 | 1.3 | Low | | | |
| Boys Bradley Bathroom Faucet #2 (Left of Center) | 20830900-011BF | 5/21/2026 | ND | Non-Detect | | | |
| Boys Bradley Bathroom Faucet #3 | 20830900-012BF | NOT IN USE | | | | | |
| Boys Bradley Bathroom Faucet #4 (Far Right) | 20830900-013BF | NOT IN USE | | | | | |
| Girl's Bradley Bathroom Faucet #1 (Far Left) | 20830900-014BF | 5/21/2026 | 1.4 | Low | | | |
| Girl's Bradley Bathroom Faucet #2 | 20830900-015BF | NOT IN USE | | | | | |
| Center) | 20830900-016BF | 5/21/2026 | 1.2 | Low | | | |
| Girl's Bradley Bathroom Faucet #4 (Far Right) | 20830900-017BF | 5/21/2026 | 1.2 | Low | | | |
| Room 203 Faucet (In Library) | 20830900-018SF | 5/21/2026 | 2.2 | Low | | | |
| A Wing, Boys Bathroom Faucet #1 (Far Left) | 20830900-019BF | 5/21/2026 | 2.4 | Low | | | |
| A Wing, Boys Bathroom Faucet #2 (Left of Center) | 20830900-020BF | 5/21/2026 | ND | Non-Detect | | | |
| A Wing, Boys Bathroom Faucet #3 | 20830900-021BF | NOT IN USE | | | | | |
| A Wing, Boys Bathroom Faucet #4 (Far Right) | 20830900-022BF | 5/21/2026 | 2.1 | Low | | | |
| Middle Island Faucet | 20830900-023CF | 5/21/2026 | 1.3 | Low | | | |
| Middle Island Drinkng Fountain | 20830900-024DW | 5/21/2026 | 2 | Low | | | |
| Classroom A 101 Faucet | 20830900-025CF | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 101 Drinking Fountain | 20830900-026DW | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 102 Faucet | 20830900-027CF | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 102 Drinking Fountain | 20830900-028DW | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 103 Faucet | 20830900-029CF | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 103 Drinking Fountain | 20830900-030DW | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 104 Faucet | 20830900-031CF | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 104 Drinking Fountain | 20830900-032DW | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 105 Faucet | 20830900-033CF | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 105 Drinking Fountain | 20830900-034DW | 5/21/2026 | 5.3 | Moderate | | | |
| Classroom A 106 Faucet | 20830900-035CF | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 106 Drinking Fountain | 20830900-036DW | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 107 Faucet | 20830900-037CF | 5/21/2026 | 1.4 | Low | | | |
| Classroom A 107 Drinking Fountain | 20830900-038DW | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 108 Faucet | 20830900-039CF | 5/21/2026 | ND | Non-Detect | | | |
| Classroom A 108 Drinking Fountain | 20830900-040DW | 5/21/2026 | ND | Non-Detect | | | |
| A Wing, Girls Bathroom Faucet #1 (Far Left) | 20830900-041BF | 5/21/2026 | 1.8 | Low | | | |
| A Wing, Girls Bathroom Faucet #2 | 20830900-042BF | NOT IN USE | | | | | |
| Center) | 20830900-043BF | 5/21/2026 | ND | Non-Detect | | | |
| A Wing, Girls Bathroom Faucet #4 (Far Right) | 20830900-044BF | NOT IN USE | | | | | |
| Staff Room Bathroom Faucet | 20830900-045BF | 5/21/2026 | ND | Non-Detect | | | |
| B, Wing Classroom B 215 Faucet | 20830900-046CF | 5/21/2026 | ND | Non-Detect | | | |
| B, Wing Classroom B 215 Drinking Fountain | 20830900-047DW | NOT IN USE | | | | | |
| Room 214 Bathroom Faucet | 20830900-048BF | 5/21/2026 | ND | Non-Detect | | | |
| B Wing, Boys Bathroom Faucet #1 | 20830900-049BF | 5/21/2026 | 2 | Low | | | |
| B Wing, Boys Bathroom Faucet #2 | 20830900-050BF | NOT IN USE | | | | | |

| | | | | |
|---|---|---|---|---|
| B Wing, Boys Bathroom Faucet #3 | 20830900-051BF | NOT IN USE | | |
| B Wing, Boys Bathroom Faucet #4 | 20830900-052BF | 5/21/2026 | 1.6 | Low |
| Middle Island Faucet | 20830900-053CF | 5/21/2026 | ND | Non-Detect |
| Middle Island Drinkng Fountain | 20830900-054DW | 5/21/2026 | ND | Non-Detect |
| Classroom B 101 Faucet | 20830900-055CF | 5/21/2026 | ND | Non-Detect |
| Classroom B 101 Drinking Fountain | 20830900-056DW | 5/21/2026 | ND | Non-Detect |
| Classroom B 102 Faucet | 20830900-057CF | 5/21/2026 | ND | Non-Detect |
| Classroom B 102 Drinking Fountain | 20830900-058DW | 5/21/2026 | ND | Non-Detect |
| Classroom B 103 Faucet | 20830900-059CF | 5/21/2026 | ND | Non-Detect |
| Classroom B 103 Drinking Fountain | 20830900-060DW | 5/21/2026 | ND | Non-Detect |
| Classroom B 106 Faucet | 20830900-061CF | 5/21/2026 | ND | Non-Detect |
| Classroom B 106 Drinking Fountain | 20830900-062DW | 5/21/2026 | ND | Non-Detect |
| Classroom B 107 Faucet | 20830900-063CF | 5/21/2026 | ND | Non-Detect |
| Classroom B 107 Drinking Fountain | 20830900-064DW | 5/21/2026 | ND | Non-Detect |
| Classroom B 108 Faucet | 20830900-065CF | 5/21/2026 | ND | Non-Detect |
| Classroom B 108 Drinking Fountain | 20830900-066DW | 5/21/2026 | ND | Non-Detect |
| B Wing, Girls Bathroom Faucet #1 (Far Left) | 20830900-067BF | 5/21/2026 | 1.7 | Low |
| B Wing, Girls Bathroom Faucet #2 | 20830900-068BF | NOT IN USE | | |
| B Wing, Girls Bathroom Faucet #3 | 20830900-069BF | NOT IN USE | | |
| B Wing, Girls Bathroom Faucet #4 (Far Right) | 20830900-070BF | 5/21/2026 | ND | Non-Detect |
| Classroom B 220 Faucet | 20830900-071CF | 5/21/2026 | ND | Non-Detect |
| Staff Restroom Faucet (C Wing) | 20830900-072BF | 5/21/2026 | 3.3 | Low |
| Classroom B 225 Faucet | 20830900-073CF | 5/21/2026 | ND | Non-Detect |
| C Wing, Girls Bathroom Faucet #1 (Far Left) | 20830900-074BF | 5/21/2026 | 1.7 | Low |
| C Wing, Girls Bathroom Faucet #2 | 20830900-075BF | 5/21/2026 | 1.4 | Low |
| C Wing, Girls Bathroom Faucet #3 | 20830900-076BF | 5/21/2026 | 1.2 | Low |
| C Wing, Girls Bathroom Faucet #4 (Far Right) | 20830900-077BF | 5/21/2026 | ND | Non-Detect |
| Middle Island Faucet | 20830900-078CF | 5/21/2026 | ND | Non-Detect |
| Middle Island Drinkng Fountain | 20830900-079DW | 5/21/2026 | ND | Non-Detect |
| Classroom C 101 Faucet | 20830900-080CF | 5/21/2026 | 5 | Low |
| Classroom C 101 Drinking Fountain | 20830900-081DW | 5/21/2026 | ND | Non-Detect |
| Classroom C 102 Faucet | 20830900-082CF | 5/21/2026 | ND | Non-Detect |
| Classroom C 102 Drinking Fountain | 20830900-083DW | 5/21/2026 | ND | Non-Detect |
| Classroom C 103 Faucet | 20830900-084CF | 5/21/2026 | ND | Non-Detect |
| Classroom C 103 Drinking Fountain | 20830900-085DW | 5/21/2026 | ND | Non-Detect |
| Classroom C 104 Faucet | 20830900-086CF | 5/21/2026 | ND | Non-Detect |
| Classroom C 104 Drinking Fountain | 20830900-087DW | 5/21/2026 | ND | Non-Detect |
| Classroom C 105 Faucet | 20830900-088CF | 5/21/2026 | ND | Non-Detect |
| Classroom C 105 Drinking Fountain | 20830900-089DW | 5/21/2026 | ND | Non-Detect |
| Classroom C 106 Faucet | 20830900-090CF | 5/21/2026 | ND | Non-Detect |
| Classroom C 106 Drinking Fountain | 20830900-091DW | 5/21/2026 | ND | Non-Detect |
| Classroom C 107 Faucet | 20830900-092CF | 5/21/2026 | ND | Non-Detect |
| Classroom C 107 Drinking Fountain | 20830900-093DW | 5/21/2026 | ND | Non-Detect |
| Classroom C 108 Faucet | 20830900-094CF | 5/21/2026 | ND | Non-Detect |
| Classroom C 108 Drinking Fountain | 20830900-095DW | 5/21/2026 | ND | Non-Detect |
| C Wing, Boys Bathroom Faucet #1 (Far Left) | 20830900-096BF | 5/21/2026 | 1.9 | Low |
| C Wing, Boys Bathroom Faucet #2 (Left of Center) | 20830900-097BF | 5/21/2026 | ND | Non-Detect |
| C Wing, Boys Bathroom Faucet #3 | 20830900-098BF | NOT IN USE | | |
| C Wing, Boys Bathroom Faucet #4 (Far Right) | 20830900-099BF | 5/21/2026 | ND | Non-Detect |
| Drinking Fountain (Outside Staff Room) | 20830900-100DW | 5/21/2026 | ND | Non-Detect |
| Staff Room Faucet | 20830900-101SF | 5/21/2026 | ND | Non-Detect |
| Staff Room Insta Hot | 20830900-102OT | 5/21/2026 | ND | Non-Detect |
| Staff Bathroom Faucet (Right) | 20830900-103BF | 5/21/2026 | ND | Non-Detect |
| Staff Bathroom Faucet (Left) | 20830900-104BF | 5/21/2026 | ND | Non-Detect |
| Staff Work Room Faucet | 20830900-105SF | 5/21/2026 | ND | Non-Detect |
| Office Health Room Faucet (Room 240) | 20830900-106NS | 5/21/2026 | ND | Non-Detect |
| Office Health Room Eyewash Sprayer | 20830900-107OT | 5/21/2026 | 12.8 | **High** |
| Bathroom Faucet Room 240 | 20830900-108BF | 5/21/2026 | ND | Non-Detect |

**UMPQUA Research Company**
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

# ANALYSIS REPORT
## URC # 6052619

| | | |
|---|---|---|
| Springfield Public Schools | Project: Lead Testing | Date Reported: 06/18/26 |
| 1890 42nd Street | Project #: Mt. Vernon Elementary School | Date Received: 05/26/26 13:00 |
| Springfield, OR 97477 | | Sampled By: Mario Rodriguez |
| | Client Contact: John Harshberger | |
| | - | |

**Method: USEPA 200.8** Matrix: Drinking Water

| | Sample Location | Code | Result | Units | MRL | MCL | Sampled | Analyzed | Analyst | Qualifier |
|---|---|---|---|---|---|---|---|---|---|---|
| 6052619-01 | Sample Location: 20830900 001KF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:08 | 06/10/26 | DST | |
| 6052619-02 | Sample Location: 20830900 002KF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:09 | 06/10/26 | DST | |
| 6052619-03 | Sample Location: 20830900 003KF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.3 | ppb | 1.0 | 15 | 05/21/26 05:09 | 06/10/26 | DST | |
| 6052619-04 | Sample Location: 20830900 004BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 2.9 | ppb | 1.0 | 15 | 05/21/26 05:10 | 06/10/26 | DST | |
| 6052619-05 | Sample Location: 20830900 005KF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:11 | 06/10/26 | DST | |
| 6052619-06 | Sample Location: 20830900 006KF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:11 | 06/10/26 | DST | |
| 6052619-07 | Sample Location: 20830900 007WB | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:13 | 06/10/26 | DST | |
| 6052619-08 | Sample Location: 20830900 008DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:14 | 06/10/26 | DST | |
| 6052619-09 | Sample Location: 20830900 009DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:14 | 06/10/26 | DST | |
| 6052619-10 | Sample Location: 20830900 010BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.3 | ppb | 1.0 | 15 | 05/21/26 05:15 | 06/10/26 | DST | |
| 6052619-11 | Sample Location: 20830900 011BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:15 | 06/10/26 | DST | |
| 6052619-12 | Sample Location: 20830900 014BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.4 | ppb | 1.0 | 15 | 05/21/26 05:17 | 06/10/26 | DST | |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

**UMPQUA Research Company**
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

# ANALYSIS REPORT
## URC # 6052619

**Method: USEPA 200.8** Matrix: Drinking Water

| | Sample Location | Code | Result | Units | MRL | MCL | Sampled | Analyzed | Analyst | Qualifier |
|---|---|---|---|---|---|---|---|---|---|---|
| 6052619-13 | Sample Location: 20830900 016BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.2 | ppb | 1.0 | 15 | 05/21/26 05:19 | 06/10/26 | DST | |
| 6052619-14 | Sample Location: 20830900 017BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.2 | ppb | 1.0 | 15 | 05/21/26 05:19 | 06/10/26 | DST | |
| 6052619-15 | Sample Location: 20830900 018SF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 2.2 | ppb | 1.0 | 15 | 05/21/26 05:20 | 06/10/26 | DST | |
| 6052619-16 | Sample Location: 20830900 019BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 2.4 | ppb | 1.0 | 15 | 05/21/26 05:22 | 06/10/26 | DST | |
| 6052619-17 | Sample Location: 20830900 020BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:23 | 06/10/26 | DST | |
| 6052619-18 | Sample Location: 20830900 022BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 2.1 | ppb | 1.0 | 15 | 05/21/26 05:24 | 06/10/26 | DST | |
| 6052619-19 | Sample Location: 20830900 023CF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.3 | ppb | 1.0 | 15 | 05/21/26 05:25 | 06/11/26 | DST | |
| 6052619-20 | Sample Location: 20830900 024DW | | | | | | | | | |
| **Lead (‡)** | | 1030 | 2.0 | ppb | 1.0 | 15 | 05/21/26 05:25 | 06/11/26 | DST | |
| 6052619-21 | Sample Location: 20830900 025CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:27 | 06/11/26 | DST | |
| 6052619-22 | Sample Location: 20830900 026DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:27 | 06/11/26 | DST | |
| 6052619-23 | Sample Location: 20830900 027CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:28 | 06/11/26 | DST | |
| 6052619-24 | Sample Location: 20830900 028DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:28 | 06/11/26 | DST | |
| 6052619-25 | Sample Location: 20830900 029CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:30 | 06/11/26 | DST | |
| 6052619-26 | Sample Location: 20830900 030DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:30 | 06/11/26 | DST | |
| 6052619-27 | Sample Location: 20830900 031CF | | | | | | | | | |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

**UMPQUA Research Company**
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

# ANALYSIS REPORT
## URC # 6052619

**Method: USEPA 200.8** Matrix: Drinking Water

| | Sample Location | Code | Result | Units | MRL | MCL | Sampled | Analyzed | Analyst | Qualifier |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:31 | 06/11/26 | DST | |
| 6052619-28 | Sample Location: 20830900 032DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:32 | 06/11/26 | DST | |
| 6052619-29 | Sample Location: 20830900 033CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:33 | 06/11/26 | DST | |
| 6052619-30 | Sample Location: 20830900 034DW | | | | | | | | | |
| **Lead (‡)** | | 1030 | 5.3 | ppb | 1.0 | 15 | 05/21/26 05:33 | 06/11/26 | DST | |
| 6052619-31 | Sample Location: 20830900 035CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:35 | 06/17/26 | DST | |
| 6052619-32 | Sample Location: 20830900 036DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:35 | 06/11/26 | DST | |
| 6052619-33 | Sample Location: 20830900 037CF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.4 | ppb | 1.0 | 15 | 05/21/26 05:36 | 06/11/26 | DST | |
| 6052619-34 | Sample Location: 20830900 038DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:36 | 06/11/26 | DST | |
| 6052619-35 | Sample Location: 20830900 039CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:38 | 06/11/26 | DST | |
| 6052619-36 | Sample Location: 20830900 040DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:38 | 06/11/26 | DST | |
| 6052619-37 | Sample Location: 20830900 041BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.8 | ppb | 1.0 | 15 | 05/21/26 05:40 | 06/11/26 | DST | |
| 6052619-38 | Sample Location: 20830900 043BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:41 | 06/11/26 | DST | |
| 6052619-39 | Sample Location: 20830900 045BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:42 | 06/11/26 | DST | |
| 6052619-40 | Sample Location: 20830900 046CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:43 | 06/11/26 | DST | |
| 6052619-41 | Sample Location: 20830900 048BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:44 | 06/11/26 | DST | |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

**UMPQUA Research Company**
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

# ANALYSIS REPORT
## URC # 6052619

**Method: USEPA 200.8** Matrix: Drinking Water

| | Sample Location | Code | Result | Units | MRL | MCL | Sampled | Analyzed | Analyst | Qualifier |
|---|---|---|---|---|---|---|---|---|---|---|
| 6052619-42 | Sample Location: 20830900 049BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 2.0 | ppb | 1.0 | 15 | 05/21/26 05:45 | 06/11/26 | DST | |
| 6052619-43 | Sample Location: 20830900 052BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.6 | ppb | 1.0 | 15 | 05/21/26 05:47 | 06/11/26 | DST | |
| 6052619-44 | Sample Location: 20830900 053CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:48 | 06/11/26 | DST | |
| 6052619-45 | Sample Location: 20830900 054DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:49 | 06/11/26 | DST | |
| 6052619-46 | Sample Location: 20830900 055CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:50 | 06/11/26 | DST | |
| 6052619-47 | Sample Location: 20830900 056DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:50 | 06/11/26 | DST | |
| 6052619-48 | Sample Location: 20830900 057CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:51 | 06/11/26 | DST | |
| 6052619-49 | Sample Location: 20830900 058DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:51 | 06/11/26 | DST | |
| 6052619-50 | Sample Location: 20830900 059CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:52 | 06/11/26 | DST | |
| 6052619-51 | Sample Location: 20830900 060DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:52 | 06/11/26 | DST | |
| 6052619-52 | Sample Location: 20830900 061CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:54 | 06/11/26 | DST | |
| 6052619-53 | Sample Location: 20830900 062DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:55 | 06/11/26 | DST | |
| 6052619-54 | Sample Location: 20830900 063CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:56 | 06/11/26 | DST | |
| 6052619-55 | Sample Location: 20830900 064DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:56 | 06/11/26 | DST | |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

**UMPQUA Research Company**
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

# ANALYSIS REPORT
## URC # 6052619

**Method: USEPA 200.8** Matrix: Drinking Water

| | Sample Location | Code | Result | Units | MRL | MCL | Sampled | Analyzed | Analyst | Qualifier |
|---|---|---|---|---|---|---|---|---|---|---|
| 6052619-56 | Sample Location: 20830900 065CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:57 | 06/11/26 | DST | |
| 6052619-57 | Sample Location: 20830900 066DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:58 | 06/11/26 | DST | |
| 6052619-58 | Sample Location: 20830900 067BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.7 | ppb | 1.0 | 15 | 05/21/26 05:59 | 06/11/26 | DST | |
| 6052619-59 | Sample Location: 20830900 070BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:59 | 06/11/26 | DST | |
| 6052619-60 | Sample Location: 20830900 071CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 05:59 | 06/11/26 | DST | |
| 6052619-61 | Sample Location: 20830900 072BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 3.3 | ppb | 1.0 | 15 | 05/21/26 06:02 | 06/11/26 | DST | |
| 6052619-62 | Sample Location: 20830900 073CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:03 | 06/11/26 | DST | |
| 6052619-63 | Sample Location: 20830900 074BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.7 | ppb | 1.0 | 15 | 05/21/26 06:04 | 06/11/26 | DST | |
| 6052619-64 | Sample Location: 20830900 075BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.4 | ppb | 1.0 | 15 | 05/21/26 06:05 | 06/11/26 | DST | |
| 6052619-65 | Sample Location: 20830900 076BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.2 | ppb | 1.0 | 15 | 05/21/26 06:06 | 06/11/26 | DST | |
| 6052619-66 | Sample Location: 20830900 077BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:06 | 06/11/26 | DST | |
| 6052619-67 | Sample Location: 20830900 078CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:08 | 06/11/26 | DST | |
| 6052619-68 | Sample Location: 20830900 079DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:08 | 06/11/26 | DST | |
| 6052619-69 | Sample Location: 20830900 080CF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 5.0 | ppb | 1.0 | 15 | 05/21/26 06:10 | 06/11/26 | DST | |
| 6052619-70 | Sample Location: 20830900 081DW | | | | | | | | | |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

**UMPQUA Research Company**
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

# ANALYSIS REPORT
## URC # 6052619

**Method: USEPA 200.8** Matrix: Drinking Water

| | Sample Location | Code | Result | Units | MRL | MCL | Sampled | Analyzed | Analyst | Qualifier |
|---|---|---|---|---|---|---|---|---|---|---|
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:10 | 06/11/26 | DST | |
| 6052619-71 | Sample Location: 20830900 082CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:12 | 06/11/26 | DST | |
| 6052619-72 | Sample Location: 20830900 083DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:12 | 06/11/26 | DST | |
| 6052619-73 | Sample Location: 20830900 084CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:13 | 06/11/26 | DST | |
| 6052619-74 | Sample Location: 20830900 085DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:13 | 06/11/26 | DST | |
| 6052619-75 | Sample Location: 20830900 086CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:15 | 06/11/26 | DST | |
| 6052619-76 | Sample Location: 20830900 087DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:15 | 06/11/26 | DST | |
| 6052619-77 | Sample Location: 20830900 088CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:16 | 06/11/26 | DST | |
| 6052619-78 | Sample Location: 20830900 089DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:16 | 06/11/26 | DST | |
| 6052619-79 | Sample Location: 20830900 090CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:17 | 06/11/26 | DST | |
| 6052619-80 | Sample Location: 20830900 091DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:18 | 06/11/26 | DST | |
| 6052619-81 | Sample Location: 20830900 092CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:19 | 06/11/26 | DST | |
| 6052619-82 | Sample Location: 20830900 093DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:19 | 06/11/26 | DST | |
| 6052619-83 | Sample Location: 20830900 094CF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:20 | 06/11/26 | DST | |
| 6052619-84 | Sample Location: 20830900 095DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:20 | 06/11/26 | DST | |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

**UMPQUA Research Company**
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

# ANALYSIS REPORT
## URC # 6052619

**Method: USEPA 200.8** Matrix: Drinking Water

| | Sample Location | Code | Result | Units | MRL | MCL | Sampled | Analyzed | Analyst | Qualifier |
|---|---|---|---|---|---|---|---|---|---|---|
| 6052619-85 | Sample Location: 20830900 096BF | | | | | | | | | |
| **Lead (‡)** | | 1030 | 1.9 | ppb | 1.0 | 15 | 05/21/26 06:22 | 06/11/26 | DST | |
| 6052619-86 | Sample Location: 20830900 097BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:22 | 06/11/26 | DST | |
| 6052619-87 | Sample Location: 20830900 099BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:24 | 06/11/26 | DST | |
| 6052619-88 | Sample Location: 20830900 100DW | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:24 | 06/11/26 | DST | |
| 6052619-89 | Sample Location: 20830900 101SF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:25 | 06/11/26 | DST | |
| 6052619-90 | Sample Location: 20830900 102OT | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:26 | 06/11/26 | DST | |
| 6052619-91 | Sample Location: 20830900 103BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:27 | 06/11/26 | DST | |
| 6052619-92 | Sample Location: 20830900 104BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:27 | 06/11/26 | DST | |
| 6052619-93 | Sample Location: 20830900 105SF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:28 | 06/11/26 | DST | |
| 6052619-94 | Sample Location: 20830900 106NS | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:29 | 06/11/26 | DST | |
| 6052619-95 | Sample Location: 20830900 107OT | | | | | | | | | |
| **Lead (‡)** | | 1030 | 12.8 | ppb | 1.0 | 15 | 05/21/26 06:30 | 06/11/26 | DST | |
| 6052619-96 | Sample Location: 20830900 108BF | | | | | | | | | |
| Lead (‡) | | 1030 | ND | ppb | 1.0 | 15 | 05/21/26 06:30 | 06/11/26 | DST | |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

**UMPQUA Research Company**
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

**ANALYSIS REPORT**
**URC # 6052619**

**Qualifiers and Definitions**

| | |
|---|---|
| DET | Analyte DETECTED |
| ND | Analyte NOT DETECTED at or above the MRL (minimum reporting limit) |
| NA | Not Applicable |
| NR | Not Reported |
| dry | Sample results reported on a dry weight basis |
| RPD | Relative Percent Difference |
| MRL | Minimum Reporting Limit |
| MDL | Minimum Detection Limit |
| MCL | Maximum Contamination Level |
| (‡) | ORELAP Accredited Analyte |
| (~) | Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values. |

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR
**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School
**PWS Number:**
Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667
**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**
**Sample Collected By:** MARIO RODRIGUEZ
If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| L0052619-01 | 20830900 001KF | 5/21/26 | 05:08 | | ☐ | ☐ | ☐ | ☐ | |
| -02 | 20830900 002KF | | 05:09 | | ☐ | ☐ | ☐ | ☐ | |
| -03 | 20830900 003KF | | 05:09 | | ☐ | ☐ | ☐ | ☐ | |
| -04 | 20830900 004BF | | 05:10 | | ☐ | ☐ | ☐ | ☐ | |
| -05 | 20830900 005KF | | 05:11 | | ☐ | ☐ | ☐ | ☐ | |
| -06 | 20830900 006KF | | 05:11 | | ☐ | ☐ | ☐ | ☐ | |
| -07 | 20830900 007WB | | 05:13 | | ☐ | ☐ | ☐ | ☐ | |
| -08 | 20830900 008DW | | 05:14 | | ☐ | ☐ | ☐ | ☐ | |
| -09 | 20830900 009DW | | 05:14 | | ☐ | ☐ | ☐ | ☐ | |
| -10 | 20830900 010BF | | 05:15 | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 08:41 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 13:00 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 2.7 °C
Cooling process, on ice: yes no



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR

**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School

**PWS Number:**

Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667

**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**

**Sample Collected By:** MARIO RODRIGUEZ

If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 100S2619-11 | 20830900 011BF | 5/21/26 | 05:15 | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 012BF | | — | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 013BF | | — | | ☐ | ☐ | ☐ | ☐ | |
| -12 | 20830900 014BF | | 05:17 | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 015BF | | — | | ☐ | ☐ | ☐ | ☐ | |
| -13 | 20830900 016BF | | 05:19 | | ☐ | ☐ | ☐ | ☐ | |
| -14 | 20830900 017BF | | 05:19 | | ☐ | ☐ | ☐ | ☐ | |
| -15 | 20830900 018SF | | 05:20 | | ☐ | ☐ | ☐ | ☐ | |
| -16 | 20830900 019BF | | 05:22 | | ☐ | ☐ | ☐ | ☐ | |
| -17 | 20830900 020BF | | 05:23 | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 08:41 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 13:10 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 2.1 °C
Cooling process, on ice: yes (no)



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR
**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School
**PWS Number:**
Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667
**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**
**Sample Collected By:** MARIO RODRIGUEZ
If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 10052619 ~~-18~~ | 20830900 021BF | 5/21/26 | — | | ☐ | ☐ | ☐ | ☐ | |
| -18 | 20830900 022BF | | 05:24 | | ☐ | ☐ | ☐ | ☐ | |
| -19 | 20830900 023CF | | 05:25 | | ☐ | ☐ | ☐ | ☐ | |
| -20 | 20830900 024DW | | 05:25 | | ☐ | ☐ | ☐ | ☐ | |
| -21 | 20830900 025CF | | 05:27 | | ☐ | ☐ | ☐ | ☐ | |
| -22 | 20830900 026DW | | 05:27 | | ☐ | ☐ | ☐ | ☐ | |
| -23 | 20830900 027CF | | 05:28 | | ☐ | ☐ | ☐ | ☐ | |
| -24 | 20830900 028DW | | 05:28 | | ☐ | ☐ | ☐ | ☐ | |
| -25 | 20830900 029CF | | 05:30 | | ☐ | ☐ | ☐ | ☐ | |
| -26 | 20830900 030DW | | 05:30 | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 09:41 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 12:10 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:20 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 21.7 °C
Cooling process, on ice: yes (no)



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR
**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School
**PWS Number:**
Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667
**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**
**Sample Collected By:** MARIO RODRIGUEZ
**If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client:** _____ **Miles** _____ **Lab Tech Hours**

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 605 2619-27 | 20830900 031CF | 5/21/26 | 05:31 | | ☐ | ☐ | ☐ | ☐ | |
| -28 | 20830900 032DW | | 05:32 | | ☐ | ☐ | ☐ | ☐ | |
| -29 | 20830900 033CF | | 05:33 | | ☐ | ☐ | ☐ | ☐ | |
| -30 | 20830900 034DW | | 05:33 | | ☐ | ☐ | ☐ | ☐ | |
| -31 | 20830900 035CF | | 05:35 | | ☐ | ☐ | ☐ | ☐ | |
| -32 | 20830900 036DW | | 05:35 | | ☐ | ☐ | ☐ | ☐ | |
| -33 | 20830900 037CF | | 05:36 | | ☐ | ☐ | ☐ | ☐ | |
| -34 | 20830900 038DW | | 05:36 | | ☐ | ☐ | ☐ | ☐ | |
| -35 | 20830900 039CF | | 05:38 | | ☐ | ☐ | ☐ | ☐ | |
| -36 | 20830900 040DW | | 05:38 | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 08:42 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 13:00 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: _____ °C
Cooling process, on ice: yes no



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR

**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School

**PWS Number:**

Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667

**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**

**Sample Collected By:** MARIO RODRIGUEZ

If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| L0526019-37 | 20830900 041BF | 5/21/26 | 05:40 | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 042BF | | — | | ☐ | ☐ | ☐ | ☐ | |
| -38 | 20830900 043BF | | 05:41 | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 044BF | | — | | ☐ | ☐ | ☐ | ☐ | |
| -39 | 20830900 045BF | | 05:42 | | ☐ | ☐ | ☐ | ☐ | |
| -40 | 20830900 046CF | | 05:43 | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 047DW | | — | | ☐ | ☐ | ☐ | ☐ | |
| -41 | 20830900 048BF | | 05:44 | | ☐ | ☐ | ☐ | ☐ | |
| -42 | 20830900 049BF | | 05:45 | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 050BF | | — | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 05:42 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 13:10 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 21.7 °C
Cooling process, on ice: yes (no)



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR

**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School
**PWS Number:**
Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667
**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**
**Sample Collected By:** MARIO RODRIGUEZ
If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 60052619 ~~-43~~ | 20830900 051BF | 5/21/26 | — | | ☐ | ☐ | ☐ | ☐ | |
| -43 | 20830900 052BF | | 05:47 | | ☐ | ☐ | ☐ | ☐ | |
| -44 | 20830900 053CF | | 05:48 | | ☐ | ☐ | ☐ | ☐ | |
| -45 | 20830900 054DW | | 05:49 | | ☐ | ☐ | ☐ | ☐ | |
| -46 | 20830900 055CF | | 05:50 | | ☐ | ☐ | ☐ | ☐ | |
| -47 | 20830900 056DW | | 05:50 | | ☐ | ☐ | ☐ | ☐ | |
| -48 | 20830900 057CF | | 05:51 | | ☐ | ☐ | ☐ | ☐ | |
| -49 | 20830900 058DW | | 05:51 | | ☐ | ☐ | ☐ | ☐ | |
| -50 | 20830900 059CF | | 05:52 | | ☐ | ☐ | ☐ | ☐ | |
| -51 | 20830900 060DW | | 05:52 | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 08:43 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 13:00 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 21.2 °C
Cooling process, on ice: yes (no)



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR
**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School
**PWS Number:**
Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667
**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**
**Sample Collected By:** MARIO RODRIGUEZ
**If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client:** _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 0052619-52 | 20830900 061CF | 5/21/26 | 05:54 | | ☐ | ☐ | ☐ | ☐ | |
| -53 | 20830900 062DW | | 05:55 | | ☐ | ☐ | ☐ | ☐ | |
| -54 | 20830900 063CF | | 05:56 | | ☐ | ☐ | ☐ | ☐ | |
| -55 | 20830900 064DW | | 05:56 | | ☐ | ☐ | ☐ | ☐ | |
| -56 | 20830900 065CF | | 05:57 | | ☐ | ☐ | ☐ | ☐ | |
| -57 | 20830900 066DW | | 05:58 | | ☐ | ☐ | ☐ | ☐ | |
| -58 | 20830900 067BF | | 05:59 | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 068BF | | — | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 069BF | | — | | ☐ | ☐ | ☐ | ☐ | |
| -59 | 20830900 070BF | | 05:59 | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 08:43 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 13:00 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 21.2 °C
Cooling process, on ice: yes no



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR
**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School
**PWS Number:**
Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667
**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**
**Sample Collected By:** MARIO RODRIGUEZ
If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 1005261019-60 | 20830900 071CF | 5/21/26 | 05:59 | | ☐ | ☐ | ☐ | ☐ | |
| -61 | 20830900 072BF | | 06:02 | | ☐ | ☐ | ☐ | ☐ | |
| -62 | 20830900 073 CF | | 06:03 | | ☐ | ☐ | ☐ | ☐ | |
| -63 | 20830900 074BF | | 06:04 | | ☐ | ☐ | ☐ | ☐ | |
| -64 | 20830900 075BF | | 06:05 | | ☐ | ☐ | ☐ | ☐ | |
| -65 | 20830900 076BF | | 06:06 | | ☐ | ☐ | ☐ | ☐ | |
| -66 | 20830900 077BF | | 06:06 | | ☐ | ☐ | ☐ | ☐ | |
| -67 | 20830900 078CF | | 06:08 | | ☐ | ☐ | ☐ | ☐ | |
| -68 | 20830900 079DW | | 06:08 | | ☐ | ☐ | ☐ | ☐ | |
| -69 | 20830900 080CF | | 06:10 | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 08:44 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 1320 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 21.7 °C
Cooling process, on ice: yes (no)



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR

**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School

**PWS Number:**

Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667

**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**

**Sample Collected By:** MARIO RODRIGUEZ

If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 60052619-70 | 20830900 081DW | 5/21/26 | 06:10 | | ☐ | ☐ | ☐ | ☐ | |
| -71 | 20830900 082CF | | 06:12 | | ☐ | ☐ | ☐ | ☐ | |
| -72 | 20830900 083DW | | 06:12 | | ☐ | ☐ | ☐ | ☐ | |
| -73 | 20830900 084CF | | 06:13 | | ☐ | ☐ | ☐ | ☐ | |
| -74 | 20830900 085DW | | 06:13 | | ☐ | ☐ | ☐ | ☐ | |
| -75 | 20830900 086CF | | 06:15 | | ☐ | ☐ | ☐ | ☐ | |
| -76 | 20830900 087DW | | 06:15 | | ☐ | ☐ | ☐ | ☐ | |
| -77 | 20830900 088CF | | 06:16 | | ☐ | ☐ | ☐ | ☐ | |
| -78 | 20830900 089DW | | 06:16 | | ☐ | ☐ | ☐ | ☐ | |
| -79 | 20830900 090CF | | 06:17 | | ☐ | ☐ | ☐ | ☐ | |

| | Date/Time | | Date/Time |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | 5/22/26 06:44 | **Received By Sample Custodian:** Signature | |
| **Relinquished By Sample Custodian:** Signature | | **Received By Login:** Signature | 5/26/26 13:00 |
| **Relinquished By Log In:** Signature | 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 21.7 °C
Cooling process, on ice: yes no



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR

**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School

**PWS Number:**

Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667

**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**

**Sample Collected By:** MARIO RODRIGUEZ

If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 100526 19 - 80 | 20830900 091DW | 5/21/26 | 06:18 | | ☐ | ☐ | ☐ | ☐ | |
| -81 | 20830900 092CF | | 06:19 | | ☐ | ☐ | ☐ | ☐ | |
| -82 | 20830900 093DW | | 06:19 | | ☐ | ☐ | ☐ | ☐ | |
| -83 | 20830900 094CF | | 06:20 | | ☐ | ☐ | ☐ | ☐ | |
| -84 | 20830900 095DW | | 06:20 | | ☐ | ☐ | ☐ | ☐ | |
| -85 | 20830900 096BF | | 06:22 | | ☐ | ☐ | ☐ | ☐ | |
| -86 | 20830900 097BF | | 06:22 | | ☐ | ☐ | ☐ | ☐ | |
| | 20830900 098BF | | — | | ☐ | ☐ | ☐ | ☐ | |
| -87 | 20830900 099BF | | 06:24 | | ☐ | ☐ | ☐ | ☐ | |
| -88 | 20830900 100DW | | 06:24 | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 07:44 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 13:00 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 21.7 °C
Cooling process, on ice: yes no



F-236 02/02/21 QA

# CHAIN OF CUSTODY RECORD

## ANALYTICAL SERVICES

**Umpqua Research Company**
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

**CLIENT NAME:** Springfield SD 19
**MAILING ADDRESS:** 1890 42nd St., Springfield, OR
**PO Number:**
**Date:** 5/22/26

**Project Name:** Springfield School District
Mt Vernon Elementary School
**PWS Number:**
Report Data To Oregon DWP? (Circle One) Yes No

**Client Contact Person:** John Harshberger **Telephone:** 541 979 9667
**E-Mail:** john.harshberger@springfield.k12.or.us **Fax:**
**Sample Collected By:** MARIO RODRIGUEZ
If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours

| Lab Use Only URC SAMPLE ID | SAMPLE LOCATION / CLIENT SAMPLE ID | COLLECTION DATE | COLLECTION TIME | # of Bottles | MATRIX DW | MATRIX AQ | MATRIX Soil / Sludge | MATRIX Solid | ANALYSIS REQUIRED |
|---|---|---|---|---|---|---|---|---|---|
| 2052619-89 | 20830900 101SF | 5/21/26 | 06:25 | | ☐ | ☐ | ☐ | ☐ | |
| -90 | 20830900 102OT | | 06:26 | | ☐ | ☐ | ☐ | ☐ | |
| -91 | 20830900 103BF | | 06:27 | | ☐ | ☐ | ☐ | ☐ | |
| -92 | 20830900 104BF | | 06:27 | | ☐ | ☐ | ☐ | ☐ | |
| -93 | 20830900 105SF | | 06:28 | | ☐ | ☐ | ☐ | ☐ | |
| -94 | 20830900 106NS | | 06:29 | | ☐ | ☐ | ☐ | ☐ | |
| -95 | 20830900 107OT | | 06:30 | | ☐ | ☐ | ☐ | ☐ | |
| -96 | 20830900 108BF | | 06:50 | | ☐ | ☐ | ☐ | ☐ | |
| | | | | | ☐ | ☐ | ☐ | ☐ | |
| | | | | | ☐ | ☐ | ☐ | ☐ | |

| | | | |
|---|---|---|---|
| **Relinquished By Customer/Sample Collector:** Signature | Date/Time 5/22/26 08:45 | **Received By Sample Custodian:** Signature | Date/Time |
| **Relinquished By Sample Custodian:** Signature | Date/Time | **Received By Login:** Signature | Date/Time 5/26/26 13:00 |
| **Relinquished By Log In:** Signature | Date/Time 5/26/26 16:26 | **Received by Analyst/Custodian:** Signature | Date/Time 5/27/26 1507 |

**REPORTING PREFERENCES**
Report Delivery: (Circle One) E-Mail USPS
Report Results To: (Circle One) MDL MRL
Comments:

**LAB USE ONLY**
Cooler: (circle one) Client URC
URC Containers: (circle one) ALL SOME NONE
Sampling Procedure Number:

Temp Gun ID# Qi-015
Temperature at receipt: 21.7 °C
Cooling process, on ice: yes no



F-236 02/02/21 QA