

Lead in Water Test Results Summary: Riverbend Elementary School

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.


- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Kitchen Sink Food Prep	20831600-001KF	5/20/2026	ND	Non-Detect	[enter date]	[enter result]	[autofill]
Kitchen Sink Sprayer	20831600-002KF	5/20/2026	ND	Non-Detect			
Kitchen Handwash Station	20831600-003KF	5/20/2026	ND	Non-Detect			
Kitchen Bathroom Faucet	20831600-004BF	5/20/2026	ND	Non-Detect			
Kitchen Faucet (Dishwasher)	20831600-005KF	5/20/2026	ND	Non-Detect			
Kitchen Faucet sprayer Dishwasher	20831600-006KF	5/20/2026	ND	Non-Detect			
Drinking Fountain #1 (By Gym)	20831600-007DW	5/20/2026	ND	Non-Detect			
Drinking Fountain #2	20831600-008DW	5/20/2026	ND	Non-Detect			
Boys Bradley Bathroom Faucet #1 (Far Left)	20831600-009BF	5/20/2026	3.8	Low			
Boys Bradley Bathroom Faucet #2 (Center)	20831600-010BF	5/20/2026	1.9	Low			
Boys Bradley Bathroom Faucet #3 (Far Right)	20831600-011BF	NOT IN USE					
Boys Bradley Bathroom Faucet #4 (Far Right)	20831600-012BF		2.5	Low			
Girl's Bradley Bathroom Faucet #1 (Far Left)	20831600-013BF	NOT IN USE					
Girl's Bradley Bathroom Faucet #2 (Left from Center)	20831600-014BF		5.2	Moderate			
Center)	20831600-015BF	NOT IN USE					
Girl's Bradley Bathroom Faucet #4 (Far Right)	20831600-016BF	5/20/2026	2.3	Low			
Room 203 Faucet (In Library)	20831600-017SF	5/20/2026	ND	Non-Detect			
A Wing, Boys Bathroom Faucet #1 (Far Left)	20831600-018BF	5/20/2026	2.8	Low			
Center)	20831600-019BF	5/20/2026	ND	Non-Detect			
Center)	20831600-020BF	5/20/2026	1.7	Low			
A Wing, Boys Bathroom Faucet #4 (Far Right)	20831600-021BF	5/20/2026	1.5	Low			
Middle Island Faucet	20831600-022CF	5/20/2026	ND	Non-Detect			
Middle Island Drinking Fountain	20831600-023DW	5/20/2026	ND	Non-Detect			
Classroom A 101 Faucet	20831600-024CF	5/20/2026	ND	Non-Detect			
Classroom A 101 Drinking Fountain	20831600-025DW	5/20/2026	ND	Non-Detect			
Classroom A 102 Faucet	20831600-026CF	5/20/2026	ND	Non-Detect			
Classroom A 102 Drinking Fountain	20831600-027DW	5/20/2026	ND	Non-Detect			
Classroom A 103 Faucet	20831600-028CF	5/20/2026	ND	Non-Detect			
Classroom A 103 Drinking Fountain	20831600-029DW	5/20/2026	ND	Non-Detect			
Classroom A 104 Faucet	20831600-030CF	NOT IN USE					
Classroom A 104 Drinking Fountain	20831600-031DW	NOT IN USE					
Classroom A 105 Faucet	20831600-032CF	5/20/2026	ND	Non-Detect			
Classroom A 105 Drinking Fountain	20831600-033DW	5/20/2026	ND	Non-Detect			
Classroom A 106 Faucet	20831600-034CF	5/20/2026	ND	Non-Detect			
Classroom A 106 Drinking Fountain	20831600-035DW	5/20/2026	ND	Non-Detect			
Classroom A 107 Faucet	20831600-036CF	5/20/2026	ND	Non-Detect			
Classroom A 107 Drinking Fountain	20831600-037DW	5/20/2026	ND	Non-Detect			
Classroom A 108 Faucet	20831600-038CF	5/20/2026	ND	Non-Detect			
Classroom A 108 Drinking Fountain	20831600-039DW	5/20/2026	ND	Non-Detect			
A Wing, Girls Bathroom Faucet #1 (Far Left)	20831600-040BF	5/20/2026	4.4	Low			
A Wing, Girls Bathroom Faucet #2	20831600-041BF	5/20/2026	1.5	Low			
A Wing, Girls Bathroom Faucet #3	20831600-042BF	5/20/2026	ND	Non-Detect			
A Wing, Girls Bathroom Faucet #4 (Far Right)	20831600-043BF	5/20/2026	1	Low			
Staff Room Bathroom Faucet	20831600-044BF	5/20/2026	ND	Non-Detect			
B, Wing Classroom B 215 Faucet	20831600-045CF	5/20/2026	ND	Non-Detect			
B, Wing Classroom B 215 Drinking Fountain	20831600-046DW	NOT IN USE					
Bathroom Faucet Room 219	20831600-047BF	5/20/2026	ND	Non-Detect			
B Wing, Boys Bathroom Faucet #1 (Left)	20831600-048BF	5/20/2026	3.2	Low			
Center)	20831600-049BF	NOT IN USE					
B Wing, Boys Bathroom Faucet #3 (Right)	20831600-050BF	5/20/2026	2	Low			

B Wing, Boys Bathroom Faucet #4 (Far Right)	20831600-051BF	NOT IN USE			
Middle Island Faucet	20831600-052CF	5/20/2026	ND	Non-Detect	
Middle Island Drinkng Fountain	20831600-053DW	5/20/2026	ND	Non-Detect	
Classroom B 101 Faucet	20831600-054CF	5/20/2026	ND	Non-Detect	
Classroom B 101 Drinking Fountain	20831600-055DW	5/20/2026	ND	Non-Detect	
Classroom B 102 Faucet	20831600-056CF	5/20/2026	ND	Non-Detect	
Classroom B 102 Drinking Fountain	20831600-057DW	5/20/2026	ND	Non-Detect	
Classroom B 103 Faucet	20831600-058CF	5/20/2026	ND	Non-Detect	
Classroom B 103 Drinking Fountain	20831600-059DW	5/20/2026	ND	Non-Detect	
Classroom B 106 Faucet	20831600-060CF	5/20/2026	ND	Non-Detect	
Classroom B 106 Drinking Fountain	20831600-061DW	5/20/2026	ND	Non-Detect	
Classroom B 107 Faucet	20831600-062CF	5/20/2026	ND	Non-Detect	
Classroom B 107 Drinking Fountain	20831600-063DW	5/20/2026	ND	Non-Detect	
Classroom B 108 Faucet	20831600-064CF	NOT IN USE			
Classroom B 108 Drinking Fountain	20831600-065DW	5/20/2026	ND	Non-Detect	
B Wing, Girls Bathroom Faucet #1 (Far Left)	20831600-066BF	5/20/2026	2.1	Low	
Center)	20831600-067BF	5/20/2026	1.3	Low	
Center)	20831600-068BF	5/20/2026	1.3	Low	
B Wing, Girls Bathroom Faucet #4 (Far Right)	20831600-069BF	5/20/2026	1.3	Low	
Classroom B 220 Faucet	20831600-070CF	5/20/2026	ND	Non-Detect	
Staff Restroom Faucet (C Wing)	20831600-071BF	5/20/2026	ND	Non-Detect	
Classroom B 225 Faucet	20831600-072CF	5/20/2026	ND	Non-Detect	
C Wing, Girls Bathroom Faucet #1 (Far Left)	20831600-073BF	5/20/2026	5	Low	
Center)	20831600-074BF	5/20/2026	3.3	Low	
Center)	20831600-075BF	5/20/2026	2.6	Low	
C Wing, Girls Bathroom Faucet #4 (Far Right)	20831600-076BF	5/20/2026	2.4	Low	
Middle Island Faucet	20831600-077CF	5/20/2026	ND	Non-Detect	
Middle Island Drinking Fountain	20831600-078DW	5/20/2026	ND	Non-Detect	
Classroom C 101 Faucet	20831600-079CF	5/20/2026	ND	Non-Detect	
Classroom C 101 Drinking Fountain	20831600-080DW	5/20/2026	ND	Non-Detect	
Classroom C 102 Faucet	20831600-081CF	5/20/2026	ND	Non-Detect	
Classroom C 102 Drinking Fountain	20831600-082DW	5/20/2026	ND	Non-Detect	
Classroom C 103 Faucet	20831600-083CF	5/20/2026	ND	Non-Detect	
Classroom C 103 Drinking Fountain	20831600-084DW	5/20/2026	ND	Non-Detect	
Classroom C 104 Faucet	20831600-085CF	5/20/2026	ND	Non-Detect	
Classroom C 104 Drinking Fountain	20831600-086DW	5/20/2026	ND	Non-Detect	
Classroom C 105 Faucet	20831600-087CF	5/20/2026	ND	Non-Detect	
Classroom C 105 Drinking Fountain	20831600-088DW	5/20/2026	ND	Non-Detect	
Classroom C 106 Faucet	20831600-089CF	5/20/2026	ND	Non-Detect	
Classroom C 106 Drinking Fountain	20831600-090DW	5/20/2026	ND	Non-Detect	
Classroom C 107 Faucet	20831600-091CF	5/20/2026	ND	Non-Detect	
Classroom C 107 Drinking Fountain	20831600-092DW	5/20/2026	ND	Non-Detect	
Classroom C 108 Faucet	20831600-093CF	5/20/2026	ND	Non-Detect	
Classroom C 108 Drinking Fountain	20831600-094DW	5/20/2026	ND	Non-Detect	
C Wing, Boys Bathroom Faucet #1 (Far Left)	20831600-095BF	5/20/2026	ND	Non-Detect	
Center)	20831600-096BF	NOT IN USE			
Center)	20831600-097BF	5/20/2026	2	Low	
C Wing, Boys Bathroom Faucet #4 (Far Right)	20831600-098BF	NOT IN USE			
Drinking Fountain (Outside Staff Room)	20831600-099DW	5/20/2026	1.1	Low	
Staff Room Faucet	20831600-100SF	5/20/2026	ND	Non-Detect	
Staff Room Insta Hot	20831600-101OT	5/20/2026	ND	Non-Detect	
Staff Bathroom Faucet (Right)	20831600-102BF	5/20/2026	ND	Non-Detect	
Staff Bathroom Faucet (Left)	20831600-103BF	5/20/2026	ND	Non-Detect	
Staff Work Room Faucet	20831600-104SF	5/20/2026	ND	Non-Detect	
Office Health Room Faucet (Room 240)	20831600-105NS	5/20/2026	ND	Non-Detect	
Office Health Room Eyewash Sprayer	20831600-106OT	5/20/2026	7.8	Moderate	
Bathroom Faucet Room 240	20831600-107BF	5/20/2026	ND	Non-Detect	



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6052616

Springfield Public Schools	Project: Lead Testing	Date Reported: 06/10/26
1890 42nd Street	Project #: Riverbend Elementary School	Date Received: 05/26/26 13:00
Springfield, OR 97477	Client Contact: Jody Olson	Sampled By: Mario Rodriguez

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6052616-01	Sample Location: 20831600 001KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:02	06/05/26	DST	
6052616-02	Sample Location: 20831600 002KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:03	06/05/26	DST	
6052616-03	Sample Location: 20831600 003KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:04	06/05/26	DST	
6052616-04	Sample Location: 20831600 004BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:05	06/05/26	DST	
6052616-05	Sample Location: 20831600 005KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:06	06/05/26	DST	
6052616-06	Sample Location: 20831600 006KF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:06	06/05/26	DST	
6052616-07	Sample Location: 20831600 007DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:07	06/05/26	DST	
6052616-08	Sample Location: 20831600 008DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:08	06/05/26	DST	
6052616-09	Sample Location: 20831600 009BF									
Lead (±)		1030	3.8	ppb	1.0	15	05/20/26 05:09	06/05/26	DST	
6052616-10	Sample Location: 20831600 010BF									
Lead (±)		1030	1.9	ppb	1.0	15	05/20/26 05:10	06/05/26	DST	
6052616-11	Sample Location: 20831600 012BF									
Lead (±)		1030	2.5	ppb	1.0	15	05/20/26 05:11	06/05/26	DST	
6052616-12	Sample Location: 20831600 014BF									
Lead (±)		1030	5.2	ppb	1.0	15	05/20/26 05:13	06/05/26	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6052616

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6052616-13	Sample Location: 20831600 016BF									
Lead (±)		1030	2.3	ppb	1.0	15	05/20/26 05:14	06/05/26	DST	
6052616-14	Sample Location: 20831600 017SF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:16	06/05/26	DST	
6052616-15	Sample Location: 20831600 018BF									
Lead (±)		1030	2.8	ppb	1.0	15	05/20/26 05:18	06/05/26	DST	
6052616-16	Sample Location: 20831600 019BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:18	06/05/26	DST	
6052616-17	Sample Location: 20831600 020BF									
Lead (±)		1030	1.7	ppb	1.0	15	05/20/26 05:19	06/05/26	DST	
6052616-18	Sample Location: 20831600 021BF									
Lead (±)		1030	1.5	ppb	1.0	15	05/20/26 05:19	06/05/26	DST	
6052616-19	Sample Location: 20831600 022CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:21	06/05/26	DST	
6052616-20	Sample Location: 20831600 023DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:21	06/05/26	DST	
6052616-21	Sample Location: 20831600 024CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:22	06/05/26	DST	
6052616-22	Sample Location: 20831600 025DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:22	06/05/26	DST	
6052616-23	Sample Location: 20831600 026CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:24	06/05/26	DST	
6052616-24	Sample Location: 20831600 027DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:24	06/05/26	DST	
6052616-25	Sample Location: 20831600 028CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:26	06/05/26	DST	
6052616-26	Sample Location: 20831600 029DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:26	06/05/26	DST	
6052616-27	Sample Location: 20831600 032CF									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6052616

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:28	06/05/26	DST	
6052616-28	Sample Location: 20831600 033DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:29	06/05/26	DST	
6052616-29	Sample Location: 20831600 034CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:32	06/05/26	DST	
6052616-30	Sample Location: 20831600 035DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:32	06/05/26	DST	
6052616-31	Sample Location: 20831600 036CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:33	06/05/26	DST	
6052616-32	Sample Location: 20831600 037DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:33	06/05/26	DST	
6052616-33	Sample Location: 20831600 038CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:35	06/05/26	DST	
6052616-34	Sample Location: 20831600 039DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:35	06/05/26	DST	
6052616-35	Sample Location: 20831600 040BF									
Lead (±)		1030	4.4	ppb	1.0	15	05/20/26 05:37	06/05/26	DST	
6052616-36	Sample Location: 20831600 041BF									
Lead (±)		1030	1.5	ppb	1.0	15	05/20/26 05:37	06/05/26	DST	
6052616-37	Sample Location: 20831600 042BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:37	06/05/26	DST	
6052616-38	Sample Location: 20831600 043BF									
Lead (±)		1030	1.0	ppb	1.0	15	05/20/26 05:38	06/05/26	DST	
6052616-39	Sample Location: 20831600 044BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:40	06/05/26	DST	
6052616-40	Sample Location: 20831600 045CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:42	06/05/26	DST	
6052616-41	Sample Location: 20831600 047BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:43	06/05/26	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6052616

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6052616-42	Sample Location: 20831600 048BF									
Lead (±)		1030	3.2	ppb	1.0	15	05/20/26 05:44	06/05/26	DST	
6052616-43	Sample Location: 20831600 050BF									
Lead (±)		1030	2.0	ppb	1.0	15	05/20/26 05:45	06/05/26	DST	
6052616-44	Sample Location: 20831600 052CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:46	06/05/26	DST	
6052616-45	Sample Location: 20831600 053DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:46	06/05/26	DST	
6052616-46	Sample Location: 20831600 054CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:48	06/05/26	DST	
6052616-47	Sample Location: 20831600 055DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:48	06/05/26	DST	
6052616-48	Sample Location: 20831600 056CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:49	06/05/26	DST	
6052616-49	Sample Location: 20831600 057DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:49	06/05/26	DST	
6052616-50	Sample Location: 20831600 058CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:50	06/05/26	DST	
6052616-51	Sample Location: 20831600 059DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:50	06/05/26	DST	
6052616-52	Sample Location: 20831600 060CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:51	06/05/26	DST	
6052616-53	Sample Location: 20831600 061DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:52	06/05/26	DST	
6052616-54	Sample Location: 20831600 062CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:53	06/05/26	DST	
6052616-55	Sample Location: 20831600 063DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:53	06/05/26	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6052616

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6052616-56	Sample Location: 20831600 065DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:54	06/05/26	DST	
6052616-57	Sample Location: 20831600 066BF									
Lead (±)		1030	2.1	ppb	1.0	15	05/20/26 05:56	06/05/26	DST	
6052616-58	Sample Location: 20831600 067BF									
Lead (±)		1030	1.3	ppb	1.0	15	05/20/26 05:56	06/05/26	DST	
6052616-59	Sample Location: 20831600 068BF									
Lead (±)		1030	1.3	ppb	1.0	15	05/20/26 05:56	06/09/26	DST	
6052616-60	Sample Location: 20831600 069BF									
Lead (±)		1030	1.3	ppb	1.0	15	05/20/26 05:57	06/09/26	DST	
6052616-61	Sample Location: 20831600 070CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 05:59	06/09/26	DST	
6052616-62	Sample Location: 20831600 071BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:03	06/09/26	DST	
6052616-63	Sample Location: 20831600 072CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:04	06/09/26	DST	
6052616-64	Sample Location: 20831600 073BF									
Lead (±)		1030	5.0	ppb	1.0	15	05/20/26 06:05	06/09/26	DST	
6052616-65	Sample Location: 20831600 074BF									
Lead (±)		1030	3.3	ppb	1.0	15	05/20/26 06:05	06/09/26	DST	
6052616-66	Sample Location: 20831600 075BF									
Lead (±)		1030	2.6	ppb	1.0	15	05/20/26 06:05	06/09/26	DST	
6052616-67	Sample Location: 20831600 076BF									
Lead (±)		1030	2.4	ppb	1.0	15	05/20/26 06:06	06/09/26	DST	
6052616-68	Sample Location: 20831600 077CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:07	06/09/26	DST	
6052616-69	Sample Location: 20831600 078DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:08	06/09/26	DST	
6052616-70	Sample Location: 20831600 079CF									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6052616

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:09	06/09/26	DST	
6052616-71	Sample Location: 20831600 080DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:09	06/09/26	DST	
6052616-72	Sample Location: 20831600 081CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:10	06/09/26	DST	
6052616-73	Sample Location: 20831600 082DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:11	06/09/26	DST	
6052616-74	Sample Location: 20831600 083CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:12	06/09/26	DST	
6052616-75	Sample Location: 20831600 084DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:12	06/09/26	DST	
6052616-76	Sample Location: 20831600 085CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:14	06/09/26	DST	
6052616-77	Sample Location: 20831600 086DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:14	06/09/26	DST	
6052616-78	Sample Location: 20831600 087CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:15	06/09/26	DST	
6052616-79	Sample Location: 20831600 088DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:15	06/09/26	DST	
6052616-80	Sample Location: 20831600 089CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:16	06/09/26	DST	
6052616-81	Sample Location: 20831600 090DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:16	06/09/26	DST	
6052616-82	Sample Location: 20831600 091CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:17	06/09/26	DST	
6052616-83	Sample Location: 20831600 092DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:18	06/09/26	DST	
6052616-84	Sample Location: 20831600 093CF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:18	06/09/26	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6052616

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6052616-85	Sample Location: 20831600 094DW									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:19	06/09/26	DST	
6052616-86	Sample Location: 20831600 095BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:20	06/09/26	DST	
6052616-87	Sample Location: 20831600 097BF									
Lead (±)		1030	2.0	ppb	1.0	15	05/20/26 06:21	06/09/26	DST	
6052616-88	Sample Location: 20831600 099DW									
Lead (±)		1030	1.1	ppb	1.0	15	05/20/26 06:22	06/09/26	DST	
6052616-89	Sample Location: 20831600 100SF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:23	06/09/26	DST	
6052616-90	Sample Location: 20831600 101OT									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:23	06/09/26	DST	
6052616-91	Sample Location: 20831600 102BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:24	06/09/26	DST	
6052616-92	Sample Location: 20831600 103BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:24	06/09/26	DST	
6052616-93	Sample Location: 20831600 104SF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:25	06/09/26	DST	
6052616-94	Sample Location: 20831600 105NS									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 06:26	06/09/26	DST	
6052616-95	Sample Location: 20831600 106OT									
Lead (±)		1030	7.8	ppb	1.0	15	05/20/26 06:27	06/09/26	DST	
6052616-96	Sample Location: 20831600 107BF									
Lead (±)		1030	ND	ppb	1.0	15	05/20/26 00:00	06/09/26	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6052616

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St,
Springfield, OR
PO Number:
Date: 5/22/26

Project Name: Springfield School District		Client Contact Person: John Harsberger		Telephone: 541 979 9667					
Riverbend Elementary School		E-Mail: john.harsberger@springfield.k12.or.us		Fax:					
PWS Number:		Sample Collected By: MARCO RODRIGUEZ							
Report Data To Oregon DWP?		(Circle One) Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: Miles Lab Tech Hours					
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION		MATRIX		ANALYSIS REQUIRED			
URC SAMPLE ID		DATE	TIME	# of Bottles	DW		AQ	Soil / Sludge	Solid
10052610-01	20831600 001KF	5/20/26	05:02		☐	☐	☐	☐	
-02	20831600 002KF		05:03		☐	☐	☐	☐	
-03	20831600 003KF		05:04		☐	☐	☐	☐	
-04	20831600 004BF		05:05		☐	☐	☐	☐	
-05	20831600 005KF		05:06		☐	☐	☐	☐	
-06	20831600 006KF		05:06		☐	☐	☐	☐	
-07	20831600 007DW		05:07		☐	☐	☐	☐	
-08	20831600 008DW		05:08		☐	☐	☐	☐	
-09	20831600 009BF		05:09		☐	☐	☐	☐	
-10	20831600 010BF		05:10		☐	☐	☐	☐	
Relinquished By Customer/Sample Collector: Signature: [Signature]		Date/Time: 5/22/26 08:32		Received By Sample Custodian: Signature: [Signature]		Date/Time: 5/20/26 13:00			
Relinquished By Sample Custodian: Signature: [Signature]		Date/Time: 5/20/26 14:48		Received By Log In: Signature: [Signature]		Date/Time: 5/20/26 15:00			
Relinquished By Log In: Signature: [Signature]		Date/Time: 5/20/26 14:48		Received By Analyst/Custodian: Signature: [Signature]		Date/Time: 5/20/26 15:00			
REPORTING PREFERENCES		LAB USE ONLY		Cooler: (circle one) Client URC		Temp Gun ID# Qi-015			
Report Delivery: (Circle One) E-Mail USPS				URC Containers: (circle one) ALL SOME NONE		Temperature at receipt: 21.7 °C			
Report Results To: (Circle One) MDL MRL				Sampling Procedure Number:		Cooling process, on ice: yes no			
Comments:									

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number: _____
Date: 5/22/20

Project Name: Springfield School District		Client Contact Person: John Harshberger		Telephone: 541 979 9667					
Riverbend Elementary School		E-Mail: john.harshberger@springfield.k12.or.us		Fax: _____					
PWS Number: _____		Sample Collected By: MARCO RODRIGUEZ							
Report Data To Oregon DWP? (Circle One) Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours							
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION		MATRIX		ANALYSIS REQUIRED			
URC SAMPLE ID		DATE	TIME	# of Bottles	DW		AQ	Soil / Sludge	Solid
1005261044	20831600 011BF	5/20/20	05:11	1	☐	☐	☐	☐	☐
-11	20831600 012BF		05:11	1	☐	☐	☐	☐	☐
	20831600 013BF		05:13	1	☐	☐	☐	☐	☐
-12	20831600 014BF		05:13	1	☐	☐	☐	☐	☐
	20831600 015BF		05:14	1	☐	☐	☐	☐	☐
-13	20831600 016BF		05:14	1	☐	☐	☐	☐	☐
-14	20831600 017SF		05:16	1	☐	☐	☐	☐	☐
-15	20831600 018BF		05:16	1	☐	☐	☐	☐	☐
-16	20831600 019BF		05:18	1	☐	☐	☐	☐	☐
-17	20831600 020BF		05:19	1	☐	☐	☐	☐	☐
Relinquished By Customer/Sample Collector: _____		Date/Time: 5/22/20 08:32		Received By Sample Custodian: _____		Date/Time: 5/20/20 13:00			
Relinquished By Sample Custodian: _____		Date/Time: 5/20/20 14:48		Received By Log In: _____		Date/Time: 5/27/20 15:20			
Relinquished By Log In: _____		Date/Time: 5/20/20 14:48		Received By Analyst/Custodian: _____		Date/Time: 5/27/20 15:20			
Signature		Signature		Signature		Signature			
REPORTING PREFERENCES		LAB USE ONLY		Cooler: (circle one) Client URC		Temp Gun ID# Qi-015			
Report Delivery: (Circle One) E-Mail USPS		Cooler: (circle one) Client URC		URC Containers: (circle one) ALL SOME NONE		Temperature at receipt: 21.7 °C			
Report Results To: (Circle One) MDL MRL		Sampling Procedure Number: _____		Cooling process, on ice: yes no					
Comments: _____									

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number: _____
Date: 5/22/26

Project Name: Springfield School District		Client Contact Person: John Harshberger		Telephone: 541 979 9667					
Riverbend Elementary School		E-Mail: john.harshberger@springfield.k12.or.us		Fax: _____					
PWS Number: _____		Sample Collected By: <u>MA810</u> <u>RODRIQUEZ</u>							
Report Data To Oregon DWP? (Circle One) Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours							
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION		MATRIX		ANALYSIS REQUIRED			
URC SAMPLE ID		DATE	TIME	# of Bottles	DW		AQ	Soil / Sludge	Solid
1052616-18	20831600 021BF	5/20/26	05:19		☐	☐	☐	☐	
-19	20831600 022CF		05:21		☐	☐	☐	☐	
-20	20831600 023DW		05:21		☐	☐	☐	☐	
-21	20831600 024CF		05:22		☐	☐	☐	☐	
-22	20831600 025DW		05:22		☐	☐	☐	☐	
-23	20831600 026CF		05:24		☐	☐	☐	☐	
-24	20831600 027DW		05:24		☐	☐	☐	☐	
-25	20831600 028CF		05:26		☐	☐	☐	☐	
-26	20831600 029DW		05:26		☐	☐	☐	☐	
	20831600 030CF				☐	☐	☐	☐	
Relinquished By Customer/Sample Collector: _____		Date/Time: 5/22/26 08:33		Received By Sample Custodian: _____		Date/Time: 5/22/26 13:00			
Relinquished By Sample Custodian: _____		Date/Time: 5/22/26 14:48		Received By Log In: _____		Date/Time: 5/21/26 15:26			
Relinquished By Log In: _____		Date/Time: 5/22/26 14:48		Received by Analyst/Custodian: _____		Temp Gun ID# Q1-015			
REPORTING PREFERENCES		LAB USE ONLY		Cooler: (circle one) Client URC		Temperature at receipt: 21.7 °C			
Report Delivery: (Circle One) E-Mail USPS		URC Containers: (circle one) ALL SOME NONE		Sampling Procedure Number: _____		Cooling process, on ice: yes no			
Report Results To: (Circle One) MDL MRL									
Comments: _____									

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number: _____
Date: 5/22/26

Project Name: Springfield School District		Client Contact Person: John Harshberger		Telephone: 541 979 9667					
Riverbend Elementary School		E-Mail: john.harshberger@springfield.k12.or.us		Fax: _____					
PWS Number: _____		Sample Collected By: MBOC RODRIGUEZ							
Report Data To Oregon DWP? (Circle One) Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours							
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION		MATRIX		ANALYSIS REQUIRED			
URC SAMPLE ID		DATE	TIME	# of Bottles	DW		AQ	Soil / Sludge	Solid
10091616-27	20831600 031DW	5/20/26	—		☐	☐	☐	☐	☐
-27	20831600 032CF		05:28		☐	☐	☐	☐	☐
-28	20831600 033DW		05:29		☐	☐	☐	☐	☐
-29	20831600 034CF		05:32		☐	☐	☐	☐	☐
-30	20831600 035DW		05:32		☐	☐	☐	☐	☐
-31	20831600 036CF		05:33		☐	☐	☐	☐	☐
-32	20831600 037DW		05:33		☐	☐	☐	☐	☐
-33	20831600 038CF		05:35		☐	☐	☐	☐	☐
-34	20831600 039DW		05:35		☐	☐	☐	☐	☐
-35	20831600 040BF		05:37		☐	☐	☐	☐	☐
Relinquished By Customer/Sample Collector: _____		Date/Time: 5/22/26 8:34		Received By Sample Custodian: _____		Date/Time: _____			
Relinquished By Sample Custodian: _____		Date/Time: _____		Received By Log In: _____		Date/Time: 5/22/26 13:00			
Relinquished By Log In: _____		Date/Time: 5/21/26 14:48		Received By Analyst/Custodian: _____		Date/Time: 5/21/26 15:26			
REPORTING PREFERENCES		LAB USE ONLY		Cooler: (circle one) Client URC		Temp Gun ID# 01-015			
Report Delivery: (Circle One) E-Mail USPS				URC Containers: (circle one) ALL SOME NONE		Temperature at receipt: 21.7 °C			
Report Results To: (Circle One) MDL MRL				Sampling Procedure Number: _____		Cooling process, on ice: yes no			
Comments: _____									

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number: _____
Date: 5/22/26

Project Name: Springfield School District		Client Contact Person: John Harshberger		Telephone: 541 979 9667					
Riverbend Elementary School		E-Mail: john.harshberger@springfield.k12.or.us		Fax: _____					
PWS Number: _____		Sample Collected By: MRLC RODRIGUEZ							
Report Data To Oregon DWP? Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours							
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION		MATRIX		ANALYSIS REQUIRED			
URC SAMPLE ID		DATE	TIME	# of Bottles	DW		AQ	Soil / Sludge	Solid
6052616-36	20831600 041BF	5/20/26	05:37		☐	☐	☐	☐	☐
-37	20831600 042BF		05:37		☐	☐	☐	☐	☐
-38	20831600 043BF		05:38		☐	☐	☐	☐	☐
-39	20831600 044BF		05:40		☐	☐	☐	☐	☐
-40	20831600 045CF		05:42		☐	☐	☐	☐	☐
.	20831600 046DW		—		☐	☐	☐	☐	☐
-41	20831600 047BF		05:43		☐	☐	☐	☐	☐
-42	20831600 048BF		05:44		☐	☐	☐	☐	☐
	20831600 049BF		—		☐	☐	☐	☐	☐
-43	20831600 050BF		05:45		☐	☐	☐	☐	☐
Relinquished By Customer/Sample Collector: _____		Date/Time: 5/22/26 05:35		Received By Sample Custodian: _____		Date/Time: 5/22/26 05:35			
Signature: _____		Signature: _____		Received By Log In: _____		Date/Time: 5/22/26 13:20			
Relinquished By Sample Custodian: _____		Signature: _____		Received By Analysis/Custodian: _____		Date/Time: 5/22/26 15:26			
Signature: _____		Signature: _____		Signature: _____		Signature: _____			
REPORTING PREFERENCES		LAB USE ONLY		Cooler: (circle one) Client URC		Temp Gun ID# Qi-015			
Report Delivery: (Circle One) E-Mail USPS				URC Containers: (circle one) ALL SOME NONE		Temperature at receipt: 21.2 °C			
Report Results To: (Circle One) MDL MRL						Cooling process, on ice: yes no			
Comments: _____		Sampling Procedure Number: _____							

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number: _____
Date: 5/22/26

Project Name: Springfield School District		Client Contact Person: John Harshberger		Telephone: 541 979 9667				
Riverbend Elementary School		E-Mail: john.harshberger@springfield.k12.or.us		Fax: _____				
PWS Number: _____		Sample Collected By: MAJO RODRIGUEZ						
Report Data To Oregon DWP? (Circle One) Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours						
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION	# of Bottles	MATRIX	ANALYSIS REQUIRED			
URC SAMPLE ID		DATE	TIME	DW	AQ	Soil / Sludge	Solid	
U0526016-	20831600 051BF	5/20/26	—	☐	☐	☐	☐	
-44	20831600 052CF		05:46	☐	☐	☐	☐	
-45	20831600 053DW		05:46	☐	☐	☐	☐	
-46	20831600 054CF		05:48	☐	☐	☐	☐	
-47	20831600 055DW		05:46	☐	☐	☐	☐	
-48	20831600 056CF		05:49	☐	☐	☐	☐	
-49	20831600 057DW		05:49	☐	☐	☐	☐	
-50	20831600 058CF		05:50	☐	☐	☐	☐	
-51	20831600 059DW		05:50	☐	☐	☐	☐	
-52	20831600 060CF		05:51	☐	☐	☐	☐	
Relinquished By Customer/Sample Collector: _____		Signature _____		Received By Sample Custodian: _____		Signature _____		Date/Time _____
Relinquished By Sample Custodian: _____		Signature _____		Received By Login: _____		Signature _____		Date/Time _____
Relinquished By Log In: _____		Date/Time _____		Received By Analyst/Custodian: _____		Signature _____		Date/Time _____
REPORTING PREFERENCES		LAB USE ONLY		Cooler: (circle one) Client URC		Temp Gun ID# 01-015		Temperature at receipt: 21.7 °C
Report Delivery: (Circle One) E-Mail USPS		URC Containers: (circle one) ALL SOME NONE		Cooling process, on ice: yes no				
Report Results To: (Circle One) MDL MRL		Sampling Procedure Number: _____						
Comments: _____								

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number: _____
Date: 5/22/26

Project Name: Springfield School District		Client Contact Person: John Harshberger		Telephone: 541 979 9667				
Riverbend Elementary School		E-Mail: john.harshberger@springfield.k12.or.us		Fax: _____				
PWS Number: _____		Sample Collected By: MARLO BODEKNEZ						
Report Data To Oregon DWP? (Circle One) Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours						
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION	# of Bottles	MATRIX	ANALYSIS REQUIRED			
URC SAMPLE ID		DATE	TIME	DW	AQ	Soil / Sludge	Solid	
16052616-53	20831600 061DW	5/20/26	05:52	☐	☐	☐	☐	
-54	20831600 062CF		05:53	☐	☐	☐	☐	
-55	20831600 063DW		05:53	☐	☐	☐	☐	
	20831600 064CF		—	☐	☐	☐	☐	
-56	20831600 065DW		05:54	☐	☐	☐	☐	
-57	20831600 066BF		05:56	☐	☐	☐	☐	
-58	20831600 067BF		05:56	☐	☐	☐	☐	
-59	20831600 068BF		05:56	☐	☐	☐	☐	
-60	20831600 069BF		05:57	☐	☐	☐	☐	
-61	20831600 070CF		05:59	☐	☐	☐	☐	
Relinquished By Customer/Sample Collector: _____		Signature		Date/Time				
Relinquished By Sample Custodian: _____		Signature		Date/Time				
Relinquished By Log In: _____		Signature		Date/Time				
Relinquished By Log In: _____		Signature		Date/Time				
REPORTING PREFERENCES		LAB USE ONLY						
Report Delivery: (Circle One) E-Mail USPS		Cooler: (circle one) Client URC						
Report Results To: (Circle One) MDL MRL		URC Containers: (circle one) ALL SOME NONE						
Comments: _____		Sampling Procedure Number: _____						
		Temp Gun ID# QI-015						
		Temperature at receipt: 21.7 °C						
		Cooling process, on ice: yes no						

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number:
Date: 5/22/26

Project Name: Springfield School District		Client Contact Person: John Harsberger		Telephone: 541 979 9667	
Riverbend Elementary School		E-Mail: john.harsberger@springfield.k12.or.us		Fax:	
PWS Number:		(Circle One) Report Data To Oregon DWP? Yes No			
Sample Collected By: MADU <u>Reddick</u>		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours			
Lab Use Only		SAMPLE LOCATION / CLIENT SAMPLE ID		COLLECTION	
URC SAMPLE ID		DATE		TIME	
10052616-62		5/20/26		06:03	
-63				06:04	
-64				06:05	
-65				06:05	
-66				06:05	
-67				06:06	
-68				06:07	
-69				06:08	
-70				06:09	
-71				06:09	
20831600 071BF		20831600 072CF		20831600 073BF	
20831600 074BF		20831600 075BF		20831600 076BF	
20831600 077CF		20831600 078DW		20831600 079CF	
20831600 080DW					
Relinquished By Customer/Sample Collector: <u>Paul Harsberger</u>		Date/Time: 5/22/26 08:32		Received By Sample Custodian: <u>John Harsberger</u>	
Relinquished By Sample Custodian: <u>Paul Harsberger</u>		Date/Time: 5/22/26 08:32		Received By Login: <u>John Harsberger</u>	
Relinquished By Log In: <u>Paul Harsberger</u>		Date/Time: 5/22/26 14:48		Received By Analyst/Custodian: <u>John Harsberger</u>	
Signature		Signature		Signature	
REPORTING PREFERENCES		LAB USE ONLY		Temp Gun ID# QI-015	
Report Delivery: (Circle One) E-Mail USPS		Cooler: (circle one) Client URC		Temperature at receipt: 21.7 °C	
Report Results To: (Circle One) MDL MRL		URC Containers: (circle one) ALL SOME NONE		Cooling process, on ice: yes no	
Comments:		Sampling Procedure Number:			

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number:
Date: 5/22/20

Project Name: Springfield School District		Client Contact Person: John Harshberger		Telephone: 541 979 9667	
Riverbend Elementary School		E-Mail: john.harshberger@springfield.k12.or.us		Fax:	
PWS Number:		Sample Collected By: MABU 200241062			
Report Data To Oregon DWP? (Circle One) Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: Miles Lab Tech Hours			
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION	# of Bottles	MATRIX	ANALYSIS REQUIRED
URC SAMPLE ID		DATE	TIME	DW AQ Soil / Sludge Solid	
10052010 -72	20831600 081CF	5/20/20	06:10	☐	☐
-73	20831600 082DW		06:11	☐	☐
-74	20831600 083CF		06:12	☐	☐
-75	20831600 084DW		06:12	☐	☐
-76	20831600 085CF		06:14	☐	☐
-77	20831600 086DW		06:14	☐	☐
-78	20831600 087CF		06:15	☐	☐
-79	20831600 088DW		06:15	☐	☐
-80	20831600 089CF		06:16	☐	☐
-81	20831600 090DW		06:16	☐	☐
Relinquished By Customer/Sample Collector: [Signature]		Received By Sample Custodian: [Signature]		Date/Time: 5/20/20 0:35	
Relinquished By Sample Custodian: [Signature]		Received By Log In: [Signature]		Date/Time: 5/20/20 13:00	
Relinquished By Log In: [Signature]		Received By Analyst/Custodian: [Signature]		Date/Time: 5/27/20 15:00	
REPORTING PREFERENCES		LAB USE ONLY		Temp Gun ID# 01-015	
Report Delivery: (Circle One) E-Mail USPS		Cooler: (circle one) Client URC		Temperature at receipt: 21.7 °C	
Report Results To: (Circle One) MDL MRL		URC Containers: (circle one) ALL SOME NONE		Cooling process, on ice: yes no	
Comments:		Sampling Procedure Number:			

CHAIN OF CUSTODY RECORD
ANALYTICAL SERVICES

Umpqua Research Company
626 N.E. DIVISION ST. - P.O. BOX 609
MYRTLE CREEK, OR 97457
Ph: (541) 863-5201 Fax: (541) 863-6199
ORELAP ID # OR100031

CLIENT NAME: Springfield SD 19
MAILING ADDRESS: 1890 42nd St., Springfield, OR
PO Number: _____
Date: 5/22/26

Project Name: Springfield School District		Client Contact Person: John Harshberger		Telephone: 541 979 9667				
Riverbend Elementary School		E-Mail: john.harshberger@springfield.k12.or.us		Fax: _____				
PWS Number: _____		Sample Collected By: MADIE ROBERGUEZ						
Report Data To Oregon DWP? Yes No		If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours						
Lab Use Only	SAMPLE LOCATION / CLIENT SAMPLE ID	COLLECTION	# of Bottles	MATRIX	ANALYSIS REQUIRED			
URC SAMPLE ID		DATE	TIME	DW	AQ	Soil / Sludge	Solid	
1052616-82	20831600 091CF	5/22/26	06:17	☐	☐	☐	☐	
-83	20831600 092DW		06:19	☐	☐	☐	☐	
-84	20831600 093CF		06:18	☐	☐	☐	☐	
-85	20831600 094DW		06:19	☐	☐	☐	☐	
-86	20831600 095BF		06:20	☐	☐	☐	☐	
	20831600 096BF		—	☐	☐	☐	☐	
-87	20831600 097BF		06:21	☐	☐	☐	☐	
	20831600 098BF		—	☐	☐	☐	☐	
-88	20831600 099DW		06:22	☐	☐	☐	☐	
-89	20831600 100SF		06:23	☐	☐	☐	☐	
Relinquished By Customer/Sample Collector: _____		Date/Time: 5/22/26 07:38		Received By Sample Custodian: _____		Date/Time: _____		
Relinquished By Sample Custodian: _____		Date/Time: _____		Received By Log In: _____		Date/Time: 5/22/26 13:00		
Relinquished By Log In: _____		Date/Time: 5/22/26 14:48		Received By Analyst/Custodian: _____		Date/Time: 5/22/26 15:00		
REPORTING PREFERENCES		LAB USE ONLY		Cooler: (circle one) Client URC		Temp Gun ID# Qi-015		
Report Delivery: (Circle One) E-Mail USPS				URC Containers: (circle one) ALL SOME NONE		Temperature at receipt: 21.7 °C		
Report Results To: (Circle One) MDL MRL						Cooling process, on ice: yes no		
Comments: _____		Sampling Procedure Number: _____						

ANALYTICAL SERVICES

CLIENT NAME: Springfield SD 19

MAILING ADDRESS: 1890 42nd St., Springfield, OR

MAILING ADDRESS: 1890 42nd St., Springfield, OR

PO Number: _____

Date: 5/22/22

Project Name: <u>Springfield School District</u> Riverbend Elementary School PWS Number: _____ Report Data To Oregon DWP? (Circle One) Yes ☐ No ☒										Client Contact Person: <u>John Harsberger</u> E-Mail: <u>john.harsberger@springfield.k12.or.us</u> Telephone: <u>541 979 9667</u> Fax: _____													
Sample Collected By: <u>MAKLO</u> If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours										Sample Collected By: <u>MAKLO</u> If the sample was collected by a URC Lab Technician, enter the Sample Collection Fee miles and hours to be charged to client: _____ Miles _____ Lab Tech Hours													
Lab Use Only		SAMPLE LOCATION / CLIENT SAMPLE ID		COLLECTION		MATRIX				ANALYSIS REQUIRED													
URC SAMPLE ID				DATE	TIME	# of Bottles	DW	AQ	Soil / Sludge			Solid											
<u>1052610-90</u>		20831600 101OT		<u>5/20/26</u>	<u>06:23</u>		☐	☐	☐	☐													
<u>-91</u>		20831600 102BF			<u>06:24</u>		☐	☐	☐	☐													
<u>-92</u>		20831600 103BF			<u>06:24</u>		☐	☐	☐	☐													
<u>-93</u>		20831600 104SF			<u>06:25</u>		☐	☐	☐	☐													
<u>-94</u>		20831600 105NS			<u>06:26</u>		☐	☐	☐	☐													
<u>-95</u>		20831600 106OT			<u>06:27</u>		☐	☐	☐	☐													
<u>-96</u>		20831600 107BF					☐	☐	☐	☐													
Relinquished By Customer/Sample Collector: _____ Signature: _____ Date/Time: <u>5/22/26 08:39</u>												Received By Sample Custodian: _____ Signature: _____ Date/Time: <u>5/22/26 13:00</u>											
Relinquished By Sample Custodian: _____ Signature: _____ Date/Time: _____												Received By Log-In: _____ Signature: _____ Date/Time: _____											
Relinquished By Log In: _____ Signature: _____ Date/Time: _____												Received by Analysis/Custodian: _____ Signature: _____ Date/Time: <u>5/22/26 15:00</u>											
REPORTING PREFERENCES Report Delivery: (Circle One) E-Mail USPS Report Results To: (Circle One) MDL MRL Comments: _____												LAB USE ONLY Cooler: (circle one) Client URC URC Containers: (circle one) ALL SOME NONE Sampling Procedure Number: _____ Temp Gun ID# <u>Qi-015</u> Temperature at receipt: <u>21.7</u> °C Cooling process, on ice: <u>yes</u> ☒ <u>no</u> ☐											