

Belfast Central School																	Date Last Updated:		7/10/2026	
Lead in School Drinking Water Remedial Action Plan																				
School Outlet ID (Should match Sampling Plan)	Laboratory Sample ID	Outlet Location	Outlet Description	Was the outlet deemed 'Applicable' or 'Not Applicable' for sampling? *if not applicable place criteria in Notes/Comments	Sample Results (ppb or mcg/L) *if not applicable mark "N/A"		Remedial Actions (Please mark "x" for all that apply)													
					Initial	Post Remediation	Date Taken out of Service	Date Retested	Date Returned to Service	Outlet / Plumbing Replacement	Permanent Removal	Actions Requiring Maintenance Schedule							Date(s) Remedial Action Taken	Notes/Comments
												Filter Installed and Maintained	Signage	Supervision	Continuing Education	Systematic Flushing	Engineering Controls			
BCS Main Building	218.1-1	Kitchen Back Corner Handwash	Sink	Not Applicable	12.1	<1.0	12/2/25	5/29/26	6/18/2026			1/5/26	12/2/25			X			Hand Washing Station labeled with clear 'Do not Drink' signage.	
BCS Main Building	218.1-2	Kitchen Center 2 Bay	Kitchen Sink	Applicable	7.2	3.06	12/2/25	1/23/26	1/30/2026			1/5/26	12/2/25			X			water filtration system with lead removal installed	
BCS Main Building	218.1-4	Kitchen 3 Bay Left	Kitchen Sink	Applicable	5.5	<1.00	12/2/25	1/23/26	1/30/2026			1/5/26	12/2/25			X			water filtration system with lead removal installed	
BCS Main Building	218.1-6	Kitchen 3 Bay Right	Kitchen Sink	Applicable	12.4	2.99	12/2/25	1/23/26	1/30/2026			1/5/26	12/2/25			X			water filtration system with lead removal installed	
BCS Main Building	218.1-7	Kitchen Hand Wash by Cafe Entrance	Sink	Not Applicable	6.9	<1.00	12/2/25	1/23/26	1/30/2026				12/2/25			X			Hand Washing Station labeled with clear 'Do not Drink' signage.	
BCS Main Building	218.1-8	Kitchen Lav	Restroom Sink	Not Applicable	5.3	1.67	12/2/25	1/23/26	1/30/2026				12/2/25			X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-11	150 Kitchenette Sink	Sink	Applicable	9.6	<1.00	12/2/25	3/31/26	4/14/2026			1/5/26	12/2/25	X	X	X				
BCS Main Building	218.1-12	150 Left Lav	Restroom Sink	Not Applicable	14.7	5	12/2/25	2/25/26	3/17/2026				12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-13	150 Left Low Sink	Classroom Sink	Not Applicable	5.7		12/2/25	3/31/26	<1.0				12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-14	150 Right Low Sink	Classroom Sink	Not Applicable	7.5		12/2/25	3/31/26	<1.0				12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-15	150 Right Lav	Restroom Sink	Not Applicable	9.9	4.09	12/2/25	2/25/26	3/17/2026				12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-20	106D Faculty Room	Sink	Applicable	7	1.2	12/2/25	1/23/26	1/30/2026			1/5/26	12/2/25			X				
BCS Main Building	218.1-21	100 Main	Classroom Sink	Not Applicable	5.4	<1.0	12/2/25	3/31/26	4/14/2026				12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-22	100 DF	Drinking Fountain	Applicable	5.4	<1.0	12/2/25	3/31/26	4/14/2026				12/2/25			X				
BCS Main Building	218.1-23	100 Lav	Restroom Sink	Not Applicable	6.4	<1.0	12/2/25	5/29/26	6/18/2026				12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-25	101 DF	Drinking Fountain	Applicable	11.2	<1.0	12/2/25	3/31/26	4/14/2026				12/2/25			X				
BCS Main Building	218.1-26	101 Lav	Restroom Sink	Not Applicable	5.7	4	12/2/25	1/2/00	3/17/2026				12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-27	102 Main	Classroom Sink	Not Applicable	6.9	<1.0	12/2/25	5/29/26	6/18/2026				12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-29	103 Main	Classroom Sink	Not Applicable	8.1	<1.0	12/2/25	5/29/26	6/18/2026				12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-30	103 Lav	Restroom Sink	Not Applicable	5.2	4.6	12/2/25	2/25/26	3/17/2026				12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-31	104 Main	Classroom Sink	Not Applicable	8.8	4.5	12/2/25	2/25/26	3/17/2026				12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-32	104 DF	Drinking Fountain	Applicable	5.2	4.6	12/2/25	2/25/26	3/17/2026				12/2/25			X				
BCS Main Building	218.1-33	104 Lav	Restroom Sink	Not Applicable	14.7	3.4	12/2/25	2/25/26	3/17/2026				12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-34	105 Main	Classroom Sink	Not Applicable	8	<1.0	12/2/25	5/29/26	6/18/2026				12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	
BCS Main Building	218.1-35	105 Lav	Restroom Sink	Not Applicable	7.1	<1.0	12/2/25	5/29/26	6/18/2026				12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption	

[illegible]