

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518887
LIMS Reference ID: AD18887
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Thomas Jefferson ES LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/28/2025 14:30

Reported:

05/15/2025 17:16

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TJES-FB Lims Reference ID: AD18887-01 Matrix: Drinking Water Sampled: 04/25/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-14 Lims Reference ID: AD18887-02 Matrix: Drinking Water Sampled: 04/25/25 06:32:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-13 Lims Reference ID: AD18887-04 Matrix: Drinking Water Sampled: 04/25/25 06:35:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-11 Lims Reference ID: AD18887-06 Matrix: Drinking Water Sampled: 04/25/25 06:38:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-12 Lims Reference ID: AD18887-08 Matrix: Drinking Water Sampled: 04/25/25 06:41:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-09 Lims Reference ID: AD18887-10 Matrix: Drinking Water Sampled: 04/25/25 06:44:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-07 Lims Reference ID: AD18887-12 Matrix: Drinking Water Sampled: 04/25/25 06:47:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-WC-HALL1R Lims Reference ID: AD18887-14 Matrix: Drinking Water Sampled: 04/25/25 06:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-SO-NURSE Lims Reference ID: AD18887-15 Matrix: Drinking Water Sampled: 04/25/25 06:52:00									
Metals									
Lead	6.72		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:34	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518887
LIMS Reference ID: AD18887
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Thomas Jefferson ES LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/28/2025 14:30

Reported:

05/15/2025 17:16

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TJES-SO-MAIN Lims Reference ID: AD18887-17 Matrix: Drinking Water Sampled: 04/25/25 06:55:00									
Metals									
Lead	5.80		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-WC-HALL2R Lims Reference ID: AD18887-19 Matrix: Drinking Water Sampled: 04/25/25 06:58:00									
Metals									
Lead	1.28		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-SO-05 Lims Reference ID: AD18887-20 Matrix: Drinking Water Sampled: 04/25/25 07:00:00									
Metals									
Lead	2.03		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-03 Lims Reference ID: AD18887-22 Matrix: Drinking Water Sampled: 04/25/25 07:03:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-04 Lims Reference ID: AD18887-24 Matrix: Drinking Water Sampled: 04/25/25 07:06:00									
Metals									
Lead	1.15		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-02 Lims Reference ID: AD18887-26 Matrix: Drinking Water Sampled: 04/25/25 07:09:00									
Metals									
Lead	1.32		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-WC-HALL3L Lims Reference ID: AD18887-28 Matrix: Drinking Water Sampled: 04/25/25 07:12:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-WC-HALL3R Lims Reference ID: AD18887-29 Matrix: Drinking Water Sampled: 04/25/25 07:13:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 14:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-BF-HALL3 Lims Reference ID: AD18887-30 Matrix: Drinking Water Sampled: 04/25/25 07:13:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:21	05/12/25 15:01	PL	EPA 200.8 (DA)/EPA 200.8

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Thomas Jefferson ES LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/28/2025 14:30

Reported:

05/15/2025 17:16

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TJES-DW-GYM									
Lims Reference ID:			AD18887-31		Matrix: Drinking Water			Sampled: 04/25/25 07:15:00	
Metals									
Lead	2.63		1	1.00	µg/L	05/09/25 12:21	05/12/25 15:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-SO-FAC									
Lims Reference ID:			AD18887-33		Matrix: Drinking Water			Sampled: 04/25/25 07:18:00	
Metals									
Lead	4.14		1	1.00	µg/L	05/09/25 12:21	05/12/25 15:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-DW-CAFE									
Lims Reference ID:			AD18887-35		Matrix: Drinking Water			Sampled: 04/25/25 07:21:00	
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-SO-KIT1									
Lims Reference ID:			AD18887-37		Matrix: Drinking Water			Sampled: 04/25/25 07:24:00	
Metals									
Lead	1.57		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-SO-KIT2									
Lims Reference ID:			AD18887-39		Matrix: Drinking Water			Sampled: 04/25/25 07:27:00	
Metals									
Lead	5.13		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-DW-114									
Lims Reference ID:			AD18887-41		Matrix: Drinking Water			Sampled: 04/25/25 07:31:00	
Metals									
Lead	1.44		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-DW-113									
Lims Reference ID:			AD18887-43		Matrix: Drinking Water			Sampled: 04/25/25 07:34:00	
Metals									
Lead	2.52		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-DW-112									
Lims Reference ID:			AD18887-45		Matrix: Drinking Water			Sampled: 04/25/25 07:37:00	
Metals									
Lead	2.01		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-DW-109									
Lims Reference ID:			AD18887-47		Matrix: Drinking Water			Sampled: 04/25/25 07:40:00	
Metals									
Lead	1.01		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:41	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518887
LIMS Reference ID: AD18887
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Thomas Jefferson ES LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/28/2025 14:30

Reported:

05/15/2025 17:16

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TJES-02-WC-HALL4L Lims Reference ID: AD18887-49 Matrix: Drinking Water Sampled: 04/25/25 07:43:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-WC-HALL4R Lims Reference ID: AD18887-50 Matrix: Drinking Water Sampled: 04/25/25 07:43:00									
Metals									
Lead	1.05		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-SO-LIB Lims Reference ID: AD18887-51 Matrix: Drinking Water Sampled: 04/25/25 07:45:00									
Metals									
Lead	1.23		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-DW-116 Lims Reference ID: AD18887-53 Matrix: Drinking Water Sampled: 04/25/25 07:48:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 15:54	05/14/25 13:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-WC-HALL6 Lims Reference ID: AD18887-55 Matrix: Drinking Water Sampled: 04/25/25 07:51:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-BF-HALL6 Lims Reference ID: AD18887-56 Matrix: Drinking Water Sampled: 04/25/25 07:51:00									
Metals									
Lead	ND		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-DW-HALL6 Lims Reference ID: AD18887-57 Matrix: Drinking Water Sampled: 04/25/25 07:53:00									
Metals									
Lead	3.05		1	1.00	µg/L	05/09/25 12:24	05/12/25 15:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-WC-HALL5L Lims Reference ID: AD18887-59 Matrix: Drinking Water Sampled: 04/25/25 07:56:00									
Metals									
Lead	1.97		1	1.00	µg/L	05/09/25 12:24	05/12/25 16:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-DW-104 Lims Reference ID: AD18887-60 Matrix: Drinking Water Sampled: 04/25/25 07:58:00									
Metals									
Lead	1.41		1	1.00	µg/L	05/09/25 12:24	05/12/25 16:04	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518887
LIMS Reference ID: AD18887
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Thomas Jefferson ES LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/28/2025 14:30
Reported: 05/15/2025 17:16

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: TJES-02-DW-102 Lims Reference ID: AD18887-62 Matrix: Drinking Water Sampled: 04/25/25 08:01:00									
Metals									
Lead	3.92		1	1.00	µg/L	05/09/25 12:24	05/12/25 16:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: TJES-02-DW-101 Lims Reference ID: AD18887-64 Matrix: Drinking Water Sampled: 04/25/25 08:03:00									
Metals									
Lead	1.70		1	1.00	µg/L	05/09/25 12:24	05/12/25 16:08	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518887
LIMS Reference ID: AD18887
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Thomas Jefferson ES LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/28/2025 14:30
Reported: 05/15/2025 17:16

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518887
LIMS Reference ID: AD18887
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Thomas Jefferson ES LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/28/2025 14:30
Reported: 05/15/2025 17:16

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry

Chain of Custody

EMSL Order Number (Lab Use Only):

AD18887

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Report To Contact Name: James Eberts		Bill To Company: Epic Environmental Services, LLC	
Company Name: Epic Environmental Services, LLC		Attention To: James Eberts / Timothy Eberts	
Street: 80 Fork Bridge Road		Street: 80 Fork Bridge Road	
City: Pittsgrove	State/Province: NJ	City: Pittsgrove	State/Province: NJ
Zip/Postal Code: 08318	Zip/Postal Code: 08318	Phone: 856-205-1077	Fax:
Project Name: Thomas Jefferson ES / IW		Email Results To: jeberts@epicenviro.com / teberts@epicenviro.com	
U.S. State where Samples Collected: NJ		Purchase Order: 24-1071C	
Number of Samples in Shipment: 65		Date of Shipment: 4/28/25	

Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):			
Samples Collected by: EMSL ☐ Client ☒ check one		Sampled By (Signature): Casey Lyons	
Standard Turnaround Time: ☒ 2 Weeks		The following TATs are subject to lab approval: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day	

Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O= Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	List Test(s) Needed				Comments		
						Field pH	Field Temp. Deg C	Field Temp. Test Time	Field Temp. Test Time			
TJES -FB	☐	☒	4/25/25 N/A	W	2						Field Blank	
TJES-DW-14	☐	☒	0632	W	1							
↓ (Flush)	☐	☒	0633	W							Flush	
TJES-DW-13	☐	☒	0635	W								
↓ (Flush)	☐	☒	0636	W	↓						Flush	
Released By (Signature) Casey Lyons				Date & Time 4/28/2025				Received By Marilyn (WT)				Date & Time 4/28/25 1430

Please indicate reporting requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other _____

Instructions or Comments: Note: Field pH and Field Temperature are tested on the same day as the date of sample collection. Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING
EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD18887

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples	Comp	Lab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O= Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	List Test(s) Needed				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
TJES-DW-11 ↓ (Flush)	☐	☐	4/25/25 0638	W	2										
TJES-DW-12 ↓ (Flush)	☐	☐	0639	W											Flush
TJES-DW-09 ↓ (Flush)	☐	☐	0641	W											Flush
TJES-DW-07 ↓ (Flush)	☐	☐	0642	W											Flush
TJES-DW-09 ↓ (Flush)	☐	☐	0644	W											Flush
TJES-DW-07 ↓ (Flush)	☐	☐	0645	W											Flush
TJES-DW-07 ↓ (Flush)	☐	☐	0647	W											Flush
TJES-DW-07 ↓ (Flush)	☐	☐	0648	W											Flush
TJES-WC-HALL1R	☐	☐	0650	W											
TJES-SO-NURSE ↓ (Flush)	☐	☐	0652	W											
TJES-SO-MAIN ↓ (Flush)	☐	☐	0653	W											Flush
TJES-SO-MAIN ↓ (Flush)	☐	☐	0655	W											
TJES-WC-HALL2R	☐	☐	0656	W											
TJES-SO-05 ↓ (Flush)	☐	☐	0658	W											
TJES-SO-05 ↓ (Flush)	☐	☐	0700	W											
TJES-SO-05 ↓ (Flush)	☐	☐	0701	W											
TJES-DW-03	☐	☐	0703	W											

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD18887

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples			Matrix	Preservative	EPA	List Test(s) Needed				Test Time			Comments
	Comp	Grab	Collect Date/Time				W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	200.8	Field pH	Field Temp	Deg C	Field Temp	
TJES-DW-03 (Flush)	☐	☐	4/25/25 0704	W	2								Flush	
TJES-DW-04 ↓ (Flush)	☐	☐	0706	W									Flush	
TJES-DW-02 ↓ (Flush)	☐	☒	0709	W									Flush	
TJES-WC-HALL3L	☐	☒	0710	W									Flush	
TJES-WC-HALL3R	☐	☒	0712	W										
TJES-BF-HALL3	☐	☒	0713	W										
TJES-DW-GYM ↓ (Flush)	☐	☒	0715	W									Flush	
TJES-SO-FAC ↓ (Flush)	☐	☒	0716	W									Flush	
TJES-DW-CAFE ↓ (Flush)	☐	☒	0718	W									Flush	
TJES-SO-KIT1 ↓ (Flush)	☐	☒	0719	W									Flush	
TJES-SO-KIT2	☐	☒	0721	W										
	☐	☒	0722	W										
	☐	☒	0724	W										
	☐	☒	0725	W										
	☐	☒	0727	W										

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD18887

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Matrix	Preservative	EPA	List Test(s) Needed				Field Temp			Comments
	Comp	Grab				Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	200. 8	Field pH		Field pH	
TJES-SO-KIT3 (Flush)	☐	☐	4/25/25 0728	W	2								Flush
TJES-02-DW-114 ↓ (Flush)	☐	☐	0731	W									Flush
TJES-02-DW-113 ↓ (Flush)	☐	☐	0732	W									Flush
TJES-02-DW-112 ↓ (Flush)	☐	☐	0734	W									Flush
TJES-02-DW-111 ↓ (Flush)	☐	☐	0735	W									Flush
TJES-02-DW-110 ↓ (Flush)	☐	☐	0737	W									Flush
TJES-02-DW-109 ↓ (Flush)	☐	☐	0738	W									Flush
TJES-02-DW-108 ↓ (Flush)	☐	☐	0740	W									Flush
TJES-02-DW-107 ↓ (Flush)	☐	☐	0741	W									Flush
TJES-02-DW-106 ↓ (Flush)	☐	☐	0743	W									Flush
TJES-02-DW-105 ↓ (Flush)	☐	☐	0743	W									Flush
TJES-02-DW-104 ↓ (Flush)	☐	☐	0745	W									Flush
TJES-02-DW-103 ↓ (Flush)	☐	☐	0746	W									Flush
TJES-02-DW-102 ↓ (Flush)	☐	☐	0748	W									Flush
TJES-02-DW-101 ↓ (Flush)	☐	☐	0749	W									Flush
TJES-02-DW-100 ↓ (Flush)	☐	☐	0751	W									Flush
TJES-02-BF-HAL46	☐	☐	0751	W									Flush

(Lab) Received Temperature: _____ °C



EMSL Order Number (Lab Use Only):

PHONE: _____
FAX: _____

418887

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Matrix	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	List Test(s) Needed						Comments
	Comp	Grab			Collect Date/Time	EPA	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	
TJES-02-DW-HALL6 ↓ (Flush)	☐	☐	W	2							Flush
TJES-02-LC-HALLSL	☐	☐	W	↓							
TJES-02-DW-104 ↓ (Flush)	☐	☒	W								Flush
TJES-02-DW-102 ↓ (Flush)	☐	☒	W								Flush
TJES-02-DW-101 ↓ (Flush)	☐	☒	W								Flush
_____	☐	☒	W	↓							_____
	☐	☒	W								
	☐	☒	W								
	☐	☒	W								
	☐	☒	W								
	☐	☒	W								
	☐	☒	W								
	☐	☒	W								
	☐	☒	W								
	☐	☒	W								

(Lab) Received Temperature: °C

