

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518896
LIMS Reference ID: AD18896
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Washington TWP HS - Core LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/29/2025 14:30

Reported:

05/16/2025 18:06

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: CORE-FB

Lims Reference ID: AD18896-01 Matrix: Drinking Water

Sampled: 04/23/25 00:00:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:09	05/15/25 00:48	JW1	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	-----	--------------------------

Sample: WTHS-CORE-WC-Hall1CR

Lims Reference ID: AD18896-02 Matrix: Drinking Water

Sampled: 04/23/25 06:05:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:09	05/15/25 00:50	JW1	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	-----	--------------------------

Sample: WTHS-CORE-DW-Hall1CL

Lims Reference ID: AD18896-03 Matrix: Drinking Water

Sampled: 04/23/25 06:06:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:12	05/14/25 19:48	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WTHS-CORE-DW-Hall1L

Lims Reference ID: AD18896-05 Matrix: Drinking Water

Sampled: 04/23/25 06:08:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:12	05/14/25 19:43	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WTHS-CORE-BF-Hall1

Lims Reference ID: AD18896-07 Matrix: Drinking Water

Sampled: 04/23/25 06:10:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:12	05/14/25 19:50	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WTHS-CORE-SO-G104A

Lims Reference ID: AD18896-08 Matrix: Drinking Water

Sampled: 04/23/25 06:11:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:12	05/14/25 19:52	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WTHS-CORE-SO-G104B

Lims Reference ID: AD18896-10 Matrix: Drinking Water

Sampled: 04/23/25 06:13:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:12	05/14/25 19:54	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WTHS-CORE-SO-G104C

Lims Reference ID: AD18896-12 Matrix: Drinking Water

Sampled: 04/23/25 06:14:00

Metals

Lead	1.03	1	1.00	µg/L	05/13/25 17:12	05/14/25 20:00	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WTHS-CORE-SO-G104D

Lims Reference ID: AD18896-14 Matrix: Drinking Water

Sampled: 04/23/25 06:16:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:12	05/14/25 20:02	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518896
LIMS Reference ID: AD18896
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Washington TWP HS - Core LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/29/2025 14:30
Reported: 05/16/2025 18:06

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WTHS-CORE-SO-G104E Lims Reference ID: AD18896-16 Matrix: Drinking Water Sampled: 04/23/25 06:17:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 12:04	05/15/25 20:50	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: WTHS-CORE-SO-G104F Lims Reference ID: AD18896-18 Matrix: Drinking Water Sampled: 04/23/25 06:19:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-SO-G104G Lims Reference ID: AD18896-20 Matrix: Drinking Water Sampled: 04/23/25 06:21:00									
Metals									
Lead	1.49		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-SO-Lib Lims Reference ID: AD18896-22 Matrix: Drinking Water Sampled: 04/23/25 06:24:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-SO-Main Lims Reference ID: AD18896-24 Matrix: Drinking Water Sampled: 04/23/25 06:27:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-DW-G111L Lims Reference ID: AD18896-26 Matrix: Drinking Water Sampled: 04/23/25 06:29:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-DW-G111R Lims Reference ID: AD18896-28 Matrix: Drinking Water Sampled: 04/23/25 06:31:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-SO-G111 Lims Reference ID: AD18896-30 Matrix: Drinking Water Sampled: 04/23/25 06:33:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-DW-Hall3R Lims Reference ID: AD18896-32 Matrix: Drinking Water Sampled: 04/23/25 06:36:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:24	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518896
LIMS Reference ID: AD18896
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Washington TWP HS - Core LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/29/2025 14:30
Reported: 05/16/2025 18:06

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WTHS-CORE-DW-Hall3L Lims Reference ID: AD18896-34 Matrix: Drinking Water Sampled: 04/23/25 06:38:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-DW-Hall4L Lims Reference ID: AD18896-36 Matrix: Drinking Water Sampled: 04/23/25 06:40:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-DW-Hall4R Lims Reference ID: AD18896-38 Matrix: Drinking Water Sampled: 04/23/25 06:42:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-SO-Kit1 Lims Reference ID: AD18896-40 Matrix: Drinking Water Sampled: 04/23/25 06:44:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-SO-Kit2 Lims Reference ID: AD18896-42 Matrix: Drinking Water Sampled: 04/23/25 06:46:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:12	05/14/25 20:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-IM-Kit Lims Reference ID: AD18896-44 Matrix: Drinking Water Sampled: 04/23/25 06:49:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 20:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-02-DW-Hall5R Lims Reference ID: AD18896-45 Matrix: Drinking Water Sampled: 04/23/25 06:51:00									
Metals									
Lead	1.49		1	1.00	µg/L	05/14/25 17:32	05/14/25 20:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-02-DW-Hall5CR Lims Reference ID: AD18896-47 Matrix: Drinking Water Sampled: 04/23/25 06:53:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 20:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-02-DW-Hall5CL Lims Reference ID: AD18896-49 Matrix: Drinking Water Sampled: 04/23/25 06:55:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:00	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518896
LIMS Reference ID: AD18896
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Washington TWP HS - Core LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/29/2025 14:30
Reported: 05/16/2025 18:06

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WTHS-CORE-02-DW-Hall5L Lims Reference ID: AD18896-51 Matrix: Drinking Water Sampled: 04/23/25 06:57:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-02-DW-Hall6CR Lims Reference ID: AD18896-53 Matrix: Drinking Water Sampled: 04/23/25 06:59:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-02-DW-Hall6R Lims Reference ID: AD18896-55 Matrix: Drinking Water Sampled: 04/23/25 07:01:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-02-WC-Hall6 Lims Reference ID: AD18896-57 Matrix: Drinking Water Sampled: 04/23/25 07:04:00									
Metals									
Lead	1.10		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-CORE-02-BF-Hall6 Lims Reference ID: AD18896-58 Matrix: Drinking Water Sampled: 04/23/25 07:04:00									
Metals									
Lead	1.38		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:14	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518896
LIMS Reference ID: AD18896
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Washington TWP HS - Core LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/29/2025 14:30

Reported:

05/16/2025 18:06

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012518896**LIMS Reference ID:** AD18896**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Washington TWP HS - Core LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/29/2025 14:30

Reported:

05/16/2025 18:06

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
4018896

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Report To Contact Name: James Eberts				Bill To Company: Epic Environmental Services, LLC			
Company Name: Epic Environmental Services, LLC				Attention To: James Eberts / Timothy Eberts			
Street: 80 Fork Bridge Road				Street: 80 Fork Bridge Road			
City: Pittsgrove		State/Province: NJ		Zip/Postal Code: 08318		City: Pittsgrove	
Phone: 856-205-1077		Fax:		Phone: 856-205-1077		Fax:	
Project Name: <u>Washington Twp HS-Core IIV</u>				Email Results To: <u>jeberts@epiceniro.com / teberts@epicen</u>			
U.S. State where Samples Collected: NJ				Purchase Order: <u>24-10716</u>			
Number of Samples in Shipment: <u>58</u>				Date of Shipment: <u>4/28/2025</u>			
Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):							
Samples Collected by: EMSL ☐ Client ☒ check one		Sampled By (Signature): <u>James Eberts</u>		Samples Received Chilled (Y/N)			
Standard Turnaround Time: ☒ 2 Weeks		The following TATs are subject to lab approval: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day					
Failure to complete will hinder processing of samples							
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	Field pH
CORE -FB	☒	☒	4/23/25 FB	W	2	X	
CORE-WC-HAL10R	☒	☒	0605	W		X	
CORE-DW-HAL10L	☒	☒	0606	W		X	
↓ (Flush)	☒	☒	0607	W		X	
CORE-DW-HAL11L	☒	☒	0608	W		X	
Released By (Signature)			Date & Time		Received By		
<u>Casey Lyons</u>			4/28/2025		<u>Thermy (W)</u>		
					4/29/25 1430		

Please indicate reporting requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other

Instructions or Comments: Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.

Analyze FIRST DRAIN Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb

(Lab) Received Temperature: _____ °C

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
A1018896

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				List Test(s) Needed								Comments
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O= Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
CORE-Dur-HALL (Flush)	☐	☐	11/23/25 0609	W	2						Flush	
CORE-BF-HALL	☐	☐	0610	W	↓							
CORE-SO-6104A	☐	☐	0611	W								
↓ (Flush)	☐	☒	0612	W								Flush
CORE-SO-6104B	☐	☒	0613	W								
↓ (Flush)	☐	☒	0614	W								Flush
CORE-SO-6104C	☐	☒	0614	W								
↓ (Flush)	☐	☒	0615	W								Flush
CORE-SO-6104D	☐	☒	0616	W								
↓ (Flush)	☐	☒	0616	W								Flush
CORE-SO-6104E	☐	☒	0617	W								
↓ (Flush)	☐	☒	0618	W							Flush	
CORE-SO-6104F	☐	☒	0619	W								
↓ (Flush)	☐	☒	0620	W							Flush	
CORE-SO-6104G	☐	☒	0621	W								
↓ (Flush)	☐	☒	0622	W							Flush	
CORE-SO-6104H	☐	☒	0624	W								

(Lab) Received Temperature: _____ °C

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
AD18896

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples	Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	List Test(s) Needed				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
	CORE-SO-1IB(Flush)	☐	☐	4/23/24 0625	W	2										Flush
	CORE-SO-MAIN	☐	☐	0627	W											Flush
	↓ (Flush)	☐	☐	0628	W											Flush
	CORE-DW-G111L	☐	☐	0629	W											Flush
	↓ (Flush)	☐	☐	0630	W											Flush
	CORE-DW-G111R	☐	☐	0631	W											Flush
	↓ (Flush)	☐	☐	0632	W											Flush
	CORE-SO-G111	☐	☐	0633	W											Flush
	↓ (Flush)	☐	☐	0634	W											Flush
	CORE-DW-HAL3R	☐	☐	0636	W											Flush
	↓ (Flush)	☐	☐	0637	W											Flush
	CORE-DW-HAL3L	☐	☐	0638	W											Flush
	↓ (Flush)	☐	☐	0639	W											Flush
	CORE-DW-HAL4L	☐	☐	0640	W											Flush
	↓ (Flush)	☐	☐	0641	W											Flush
	CORE-DW-HAL4R	☐	☐	0642	W											Flush
	↓ (Flush)	☐	☐	0643	W											Flush

(Lab) Received Temperature: _____ °C

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
1018896

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples	Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	List Test(s) Needed	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
	CORE-SO-KIT1 ↓ (Flush)	☐	☐	4/23/25 0644 0645	W	2							Flush
	CORE-SO-KIT2 ↓ (Flush)	☐	☐	0646 0647	W								Flush
	CORE-IM-KIT ↓ (Flush)	☐	☐	0649	W								Ice Machine
	CORE-02-DW-HAUSR ↓ (Flush)	☐	☐	0651 0652	W								Flush
	CORE-02-DW-HAUSR ↓ (Flush)	☐	☐	0653 0654	W								Flush
	CORE-02-DW-HAUSR ↓ (Flush)	☐	☐	0655 0656	W								Flush
	CORE-02-DW-HAUSR ↓ (Flush)	☐	☐	0657 0658	W								Flush
	CORE-02-DW-HAUSR ↓ (Flush)	☐	☐	0659 0700	W								Flush
	CORE-02-DW-HAUSR ↓ (Flush)	☐	☐	0701 0702	W								Flush

(Lab) Received Temperature: _____ °C



AD1896

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

[illegible]

(Lab) Received Temperature: _____°C