

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Washington Twp HS - 9/10 LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/29/2025 14:30
Reported: 05/16/2025 15:29

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WTHS-9/10-FB Lims Reference ID: AD19314-01 Matrix: Drinking Water Sampled: 04/23/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-AuxBOYLR Lims Reference ID: AD19314-02 Matrix: Drinking Water Sampled: 04/23/25 07:40:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-AuxGRLLR Lims Reference ID: AD19314-03 Matrix: Drinking Water Sampled: 04/23/25 07:41:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-H111 Lims Reference ID: AD19314-04 Matrix: Drinking Water Sampled: 04/23/25 07:43:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-H110 Lims Reference ID: AD19314-05 Matrix: Drinking Water Sampled: 04/23/25 07:44:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall1L Lims Reference ID: AD19314-06 Matrix: Drinking Water Sampled: 04/23/25 07:45:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall1R Lims Reference ID: AD19314-07 Matrix: Drinking Water Sampled: 04/23/25 07:46:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Gym Lims Reference ID: AD19314-08 Matrix: Drinking Water Sampled: 04/23/25 07:48:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Block Lims Reference ID: AD19314-09 Matrix: Drinking Water Sampled: 04/23/25 07:49:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:38	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Washington Twp HS - 9/10 LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/29/2025 14:30

Reported:

05/16/2025 15:29

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WTHS-9/10-WC-Hall2L Lims Reference ID: AD19314-10 Matrix: Drinking Water Sampled: 04/23/25 07:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall2R Lims Reference ID: AD19314-11 Matrix: Drinking Water Sampled: 04/23/25 07:51:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 17:32	05/14/25 21:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-BF-Hall2 Lims Reference ID: AD19314-12 Matrix: Drinking Water Sampled: 04/23/25 07:52:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-SO-Mus Lims Reference ID: AD19314-13 Matrix: Drinking Water Sampled: 04/23/25 07:54:00									
Metals									
Lead	8.99		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall3L Lims Reference ID: AD19314-15 Matrix: Drinking Water Sampled: 04/23/25 07:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall3R Lims Reference ID: AD19314-16 Matrix: Drinking Water Sampled: 04/23/25 07:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall4L Lims Reference ID: AD19314-17 Matrix: Drinking Water Sampled: 04/23/25 07:59:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall4R Lims Reference ID: AD19314-18 Matrix: Drinking Water Sampled: 04/23/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-IM-Nurse Lims Reference ID: AD19314-19 Matrix: Drinking Water Sampled: 04/23/25 08:02:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:08	05/14/25 22:31	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Washington Twp HS - 9/10 LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/29/2025 14:30

Reported:

05/16/2025 15:29

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WTHS-9/10-SO-NurRR1 Lims Reference ID: AD19314-20 Matrix: Drinking Water Sampled: 04/23/25 08:03:00									
Metals									
Lead	1.40		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-SO-NurRR2 Lims Reference ID: AD19314-21 Matrix: Drinking Water Sampled: 04/23/25 08:03:00									
Metals									
Lead	3.11		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall5L Lims Reference ID: AD19314-23 Matrix: Drinking Water Sampled: 04/23/25 08:05:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-WC-Hall5R Lims Reference ID: AD19314-24 Matrix: Drinking Water Sampled: 04/23/25 08:06:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-WC-Hall6 Lims Reference ID: AD19314-25 Matrix: Drinking Water Sampled: 04/23/25 08:08:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02--BF-Hall6 Lims Reference ID: AD19314-26 Matrix: Drinking Water Sampled: 04/23/25 08:08:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-WC-Glock Lims Reference ID: AD19314-27 Matrix: Drinking Water Sampled: 04/23/25 08:10:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-WC-Hall6L Lims Reference ID: AD19314-28 Matrix: Drinking Water Sampled: 04/23/25 08:11:00									
Metals									
Lead	ND		1	1.00	µg/L	05/13/25 17:08	05/14/25 22:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-Fac Lims Reference ID: AD19314-29 Matrix: Drinking Water Sampled: 04/23/25 08:12:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:43	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Washington Twp HS - 9/10 LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/29/2025 14:30

Reported:

05/16/2025 15:29

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WTHS-9/10-02-WC-Hall7L Lims Reference ID: AD19314-30 Matrix: Drinking Water Sampled: 04/23/25 08:14:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-WC-Hall7R Lims Reference ID: AD19314-31 Matrix: Drinking Water Sampled: 04/23/25 08:14:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-WC-Hall8L Lims Reference ID: AD19314-32 Matrix: Drinking Water Sampled: 04/23/25 08:15:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-WC-Hall8R Lims Reference ID: AD19314-33 Matrix: Drinking Water Sampled: 04/23/25 08:16:00									
Metals									
Lead	ND		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J210A Lims Reference ID: AD19314-34 Matrix: Drinking Water Sampled: 04/23/25 08:17:00									
Metals									
Lead	4.49		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J210B Lims Reference ID: AD19314-36 Matrix: Drinking Water Sampled: 04/23/25 08:19:00									
Metals									
Lead	5.04		1	1.00	µg/L	05/14/25 10:59	05/14/25 23:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211A Lims Reference ID: AD19314-38 Matrix: Drinking Water Sampled: 04/23/25 08:21:00									
Metals									
Lead	4.26		1	1.00	µg/L	05/13/25 17:08	05/14/25 21:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211B Lims Reference ID: AD19314-40 Matrix: Drinking Water Sampled: 04/23/25 08:23:00									
Metals									
Lead	20.2		1	1.00	µg/L	05/13/25 17:08	05/14/25 22:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211B Flush Lims Reference ID: AD19314-41 Matrix: Drinking Water Sampled: 04/23/25 08:24:00									
Metals									
Lead	3.93		1	1.00	µg/L	05/14/25 15:46	05/16/25 02:58	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Washington Twp HS - 9/10 LIW

Customer PO:

24-1071C

EMSL Sales Rep:

Justin Monturano

Received:

04/29/2025 14:30

Reported:

05/16/2025 15:29

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WTHS-9/10-02-SO-J211C Lims Reference ID: AD19314-42 Matrix: Drinking Water Sampled: 04/23/25 08:25:00									
Metals									
Lead	19.1		1	1.00	µg/L	05/13/25 17:08	05/15/25 07:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211C Flush Lims Reference ID: AD19314-43 Matrix: Drinking Water Sampled: 04/23/25 08:26:00									
Metals									
Lead	2.87		1	1.00	µg/L	05/14/25 15:46	05/16/25 03:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211D Lims Reference ID: AD19314-44 Matrix: Drinking Water Sampled: 04/23/25 08:27:00									
Metals									
Lead	18.2		1	1.00	µg/L	05/13/25 17:08	05/15/25 07:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211D Flush Lims Reference ID: AD19314-45 Matrix: Drinking Water Sampled: 04/23/25 08:28:00									
Metals									
Lead	1.37		1	1.00	µg/L	05/14/25 15:46	05/16/25 03:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211E Lims Reference ID: AD19314-46 Matrix: Drinking Water Sampled: 04/23/25 08:29:00									
Metals									
Lead	29.7		1	1.00	µg/L	05/13/25 17:08	05/15/25 07:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211E Flush Lims Reference ID: AD19314-47 Matrix: Drinking Water Sampled: 04/23/25 08:30:00									
Metals									
Lead	8.00		1	1.00	µg/L	05/14/25 15:46	05/16/25 03:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211F Lims Reference ID: AD19314-48 Matrix: Drinking Water Sampled: 04/23/25 08:31:00									
Metals									
Lead	12.2		1	1.00	µg/L	05/13/25 17:08	05/14/25 22:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-SO-J211G Lims Reference ID: AD19314-50 Matrix: Drinking Water Sampled: 04/23/25 08:33:00									
Metals									
Lead	8.15		1	1.00	µg/L	05/13/25 17:08	05/14/25 22:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WTHS-9/10-02-CM-211 Lims Reference ID: AD19314-52 Matrix: Drinking Water Sampled: 04/23/25 08:35:00									
Metals									
Lead	7.47		1	1.00	µg/L	05/13/25 17:08	05/14/25 22:20	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Washington Twp HS - 9/10 LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/29/2025 14:30
Reported: 05/16/2025 15:29

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: WTHS-9/10-02-WC-Hall9L Lims Reference ID: AD19314-54 Matrix: Drinking Water Sampled: 04/23/25 08:38:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:08	05/14/25 22:22	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WTHS-9/10-02-WC-Hall9R Lims Reference ID: AD19314-55 Matrix: Drinking Water Sampled: 04/23/25 08:39:00

Metals

Lead	ND	1	1.00	µg/L	05/13/25 17:08	05/14/25 22:23	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Washington Twp HS - 9/10 LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/29/2025 14:30
Reported: 05/16/2025 15:29

Work Order Case Narrative

Two extra samples, WTHS-9/10-SO-Nur and WTHS-9/10-So-Nur (Flush); Customer was notified on 5/2 - KHR

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Washington Twp HS - 9/10 LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/29/2025 14:30
Reported: 05/16/2025 15:29

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012519314
LIMS Reference ID: AD19314
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Washington Twp HS - 9/10 LIW

Customer PO: 24-1071C
EMSL Sales Rep: Justin Monturano
Received: 04/29/2025 14:30
Reported: 05/16/2025 15:29

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

AD19314

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Report To Contact Name: James Eberts				Bill To Company: Epic Environmental Services, LLC			
Company Name: Epic Environmental Services, LLC				Attention To: James Eberts / Timothy Eberts			
Street: 80 Fork Bridge Road				Street: 80 Fork Bridge Road			
City: Pittsgrove		State/Province: NJ		City: Pittsgrove		State/Province: NJ	
Phone: 856-205-1077		Fax:		Phone: 856-205-1077		Fax:	
Project Name: Washington Turn HS-9/10 Lit				Email Results To: jeberts@epicenviro.com / teberts@epicen			
U.S. State where Samples Collected: NJ				Purchase Order: 24-1071C			
Number of Samples Collected: 55				Date of Shipment: 4/28/2025			
Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):							
Samples Collected by: EMSL ☐ Client ☒ check one		Standard Turnaround Time: ☒ 2 Weeks		Sampled By (Signature): Lucy Ayers		Samples Received Chilled (Y/N):	
Failure to complete will hinder processing of samples		The following TATs are subject to lab approval: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day					
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix	Preservative	EPA	Comments
9/10 -FB	☐	☒	4/23/25 N/A	W=Water S=Soil A=Air SL=Sludge O=Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	200.8	Field Blank
9/10-WE-AUX BOYER	☐	☒	0740	W		X	
9/10-WE-AUX GRILL	☐	☒	0741	W		X	
9/10-WE-H111	☐	☒	0743	W		X	
9/10-WE-H110	☐	☒	0744	W		X	
Released By (Signature)			Date & Time		Received By		
Casey Lyons			4/28/25		Aronmily (wr) 4/29/25 1430		

Instructions or Comments: Please indicate reporting requirements: ☐ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other _____
Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.
Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb
Rec'd Pres.

(Lab) Received Temperature: _____ °C

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
1019314

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				List Test(s) Needed										
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O= Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
9/10-WC-HALL1L	☐	☐	4/23/25 0745	W	2									
9/10-WC-HALL1R	☐	☐	0746	W										
9/10-WC-SYM	☐	☐	0748	W										
9/10-WC-BLOCK	☐	☒	0749	W										
9/10-WC-HALL2L	☐	☒	0750	W										
9/10-WC-HALL2R	☐	☒	0751	W										
9/10-WC-HALL2	☐	☒	0752	W										
9/10-SO-MUS	☐	☒	0754	W										
↓ (Flush)	☐	☒	0755	W										Flush
9/10-WC-HALL3L	☐	☒	0758	W										
9/10-WC-HALL3R	☐	☒	0758	W										
9/10-WC-HALL4L	☐	☒	0759	W										
9/10-WC-HALL4R	☐	☒	0800	W										
9/10-IM-NURSE	☐	☒	0802	W										Ice Machine
9/10-SO-NURSE1	☐	☒	0803	W										
9/10-SO-NURSE2	☐	☒	0803	W										
↓ (Flush)	☐	☒	0804	W										Flush

(Lab) Received Temperature: _____ °C

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
AD1934

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				List Test(s) Needed											
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O= Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8					Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
9/10-WC-HALLSL	☐	☐	4/23/25 0805	W	2										
9/10-WC-HALLSR	☐	☐	0806	W											
9/10-02-WC-HALL6	☐	☐	0808	W											
9/10-02-BF-HALL6	☐	☒	0808	W											
9/10-02-WC-GLACK	☐	☒	0810	W											
9/10-02-WC-HALL6L	☐	☒	0811	W											
9/10-02-SO-FAC	☐	☒	0812	W											
9/10-02-WC-HALL7L	☐	☒	0814	W											
9/10-02-WC-HALL7R	☐	☒	0814	W											
9/10-02-WC-HALL8L	☐	☒	0815	W											
9/10-02-WC-HALL8R	☐	☒	0816	W											
9/10-02-SO-J210A	☐	☒	0817	W											
↓ (Flush)	☐	☒	0818	W											Flush
9/10-02-SO-J210B	☐	☒	0819	W											
↓ (Flush)	☐	☒	0820	W											Flush
9/10-02-SO-J211A	☐	☒	0821	W											
↓ (Flush)	☐	☒	0822	W											Flush

(Lab) Received Temperature: _____ °C

Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):
AD19314

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				List Test(s) Needed								Comments
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix	Preservative	EPA	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
9/10-02-SO-J211B	☐	☐	4/12/25 0823	W	2	200.8						Flush
↓ (Flush)	☐	☐	0824	W								
9/10-02-SO-J211C	☐	☐	0825	W								
↓ (Flush)	☐	☐	0826	W								Flush
9/10-02-SO-J211D	☐	☐	0827	W								
↓ (Flush)	☐	☐	0828	W								
9/10-02-SO-J211E	☐	☐	0829	W								Flush
↓ (Flush)	☐	☐	0830	W								
9/10-02-SO-J211F	☐	☐	0831	W								
↓ (Flush)	☐	☐	0832	W								Flush
9/10-02-SO-J211G	☐	☐	0833	W								
↓ (Flush)	☐	☐	0834	W								
9/10-02-CM-211	☐	☐	0835	W								Flush
↓ (Flush)	☐	☐	0836	W								
9/10-02-WC-HA119L	☐	☐	0838	W								
9/10-02-WC-HA119R	☐	☐	0839	W								Flush
↓	☐	☐										
↓	☐	☐										

(Lab) Received Temperature: _____ °C